

January 22, 2008

**Lakeland Industry & Community Association**

Box8237  
5006-50 Avenue  
Bonnyville, Alberta  
T9N 2J5

**ATTENTION: Mr. Mike Bisaga**

**REFERENCE: Ambient Air Monitoring Report For December 2007**

---

Maxxam Analytics Inc. is pleased to submit this report of data collected at the Ambient Air Monitoring Station located at the Lakeland Industry & Community Assoc. Cold Lake site for the month of December 2007.

Included is a summary of the monthly continuous and hourly average reports, equipment calibration reports, as well as a brief description of the calibration procedure. The passive network data are also included in this report.

During the month of December 2007 the following proceedings were noted:

**Cold Lake South Site**

- All analyzers and wind systems were all above 90% uptime objective for the month.
- All data was within Provincial objectives for the month.
- All data was corrected using daily zero calibration data. Furthermore the PM 2.5 data was corrected using Alberta Environment correction standards.
- There was 0 hours of data for THC that was invalidated as no concentrations fell below the historical background average of 1.5 ppm, a concentration agreed to with the LICA Program Manager.
- On December 9<sup>th</sup>, 2007 there was an AQI value listed as fair. The offending pollutant was PM 2.5 with a hourly concentration of 33.5 ug/m<sup>3</sup>; the AQI value was 28 and occurred at hour beginning 23:00.
- On December 9<sup>th</sup> the daily calibration for the NO<sub>x</sub> analyzer was over range. The technician investigated and found all diagnostic parameters on the analyzer to be normal, it was discovered that flow to the permeation oven was not present. On December 10<sup>th</sup> the technician returned to repair the flow issue with the permeation oven. A filter was replaced on the pump. A couple 'As Found' points were completed and the analyzer was found to be operating normally and unaffected by the problem. No data was invalidated. Stabilization of permeation oven occurred over several days after repairs occurred.
- During the monthly calibration of the PM 2.5 equipment, a new sample tube connector was installed to reduce leakage in the flow system.
- A new trailer temperature sensor was installed in order to allow monitoring of the trailer temperature. The sensor was installed on December 18<sup>th</sup>. The data from the sensor is not reported and is used solely for troubleshooting and analysis of data.

- On December 25<sup>th</sup> the technician went to the station to investigate the loss of communications. Communication was re-established and there was no observable reason for the initial loss of communications.
- On December 31<sup>st</sup> a technician was sent out to the trailer to investigate an over range daily span value on the NO<sub>x</sub> analyzer. It was discovered a leak in the airflow from the pump to the permeation oven developed, the technician repaired the issue and an internal calibration was run. The analyzer was found to be operating normally and was unaffected by the situation, therefore no data was invalidated.

### **Passive Network**

A summary of the passive monitoring are reported as follows:

- Monitoring period averages for O<sub>3</sub> ranged from 18.8 – 50.5 ppb.
- Monitoring period averages for SO<sub>2</sub> ranged from 0.3 – 1.7 ppb.
- Monitoring period averages for NO<sub>2</sub> ranged from 1.2 – 10.7 ppb.
- Monitoring period averages for H<sub>2</sub>S ranged from 0.13 – 0.22 ppb.


Site #1 – The technician noted that some construction activity was present at the site at the time of the change out.

Please feel free to contact either of Craig Snider at (403) 219-3689 or Darren Morissette (403)-219-3661, should you have any questions concerning this report.

Sincerely,


Maxxam Analytics Inc.

Prepared by:



Darren Morissette, CEPIT  
Senior Technologist

Reviewed by:



Craig Snider, CET  
Ambient Manager

**Lakeland Industry & Community Association**  
Cold Lake Monitoring Site  
Ambient Air Monitoring  
Data Report  
For  
December 2007

Prepared By:

**MAXXAM ANALYTICS INC.**

# **Lakeland Industry & Community Assoc.**

## **COLD LAKE**

### **AMBIENT AIR MONITORING STATION**

#### **TABLE OF CONTENTS**

<b>CALIBRATION PROCEDURE</b>	<b>3</b>
<b>MONTHLY CONTINUOUS SUMMARY – COLD LAKE</b>	<b>4</b>
<b>PASSIVE NETWORK DATA SUMMARY</b>	<b>5</b>
<b>GENERAL MONTHLY SUMMARY- COLD LAKE</b>	<b>6</b>
<b>MONTHLY GRAPHS, SUMMARIES AND WIND ROSES</b>	<b>9</b>
<b>COLD LAKE SOUTH</b>	
AIR QUALITY INDEX MONTHLY SUMMARY	10
SULPHUR DIOXIDE MONTHLY SUMMARY	12
TOTAL REDUCED SULPHUR MONTHLY SUMMARY	20
TOTAL HYDROCARBONS MONTHLY SUMMARY	28
PARTICULATE MATTER 2.5 MONTHLY SUMMARY	36
NITROGEN DIOXIDE MONTHLY SUMMARY	43
NITRIC OXIDE MONTHLY SUMMARY	51
OXIDES OF NITROGEN MONTHLY SUMMARY	58
OZONE MONTHLY SUMMARY	66
VECTOR WIND SPEED MONTHLY SUMMARY	74
VECTOR WIND DIRECTION MONTHLY SUMMARY	81
TEMPURATURE MONTHLY SUMMARY	86
RELATIVE HUMIDITY MONTHLY SUMMARY	89
<b>DECEMBER 2007 CALIBRATION REPORTS</b>	<b>92</b>
<b>COLD LAKE SOUTH</b>	
SULPHUR DIOXIDE	93
TOTAL REDUCED SULPHUR	97
TOTAL HYDROCARBONS	101
PARTICULATE MATTER 2.5	105
NITROGEN DIOXIDE	107
OZONE	113
<b>DECEMBER 2007 PASSIVE BUBBLE MAPS</b>	<b>117</b>
<b>DECEMBER 2007 PASSIVE AMBIENT AIR MONITORING ANALYSIS</b>	<b>122</b>
<b>DECEMBER 2007 PASSIVE FIELD DATA</b>	<b>131</b>

## **CALIBRATION PROCEDURE**

The following calibration procedure applies to all calibrations conducted at the Lakeland Industry & Community Association Air Monitoring Station.

Calibration gas concentrations are generated using a dynamic mass flow controlled calibrator. EPA Protocol one gases are diluted with zero air generated on site. The Mass Flow Controllers in the calibrator are referenced using an NIST traceable flow meter once per month. All listed flows are reported as corrected to Standard Temperature and Pressure (STP).

Generated zero gas is introduced to the analyzer first. Three concentrations of calibration gas are then generated in order to introduce points at approximately 50-80%, 25-40% & 10-20% of the analyzer's full-scale range. An auto zero and span are then performed to validate the daily zero and span values recorded to the next multi-point calibration.

All indicated concentrations are taken from the ESC data logger used to collect the data for monthly reporting.

Conformance of each calibration to Alberta Environment regulations is outlined in the individual calibration reports. The slope and correlation coefficient are derived from the calculated and indicated analyzer responses. The percent change is calculated using the previous calibration correction factor and the current correction factor before adjustment. The calibration conforms to the procedure outlined in the *Air Monitoring Directive, Appendix A-10, Section 1.6*.

# LAKELAND INDUSTRY & COMMUNITY ASSOCIATION

## MONTHLY CONTINUOUS DATA SUMMARY

### COLD LAKE

**Continuous Ambient Monitoring – December 2007**

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION COLD LAKE SITE					MAXIMUM VALUES					OPERATIONAL TIME (PERCENT)	
					1-HOUR				24-HOUR		
PARAMETER	OBJECTIVES		EXCEEDENCES		MONTHLY AVERAGE	READING	DAY	HOUR	READING	DAY	
	1-HR	24-HR	1-HR	24-HR							
SO <sub>2</sub> (PPB)	172	57	0	0	0.20	4	31	10,11	1.6	4	100.0
TRS (PPB)	-	-	-	-	0.00	1	14	21,22	0.1	14	100.0
NO <sub>2</sub> (PPB)	212	106	0	0	9.38	32	17	6	23	9	100.0
NO (PPB)	-	-	-	-	3.58	69	14	21	19.6	14	100.0
NOx (PPB)	-	-	-	-	12.85	98	14	21	37.9	14	100.0
O <sub>3</sub> (PPB)	82	-	0	-	19.97	37	1	1,2	32.7	3	100.0
THC (PPM)	-	-	-	-	2.33	4.8	16	21	3.3	9,14	100.0
PM 2.5 (UG/M <sup>3</sup> )	-	30	-	0	3.36	33.5	9	0	9.9	9	100.0
TEMPERATURE (DEG C)	-	-	-	-	-15.01	-1.3	24	15	-5.3	25	100.0
RELATIVE HUMIDITY (%)	-	-	-	-	80.66	95.8	26	2	93.5	26	100.0
VECTOR WS (KPH)	-	-	-	-	4.58	17.2	20	0	11.1	3	100.0
VECTOR WD (DEGREES)	-	-	-	-	S	-	-	-	-	-	100.0

**LAKELAND INDUSTRY & COMMUNITY ASSOCIATION  
Passive Ambient Monitoring Network – December 2007**

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION PASSIVE NETWORK			
NETWORK MAXIMUM (PPB)		NETWORK AVERAGE (PPB)	
PARAMETER	STATION	READING	READING
NO <sub>2</sub>	#25	10.7	3.9
SO <sub>2</sub>	#13a	1.7	0.8
H <sub>2</sub> S	#21	0.22	0.18
O <sub>3</sub>	#3	50.5	24.7

## **GENERAL MONTHLY SUMMARY – COLD LAKE**

### **Equipment Operation**

The following summary outlines the analyzer performance. Any non-conformances, problems or maintenance performed are detailed at the end of each section.

#### **AQM STATION – LICA – COLD LAKE**

##### **SO<sub>2</sub>**

- Analyzer make / model    TECO 43A

No operational issues during the month. The inlet filter was changed before the monthly calibration was started. Data was corrected using daily zero information.

##### **TRS**

- Analyzer make / model    TECO 43A  
CD NOVA CDN 101 Converter

No operational issues during the month. The inlet filter was changed before the monthly calibration was started. Data was corrected using daily zero information.

##### **THC**

- Analyzer make / model    TECO 51C-LT

No operational issues during the month. The inlet filter was changed before the monthly calibration was started. Data was corrected using daily zero information. It was agreed to with the LICA Program Manager to invalidate all data, after zero correction, which falls below the historical background average of 1.5 ppm. As a result 0 hours of data was invalidated and the uptime was at 100.0%.

##### **NO<sub>x</sub>**

- Analyzer make / model    TECO 42C

On December 9<sup>th</sup> the technician investigated the reason for an over range daily calibration value. All diagnostic tests were completed and found the analyzer to operating normal and unaffected. On December 10<sup>th</sup> the technician returned to repair a broken filter on the pump supplying flow to the permeation oven. A couple of ‘As Found’ points were completed and found the analyzer unchanged and unaffected, therefore no data was invalidated. The daily span was unsteady for a couple of days afterwards while the permeation oven stabilized. On December 31<sup>st</sup> the technician investigated an over range daily calibration value. It was discovered a leak developed in the airflow from the pump to permeation oven, the leak was repaired and a manual span initiated. The analyzer was operating normally and unaffected, therefore no data was invalidated. The inlet filter was changed before the monthly calibration was started. Data was corrected using daily zero information.

## **O<sub>3</sub>**

- Analyzer make / model

TECO 49I

No operational issues during the month. The inlet filter was changed before the monthly calibration was started. Data was corrected using daily zero information.

## **PM 2.5**

- Analyzer make / model

TEOM 1400A

No operational issues during the month. During the monthly calibration a new sample tube connector was installed to reduce leakage in the flow system.

## **Wind Speed & Direction**

- System make / model

MET ONE 50.5

No operational issues observed during the month. The wind system is reported as vector wind speed and vector wind direction.

## **Relative Humidity**

- System make / model

Rotronic Hygroclip-S3

No operational issues observed during the month

## **Temperature (Ambient)**

- System make / model

Rotronic Hygroclip-S3

No operational issues observed during the month.

## **Temperature (Trailer)**

- System make / model

R&R 61

A new sensor installed in the trailer on December 18<sup>th</sup>. The sensor data is not reported and is used solely for troubleshooting and analysis of data.

## **Datalogger**

- System make / model

ESC 8832

- Software make / version

ESC v 5.51a

The ESC 8832 is connected to a modem with DSL for continuous connection with the base computer.

**Trailer**

- No new information to report.

**Air Quality Index (AQI)**

The AQI data was adjusted to reflect regular monthly calibrations, maintenance, and downtime and daily calibrations. There was one fair AQI value recorded on December 9<sup>th</sup> at hour beginning 23:00. The offending pollutant was PM 2.5 with an hourly concentration of 33.5 ug/m<sup>3</sup> and an AQI value of 28.

**Passive Network**

Site #1 – Technician noted construction activity near the site during regular change out of samplers.

**LICA - COLD LAKE SITE**

**MONTHLY SUMMARIES,**

**GRAPHS**

**&**

**WIND ROSES**


# **AIR QUALITY INDEX**



**SO<sub>2</sub>**



### 01 Hour Averages



**LICA**  
**SO2\_ / WD Joint Frequency Distribution (Percent)**

December 2007

**Distribution By % Of Samples**

Logger Id : 01  
Site Name : LICA  
Parameter : SO2\_  
Units : PPB

Wind Parameter : WD  
Instrument Height : 10 Meters

**Direction**

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 20	.70	1.41	1.41	4.80	12.28	10.87	14.54	3.53	2.68	4.66	9.18	16.38	9.18	3.38	2.40	2.54	100.00
< 60	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
< 110	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
< 170	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
< 340	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
>= 340	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
<b>Totals</b>	<b>.70</b>	<b>1.41</b>	<b>1.41</b>	<b>4.80</b>	<b>12.28</b>	<b>10.87</b>	<b>14.54</b>	<b>3.53</b>	<b>2.68</b>	<b>4.66</b>	<b>9.18</b>	<b>16.38</b>	<b>9.18</b>	<b>3.38</b>	<b>2.40</b>	<b>2.54</b>	

Calm : .00 %

Total # Operational Hours : 708

**Distribution By Samples**

**Direction**

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 20	5	10	10	34	87	77	103	25	19	33	65	116	65	24	17	18	708
< 60																	
< 110																	
< 170																	
< 340																	
>= 340																	
<b>Totals</b>	<b>5</b>	<b>10</b>	<b>10</b>	<b>34</b>	<b>87</b>	<b>77</b>	<b>103</b>	<b>25</b>	<b>19</b>	<b>33</b>	<b>65</b>	<b>116</b>	<b>65</b>	<b>24</b>	<b>17</b>	<b>18</b>	

Calm : .00 %

Total # Operational Hours : 708

Logger : 01 Parameter : SO2


Class Limits (PPB)




Site : LICA

Period : 12/01/07-12/31/07

Level : 10




Calibration Graph for Site: LICA Parameter: SO2\_ Sequence: SO2 Phase: SPAN






### 01 Hour Averages



**TRS**



### 01 Hour Averages



LICA  
 TRS\_ / WD Joint Frequency Distribution (Percent)

December 2007

Distribution By % Of Samples

Logger Id : 01  
 Site Name : LICA  
 Parameter : TRS\_  
 Units : PPB

Wind Parameter : WD  
 Instrument Height : 10 Meters

Direction

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 3	.70	1.41	1.41	4.80	12.28	10.87	14.54	3.53	2.68	4.66	9.18	16.38	9.18	3.38	2.40	2.54	100.00
< 10	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 50	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 50	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	.70	1.41	1.41	4.80	12.28	10.87	14.54	3.53	2.68	4.66	9.18	16.38	9.18	3.38	2.40	2.54	

Calm : .00 %

Total # Operational Hours : 708

Distribution By Samples

Direction


Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 3	5	10	10	34	87	77	103	25	19	33	65	116	65	24	17	18	708
< 10																	
< 50																	
>= 50																	
Totals	5	10	10	34	87	77	103	25	19	33	65	116	65	24	17	18	

Calm : .00 %

Total # Operational Hours : 708

Logger : 01 Parameter : TRS\_


Class Limits (PPB)




Site : LICA

Period : 12/01/07-12/31/07

Level : 10




Calibration Graph for Site: LICA Parameter: TRS\_ Sequence: TRS Phase: SPAN






### 01 Hour Averages



# **THC**



### 01 Hour Averages



**LICA**  
**THC / WD Joint Frequency Distribution (Percent)**

December 2007

**Distribution By % Of Samples**

Logger Id : 01  
Site Name : LICA  
Parameter : THC  
Units : PPM

Wind Parameter : WD  
Instrument Height : 10 Meters

**Direction**

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 3.0	.70	1.12	1.12	4.09	11.58	9.46	12.71	2.11	1.41	2.40	6.92	13.55	8.05	3.24	1.97	2.40	82.90
< 10.0	.00	.28	.28	.70	1.12	1.27	1.69	1.41	1.12	2.25	2.25	2.82	1.12	.14	.42	.14	17.09
< 50.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 50.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
<b>Totals</b>	<b>.70</b>	<b>1.41</b>	<b>1.41</b>	<b>4.80</b>	<b>12.71</b>	<b>10.73</b>	<b>14.40</b>	<b>3.53</b>	<b>2.54</b>	<b>4.66</b>	<b>9.18</b>	<b>16.38</b>	<b>9.18</b>	<b>3.38</b>	<b>2.40</b>	<b>2.54</b>	

Calm : .00 %

Total # Operational Hours : 708

**Distribution By Samples**

**Direction**

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 3.0	5	8	8	29	82	67	90	15	10	17	49	96	57	23	14	17	587
< 10.0		2	2	5	8	9	12	10	8	16	16	20	8	1	3	1	121
< 50.0																	
>= 50.0																	
<b>Totals</b>	<b>5</b>	<b>10</b>	<b>10</b>	<b>34</b>	<b>90</b>	<b>76</b>	<b>102</b>	<b>25</b>	<b>18</b>	<b>33</b>	<b>65</b>	<b>116</b>	<b>65</b>	<b>24</b>	<b>17</b>	<b>18</b>	

Calm : .00 %

Total # Operational Hours : 708

Logger : 01 Parameter : THC


Class Limits (PPM)




Site : LICA

Period : 12/01/07-12/31/07

Level : 10




Calibration Graph for Site: LICA Parameter: THC Sequence: THC Phase: SPAII





### 01 Hour Averages




# **PARTICULATE MATTER**

## **2.5**



### 01 Hour Averages



**LICA**  
**PM2 / WD Joint Frequency Distribution (Percent)**

December 2007

**Distribution By % Of Samples**

Logger Id : 01  
Site Name : LICA  
Parameter : PM2  
Units : UG/M3

Wind Parameter : WD  
Instrument Height : 10 Meters

**Direction**

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 30.0	.67	.94	1.62	4.74	12.46	11.24	14.36	3.65	2.57	4.74	8.94	16.53	9.07	3.38	2.43	2.43	99.86
< 60.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.13	.00	.00	.00	.13	
< 80.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
< 120.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
< 240.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
>= 240.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
Totals	.67	.94	1.62	4.74	12.46	11.24	14.36	3.65	2.57	4.74	8.94	16.66	9.07	3.38	2.43	2.43	

Calm : .00 %

Total # Operational Hours : 738

**Distribution By Samples**

**Direction**

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 30.0	5	7	12	35	92	83	106	27	19	35	66	122	67	25	18	18	737
< 60.0												1				1	
< 80.0																	
< 120.0																	
< 240.0																	
>= 240.0																	
Totals	5	7	12	35	92	83	106	27	19	35	66	123	67	25	18	18	

Calm : .00 %

Total # Operational Hours : 738

Logger : 01 Parameter : PM2


Class Limits (UG/M3)



Site : LICA


Period : 12/01/07-12/31/07

Level : 10






### 01 Hour Averages



**NO<sub>2</sub>**



### 01 Hour Averages



LICA  
NO2\_ / WD Joint Frequency Distribution (Percent)

December 2007

Distribution By % Of Samples

Logger Id : 01  
Site Name : LICA  
Parameter : NO2\_  
Units : PPB

Wind Parameter : WD  
Instrument Height : 10 Meters

Direction

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	.71	1.42	1.42	4.85	12.55	10.84	14.55	3.56	2.56	4.42	9.12	16.26	9.27	3.42	2.42	2.56	100.00
< 110	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	.71	1.42	1.42	4.85	12.55	10.84	14.55	3.56	2.56	4.42	9.12	16.26	9.27	3.42	2.42	2.56	

Calm : .00 %

Total # Operational Hours : 701

Distribution By Samples

Direction


Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	5	10	10	34	88	76	102	25	18	31	64	114	65	24	17	18	701
< 110																	
< 210																	
>= 210																	
Totals	5	10	10	34	88	76	102	25	18	31	64	114	65	24	17	18	

Calm : .00 %

Total # Operational Hours : 701

Logger : 01 Parameter : NO<sub>2</sub>


Class Limits (PPB)




Site : LICA

Period : 12/01/07-12/31/07

Level : 10




Calibration Graph for Site: LICA Parameter: NO2 Sequence: NO2 Phase: SPAN






### 01 Hour Averages



**NO**



### 01 Hour Averages



**LICA**  
**NO\_ / WD Joint Frequency Distribution (Percent)**

December 2007

**Distribution By % Of Samples**

Logger Id : 01  
Site Name : LICA  
Parameter : NO\_  
Units : PPB

Wind Parameter : WD  
Instrument Height : 10 Meters

**Direction**

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	.71	1.42	1.28	4.70	12.41	10.55	14.40	3.56	2.56	4.27	8.98	16.26	9.27	3.42	2.28	2.42	98.57
< 110	.00	.00	.14	.14	.14	.28	.14	.00	.00	.14	.14	.00	.00	.00	.14	.14	1.42
< 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	.71	1.42	1.42	4.85	12.55	10.84	14.55	3.56	2.56	4.42	9.12	16.26	9.27	3.42	2.42	2.56	

Calm : .00 %

Total # Operational Hours : 701

**Distribution By Samples**

**Direction**


Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	5	10	9	33	87	74	101	25	18	30	63	114	65	24	16	17	691
< 110			1	1	1	2	1			1	1				1	1	10
< 210																	
>= 210																	
Totals	5	10	10	34	88	76	102	25	18	31	64	114	65	24	17	18	

Calm : .00 %

Total # Operational Hours : 701

Logger : 01 Parameter : NO<sub>2</sub>


Class Limits (PPB)



Site : LICA


Period : 12/01/07-12/31/07

Level : 10






### 01 Hour Averages



**NO<sub>x</sub>**



### 01 Hour Averages



**LICA**  
**NOX\_ / WD Joint Frequency Distribution (Percent)**

December 2007

Distribution By % Of Samples

Logger Id : 01  
Site Name : LICA  
Parameter : NOX\_  
Units : PPB

Wind Parameter : WD  
Instrument Height : 10 Meters

Direction

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	.57	1.42	.99	4.13	12.26	10.41	14.26	3.56	2.42	4.27	8.84	16.26	8.98	3.42	2.13	2.42	96.43
< 110	.14	.00	.42	.71	.28	.42	.28	.00	.14	.14	.28	.00	.28	.00	.28	.14	3.56
< 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	.71	1.42	1.42	4.85	12.55	10.84	14.55	3.56	2.56	4.42	9.12	16.26	9.27	3.42	2.42	2.56	

Calm : .00 %

Total # Operational Hours : 701

Distribution By Samples

Direction


Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	4	10	7	29	86	73	100	25	17	30	62	114	63	24	15	17	676
< 110	1		3	5	2	3	2		1	1	2		2		2	1	25
< 210																	
>= 210																	
Totals	5	10	10	34	88	76	102	25	18	31	64	114	65	24	17	18	

Calm : .00 %

Total # Operational Hours : 701

Logger : 01 Parameter : NOX\_


Class Limits (PPB)




Site : LICA

Period : 12/01/07-12/31/07

Level : 10




Calibration Graph for Site: LICA Parameter: HOX\_ Sequence: NO2 Phase: SPAN






### 01 Hour Averages



O<sub>3</sub>



### 01 Hour Averages



LICA  
03\_ / WD Joint Frequency Distribution (Percent)

December 2007

Distribution By % Of Samples

Logger Id : 01  
Site Name : LICA  
Parameter : 03\_  
Units : PPB

Wind Parameter : WD  
Instrument Height : 10 Meters

Direction

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	.70	.98	1.41	4.80	12.71	10.87	14.54	3.53	2.68	4.66	9.18	16.38	9.18	3.38	2.40	2.54	100.00
< 110	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	.70	.98	1.41	4.80	12.71	10.87	14.54	3.53	2.68	4.66	9.18	16.38	9.18	3.38	2.40	2.54	

Calm : .00 %

Total # Operational Hours : 708

Distribution By Samples

Direction


Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	5	7	10	34	90	77	103	25	19	33	65	116	65	24	17	18	708
< 110																	
< 210																	
>= 210																	
Totals	5	7	10	34	90	77	103	25	19	33	65	116	65	24	17	18	

Calm : .00 %

Total # Operational Hours : 708

Logger : 01 Parameter : 03


Class Limits (PPB)




Site : LICA

Period : 12/01/07-12/31/07

Level : 10




Calibration Graph for Site: LICA Parameter: 03\_ Sequence: 03 Phase: SPAll






### 01 Hour Averages



# **VECTOR WIND SPEED**



### 01 Hour Averages



**LICA**  
**WSP / WD Joint Frequency Distribution (Percent)**

December 2007

**Distribution By % Of Samples**

Logger Id : 01  
Site Name : LICA  
Parameter : WSP  
Units : KPH

Wind Parameter : WD  
Instrument Height : 10 Meters

**Direction**

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 6.0	.40	1.07	1.20	3.22	4.56	7.39	11.29	3.22	2.28	4.43	6.85	12.09	4.56	.80	.94	.80	65.18
< 12.0	.13	.00	.13	1.34	6.31	3.62	2.28	.00	.00	.00	2.01	4.16	3.36	1.88	1.20	.94	27.41
< 20.0	.00	.00	.00	.00	1.34	.00	.00	.00	.00	.00	.00	.00	.80	.53	.26	.40	3.36
< 29.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
< 39.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
>= 39.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
<b>Totals</b>	<b>.53</b>	<b>1.07</b>	<b>1.34</b>	<b>4.56</b>	<b>12.23</b>	<b>11.02</b>	<b>13.57</b>	<b>3.22</b>	<b>2.28</b>	<b>4.43</b>	<b>8.87</b>	<b>16.26</b>	<b>8.73</b>	<b>3.22</b>	<b>2.41</b>	<b>2.15</b>	

Calm : 4.03 %

Total # Operational Hours : 744

**Distribution By Samples**

**Direction**


Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 6.0	3	8	9	24	34	55	84	24	17	33	51	90	34	6	7	6	485
< 12.0	1		1	10	47	27	17			15	31	25	14	9	7	7	204
< 20.0					10								6	4	2	3	25
< 29.0																	
< 39.0																	
>= 39.0																	
<b>Totals</b>	<b>4</b>	<b>8</b>	<b>10</b>	<b>34</b>	<b>91</b>	<b>82</b>	<b>101</b>	<b>24</b>	<b>17</b>	<b>33</b>	<b>66</b>	<b>121</b>	<b>65</b>	<b>24</b>	<b>18</b>	<b>16</b>	

Calm : 4.03 %

Total # Operational Hours : 744

Logger : 01 Parameter : WSP


Class Limits (KPH)



Site : LICA


Period : 12/01/07-12/31/07

Level : 10






### 01 Hour Averages



# **VECTOR WIND DIRECTION**




### 01 Hour Averages






### 01 Hour Averages



# **TEMPERATURE**




### 01 Hour Averages



# **RELATIVE HUMIDITY**



### 01 Hour Averages



**DECEMBER 2007**  
**CALIBRATION REPORTS**

**LICA – COLD LAKE**

**SO<sub>2</sub>**

## SO<sub>2</sub> Calibration Report

### Station Information

Calibration Date	December 3, 2007	Previous Calibration	November 19, 2007
<b>Lakeland Industry &amp; Community Association</b>			
<b>LICA 1 - Cold Lake South</b>			
Start Time (MST)	14:45	End Time (MST)	18:15
Reason: Monthly Calibration			
Barometric Pressure	715 mmHg	Station Temperature	21 Deg C
Cal Gas	50.2 ppm	Cal Gas Expiry date	06/18/2009
DAS Output Voltage	0 - 10 Volts		

### Equipment Information

Analyzer Make / Model:	TECO 43A	S/N :	43A-4468-272	Method:	Fluorescent
Converter Make / Model:	-	S/N :	-		
Calibrator Make / Model:	API 700	S/N :	690	Method:	Dilution
DAS Make / Model:	ESC 8832	S/N :	263		
Flow Meter:	API 700	S/N :	690		

### Analyzer Settings

Concentration Range	Before Calibration				After Calibration			
	700	ccm	OK	0 - 500	700	ppb	OK	Deg C
HVPS / Lamp Setting	OK		849		OK		845	
PMT / RxCell Temp	OK	Deg C	OK	50	OK	Deg C	OK	Deg C
Converter / IZS Temp	NA	Deg C	OK	40	NA	Deg C	OK	Deg C
Offset / Slope	98		906		103		906	

### Calibration Data

Dilution Flow Rate	Source Gas Flow Rate	Calculated Concentration	Indicated Conc. (DAS)	Correction Factor
ZERO	ZERO	0	1	N/A
ZERO	ZERO	0	0	N/A
4960	39.8	400	401	0.9965
4975	24.9	250	250	1.0000
4985	14.9	150	151	0.9907
ZERO	ZERO	0	0	N/A
Sum of Least Squares				0.9969
New Correction Factor				0.9965

### Before Calibration

### After Calibration

Auto Zero	1	0
Auto Span	341	339
Sample Lines Connected		
Percent Change from Previous Calibration		

Notes:

---



---




---

Calibration Performed by: Shea Beaton


## SO<sub>2</sub> Calibration Curve

Calibration Date	December 3, 2007		
Company	<b>Lakeland Industry &amp; Community Association</b>		
Plant / Location	<b>LICA 1 - Cold Lake South</b>		
Start Time (MST)	14:45	End Time (MST)	18:15

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient	(≥ 0.995) (0.85 to 1.15)	0.999983
			Slope	(± 3% F.S.)	1.002447
			Intercept		0.209001
0	0	n/a			
150	151	0.9907			
250	250	1.0000			
400	401	0.9965			



### 01 Minute Averages



**TRS**

## TRS Calibration Report

### Station Information

Calibration Date	December 3, 2007	Previous Calibration	November 19, 2007
<b>Lakeland Industry &amp; Community Association</b>			
<b>LICA 1 - Cold Lake South</b>			
Start Time (MST)	14:45	End Time (MST)	18:15
Reason:	Monthly Calibration		
Barometric Pressure	715	mm Hg	Station Temperature 21 Deg C
Cal Gas	10.2	ppm	Cal Gas Expiry date 07/03/2008
DAS Output Voltage	0 - 10	Volts	

### Equipment Information

Analyzer Make / Model:	TECO 43A	S/N :	43A-35786-254	Method:	Fluorescent
Converter Make / Model:	CD Nova CDN 101	S/N :	250		
Calibrator Make / Model:	Environics 2000	S/N :	1991	Method:	Dilution
DAS Make / Model:	ESC 8832	S/N :	263		
Flow Meter:	Environics 2000	S/N :	1991		

### Analyzer Settings

Parameter	Before Calibration			After Calibration		
	Setting	Unit	Status	Setting	Unit	Status
Concentration Range			0 - 100		ppb	
Sample Flow / Box Temp	400	ccm	OK	Deg C	400	ccm
HVPS / Lamp Setting	OK		887		OK	882
PMT / RxCell Temp	OK	Deg C	OK	Deg C	OK	Deg C
Converter / IZS Temp	850	Deg C	OK	Deg C	OK	Deg C
Offset / Slope	850		764		879	764

### Calibration Data

Dilution Flow Rate	Source Gas Flow Rate	Calculated Concentration	Indicated Conc. (DAS)	Correction Factor
ZERO	ZERO	0	1	N/A
ZERO	ZERO	0	0	N/A
4960	39.3	80	80	1.0023
4980	19.7	40	40	1.0048
4990	9.8	20	20	0.9996
ZERO	ZERO	0	0	N/A
Sum of Least Squares				1.0026
New Correction Factor				1.0023

### Before Calibration

### After Calibration

Auto Zero	0	0
Auto Span	81	81
Sample Lines Connected		YES
Percent Change from Previous Calibration		-0.3%

Notes:


---

Calibration Performed by: Shea Beaton


### TRS Calibration Curve

Calibration Date	December 3, 2007		
Company	<b>Lakeland Industry &amp; Community Association</b>		
Plant / Location	<b>LICA 1 - Cold Lake South</b>		
Start Time (MST)	14:45	End Time (MST)	18:15

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient	( $\geq 0.995$ ) (0.85 to 1.15) ( $\pm 3\%$ F.S.)	0.999997 0.997345 0.001554
0	0	n/a			
20	20	0.9996			
40	40	1.0048			
80	80	1.0023			



### 01 Minute Averages



# **THC**

## THC Calibration Report

### Station Information

Calibration Date:	December 18, 2007	Previous Calibration	November 19, 2007
<b>Lakeland Industry and Community Association</b>			
<b>LICA1/Cold Lake</b>			
Start Time (MST)	9:25	End Time (MST)	12:15
Reason: Monthly Calibration			
Barometric Pressure:	706 mmHg	Station Temperature:	22 Deg C
Calibrator:	API 700	S/N:	690
Cal Gas Concentration:	1010 ppm	Cal Gas Expiry Date:	Jan-10
DAS make & Model:	ESC 8832	S/N :	263
Output Voltage Range:	0 - 10 VDC		

### Analyzer Information

Make / Model	TECO 51C-LT	S/N :	51CLT-42740-8718	Method	Flame Ionization
<b>Analyzer Settings</b>					

	Before Calibration		After Calibration	
Concentration Range	0 - 50	ppm	0 - 50	ppm
Sample Pressure	6.5	psi	6.5	psi
Hydrogen Pressure	9	psi	9	psi
Air Pressure	18	psi	18	psi

### Calibration Data

Dilution Flow	Source Gas Flow	Calculated Concentration	Indicated Concentration	Correction Factor
ZERO	ZERO	0.0	0.0	N/A
2000	80.0	38.8	39.0	0.9961
2000	40.0	19.8	19.4	1.0208
2000	20.0	10.0	9.6	1.0417
ZERO	ZERO	0.0	0.0	N/A
			Correction Factor:	0.9961

### Percent Change

Previous Calibration Correction Factor:	0.9961
Current Correction Factor Before Span Adjust:	0.9961
Percent Change:	0.0%

### IZS Calibration Data

	Before Calibration		After Calibration
Auto Zero	0.0		0.0
Auto Span	30.1		30.2
Sample Lines Connected			YES

Notes:	Cylinder Pressures	
Span	1550 psi	
Hydrogen	1700 psi	
Zero Air	Maxxam-owned API 701 zero air supply with catalytic oxidizer	

Calibration Performed by: Shea Beaton

## THC Calibration Curve

Calibration Date

December 18, 2007

Company

Lakeland Industry and Community Association

Plant / Location

LICA1/Cold Lake

Start Time

(MST)

9:25

End Time

(MST)

12:15

Calculated Conc.

ppm

Indicated Response

ppm

Correction Factor

Correlation Coefficient

(≥ 0.995) 0.999749

Slope

(0.85 to 1.15)

1.006238

Intercept

(\pm 3% F.S.)

-0.269581

0.0

0.0

1.0417

10.0

9.6

1.0208

19.8


19.4

0.9961


38.8

39.0

### THC Calibration Curve



### 01 Minute Averages



# **PARTICULATE MATTER**

## **2.5**

## TEOM® Calibration

### Station

Date: December 18, 2007  
 Station Name: LICA  
 Location: Cold Lake - South  
 Operator: Maxxam Analytics

### Transfer Standard

Make/Model: Bios DC-2  
 Serial Number: 1193  
 Cell s/n: 2272  
 Thermometer s/n: 2178

### Sampler

Make/Model R & P Series 1400 a TEOM  
 Unit # AMU 1494  
 Control unit s/n 140AB213859701  
 Transducer s/n 140AB213859701  
 Parameter PM 2.5

### Set-up and current Sampler readings

F-Main Set Pt (l/min)	3.00
F-Aux Set Pt (l/min)	13.67
Filter Load (%)	37
K <sub>o</sub> Factor	11095
Temp (°C)	-11.3
Press (ATM)	0.929

### Conversion from mmHg or "Hg to ATM (Atmospheres)

$$\text{ATM} = (\text{mmHg}) \times (1.316 \times 10^{-3}) \quad \text{or} \quad \text{ATM} = ("Hg) \times (3.34207 \times 10^{-2})$$

**Note:** Tolerances are noted as **BOLD** in Brackets

### Calibration

#### **Zero flow**

##### **Pump Off**

F-Main (l/min) 0.07  
 F-Aux (l/min) 0.17

##### **Pump On (Time to reach set points)**

(45-60 Sec)	36
(45-60 Sec)	52

#### **Temperature/Pressure**

Measured Temp ( $\pm 1^\circ\text{C}$ ) -11.6  
 Measured Press ( $\pm 1.5\%$  ATM) 0.929

$\Delta^\circ\text{C}$	-0.3
$\Delta \% \text{ ATM}$	0.0%

#### **Flow Audit**

Indicated Main/Aux Flow (l/min)	3.00	/	13.65
Total Flow = Main + Aux (l/min)	16.65		
Measured Total Flow (l/min)	17.59		
Measured Main Flow (l/min)	3.09		

##### **$\Delta \% \text{ from Set-pt}$**

( $\pm 2\%$ )	0.0%	/	0.1%
( $\pm 2\%$ )	0.1%		
( $\pm 1.0 \text{ l/min. (5.65\%)}$ )	-5.3%		
( $\pm 0.2 \text{ l/min. (6.25\%)}$ )	-2.9%		

#### **Leak Check**

Main (< 0.15 l/min) 0.13  
 Aux (< 0.15 l/min) 0.08

**Actual leakage = Pump On - Pump Off**

0.06

**0.09**

#### **K<sub>o</sub> Factor**

Measured NA  
 K<sub>o</sub> Difference ( $\pm 2.5\%$ ) NA

**Start Time:** 12:00

**Finish Time:**

17:00

**Sample Inlet Cleaned:**

**YES**

**Sample Inlet Connected:**

**YES**

**Comments:**

Values were recorded prior to maintenance, replaced sample tube hose connection in order to reduce leak, leakage now at Main 0.11 l/min and Aux 0.08 l/min. Performed software flow cal to bring indicated flows closer to expected.

Fadj Main = 0.932 - Flow 3.02 lpm, Fadj Aux = 0.925 - Total flow = 16.84lpm

**Calibrator/s:**

Shea Beaton

**NO<sub>2</sub>**

## NOx - NO- NO<sub>2</sub> Calibration Report

### Station Information

Calibration Date	December 18, 2007	Previous Calibration	November 19, 2007
Company	Lakeland Ind & Comm. Assoc.	Plant/Location	LICA 1 - Cold Lake South
Start Time (MST)	8:10	End Time (MST)	14:55
Reason:	Monthly Calibration		
Barometric Pressure	706 mmHg	Station Temperature	23.0 Deg C
Cal Gas Concentration	NOx 49.8 ppm	NO 49.7 ppm	Cal Gas Expiry date 06/18/2009
DAS Output Voltage	0 - 5 Volts		

### Equipment Information

Analyzer Make / Model:	TECO 42C	S/N :	42-7408-716	Method:	Chemiluminescent
Calibrator Make / Model:	Environics 2000	S/N:	1991		
DAS Make / Model:	ESC 8832	S/N :	263		
Flow Meter:	Environics 2000	S/N :	1991		

### Analyzer Settings

Concentration Range	Before Calibration				After Calibration			
	736	ccm	317	Deg C	739	ccm	317	Deg C
Ozone Flow / Vacuum	OK	ccm	173.1	"Hg-A	OK	ccm	173.3	"Hg-A
HVPS	-821	Volts			-821	Volts		
Rx/ Temp / PMT Temp	49.5	Deg C	-2.5	Deg C	49.5	Deg C	-2.5	Deg C
Box Temp / IZS Temp	30.8	Deg C	OK	Deg C	30.7	Deg C	OK	Deg C
Offset	2.6	NOx	2.5	NO	2.5	NOx	2.6	NO
Slope	1	NOx	0.69	NO	1	NOx	0.690	NO

### Gas Phase Titration Calibration Data

Dilution Air Flow Rate	Source Flow Rate	O <sub>3</sub> Set Point	Calculated Concentration		Indicated Concentration			Correction Factor	
			NOx	NO	NOx	NO	NO <sub>2</sub>	NOx	NO
ZERO	N/A	N/A	0	0	0	0	0	N/A	N/A
4959	40.2	N/A	400	400	401	401	0	0.9986	0.9966
4959	40.2	N/A	400		404	404	0	0.9912	0.9892
								Converter Efficiency	
4959	40.2	350	400	N/A	399	96	303	98%	
4959	40.2	200	400	N/A	401	211	190	98%	
4959	40.2	100	400	N/A	402	307	95	98%	
4959	40.2	N/A	400	400	401	401	0	N/A	
								Correction Factor	
4974	25.2	N/A	251	251	251	251	0	1.0001	0.9981
4984	15.1	N/A	150	150	151	151	0	0.9962	0.9942
ZERO	N/A	N/A	0	0	0	0	0	N/A	N/A
Linearity OK?		Yes	No	Sum of Least Squares			0.9939	0.9920	
Flows Checked on-site?		Yes	No	New Correction Factor			0.9912	0.9892	
				Average Converter Efficiency			98%		

Auto Zero	Before Calibration				After Calibration			
	1	NOx	0	NO <sub>2</sub>	1	NOx	0	NO <sub>2</sub>
Auto Span	289	NOx	288	NO <sub>2</sub>	286	NOx	284	NO <sub>2</sub>
Sample Lines Connected								YES
Percent Change from Previous Calibration								0.5%


Notes: Power supply voltages +15 @ 15.1v, +5 @ 5.0v, -15 @ -15.1v, battery at 0.6v

Calibration Performed by: Shea Beaton

## NO<sub>2</sub> Calibration Curve

Calibration Date	December 18, 2007		
Company	Lakeland Ind & Comm. Assoc.		
Plant / Location	LICA 1 - Cold Lake South		
Start Time (MST)	8:10	End Time (MST)	14:55


Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient ( $\geq 0.995$ )	0.999997
			Slope (0.85 to 1.15)	0.984306
			Intercept ( $\pm 3\%$ F.S.)	-0.153710
0	0	N/A		
97	95	1.0211		
193	190	1.0158		
308	303	1.0165		



## NO Calibration Curve

Calibration Date	December 18, 2007		
Company	Lakeland Ind & Comm. Assoc.		
Plant / Location	LICA 1 - Cold Lake South		
Start Time (MST)	8:10	End Time (MST)	14:55


Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient ( $\geq 0.995$ ) Slope Intercept	0.999997 1.002932 0.088096
0	0	N/A		
150	151	0.9942		
251	251	0.9981		
400	401	0.9966		




### NOx Calibration Curve

Calibration Date	December 18, 2007		
Company	<u>Lakeland Ind &amp; Comm. Assoc.</u>		
Plant / Location	LICA 1 - Cold Lake South		
Start Time (MST)	8:10	End Time (MST)	14:55

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient ( $\geq 0.995$ ) Slope (0.85 to 1.15) Intercept ( $\pm 3\%$ F.S.)	0.999997 1.000918 0.088096
0	0	N/A		
150	151	0.9962		
251	251	1.0001		
400	401	0.9986		



### 01 Minute Averages



# OZONE

## O<sub>3</sub> Calibration Report

### Station Information

Calibration Date	December 18, 2007	Previous Calibration	November 19, 2007
Company			
Lakeland Industry & Community Association			
Plant / Location	LICA 1 - Cold Lake South		
Start Time (MST)	14:10	End Time (MST)	17:40
Reason:	Monthly Calibration		
Barometric Pressure	706	mm Hg	Station Temperature
DAS Output Voltage	0 - 10	Volts	24 Deg C

### Equipment Information

Analyzer Make / Model:	TEI 49i	S/N :	700419951	Method:	Fluorescent
Calibrator Make / Model:	Environics 2000	S/N :	1991	Method:	Dilution
DAS Make / Model:	ESC 8832	S/N :	263		

### Analyzer Settings

	Before Calibration		After Calibration	
			0 - 500	ppb
Concentration Range	29.7	659.6	29.6	659.6
Bench Temp/ Pressure	29%		29%	
O <sub>3</sub> Set Level	53.6	67.7	53.6	67.7
Bench Lamp/O <sub>3</sub> Lamp	0.711 LPM	0.722 LPM	0.732 LPM	0.743 LPM
Sample Flow A/B	0.8	1.058	0.8	1.102
Offset / Slope				

### Calibration Data

Dilution Flow Rate	Ozone Set Point	Calculated Concentration	Indicated Conc. (DAS)	Correction Factor
ZERO	ZERO	0	0	N/A
5000	350	344	331	1.0393
5000	350	344	345	0.9971
5000	200	197	200	0.9850
5000	100	97	98	0.9898
ZERO	ZERO	0	0	N/A
Sum of Least Squares				N/A
New Correction Factor				0.9971

### Before Calibration

### After Calibration

Auto Zero	0	0
Auto Span	298	309
Sample Lines Connected		YES
Percent Change from Previous Calibration		-3.8%

Notes:

---



---




---

Calibration Performed by: Shea Beaton


### O<sub>3</sub> Calibration Curve

Calibration Date	December 18, 2007		
Company	<b>Lakeland Industry &amp; Community Association</b>		
Plant / Location	<b>LICA 1 - Cold Lake South</b>		
Start Time (MST)	14:10	End Time (MST)	17:40

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient	(≥ 0.995) (0.85 to 1.15)	0.999940
			Slope	(± 3% F.S.)	1.003619
			Intercept		0.672735
0	0	n/a			
97	98	0.9898			
197	200	0.9850			
344	345	0.9971			




### 01 Minute Averages



**DECEMBER 2007**  
**LICA**  
**PASSIVE BUBBLE MAPS**



## PASSIVE BUBBLE MAP

December 2007





## PASSIVE BUBBLE MAP

December 2007





## PASSIVE BUBBLE MAP

December 2007



## PASSIVE BUBBLE MAP

December 2007



**DECEMBER 2007**

**LICA PASSIVE NETWORK**

**LAB ANALYSIS**

**Attention: MICHAEL BISAGA**

LAKELAND INDUSTRY AND COMMUNITY ASSOCIATION  
PO BOX 8237  
5006 - 50TH AVENUE  
BONNYVILLE, AB  
CANADA T9N 2J5

**Report Date: 2008/01/22**

**CERTIFICATE OF ANALYSIS**

**MAXXAM JOB #: A800650**

**Received: 2008/01/07, 10:52**

Sample Matrix: Air

# Samples Received: 1

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Analytical Method
H2S Passive Analysis (0)	1	2008/01/21	2008/01/21		EDM SOP-0320
NO2 Passive Analysis (0)	1	2008/01/21	2008/01/21		EDM SOP-0318
O3 Passive Analysis (0)	1	2008/01/14	2008/01/14		EDM SOP-0317
SO2 Passive Analysis (0)	1	2008/01/21	2008/01/21		EDM SOP-0319

Sample Matrix: Air

# Samples Received: 25

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Analytical Method
H2S Passive Analysis (0)	16	2008/01/21	2008/01/21		EDM SOP-0320
NO2 Passive Analysis (0)	22	2008/01/21	2008/01/21		EDM SOP-0318
O3 Passive Analysis (0)	22	2008/01/14	2008/01/14		EDM SOP-0317
SO2 Passive Analysis (0)	25	2008/01/21	2008/01/21		EDM SOP-0319

\* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) The detection limit is based on a 30 day sampling period.

**Encryption Key**

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JODI HANSON, Project Manager, Customer Service  
Email: jodi.hanson@maxxamanalytics.com  
Phone# (780) 468-3500

**Attention: MICHAEL BISAGA**

LAKELAND INDUSTRY AND COMMUNITY ASSOCIATION  
PO BOX 8237  
5006 - 50TH AVENUE  
BONNYVILLE, AB  
CANADA T9N 2J5

**Report Date: 2008/01/22**

**CERTIFICATE OF ANALYSIS**

-2-

=====  
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

Total cover pages: 2



Maxxam Job #: A800650  
Report Date: 2008/01/22

LAKELAND INDUSTRY AND COMMUNITY ASSOCIATION  
Client Project #: DECEMBER 2007  
Site Reference: LICA  
Sampler Initials: SB

### RESULTS OF CHEMICAL ANALYSES OF AIR

Maxxam ID		I50867		
Sampling Date		2007/11/29 15:35		
	Units	12A	RDL	QC Batch

Passive Monitoring				
Calculated H2S	ppb	0.14	0.02	2077185
Calculated NO2	ppb	2.1	0.1	2077192
Calculated O3	ppb	26.7	0.1	2062955
Calculated SO2	ppb	0.6	0.1	2077196

RDL = Reportable Detection Limit



Maxxam Job #: A800650

Report Date: 2008/01/22

LAKELAND INDUSTRY AND COMMUNITY ASSOCIATION

Client Project #: DECEMBER 2007

Site Reference: LICA

Sampler Initials: SB

### RESULTS OF CHEMICAL ANALYSES OF AIR

Maxxam ID	I50847	I50848	I50849	I50850		
Sampling Date	2007/11/29 10:50	2007/11/29 10:10	2007/11/30 15:40	2007/11/30 15:05		
Units	1	2	3	4	RDL	QC Batch

Passive Monitoring						
Calculated H2S	ppb		0.21		0.21	0.02
Calculated NO2	ppb	4.1	3.3	4.0	3.8	0.1
Calculated O3	ppb	18.8	24.6	50.5	25.8	0.1
Calculated SO2	ppb	0.3	0.8	1.2	1.0	0.1
RDL = Reportable Detection Limit						

Maxxam ID	I50851	I50852	I50853	I50854		
Sampling Date	2007/11/30 13:50	2007/11/30 16:25	2007/11/29 09:35	2007/11/29 11:35		
Units	5	7	8	9	RDL	QC Batch

Passive Monitoring						
Calculated H2S	ppb				0.17	0.02
Calculated NO2	ppb	5.3	3.6	2.9	3.2	0.1
Calculated O3	ppb	27.5	21.0	28.8	21.9	0.1
Calculated SO2	ppb	0.7	0.7	0.4	0.5	0.1
RDL = Reportable Detection Limit						

Maxxam ID	I50855	I50856	I50857	I50858		
Sampling Date	2007/11/29 12:15	2007/11/29 14:00	2007/11/29 15:35	2007/11/29 17:10		
Units	10	11	12	13	RDL	QC Batch

Passive Monitoring						
Calculated H2S	ppb	0.14	0.14	0.18	0.20	0.02
Calculated NO2	ppb	1.4	3.2	2.8	4.3	0.1
Calculated O3	ppb	21.1	22.1	26.9	24.4	0.1
Calculated SO2	ppb	0.4	0.7	0.8	1.4	0.1
RDL = Reportable Detection Limit						



Maxxam Job #: A800650  
Report Date: 2008/01/22

LAKELAND INDUSTRY AND COMMUNITY ASSOCIATION  
Client Project #: DECEMBER 2007  
Site Reference: LICA  
Sampler Initials: SB

### RESULTS OF CHEMICAL ANALYSES OF AIR

Maxxam ID	I50859	I50860	I50861	I50862		
Sampling Date	2007/11/29 08:40	2007/11/30 12:30	2007/11/30 13:10	2007/11/30 11:50		
Units	14	15	16	17	RDL	QC Batch

Passive Monitoring						
Calculated H2S	ppb		0.19	0.19	0.14	0.02
Calculated NO2	ppb	3.2	4.5	4.4	3.7	0.1
Calculated O3	ppb	24.1	22.6	24.9	21.6	0.1
Calculated SO2	ppb	0.5	0.9	0.9	0.7	0.1
RDL = Reportable Detection Limit						

Maxxam ID	I50863	I50864	I50865	I50866		
Sampling Date	2007/11/30 11:00	2007/11/29 07:45	2007/11/30 09:30	2007/11/30 14:25		
Units	18	19	20	21	RDL	QC Batch

Passive Monitoring						
Calculated H2S	ppb		0.18		0.22	0.02
Calculated NO2	ppb	2.2	5.4	1.2	5.6	0.1
Calculated O3	ppb	28.2	20.6	22.2	22.0	0.1
Calculated SO2	ppb	0.6	0.5	0.4	0.8	0.1
RDL = Reportable Detection Limit						

Maxxam ID	I50868	I50871	I50872	I50873		
Sampling Date	2007/11/29 17:10	2007/11/29 15:15	2007/11/29 16:30	2007/11/29 17:35		
Units	13A	22	23	24	RDL	QC Batch

Passive Monitoring						
Calculated H2S	ppb	0.20	0.16	0.19	0.13	0.02
Calculated NO2	ppb	4.3				0.1
Calculated O3	ppb	22.6				0.1
Calculated SO2	ppb	1.7	0.6	0.6	1.6	0.1
RDL = Reportable Detection Limit						



Maxxam Job #: A800650  
Report Date: 2008/01/22

LAKELAND INDUSTRY AND COMMUNITY ASSOCIATION  
Client Project #: DECEMBER 2007  
Site Reference: LICA  
Sampler Initials: SB

### RESULTS OF CHEMICAL ANALYSES OF AIR

Maxxam ID		I50874		
Sampling Date		2007/11/29 09:10		
	Units	25	RDL	QC Batch

Passive Monitoring				
Calculated NO <sub>2</sub>	ppb	10.7	0.1	2077192
Calculated O <sub>3</sub>	ppb	19.0	0.1	2062955
Calculated SO <sub>2</sub>	ppb	0.6	0.1	2077196

RDL = Reportable Detection Limit



Maxxam Job #: A800650  
Report Date: 2008/01/22

LAKELAND INDUSTRY AND COMMUNITY ASSOCIATION  
Client Project #: DECEMBER 2007  
Site Reference: LICA  
Sampler Initials: SB

**General Comments**

Sample I50850-01: #4 O3 low reading was noticed.

**Results relate only to the items tested.**

Quality Assurance Report  
 Maxxam Job Number: PA800650

QA/QC Batch Num Init	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
2062955 LM1	Calibration Check	Calculated O3	2008/01/14		100	%	91 - 107
	SPIKE	Calculated O3	2008/01/14		100	%	N/A
	BLANK	Calculated O3	2008/01/14	<0.1		ppb	
2077192 DF4	Calibration Check	Calculated NO2	2008/01/21		98	%	76 - 118
	SPIKE	Calculated NO2	2008/01/21		99	%	N/A
	BLANK	Calculated NO2	2008/01/21	<0.1		ppb	
2077196 DF	Calibration Check	Calculated SO2	2008/01/21		101	%	95 - 105
	SPIKE	Calculated SO2	2008/01/21		102	%	N/A
	BLANK	Calculated SO2	2008/01/21	<0.1		ppb	

N/A = Not Applicable

Edmonton: 9331 - 48th Street T6B 2R4 Telephone(780) 468-3500 FAX(780) 466-3332

# **DECEMBER 2007**

# **PASSIVE FIELD DATA**

**LAKELAND INDUSTRY & COMMUNITY  
ASSOCIATION  
PASSIVE FIELD DATA**

SAMPLER	ID	START		END		NOTES
		DATE	TIME	DATE	TIME	
SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	1	11/29/07	10:50	12/28/07	09:45	CONSTRUCTION ACTIVITY NEARBY
H <sub>2</sub> S/SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	2	11/29/07	10:10	12/28/07	09:05	
SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	3	11/30/07	15:40	12/29/07	15:15	
H <sub>2</sub> S/SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	4	11/30/07	15:05	12/29/07	14:35	
SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	5	11/30/07	13:50	12/29/07	13:15	
SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	7	11/30/07	16:25	12/29/07	16:00	
SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	8	11/29/07	09:35	12/28/07	08:30	
H <sub>2</sub> S/SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	9	11/29/07	11:35	12/28/07	10:25	
H <sub>2</sub> S/SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	10	11/29/07	12:15	12/28/07	11:05	
H <sub>2</sub> S/SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	11	11/29/07	14:00	12/28/07	12:20	
H <sub>2</sub> S/SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	12	11/29/07	15:35	12/28/07	14:00	
H <sub>2</sub> S/SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	13	11/29/07	17:10	12/28/07	15:00	
SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	14	11/29/07	08:40	12/28/07	07:10	
H <sub>2</sub> S/SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	15	11/30/07	12:30	12/29/07	11:50	
H <sub>2</sub> S/SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	16	11/30/07	13:10	12/29/07	12:30	
H <sub>2</sub> S/SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	17	11/30/07	11:50	12/29/07	11:10	
SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	18	11/30/07	11:00	12/29/07	10:15	
H <sub>2</sub> S/SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	19	11/29/07	07:45	12/29/07	08:15	
SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	20	11/30/07	09:30	12/28/07	16:20	
H <sub>2</sub> S/SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	21	11/30/07	14:25	12/29/07	13:50	
H <sub>2</sub> S/SO <sub>2</sub>	22	11/29/07	15:15	12/28/07	13:40	
H <sub>2</sub> S/SO <sub>2</sub>	23	11/29/07	16:30	12/28/07	14:35	
H <sub>2</sub> S/SO <sub>2</sub>	24	11/29/07	17:35	12/28/07	15:25	
SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	25	11/29/07	09:10	12/28/07	07:40	
H <sub>2</sub> S/SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	12A	11/29/07	15:35	12/28/07	14:00	
H <sub>2</sub> S/SO <sub>2</sub> /NO <sub>2</sub> /O <sub>3</sub>	13A	11/29/07	17:10	12/28/07	15:00	