

Lakeland Industry & Community Association

Maskwa Monitoring Site
Ambient Air Monitoring
Data Report
For
January 2012

Prepared By:



February 22, 2012

Lakeland Industry & Community Association

Ambient Air Monitoring

Maskwa

Table of Contents			Page
Introduction			
Calibration Procedure			
Monthly Continuous Summary			
General Monthly Summary			
Continuous Monitoring			
• Monthly Summaries, Graphs & Wind Roses			
• Sulphur Dioxide			
• Hydrogen Sulphide			
• Total Hydrocarbons			
• Nitrogen Dioxide			
• Nitric Oxide			
• Oxides of Nitrogen			
• Temperature			
• Precipitation			
• Relative Humidity			
• Barometric Pressure			
• Vector Wind Speed			
• Vector Wind Direction			
• Standard Deviation Wind Direction			
		Page	
		Calibration Reports	84
		• Sulphur Dioxide	85
		• Hydrogen Sulphide	88
		• Total Hydrocarbons	91
		• Nitrogen Dioxide	94

Introduction

The following Ambient Air Monitoring report was prepared for:

Mr. Mike Bisaga
Lakeland Industry & Community Association
Box 8237
5107W – 50 Street
Bonnyville, Alberta
T9N 2J5

Monitoring Location: Maskwa
Data Period: January 2012

The monthly ambient data report:

- Prepared by Lily Lin
- Reviewed by Craig Snider

Calibration Procedure

The following calibration procedure applies to all calibrations conducted at the Lakeland Industry & Community Association Air Monitoring Station.

Calibration gas concentrations are generated using a dynamic mass flow controlled calibrator. EPA Protocol one gases are diluted with zero air generated on site. The Mass Flow Controllers in the calibrator are referenced using an NIST traceable flow meter once per month. All listed flows are reported as corrected to Standard Temperature and Pressure (STP).

Generated zero gas is introduced to the analyzer first. Three concentrations of calibration gas are then generated in order to introduce points at approximately 50-80%, 25-40% & 10-20% of the analyzer's full-scale range. An auto zero and span are then performed to validate the daily zero and span values recorded to the next multi-point calibration.

All indicated concentrations are taken from the ESC data logger used to collect the data for monthly reporting.

The calibrations conducted at the LICA - Maskwa Air Monitoring Stations conform to the following Maxxam Standard Operation Procedures:

- CAL SOP-00211
- CAL SOP-00209
- CAL SOP-00213
- CAL SOP-00214
- CAL SOP-00208

Conformance of each calibration to Alberta Environment regulations is outlined in the individual calibration reports. The slope and correlation coefficient are derived from the calculated and indicated analyzer responses. The percent change is calculated using the previous calibration correction factor and the current correction factor before adjustment. All calibration's and maintenance conforms to the procedures outlined in the *Air Monitoring Directive, Appendix A-10, Section 1.6*.

MONTHLY CONTINUOUS DATA SUMMARY

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION – MASKWA

Continuous Ambient Monitoring – January 2012

LICA MASKWA SITE						MAXIMUM VALUES						OPERATIONAL TIME (PERCENT)	
						OBJECTIVES			EXCEEDENCES		MONTHLY AVERAGE		1-HOUR
PARAMETER	1-HR	24-HR	1-HR	24-HR	READING	DAY	HOUR	WIND SPEED (KPH)	WIND DIRECTION (DEGREES)	READING			DAY
SO2 (PPB)	172	48	0	0	0.63	15	11	0	6.8	307(NW)	1.9	11	100.0
H2S (PPB)	10	3	0	0	0.14	1	VAR	VAR	VAR	VAR	0.7	11, 12	99.9
THC (PPM)	-	-	-	-	2.26	3.1	5, 31	2, 23	0.6, 5.6	305(WNW), 218(SW)	2.7	24	99.9
NOx (PPB)	-	-	-	-	5.57	32	25	8	0.8	275(W)	11.6	31	99.7
NO (PPB)	-	-	-	-	0.73	8	VAR	VAR	VAR	VAR	2.3	30	99.7
NO ₂ (PPB)	159	-	0	-	4.80	23	25, 31	8, 22	0.8, 4.7	275(W), 220(SW)	9.6	31	99.7
VECTOR WS (KPH)	-	-	-	-	5.04	15.0	14	23	-	17(NNE)	9.9	10	100.0
VECTOR WD (DEGREES)	-	-	-	-	261(W)	-	-	-	-	-	-	-	100.0
RELATIVE HUMIDITY (%)	-	-	-	-	68.42	90	5	8	4.7	253(WSW)	84.5	5	100.0
TEMPERATURE (DEG C)	-	-	-	-	-9.98	9.3	8	13	11.5	281(W)	2.8	8	100.0
BAROMETRIC PRESSURE (MILIBAR)	-	-	-	-	935	957	1	VAR	VAR	VAR	954.7	1	100.0
PRECIPITATION (MM)	-	-	-	-	0.02	1.3	5	10	6.3	294(WNW)	5.1	5	100.0

NA-NOT APPLICABLE VAR-VARIOUS

General Monthly Summary

Equipment Operation

The following summary outlines the analyzer performance. Any non-conformances, problems or maintenance performed are detailed at the end of each section.

AQM STATION – LICA – Maskwa

Sulphur Dioxide (PPB)

- Analyzer make / model - API 100E, S/N: 508

No operational issue was observed during the month. The inlet filter was changed before the monthly calibration was started on January 4th. Data was corrected using daily zero information.

Hydrogen Sulphide (PPB)

- Analyzer make / model - API 101E, S/N: 511

No operational issue was observed during the month. The inlet filter was changed before the monthly calibration was started on January 3rd. Data was corrected using daily zero information.

Total HydroCarbon (PPM)

- Analyzer make / model –TECO 51C-LT, S/N: 436609738

No operational issue was observed during the month. The inlet filter was changed before the monthly calibration was started on January 4th. Both the H₂ and CH₄ gas cylinders were replaced on January 12th following a daily zero/span check. Data was corrected using daily zero information.

General Monthly Summary

AQM STATION – LICA – Maskwa

Nitrogen Dioxide (PPB)

- Analyzer make / model - API 200E, S/N: 594

No operational issue was observed during the month. It was noticed that the analyzer spanned low on December 29th. Following the as found points check on January 1st, the permeation tube was replaced. The expected span value was adjusted after the perm tube was stabilized on January 5th. The inlet filter was changed before the monthly calibration was started on January 3rd. Data was corrected using daily zero information.

Vector Wind Speed (KPH) & Vector Wind Direction (DEG)

- System make / model - RM Young 5103 VK, S/N: 56589

The wind system is reported as vector wind speed and vector wind direction.

No operational issue was observed this month.

Relative Humidity (PERCENT)

- System make / model - Met One 083

No operational issues observed during the month.

Precipitation (MM)

- System make / model - Met One 387

No operational issues observed during this month.

General Monthly Summary

AQM STATION – LICA – Maskwa

Barometric Pressure (MILLIBAR)

- System make / model - Met One 092

No operation issue was observed during the month.

Ambient Temperature (DEGC)

- System make / model - Met One 060

No operational issue was observed during the month.

Trailer Temperature (DEG C)

- System make / model – R&R 61

No operational issue was observed during the month.

Standard Deviation Wind Direction (DEG)

- System make / model –Met One 50.5H

No operational issue was observed during the month.

General Monthly Summary

AQM STATION – LICA – Maskwa

Datalogger

- System make / model - ESC 8832
- Software make/version - ESC v 5.51a

No operational issue was observed during the month.

Trailer

The manifold was cleaned on January 4th.

Continuous Monitoring

Monthly Summaries, Graphs & Wind Roses

Sulphur Dioxide

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - MASKWA
JANUARY 2012
SULPHUR DIOXIDE (SO₂) hourly averages in ppb

MST

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR		
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
DAY																												
1	0	0	0	0	0	IZS	0	0	0	0	0	2	1	0	0	0	0	0	0	0	0	0	0	0	2	0.1	24	
2	0	0	0	0	IZS	0	1	0	0	0	0	1	1	1	1	1	1	1	0	0	0	1	1	1	1	0.5	24	
3	3	2	1	IZS	4	2	1	0	1	0	1	1	1	0	0	0	0	0	0	0	0	0	0	0	4	0.7	24	
4	0	0	IZS	0	0	0	0	0	0	C	C	C	C	2	0	0	0	0	0	1	0	0	0	0	2	0.2	24	
5	0	IZS	0	1	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	0	0	0	0	1	0.1	24	
6	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0.0	24
7	0	0	1	1	2	2	2	1	1	1	1	2	2	2	1	1	1	1	0	1	1	1	1	IZS	0	2	1.1	24
8	0	0	0	0	0	1	3	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	1	0.3	24
9	1	1	0	0	0	1	1	0	1	0	0	0	0	1	0	1	1	0	2	2	IZS	0	1	0	2	0.6	24	
10	0	0	5	6	5	6	2	0	0	0	2	0	0	0	4	0	0	0	0	IZS	0	0	0	0	6	1.3	24	
11	15	12	12	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	1	1	1	1	15	1.9	24	
12	1	1	1	2	2	0	0	1	1	0	0	1	1	1	1	1	1	IZS	0	0	0	0	0	0	2	0.7	24	
13	1	1	1	1	1	1	0	0	0	0	0	0	2	4	6	1	IZS	1	0	2	0	0	1	1	6	1.0	24	
14	1	0	1	1	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	1	0.1	24	
15	0	0	0	0	0	0	1	1	2	2	1	0	0	0	IZS	0	0	0	0	0	0	0	0	0	2	0.3	24	
16	0	1	2	2	2	0	0	1	1	0	0	0	0	IZS	1	1	1	1	1	1	1	1	1	3	2	3	1.0	24
17	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	1	0	1	1	1	1	0.2	24	
18	1	1	1	1	2	1	1	1	1	1	1	1	IZS	0	0	0	0	0	0	0	0	0	0	0	2	0.5	24	
19	0	0	0	0	0	1	1	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0.1	24	
20	0	0	0	0	0	0	0	0	0	0	IZS	1	1	1	1	0	0	0	0	0	0	0	0	1	1	0.3	24	
21	1	2	1	1	0	1	1	0	IZS	0	2	2	2	2	1	2	2	1	3	3	1	0	0	0	3	1.2	24	
22	0	0	0	0	0	0	0	IZS	0	0	1	1	2	2	2	2	1	1	0	0	0	0	0	0	2	0.5	24	
23	0	1	1	1	1	0	IZS	1	0	0	0	1	1	1	0	0	0	0	0	2	2	2	2	2	2	2	0.8	24
24	1	0	0	1	1	IZS	1	1	1	1	0	0	0	0	0	1	1	2	1	1	1	1	1	1	2	0.7	24	
25	1	1	1	1	IZS	0	0	0	0	0	2	3	2	0	0	3	1	0	0	0	0	0	0	0	3	0.7	24	
26	0	0	0	IZS	0	1	1	1	1	0	0	1	0	0	0	0	0	0	0	1	0	1	1	1	1	0.3	24	
27	0	0	IZS	0	0	0	7	3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	7	0.5	24	
28	0	IZS	8	6	4	3	0	0	1	1	2	2	4	1	1	0	0	0	0	1	3	2	8	8	1.7	24		
29	IZS	1	2	4	2	1	1	2	5	2	0	0	1	1	1	1	1	1	1	1	0	0	0	IZS	5	1.3	24	
30	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	2	0	IZS	0	2	0.1	24	
31	0	0	0	0	0	0	1	0	0	0	1	1	1	1	1	1	0	0	0	1	IZS	2	1	2	0.5	24		
HOURLY MAX	15	12	12	6	5	6	7	3	5	2	2	3	4	4	6	3	2	3	3	3	3	2	3	2				
HOURLY AVG	0.9	0.8	1.3	1.0	0.9	0.7	0.8	0.5	0.5	0.3	0.6	0.7	0.8	0.7	0.7	0.5	0.4	0.3	0.3	0.5	0.4	0.3	0.7	0.5				

STATUS FLAG CODES


S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

OBJECTIVE LIMIT:


ALBERTA ENVIRONMENT:	1-HR	172	PPB	24-HR	57	PPB
-----------------------------	------	-----	-----	-------	----	-----

MONTHLY SUMMARY

NUMBER OF 1-HR EXCEEDENCES:	0					
NUMBER OF 24-HR EXCEEDENCES:	0					
NUMBER OF NON-ZERO READINGS:	269					
MAXIMUM 1-HR AVERAGE:	15	PPB	@ HOUR(S)	0	ON DAY(S)	11
MAXIMUM 24-HR AVERAGE:	1.9	PPB			ON DAY(S)	11
IZS CALIBRATION TIME:	33	HRS	OPERATIONAL TIME:	744 HRS		
MONTHLY CALIBRATION TIME:	4	HRS	AMD OPERATION UPTIME:	100.0 %		
STANDARD DEVIATION:	1.28		MONTHLY AVERAGE:	0.63 PPB		



01 Hour Averages



— LICA30 SO2_ PPB

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION -MASKWA

JANUARY 2012

SULPHUR DIOXIDE MAX instantaneous maximum in ppt

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR		
DAY	HR	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
1		0	0	0	0	1	IZS	1	0	0	0	2	3	2	1	1	0	0	0	0	0	0	0	0	0	3	0.5	24	
2		0	1	1	1	IZS	0	3	0	0	1	1	1	2	2	2	2	1	3	1	1	1	2	1	5	5	1.4	24	
3		7	4	1	IZS	8	5	2	1	2	1	2	3	2	1	1	1	1	1	1	1	1	1	1	1	8	2.1	24	
4		1	1	IZS	1	0	0	0	1	0	C	C	C	C	5	1	1	1	0	0	1	1	1	0	1	5	0.8	24	
5		0	IZS	0	4	1	2	1	1	1	0	2	7	0	0	0	0	0	0	0	0	0	2	0	0	7	0.9	24	
6		IZS	0	0	0	0	0	0	0	0	0	0	0	0	6	3	0	0	0	0	0	0	0	0	0	IZS	6	0.4	24
7		1	1	2	2	2	3	3	3	2	2	2	3	2	2	2	1	1	1	1	1	1	2	IZS	0	3	1.7	24	
8		0	0	0	0	1	2	4	3	1	1	0	0	0	0	0	0	0	0	0	0	0	0	IZS	1	2	4	0.7	24
9		3	2	0	0	1	2	2	1	2	1	1	1	1	1	1	1	1	1	5	4	IZS	0	6	0	6	1.6	24	
10		0	0	19	14	23	18	16	0	0	0	14	3	0	4	13	0	0	2	1	IZS	0	0	0	16	23	6.2	24	
11		22	18	26	4	1	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	1	1	1	1	1	1	26	3.3	24
12		2	2	2	5	1	1	2	1	1	1	1	1	2	1	2	1	IZS	0	1	1	1	0	0	0	5	1.4	24	
13		3	3	2	1	3	2	1	1	0	0	5	1	9	13	15	3	IZS	9	1	4	3	2	6	4	15	4.0	24	
14		7	1	2	3	0	0	0	0	0	0	1	2	1	3	0	IZS	0	0	0	0	0	0	0	0	7	0.9	24	
15		0	0	0	0	0	0	2	2	3	3	3	1	0	1	IZS	0	0	0	0	0	0	0	1	1	3	0.7	24	
16		0	2	3	3	3	1	1	1	1	1	0	0	0	IZS	2	2	2	1	2	2	2	9	10	10	10	2.6	24	
17		1	1	1	1	1	1	1	1	1	1	1	1	IZS	1	1	1	1	1	1	1	1	2	2	2	2	2	1.1	24
18		1	2	2	2	2	2	2	2	1	2	1	IZS	0	0	0	0	0	0	0	0	0	0	0	0	2	0.8	24	
19		1	1	0	0	0	3	2	0	0	0	IZS	1	0	1	1	0	0	0	0	0	0	0	0	0	3	0.4	24	
20		0	0	0	0	0	0	0	0	1	IZS	3	3	2	1	1	1	0	0	0	1	1	1	2	2	3	0.8	24	
21		3	4	2	1	1	4	3	2	IZS	1	4	4	3	4	1	5	4	4	6	5	2	1	1	1	6	2.9	24	
22		1	1	1	1	1	1	1	IZS	0	1	1	2	3	3	2	2	2	1	1	1	1	1	1	1	3	1.3	24	
23		1	1	2	1	1	1	IZS	2	1	1	1	2	2	1	1	1	1	1	1	4	4	3	3	3	4	1.7	24	
24		2	1	1	3	2	IZS	1	2	1	1	1	1	1	1	4	3	3	1	1	3	2	1	3	4	1.7	24		
25		2	1	1	1	IZS	0	0	0	0	1	5	10	9	0	0	6	5	1	4	0	0	0	0	10	2.0	24		
26		0	0	0	IZS	2	3	3	2	2	0	2	3	1	2	0	0	0	0	0	1	2	1	3	2	3	1.3	24	
27		1	0	IZS	0	0	3	16	10	1	0	0	0	0	1	0	0	1	1	1	1	1	0	3	0	16	1.7	24	
28		1	IZS	17	16	9	11	0	0	6	4	2	3	5	3	2	1	1	1	1	1	1	4	5	3	17	4.2	24	
29		IZS	3	5	5	4	2	2	4	5	5	1	1	1	2	2	1	1	1	1	2	1	1	1	1	IZS	5	2.3	24
30		0	0	0	0	0	0	0	0	0	0	0	0	1	1	2	1	1	1	1	1	2	1	IZS	0	2	0.5	24	
31		0	1	0	0	1	1	1	2	0	1	2	2	2	1	2	1	1	1	1	1	2	IZS	3	2	3	1.2	24	
HOURLY MAX		22	18	26	16	23	18	16	10	6	5	14	10	9	13	15	6	5	9	6	5	4	9	10	16				
HOURLY AVG		2.1	1.8	3.1	2.4	2.5	2.3	2.3	1.4	1.1	1.0	2.0	2.0	1.7	2.1	1.9	1.2	1.0	1.1	1.0	1.2	1.1	1.3	1.8	2.1				


STATUS FLAG CODES

S - OUT OF SERVICE	IZS - IZS - DAILY ZERO/SPAN CHECK
N - INVALID DATA	M - MISSING DATA
D - INSTRUMENT DRIFT	P - POWER FAILURE
C - CALIBRATION	NA - NOT APPLICABLE

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	474					
MAXIMUM INSTANTANEOUS VALUE:	26	PPB	@ HOUR(S)	2	ON DAY(S)	11
IZS CALIBRATION TIME:	33	HRS	OPERATIONAL TIME:	744	HRS	
MONTHLY CALIBRATION TIME:	4	HRS				
STANDARD DEVIATION:	2.95					

01 Hour Averages



— LICA30 SO2MAX PPB

LICA30
SO2_ / WDR Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 30
Site Name : LICA30
Parameter : SO2_
Units : PPB

Wind Parameter : WDR
Instrument Height : 10 Meters

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 20	4.38	2.12	2.68	1.41	2.82	4.38	3.81	1.41	1.41	10.46	21.35	11.17	11.73	11.88	3.25	5.65	100.00
< 60	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 110	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 170	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 340	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 340	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	4.38	2.12	2.68	1.41	2.82	4.38	3.81	1.41	1.41	10.46	21.35	11.17	11.73	11.88	3.25	5.65	

Calm : .00 %

Total # Operational Hours : 707

Distribution By Samples

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 20	31	15	19	10	20	31	27	10	10	74	151	79	83	84	23	40	707
< 60																	
< 110																	
< 170																	
< 340																	
>= 340																	
Totals	31	15	19	10	20	31	27	10	10	74	151	79	83	84	23	40	



Calm : .00 %

Total # Operational Hours : 707


Class Limits (PPB)

Period : 01/01/12-01/31/12

Level : 10



Calibration Graph for Site: LICA30 Parameter: S02_ Sequence: S02 Phase: SPAll



Hydrogen Sulphide

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - MASKWA

JANUARY 2012

HYDROGEN SULPHIDE (H₂S) hourly averages in ppb

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	DAILY 24-HOUR			
DAY	HOURLY MAX	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.		
1		0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
2		0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	1	0.2	24	
3		0	1	0	IZS	0	1	0	0	0	0	C	C	C	C	C	0	0	0	0	0	0	0	0	0	0	1	0.1	24	
4		0	0	IZS	0	0	0	0	0	0	0	0	M	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	23	
5		0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
6		IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0.0	24	
7		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0.0	24	
8		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0.0	24	
9		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0.0	24	
10		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0.0	24	
11		0	1	0	0	0	0	1	1	0	0	1	1	1	1	1	1	1	1	1	IZS	1	0	1	1	1	1	0.7	24	
12		1	1	1	1	1	1	1	1	1	0	1	1	1	1	1	0	1	IZS	0	0	0	0	0	0	0	1	0.7	24	
13		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0.0	24	
14		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0.0	24	
15		0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	1	0	0	0	0	0	1	0	0	1	1	0.1	24	
16		0	0	0	1	0	0	0	1	0	1	1	0	0	IZS	0	0	0	1	1	0	1	1	0	0	0	1	0.3	24	
17		0	0	0	0	0	0	0	0	1	1	0	1	IZS	0	0	0	0	0	0	0	0	0	0	0	0	1	0.1	24	
18		0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
19		0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
20		0	0	0	0	0	0	0	0	0	IZS	1	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0.6	24	
21		1	1	1	1	1	1	1	1	IZS	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	1	0.4	24	
22		0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
23		0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
24		0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	1	0.0	24	
25		0	0	0	0	IZS	0	0	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0.2	24	
26		0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
27		0	0	IZS	1	0	1	1	1	0	0	0	1	1	1	1	1	0	1	1	0	0	1	1	1	1	1	0.6	24	
28		1	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	0.1	24	
29		IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0.0	24	
30		0	1	0	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	0	0	0	IZS	0	1	0.1	24
31		0	0	0	0	0	0	0	1	0	0	1	1	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	1	0.1	24
HOURLY MAX		1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1			
HOURLY AVG		0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.2	0.1	0.1	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2			

STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE


OBJECTIVE LIMIT:

ALBERTA ENVIRONMENT: 1-HR 10 PPB 24-HR 3 PPB


MONTHLY SUMMARY

NUMBER OF 1-HR EXCEEDENCES:	0
NUMBER OF 24-HR EXCEEDENCES:	0
NUMBER OF NON-ZERO READINGS:	99
MAXIMUM 1-HR AVERAGE:	1 PPB @ HOUR(S) VAR ON DAY(S) VAR
MAXIMUM 24-HR AVERAGE:	0.7 PPB VAR ON DAY(S) VAR 11, 12 VAR-VARIOUS
IZS CALIBRATION TIME:	33 HRS
MONTHLY CALIBRATION TIME:	5 HRS
OPERATIONAL TIME:	743 HRS
AMD OPERATION UPTIME:	99.9 %
STANDARD DEVIATION:	0.35
MONTHLY AVERAGE:	0.14 PPB

24 HOUR AVERAGES FOR JANUARY 2012



01 Hour Averages



LAKELAND INDUSTRY & COMMUNITY ASSOCIATION -MASKWA

JANUARY 2012

HYDROGEN SULPHIDE MAX instantaneous maximum in ppb

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	23:00	DAILY	24-HOUR		
DAY	HR	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.		
1	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	0	1	0.1	24		
2	0	0	0	0	0	IZS	1	1	1	0	0	0	1	1	0	0	0	1	1	1	1	1	1	1	1	1	1	0.5	24	
3	1	1	1	1	IZS	1	1	1	1	1	1	C	C	C	C	C	0	0	0	0	0	0	0	0	0	1	0.5	24		
4	0	0	0	IZS	0	0	0	0	1	0	0	1	1	M	1	0	0	1	1	0	0	0	0	1	1	1	1	0.4	23	
5	1	IZS	1	1	1	1	0	0	1	1	1	1	0	0	0	0	0	0	0	0	0	0	1	0	0	1	0.4	24		
6	IZS	0	0	0	0	0	1	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	1	0.1	24
7	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	1	0.0	24
8	0	0	1	1	1	1	1	0	0	0	0	0	0	0	0	0	1	1	0	0	1	IZS	0	0	1	0.3	24			
9	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1	1	0	1	1	0	1	IZS	0	0	0	1	0.2	24	
10	0	0	0	0	0	1	1	0	0	0	1	0	0	0	0	0	0	0	0	0	0	IZS	1	1	1	1	1	0.3	24	
11	1	1	1	1	1	1	1	1	0	1	1	1	1	1	1	1	1	1	1	IZS	1	1	1	1	1	1	1	1.0	24	
12	1	1	2	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	IZS	0	0	0	1	0	0	2	0.8	24		
13	0	0	0	0	0	1	0	0	0	0	0	0	0	0	1	1	IZS	0	0	0	0	0	0	0	0	1	0.1	24		
14	0	0	0	0	0	0	0	0	0	0	1	0	1	0	0	0	IZS	0	0	0	1	0	0	0	0	1	0.2	24		
15	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	1	1	0	0	1	1	1	1	1	1	0.3	24		
16	1	1	1	1	1	1	1	1	1	1	1	1	1	1	IZS	1	1	1	1	1	1	1	1	1	1	1	1	1.0	24	
17	1	1	0	1	0	1	1	1	1	1	1	1	1	IZS	0	0	0	0	0	0	0	0	0	0	0	0	1	0.4	24	
18	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0.1	24	
19	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	1	0	0	0	0	1	0.0	24	
20	0	0	0	0	0	0	1	0	0	0	IZS	1	1	1	1	2	1	1	1	2	1	1	1	1	1	1	2	0.7	24	
21	1	2	1	1	1	1	1	1	1	IZS	0	1	1	1	1	0	0	1	1	1	0	0	0	1	1	1	2	0.8	24	
22	0	1	1	0	0	1	0	0	0	IZS	0	0	1	1	1	0	0	0	0	0	1	0	1	0	0	1	0.4	24		
23	0	0	1	0	0	0	IZS	1	0	0	1	0	0	1	0	0	0	1	1	0	0	0	0	0	0	1	0.3	24		
24	0	1	1	0	0	0	IZS	0	0	1	1	1	0	0	1	0	1	0	0	0	0	0	1	1	1	1	0.4	24		
25	1	1	1	1	IZS	1	0	1	2	2	2	1	1	1	0	1	0	1	0	0	0	0	0	1	0	2	0.7	24		
26	0	0	0	0	IZS	0	0	1	1	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	1	0.1	24	
27	0	0	0	IZS	1	1	1	2	2	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	2	1.0	24	
28	1	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0.1	24		
29	IZS	1	0	0	0	0	0	0	0	1	0	0	0	0	1	1	0	0	0	0	0	0	0	0	0	0	IZS	1	0.2	24
30	1	1	1	1	1	1	0	0	0	0	1	1	1	0	0	0	0	1	1	1	1	0	0	0	0	IZS	0	1	0.5	24
31	0	0	0	0	0	0	1	1	0	1	1	1	1	0	0	0	0	0	0	0	0	1	0	1	0	1	0.3	24		
HOURLY MAX	1	2	2	1	1	1	2	2	2	2	2	2	2	1	1	2	1	1	1	2	1	1	1	1	1	1	1			
HOURLY AVG	0.3	0.4	0.4	0.3	0.3	0.6	0.5	0.5	0.3	0.4	0.6	0.5	0.5	0.4	0.3	0.4	0.4	0.4	0.3	0.4	0.3	0.4	0.4	0.4	0.4	0.4	0.4			


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	276					
MAXIMUM INSTANTANEOUS VALUE:	2	PPB	@ HOUR(S)	VAR	ON DAY(S)	VAR
IZS CALIBRATION TIME:	33	HRS	OPERATIONAL TIME:	743	HRS	
MONTHLY CALIBRATION TIME:	5	HRS				
STANDARD DEVIATION:	0.52					

01 Hour Averages



— LICA30 H2S MAX PPB

LICA30
H2S_ / WDR Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 30
Site Name : LICA30
Parameter : H2S_
Units : PPB

Wind Parameter : WDR
Instrument Height : 10 Meters

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 3	4.68	2.12	2.83	1.41	2.83	4.39	3.82	1.41	1.41	10.49	20.85	11.06	11.77	11.91	3.26	5.67	100.00
< 10	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 50	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 50	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	4.68	2.12	2.83	1.41	2.83	4.39	3.82	1.41	1.41	10.49	20.85	11.06	11.77	11.91	3.26	5.67	

Calm : .00 %

Total # Operational Hours : 705

Distribution By Samples

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 3	33	15	20	10	20	31	27	10	10	74	147	78	83	84	23	40	705
< 10																	
< 50																	
>= 50																	
Totals	33	15	20	10	20	31	27	10	10	74	147	78	83	84	23	40	



Calm : .00 %

Total # Operational Hours : 705


Class Limits (PPB)

Period : 01/01/12-01/31/12

Level : 10




Calibration Graph for Site: LICA30 Parameter: H2S_ Sequence: H2S Phase: SPAll




Total Hydrocarbons

01 Hour Averages



01 Hour Averages



— LICA30 THCMAX PPM

LICA30
 THC / WDR Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 30
 Site Name : LICA30
 Parameter : THC
 Units : PPM

Wind Parameter : WDR
 Instrument Height : 10 Meters

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 3.0	4.39	2.12	2.69	1.41	2.83	4.39	3.82	1.41	1.41	10.49	20.99	11.06	11.77	11.77	3.12	5.67	99.43
< 10.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.28	.00	.00	.14	.14	.00	.56
< 50.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 50.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	4.39	2.12	2.69	1.41	2.83	4.39	3.82	1.41	1.41	10.49	21.27	11.06	11.77	11.91	3.26	5.67	

Calm : .00 %

Total # Operational Hours : 705

Distribution By Samples

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 3.0	31	15	19	10	20	31	27	10	10	74	148	78	83	83	22	40	701
< 10.0											2			1	1		4
< 50.0																	
>= 50.0																	
Totals	31	15	19	10	20	31	27	10	10	74	150	78	83	84	23	40	



Calm : .00 %

Total # Operational Hours : 705


Class Limits (PPM)

Period : 01/01/12-01/31/12

Level : 10




Calibration Graph for Site: LICA30 Parameter: THC Sequence: THC Phase: SPAll




Nitrogen Dioxide

01 Hour Averages



— LICA30 NO2_ PPB

01 Hour Averages



— LICA30 NO2MAX PPB

LICA30
 NO2_ / WDR Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 30
 Site Name : LICA30
 Parameter : NO2_
 Units : PPB

Wind Parameter : WDR
 Instrument Height : 10 Meters

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	4.71	2.14	2.85	1.42	2.85	4.42	3.71	1.42	1.42	10.57	20.57	11.14	11.71	12.00	3.28	5.71	100.00
< 110	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	4.71	2.14	2.85	1.42	2.85	4.42	3.71	1.42	1.42	10.57	20.57	11.14	11.71	12.00	3.28	5.71	

Calm : .00 %

Total # Operational Hours : 700

Distribution By Samples

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	33	15	20	10	20	31	26	10	10	74	144	78	82	84	23	40	700
< 110																	
< 210																	
>= 210																	
Totals	33	15	20	10	20	31	26	10	10	74	144	78	82	84	23	40	



Calm : .00 %

Total # Operational Hours : 700


Class Limits (PPB)

Period : 01/01/12-01/31/12

Level : 10



Calibration Graph for Site: LICA30 Parameter: NO2_ Sequence: NO2 Phase: SPAN



Nitric Oxide

LAKELAND INDUSTRY & COMMUNITY ASSOICATION - MASKWA

JANUARY 2012

NITRIC OXIDE hourly averages in ppb

MST

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY 24-HOUR			
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
DAY																												
1	0	0	0	0	0	IZS	0	0	0	C	M	C	5	4	3	1	1	0	1	0	0	0	0	1	5	0.8	23	
2	0	0	0	0	IZS	1	0	0	0	0	1	1	1	1	1	1	0	0	0	0	0	0	0	0	1	0.3	24	
3	1	0	0	IZS	1	1	0	0	0	1	C	C	C	C	C	C	C	0	0	0	0	0	0	0	1	0.3	24	
4	0	0	IZS	0	0	0	0	4	0	2	8	7	M	3	0	0	1	0	0	0	0	0	0	0	8	1.1	23	
5	0	IZS	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0.0	24	
6	IZS	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	0	0	0	0	0	0	0	0	1	0.1	24	
7	0	0	0	0	0	1	1	1	1	2	5	4	4	3	2	1	2	0	0	0	0	0	0	0	5	1.2	24	
8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0.0	24	
9	0	0	0	0	0	0	0	0	1	1	1	1	0	1	2	2	1	0	1	0	IZS	0	1	0	2	0.5	24	
10	0	0	2	2	2	3	1	0	0	0	2	1	0	0	4	0	0	0	0	0	IZS	0	0	0	1	4	0.8	24
11	8	6	6	1	0	0	1	1	1	2	2	1	2	1	1	1	0	0	IZS	0	0	0	0	0	8	1.5	24	
12	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	1	0	0	0	1	0.0	24	
13	0	0	0	0	0	0	0	0	1	0	1	1	2	3	4	1	IZS	1	0	1	0	0	0	0	4	0.7	24	
14	1	0	0	0	0	0	0	0	0	1	1	1	0	0	0	IZS	0	0	1	0	0	0	0	0	1	0.2	24	
15	0	0	0	0	0	0	0	0	0	1	1	1	0	1	IZS	0	0	0	0	0	0	0	0	0	1	0.2	24	
16	0	0	0	0	0	0	0	0	0	0	0	1	0	IZS	2	1	1	1	0	0	0	1	1	1	2	0.4	24	
17	0	1	0	0	0	1	1	1	1	1	2	2	IZS	1	0	1	1	0	0	1	0	1	1	1	2	0.7	24	
18	1	1	1	1	1	0	1	1	2	1	1	IZS	0	0	0	0	0	0	0	0	0	0	0	0	2	0.5	24	
19	0	0	0	0	0	0	0	0	0	1	IZS	1	0	1	1	0	0	0	0	0	0	0	0	0	1	0.2	24	
20	0	0	0	0	0	0	0	0	0	IZS	7	6	4	3	2	2	1	0	0	0	0	0	0	0	7	1.1	24	
21	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
22	0	0	0	0	0	0	0	IZS	1	2	2	4	5	6	6	5	2	1	1	1	1	1	1	1	6	1.7	24	
23	0	1	1	0	0	0	IZS	0	0	0	0	1	1	1	0	0	0	0	0	0	0	0	0	0	1	0.2	24	
24	0	0	0	0	0	IZS	1	1	2	5	5	3	3	3	3	2	1	0	0	1	0	0	0	5	1.3	24		
25	0	0	0	0	IZS	0	0	3	8	8	6	5	3	0	0	2	0	0	0	0	0	0	0	8	1.5	24		
26	0	0	0	IZS	0	0	0	0	0	0	1	2	0	0	0	0	0	0	0	0	0	0	0	0	2	0.1	24	
27	0	0	IZS	0	0	1	4	2	1	0	0	1	1	2	1	1	0	0	0	0	0	0	1	0	4	0.7	24	
28	0	IZS	4	3	1	1	0	0	1	1	2	3	4	3	2	1	1	0	0	0	0	1	1	1	4	1.3	24	
29	IZS	0	1	1	1	0	1	1	1	1	0	1	1	1	1	0	0	1	0	0	0	0	0	1	1	0.6	24	
30	0	0	0	0	0	0	0	1	2	1	6	8	8	7	8	6	4	0	1	0	1	0	IZS	0	8	2.3	24	
31	0	0	0	0	0	0	2	1	3	8	6	5	5	6	5	3	5	1	0	0	0	IZS	0	0	8	2.2	24	
HOURLY MAX	8	6	6	3	2	3	4	4	8	8	8	8	8	7	8	6	5	1	1	1	1	1	1	1				
HOURLY AVG	0.4	0.3	0.5	0.3	0.2	0.3	0.4	0.6	0.9	1.3	2.1	2.2	1.8	1.8	1.7	1.1	0.8	0.1	0.2	0.1	0.1	0.1	0.2	0.2				


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE


MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	242				
MAXIMUM 1-HR AVERAGE:	8	PPB	@ HOUR(S)	VAR	ON DAY(S)
MAXIMUM 24-HR AVERAGE:	2.3	PPB			30
IZS CALIBRATION TIME:	33	HRS	OPERATIONAL TIME:	742	HRS
MONTHLY CALIBRATION TIME:	9	HRS	AMD OPERATION UPTIME:	99.7	%
STANDARD DEVIATION:	1.48		MONTHLY AVERAGE:	0.73	PPB

24 HOUR AVERAGES FOR JANUARY 2012



01 Hour Averages



LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - MASKWA

JANUARY 2012

NITRIC OXIDE MAX instantaneous maximum in ppb

MST

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR				
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.			
DAY																														
1	0	0	0	0	0	IZS	0	0	2	C	M	C	C	5	4	2	1	1	1	1	1	1	1	1	1	5	1.1	23		
2	1	1	1	1	IZS	1	1	1	1	1	1	2	2	1	1	2	1	1	1	1	1	1	1	1	1	2	1.1	24		
3	2	1	1	IZS	3	7	3	0	1	3	C	C	C	C	C	C	C	0	0	0	0	0	0	0	0	7	1.3	24		
4	0	0	IZS	1	0	0	0	40	0	7	10	9	M	5	1	3	6	0	0	0	0	0	0	0	0	40	3.7	23		
5	0	IZS	0	11	0	0	2	1	28	1	1	4	0	0	1	0	0	0	0	0	0	0	0	0	0	28	2.1	24		
6	IZS	1	1	1	1	9	1	2	1	1	1	1	2	6	4	3	1	1	1	1	1	1	1	1	IZS	9	1.9	24		
7	1	1	1	1	1	28	2	1	5	3	9	6	14	5	3	2	16	1	1	1	1	1	1	1	IZS	0	28	4.5	24	
8	0	0	0	0	0	3	0	0	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	1	1	3	0.3	24
9	1	1	1	1	1	1	1	1	2	2	4	4	1	2	2	3	3	2	3	1	IZS	1	3	1	4	1.8	24	24		
10	1	1	9	6	12	9	8	1	1	1	11	3	1	2	12	1	1	3	1	IZS	1	1	1	9	12	4.2	24	24		
11	14	10	16	3	1	2	7	7	4	23	3	2	4	2	2	1	1	1	1	IZS	0	0	0	0	23	4.5	24	24		
12	0	0	0	2	0	0	0	0	15	13	13	2	1	1	2	1	22	IZS	1	1	3	1	1	1	22	3.5	24	24		
13	1	1	1	1	1	1	2	1	10	1	3	7	6	7	16	3	IZS	4	1	2	1	1	1	2	2	16	3.3	24	24	
14	2	1	1	1	1	1	3	1	1	1	2	2	1	1	1	IZS	1	1	1	1	1	1	1	1	3	1.2	24	24		
15	1	1	1	1	1	1	1	1	1	2	1	3	1	2	IZS	0	0	0	0	0	0	0	0	0	3	0.8	24	24		
16	0	0	0	0	0	0	0	0	0	1	1	1	2	IZS	3	2	1	1	1	1	1	4	4	3	4	1.1	24	24		
17	1	1	1	1	1	1	2	5	7	4	3	3	IZS	3	1	3	2	1	1	1	1	1	1	1	7	2.0	24	24		
18	1	1	1	1	1	1	1	2	5	2	2	IZS	0	0	1	1	16	1	0	0	0	0	0	0	16	1.6	24	24		
19	0	0	0	0	0	2	1	16	10	9	IZS	2	1	42	33	1	1	0	0	0	0	0	0	0	42	5.1	24	24		
20	0	0	0	0	0	0	1	2	1	IZS	12	7	6	4	2	3	6	1	0	0	0	0	0	0	12	2.0	24	24		
21	0	0	0	0	0	1	0	0	IZS	0	0	0	1	1	0	1	1	0	1	1	0	0	0	0	1	0.3	24	24		
22	0	0	0	0	0	0	12	IZS	3	4	4	8	7	7	8	7	3	1	2	1	1	1	1	1	12	3.1	24	24		
23	1	1	1	1	1	1	IZS	0	0	0	1	1	2	1	1	1	1	0	0	0	0	0	0	1	0	2	0.7	24	24	
24	1	0	1	0	0	IZS	3	4	5	14	13	6	4	3	4	2	2	1	1	1	1	1	1	1	14	3.0	24	24		
25	1	1	1	1	IZS	0	39	43	19	31	14	11	11	1	1	4	2	0	1	0	0	0	0	0	43	7.9	24	24		
26	0	0	0	IZS	0	0	3	5	3	1	2	3	1	4	1	13	0	1	0	0	0	0	0	0	13	1.6	24	24		
27	0	0	IZS	1	1	1	10	6	13	1	2	2	2	11	1	1	1	1	1	1	1	1	1	2	13	2.7	24	24		
28	1	IZS	12	8	3	5	2	3	3	3	3	4	7	7	3	2	1	1	1	1	1	1	1	2	12	3.3	24	24		
29	IZS	1	3	2	2	1	1	1	2	2	1	1	1	2	1	16	1	1	1	1	1	1	1	1	16	2.0	24	24		
30	1	1	1	1	1	1	1	2	6	3	43	36	36	11	33	25	40	1	1	1	2	1	IZS	1	43	10.8	24	24		
31	1	1	1	1	1	2	16	3	18	38	14	10	31	18	29	6	27	2	1	1	1	1	IZS	1	0	38	9.7	24	24	
HOURLY MAX	14	10	16	11	12	28	39	43	28	38	43	36	36	42	33	25	40	4	3	2	3	4	4	9						
HOURLY AVG	1.1	0.9	1.9	1.6	1.1	2.7	4.1	5.0	5.6	5.9	6.2	5.0	5.4	5.3	5.9	3.8	5.4	0.9	0.8	0.6	0.7	0.7	0.9	0.9						


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	518					
MAXIMUM INSTANTANEOUS VALUE:	43	PPB	@ HOUR(S)	10	ON DAY(S)	30
IZS CALIBRATION TIME:	33	HRS	OPERATIONAL TIME:	742	HRS	
MONTHLY CALIBRATION TIME:	10	HRS				
STANDARD DEVIATION	6.22					

01 Hour Averages



LICA30
 NO_ / WDR Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 30
 Site Name : LICA30
 Parameter : NO_
 Units : PPB

Wind Parameter : WDR
 Instrument Height : 10 Meters

		Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq	
< 50	4.71	2.14	2.85	1.42	2.85	4.42	3.71	1.42	1.42	10.57	20.57	11.14	11.71	12.00	3.28	5.71	100.00	
< 110	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
< 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
Totals	4.71	2.14	2.85	1.42	2.85	4.42	3.71	1.42	1.42	10.57	20.57	11.14	11.71	12.00	3.28	5.71		

Calm : .00 %

Total # Operational Hours : 700

Distribution By Samples

		Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq	
< 50	33	15	20	10	20	31	26	10	10	74	144	78	82	84	23	40	700	
< 110																		
< 210																		
>= 210																		
Totals	33	15	20	10	20	31	26	10	10	74	144	78	82	84	23	40		



Calm : .00 %

Total # Operational Hours : 700

Class Limits (PPB)

Period : 01/01/12-01/31/12

Level : 10



Oxides of Nitrogen

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - MASKWA
JANUARY 2012
OXIDES OF NITROGEN hourly averages in ppb

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR		
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
DAY																												
1	3	0	1	1	1	IZS	4	3	4	C	M	C	13	11	10	9	7	6	6	6	6	5	6	5	13	5.4	23	
2	5	3	2	2	IZS	2	2	1	1	1	2	3	4	4	5	5	4	5	4	4	4	4	5	7	7	3.4	24	
3	11	9	4	IZS	11	14	7	5	8	10	C	C	C	C	C	C	C	6	8	6	6	5	5	5	14	7.5	24	
4	5	8	IZS	12	8	9	6	12	7	10	17	14	M	10	6	8	14	12	11	11	12	10	8	8	17	9.9	23	
5	6	IZS	4	9	3	5	8	11	14	2	9	6	0	0	0	0	0	0	0	0	0	7	1	0	14	3.7	24	
6	IZS	0	0	0	1	1	2	1	1	2	2	1	1	5	6	4	3	1	0	0	1	1	1	1	IZS	6	1.5	24
7	1	0	2	9	10	10	11	11	12	13	15	13	10	11	9	8	13	9	6	6	7	7	7	IZS	6	15	8.7	24
8	5	4	4	4	4	5	9	10	5	3	3	1	1	1	1	1	1	1	1	3	4	IZS	3	5	10	3.4	24	
9	6	5	3	3	7	7	8	6	9	8	8	6	6	7	9	10	11	10	12	11	IZS	1	6	0	12	6.9	24	
10	0	0	11	12	12	13	5	0	0	0	6	2	0	1	9	1	0	1	0	IZS	0	0	0	2	13	3.3	24	
11	26	20	21	11	8	2	6	8	6	11	7	6	7	4	5	5	6	5	IZS	5	5	6	8	8	26	8.5	24	
12	10	12	8	10	9	4	3	5	7	5	5	4	4	4	4	5	7	IZS	4	4	5	4	4	4	12	5.7	24	
13	7	8	9	7	8	8	5	4	3	1	4	5	7	11	16	7	IZS	5	3	7	2	2	5	6	16	6.1	24	
14	3	0	3	3	1	1	3	4	7	5	5	3	2	3	1	IZS	0	0	0	0	0	0	0	0	7	1.9	24	
15	0	0	0	0	1	2	3	4	3	3	2	1	0	1	IZS	1	1	1	1	1	1	1	1	1	2	4	1.3	24
16	1	3	4	3	5	3	3	4	5	4	4	4	4	4	IZS	5	4	4	4	3	5	4	4	4	5	5	3.9	24
17	3	2	1	1	2	2	5	8	8	5	4	3	IZS	2	1	2	3	3	3	5	4	7	12	9	12	4.1	24	
18	6	6	7	8	8	6	5	5	5	4	3	IZS	1	1	1	1	2	1	1	2	2	2	1	1	8	3.4	24	
19	3	4	3	4	4	8	7	7	7	8	IZS	4	2	3	3	1	2	2	2	1	1	2	2	3	8	3.6	24	
20	2	3	5	6	4	3	5	11	11	IZS	19	15	12	10	10	11	13	11	10	10	8	7	6	4	19	8.5	24	
21	5	5	4	3	3	3	2	2	IZS	0	1	0	1	2	0	3	4	1	5	4	0	0	0	0	5	2.1	24	
22	1	0	0	1	2	4	8	IZS	9	8	8	11	12	13	15	16	14	13	11	11	10	10	9	8	16	8.4	24	
23	7	7	6	4	4	3	IZS	3	2	2	3	4	4	4	4	4	6	7	9	11	10	10	11	11	11	5.9	24	
24	13	10	9	10	11	IZS	11	10	12	16	12	8	8	8	10	11	10	9	7	6	6	5	4	4	16	9.1	24	
25	3	2	1	1	IZS	1	4	15	32	24	17	15	10	5	4	14	7	1	3	0	0	0	0	0	32	6.9	24	
26	0	0	1	IZS	1	6	7	9	11	6	5	8	2	2	0	2	1	5	1	4	3	5	5	5	11	3.7	24	
27	5	2	IZS	1	1	5	16	9	2	1	1	2	2	5	2	3	4	5	5	4	5	4	13	2	16	4.3	24	
28	4	IZS	15	9	6	5	1	3	5	7	7	8	11	8	7	5	5	5	6	5	5	5	12	6	15	6.5	24	
29	IZS	3	5	11	7	3	3	6	12	6	1	1	2	3	3	4	4	3	3	3	2	2	1	IZS	12	4.0	24	
30	1	2	3	2	2	2	2	8	8	4	14	17	17	17	20	18	18	12	13	14	17	10	IZS	4	20	9.8	24	
31	3	6	3	1	3	4	11	11	10	17	13	12	13	16	15	13	21	16	13	11	12	IZS	23	20	23	11.6	24	
HOURLY MAX	26	20	21	12	12	14	16	15	32	24	19	17	17	17	20	18	21	16	13	14	17	10	23	20				
HOURLY AVG	5.0	4.3	4.8	5.1	5.1	4.9	5.7	6.5	7.5	6.4	7.0	6.3	5.6	5.9	6.2	6.1	6.4	5.3	5.0	5.2	4.8	4.3	5.4	4.8				


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE


MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	640					
MAXIMUM 1-HR AVERAGE:	32	PPB	@ HOUR(S)	8	ON DAY(S)	25
MAXIMUM 24-HR AVERAGE:	11.6	PPB			ON DAY(S)	31
IZS CALIBRATION TIME:	33	HRS	OPERATIONAL TIME:	742	HRS	
MONTHLY CALIBRATION TIME:	9	HRS	AMD OPERATION UPTIME:	99.7	%	
STANDARD DEVIATION:	4.61		MONTHLY AVERAGE:	5.57	PPB	

24 HOUR AVERAGES FOR JANUARY 2012



01 Hour Averages



— LICA30 NOX_ PPB

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - MASKWA
JANUARY 2012
OXIDES OF NITROGEN hourly averages in ppb

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR		
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
DAY																												
1	3	0	1	1	1	IZS	4	3	4	C	M	C	13	11	10	9	7	6	6	6	6	5	6	5	13	5.4	23	
2	5	3	2	2	IZS	2	2	1	1	1	2	3	4	4	5	5	4	5	4	4	4	4	5	7	7	3.4	24	
3	11	9	4	IZS	11	14	7	5	8	10	C	C	C	C	C	C	C	6	8	6	6	5	5	5	14	7.5	24	
4	5	8	IZS	12	8	9	6	12	7	10	17	14	M	10	6	8	14	12	11	11	12	10	8	8	17	9.9	23	
5	6	IZS	4	9	3	5	8	11	14	2	9	6	0	0	0	0	0	0	0	0	0	7	1	0	14	3.7	24	
6	IZS	0	0	0	1	1	2	1	1	2	2	1	1	5	6	4	3	1	0	0	1	1	1	1	IZS	6	1.5	24
7	1	0	2	9	10	10	11	11	12	13	15	13	10	11	9	8	13	9	6	6	7	7	7	IZS	6	15	8.7	24
8	5	4	4	4	4	5	9	10	5	3	3	1	1	1	1	1	1	1	1	3	4	IZS	3	5	10	3.4	24	
9	6	5	3	3	7	7	8	6	9	8	8	6	6	7	9	10	11	10	12	11	IZS	1	6	0	12	6.9	24	
10	0	0	11	12	12	13	5	0	0	0	6	2	0	1	9	1	0	1	0	IZS	0	0	0	2	13	3.3	24	
11	26	20	21	11	8	2	6	8	6	11	7	6	7	4	5	5	6	5	IZS	5	5	6	8	8	26	8.5	24	
12	10	12	8	10	9	4	3	5	7	5	5	4	4	4	4	5	7	IZS	4	4	5	4	4	4	12	5.7	24	
13	7	8	9	7	8	8	5	4	3	1	4	5	7	11	16	7	IZS	5	3	7	2	2	5	6	16	6.1	24	
14	3	0	3	3	1	1	3	4	7	5	5	3	2	3	1	IZS	0	0	0	0	0	0	0	0	7	1.9	24	
15	0	0	0	0	1	2	3	4	3	3	2	1	0	1	IZS	1	1	1	1	1	1	1	1	1	2	4	1.3	24
16	1	3	4	3	5	3	3	4	5	4	4	4	4	4	IZS	5	4	4	4	3	5	4	4	4	5	5	3.9	24
17	3	2	1	1	2	2	5	8	8	5	4	3	IZS	2	1	2	3	3	3	5	4	7	12	9	12	4.1	24	
18	6	6	7	8	8	6	5	5	5	4	3	IZS	1	1	1	1	2	1	1	2	2	2	1	1	8	3.4	24	
19	3	4	3	4	4	8	7	7	7	8	IZS	4	2	3	3	1	2	2	2	1	1	2	2	3	8	3.6	24	
20	2	3	5	6	4	3	5	11	11	IZS	19	15	12	10	10	11	13	11	10	10	8	7	6	4	19	8.5	24	
21	5	5	4	3	3	3	2	2	IZS	0	1	0	1	2	0	3	4	1	5	4	0	0	0	0	5	2.1	24	
22	1	0	0	1	2	4	8	IZS	9	8	8	11	12	13	15	16	14	13	11	11	10	10	9	8	16	8.4	24	
23	7	7	6	4	4	3	IZS	3	2	2	3	4	4	4	4	4	6	7	9	11	10	10	11	11	11	5.9	24	
24	13	10	9	10	11	IZS	11	10	12	16	12	8	8	8	10	11	10	9	7	6	6	5	4	4	16	9.1	24	
25	3	2	1	1	IZS	1	4	15	32	24	17	15	10	5	4	14	7	1	3	0	0	0	0	0	32	6.9	24	
26	0	0	1	IZS	1	6	7	9	11	6	5	8	2	2	0	2	1	5	1	4	3	5	5	5	11	3.7	24	
27	5	2	IZS	1	1	5	16	9	2	1	1	2	2	5	2	3	4	5	5	4	5	4	13	2	16	4.3	24	
28	4	IZS	15	9	6	5	1	3	5	7	7	8	11	8	7	5	5	5	6	5	5	5	12	6	15	6.5	24	
29	IZS	3	5	11	7	3	3	6	12	6	1	1	2	3	3	4	4	3	3	3	2	2	1	IZS	12	4.0	24	
30	1	2	3	2	2	2	2	8	8	4	14	17	17	17	20	18	18	12	13	14	17	10	IZS	4	20	9.8	24	
31	3	6	3	1	3	4	11	11	10	17	13	12	13	16	15	13	21	16	13	11	12	IZS	23	20	23	11.6	24	
HOURLY MAX	26	20	21	12	12	14	16	15	32	24	19	17	17	17	20	18	21	16	13	14	17	10	23	20				
HOURLY AVG	5.0	4.3	4.8	5.1	5.1	4.9	5.7	6.5	7.5	6.4	7.0	6.3	5.6	5.9	6.2	6.1	6.4	5.3	5.0	5.2	4.8	4.3	5.4	4.8				


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE


MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	640					
MAXIMUM 1-HR AVERAGE:	32	PPB	@ HOUR(S)	8	ON DAY(S)	25
MAXIMUM 24-HR AVERAGE:	11.6	PPB			ON DAY(S)	31
IZS CALIBRATION TIME:	33	HRS	OPERATIONAL TIME:	742	HRS	
MONTHLY CALIBRATION TIME:	9	HRS	AMD OPERATION UPTIME:	99.7	%	
STANDARD DEVIATION:	4.61		MONTHLY AVERAGE:	5.57	PPB	

24 HOUR AVERAGES FOR JANUARY 2012



01 Hour Averages



LICA30
NOX_ / WDR Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 30
Site Name : LICA30
Parameter : NOX_
Units : PPB

Wind Parameter : WDR
Instrument Height : 10 Meters

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	4.71	2.14	2.85	1.42	2.85	4.42	3.71	1.42	1.42	10.57	20.57	11.14	11.71	12.00	3.28	5.71	100.00
< 110	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	4.71	2.14	2.85	1.42	2.85	4.42	3.71	1.42	1.42	10.57	20.57	11.14	11.71	12.00	3.28	5.71	

Calm : .00 %

Total # Operational Hours : 700

Distribution By Samples

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	33	15	20	10	20	31	26	10	10	74	144	78	82	84	23	40	700
< 110																	
< 210																	
>= 210																	
Totals	33	15	20	10	20	31	26	10	10	74	144	78	82	84	23	40	



Calm : .00 %

Total # Operational Hours : 700


Class Limits (PPB)

Period : 01/01/12-01/31/12

Level : 10



Calibration Graph for Site: LICA30 Parameter: NOX_ Sequence: NO2 Phase: SPAN



Temperature


LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - MASKWA
JANUARY 2012
AMBIENT TEMPERATURE hourly averages (Degrees C)

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	DAILY	24-HOUR	
DAY	DAY	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
1	1	-12	-12.4	-12.8	-13.5	-14.4	-14.9	-15.9	-16.2	-16.3	-15.5	-13.6	-11.3	-10	-8.2	-8.5	-10.8	-14.7	-17.1	-19.1	-20	-20.5	-21.4	-21.3	-20.9	-8.2	-15.1	24	
2	2	-21.3	-14.9	-10.6	-11.1	-10.3	-10	-9.5	-8.5	-8.5	-8.3	-7	-5.7	-4.7	-4.9	-5.1	-5.6	-5.6	-6	-6	-6.7	-6.9	-6.6	-4.7	-4.3	-4.3	-8.0	24	
3	3	-4.9	-3.8	-2.4	-3.1	-4.8	-5	-5.6	-6.3	-7	-6.8	-4.4	-1.3	-0.6	-0.5	-0.8	-0.6	-1.4	-2.1	-2.9	-3	-3.2	-3	-2.6	-2.2	-0.5	-3.3	24	
4	4	-2.3	-3.2	-4.1	-5	-6.7	-7.9	-8.8	-9.1	-8.9	-7.1	-5.1	-2	-0.6	2.4	1.7	-0.5	-2.1	-2.9	-3	-2.6	-3.3	-3.5	-5	-5.1	2.4	-3.9	24	
5	5	-6.5	-5.6	-4.8	-2.8	-0.6	0.1	0.5	0.7	0.8	1.3	0.8	1.5	1.9	2.4	3.4	2.1	1.4	1.7	0.9	0.1	0	-0.2	-1.3	-2.3	3.4	-0.2	24	
6	6	-2.4	-2.5	-2.5	-2.5	-2.2	-2.3	-2.2	-2.4	-2.7	-2.2	-0.7	1	1.1	2.2	1.8	-0.5	-1.7	-3	-3.6	-4.1	-4.6	-5.1	-6.5	-6.9	2.2	-2.3	24	
7	7	-7.2	-5.9	-5.9	-7.7	-7.6	-6.9	-7.4	-8.4	-9	-8.6	-5.7	-3.7	-3.1	-2.3	-2.3	-3.7	-4.8	-4.8	-5	-5.9	-6	-5.6	-4.9	-4.5	-2.3	-5.7	24	
8	8	-4.2	-3.7	-3.8	-3.1	-2.5	-1.7	-0.8	0.3	2	3.4	5.2	7.8	8.7	9.3	8.8	7.5	6.5	5.8	5.8	5.1	4.3	3.2	2.3	0.7	9.3	2.8	24	
9	9	0.6	0.5	0.2	-0.5	-1.2	-1.7	-1.6	-1.7	-0.7	0.4	2.3	3.5	3.4	3.2	3	2.4	1.4	1.3	1.1	0.7	1.5	3.2	3.5	2.8	3.5	1.2	24	
10	10	1.7	1.1	0.8	0	-0.1	0.1	0	-0.7	-1.4	-2.3	-3.1	-3.9	-4.6	-5.1	-5.9	-9	-12.1	-15.7	-16.8	-16.8	-17.1	-17.3	-17.8	-18.4	1.7	-6.9	24	
11	11	-18.7	-19.1	-19.6	-20.4	-21.2	-21.8	-22.8	-22.9	-21.1	-19.3	-17.1	-15.8	-14.7	-13.7	-12.7	-13	-15	-15.8	-16.2	-14.2	-14.2	-13.7	-14.7	-13.8	-12.7	-17.1	24	
12	12	-12.9	-11.6	-10.5	-7.6	-6.4	-7.9	-7.3	-8.5	-9.5	-8.2	-4.7	-2.5	-1.9	-2.1	-2.9	-3.2	-4	-3.9	-3.8	-3.8	-3.9	-4.2	-4.8	-4.7	-1.9	-5.9	24	
13	13	-3.8	-3.2	-3.4	-3.8	-4.7	-4.6	-3.6	-3.3	-1	-0.5	-0.3	-0.3	-0.2	-0.2	0.2	0	-0.2	-0.5	-0.7	-0.8	-1.8	-1.7	-1.9	-2.3	0.2	-1.8	24	
14	14	-2.6	-4.4	-5.2	-5	-5	-5.3	-6.2	-6.7	-7.3	-6.5	-4.5	-2.6	-2.8	-3	-3.8	-4	-4.5	-5.3	-6.2	-7.5	-8.6	-9.8	-11.7	-12.7	-2.6	-5.9	24	
15	15	-14	-15	-15.5	-16.1	-16.3	-17	-17.5	-18.8	-19.3	-19.8	-19.4	-18.9	-19	-19.1	-19	-19.9	-20.9	-21.4	-21.6	-21.8	-22	-22.7	-23.8	-24.5	-14.0	-19.3	24	
16	16	-25.4	-26.2	-26.9	-27.6	-28.2	-28.2	-27.9	-27.9	-28.2	-28.1	-27.7	-26.9	-26.5	-25.8	-26	-27.4	-28.6	-30	-29.9	-29.7	-29.7	-29.7	-30.1	-31.4	-25.4	-28.1	24	
17	17	-32.5	-33	-33.9	-34.2	-34.8	-34.7	-35.2	-35	-35.1	-33.6	-30	-27.4	-26.1	-25.5	-25.4	-27.3	-29.3	-30.5	-30.9	-31.7	-32.1	-33	-33.8	-34.1	-25.4	-31.6	24	
18	18	-34	-34.4	-34.9	-34.9	-34.4	-33.8	-33.4	-33	-32.4	-30.8	-28	-25.2	-22.9	-22.4	-21.7	-22.6	-24.2	-25.5	-26	-26.1	-26.3	-25.9	-25.6	-25.5	-21.7	-28.5	24	
19	19	-26.8	-27.5	-27.1	-27	-26.6	-27.4	-28.3	-28.7	-28.4	-25.5	-22.6	-19.9	-17.3	-16.6	-16.2	-17.6	-19.7	-21.1	-21.6	-21.7	-22.5	-22.8	-23.2	-23.7	-16.2	-23.3	24	
20	20	-23.7	-24.6	-25.4	-26.5	-25.3	-25.3	-25.5	-26.5	-25.9	-24.3	-21.4	-18.7	-16.1	-15.5	-16.7	-17.9	-20	-21.7	-23.1	-22.9	-22.9	-22.1	-20.1	-18.7	-15.5	-22.1	24	
21	21	-18.4	-18.1	-18.5	-18.6	-18.5	-17.8	-17.2	-17.2	-17	-16.9	-16.4	-16	-15.4	-15.3	-15.2	-15.1	-15.2	-15.2	-14.9	-14.9	-14.9	-14.9	-15	-14.9	-15	-14.9	-16.3	24
22	22	-15	-15.2	-16	-16.1	-15.8	-15.6	-16.1	-16.5	-16.3	-15.3	-14.3	-11.8	-8.8	-7.2	-7.4	-8.5	-11.2	-14.5	-15.8	-16.3	-16.1	-16.4	-15.6	-14.5	-7.2	-14.0	24	
23	23	-13.5	-12.8	-10.8	-8.7	-8.5	-8.6	-9.1	-9.8	-9.8	-8	-5.3	-4.3	-3.3	-3.7	-3.6	-4.6	-6.4	-7.7	-8.2	-8.9	-8.6	-7.5	-6	-5.7	-3.3	-7.6	24	
24	24	-6.6	-7.6	-8.2	-8.5	-8	-8.6	-10.4	-9.4	-9.5	-8.2	-5.3	-4	-2.6	-1.7	-2.9	-2.6	-4	-4.8	-7.7	-5.9	-6.6	-7.9	-10.1	-9.3	-1.7	-6.7	24	
25	25	-8	-7.9	-7.8	-8.7	-10.9	-11.8	-12.8	-13.7	-13.7	-9.5	-6.8	-3.7	-3.2	-2.3	-0.5	1.1	1.7	1.7	1.7	-0.1	-0.4	-1.7	-2.2	-3.3	1.7	-5.1	24	
26	26	-3.5	-4	-5	-5.8	-6.4	-7.7	-8.7	-9.8	-10.2	-7	-4.1	-2.7	0.1	0.6	0.4	-1.5	-4.2	-6.4	-6.6	-6.9	-6.9	-7.9	-8.1	0.6	-5.4	24		
27	27	-8.7	-8.9	-8.8	-7.4	-5.8	-6.1	-5.7	-6.8	-7.9	-7.3	-5.5	-4.2	-4.3	-4.8	-5.6	-5.3	-5.8	-5.7	-5.6	-5.7	-6.2	-6	-6.2	-6.5	-4.2	-6.3	24	
28	28	-5.4	-5.3	-5.7	-7.2	-9.2	-10.6	-11.3	-12.1	-13.3	-12.5	-11.8	-10.8	-9.9	-8.7	-9.4	-10.8	-12.2	-14.1	-14.9	-15.3	-14.1	-13.2	-12.3	-11.8	-5.3	-10.9	24	
29	29	-11.3	-10.7	-10.5	-10.6	-10.5	-10.8	-10.7	-10.5	-10.4	-9.7	-8.5	-7.4	-7.1	-6.3	-6.1	-6	-5.8	-5.8	-5.9	-7.1	-7.3	-7.1	-6.1	-6.1	-5.5	-5.5	-8.2	24
30	30	-5.8	-6.9	-8.1	-6.9	-5.3	-4.7	-4.3	-3.8	-3.8	-2.9	-1.3	-0.3	0.6	1.9	2.1	1.8	1.7	0.8	0.5	0.8	1.1	1.4	0.6	-0.3	2.1	-1.7	24	
31	31	-0.5	-1	-1.8	-2.6	-3	-3.6	-3.9	-4.3	-4.9	-4.5	-2.1	-1.6	0	1.2	0.4	-0.3	-0.6	-0.8	-1	-0.9	-1.4	-2.3	-3.5	-4	1.2	-2.0	24	
HOURLY MAX		1.7	1.1	0.8	0.0	-0.1	0.1	0.5	0.7	2.0	3.4	5.2	7.8	8.7	9.3	8.8	7.5	6.5	5.8	5.8	5.1	4.3	3.2	3.5	2.8				
HOURLY AVG		-11.3	-11.2	-11.3	-11.4	-11.5	-11.7	-11.9	-12.2	-12.2	-11.1	-9.3	-7.7	-6.8	-6.2	-6.3	-7.2	-8.4	-9.4	-9.9	-10.1	-10.4	-10.5	-10.7	-10.9				

STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE


24 HOUR AVERAGES FOR JANUARY 2012



MONTHLY SUMMARY

MINIMUM 1-HR AVERAGE:	-35.2 °C	@ HOUR(S)	6	ON DAY(S)	17
MAXIMUM 1-HR AVERAGE:	9.3 °C	@ HOUR(S)	13	ON DAY(S)	8
MAXIMUM 24-HR AVERAGE:	2.8 °C			ON DAY(S)	8
CALIBRATION TIME:	0 HRS	OPERATIONAL TIME:	744 HRS		
STANDARD DEVIATION:	9.62	AMD OPERATION UPTIME:	100.0 %		
		MONTHLY AVERAGE:	-9.98 °C		

01 Hour Averages



Precipitation

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - MASKWA

JANUARY 2012

PRECIPITATION hourly averages (mm)

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	23:00	DAILY	DAILY	
HOURLY MAX	HOURLY END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	TOTAL	RDGS.	
DAY																													
1		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
2		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
3		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
4		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
5		0	0	0	0	0	0	0	0	0	0	0.7	1.3	1.2	0.5	0.4	0.3	0.2	0.1	0.2	0.1	0	0.1	0	0	0	1.3	5.1	24
6		0	0	0	0	0	0	0	0	0	0	0	0.1	0	0.1	0.1	0	0	0	0	0	0	0	0	0	0	0.1	0.3	24
7		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
8		0	0	0	0	0	0	0	0	0	0	0	0.3	0.4	0.6	1	0.6	0.5	0.2	0.3	0.1	0.1	0	0	0	0	1.0	4.1	24
9		0	0	0	0	0	0	0	0	0	0	0	0.1	0.2	0.2	0.1	0	0	0	0	0	0	0	0	0	0	0.2	0.6	24
10		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
11		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
12		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
13		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
14		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
15		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
16		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
17		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
18		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
19		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
20		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
21		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
22		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
23		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
24		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
25		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.1	0	0	0.1	0.1	24
26		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
27		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
28		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
29		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
30		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.1	0.4	0.3	0.2	0.1	0.1	0.1	0.1	0.1	0	0	0.4	1.4	24
31		0	0	0	0	0	0	0	0	0	0	0	0	0	0.1	0	0	0	0	0	0	0	0	0	0	0	0.1	0.1	24


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	MD	-MISSING DATA


MONTHLY SUMMARY

MAXIMUM 1-HR AVERAGE:	1.3	MM	HOUR(S)	10	ON DAY(S)	5
MAXIMUM DAILY TOTAL	5.1	MM			ON DAY(S)	5
MONTHLY TOTAL	11.7	MM				
CALIBRATION TIME:	0	HRS	OPERATIONAL TIME:	744	HRS	
STANDARD DEVIATION:	0.10		AMD OPERATION UPTIME:	100.0	%	
			MONTHLY AVERAGE:	0.02	MM	

DAILY TOTALS FOR JANUARY 2012




01 Hour Averages



Relative Humidity

01 Hour Averages



Barometric Pressure

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - MASKWA


JANUARY 2012

BAROMETRIC PRESSURE hourly averages (millibar)

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR		
DAY	DAY	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
1	1	950	951	952	953	952	953	953	954	954	955	956	956	957	957	957	957	957	957	957	957	956	955	954	953	957	954.7	24	
2	2	952	950	949	948	945	944	942	941	939	937	936	935	934	932	932	931	930	928	928	928	928	927	927	927	927	952	936.3	24
3	3	927	928	929	930	931	932	933	934	935	936	937	938	938	938	937	937	937	937	936	935	936	936	936	936	936	938	934.5	24
4	4	935	935	935	936	935	935	934	933	933	933	933	931	930	930	929	928	928	928	927	927	927	926	926	925	936	930.8	24	
5	5	924	924	924	924	923	923	923	922	923	924	925	925	924	925	926	926	927	927	927	928	928	929	930	930	930	930	925.5	24
6	6	931	931	932	932	933	933	934	934	935	935	936	937	937	937	937	937	938	938	938	938	938	939	939	939	939	939	935.8	24
7	7	939	939	939	939	939	939	939	938	938	939	939	939	939	939	939	938	937	937	937	936	936	935	934	933	939	937.8	24	
8	8	933	931	930	930	929	929	929	928	928	929	929	930	930	930	930	931	932	932	932	932	932	933	933	933	933	933	930.7	24
9	9	933	934	934	933	933	933	933	932	931	931	930	929	928	927	928	928	928	928	928	928	928	928	929	929	934	930.1	24	
10	10	930	930	930	931	932	933	934	935	936	938	940	941	942	943	944	946	948	950	952	952	953	953	953	954	954	954	941.7	24
11	11	954	954	954	954	954	954	954	953	953	953	952	951	949	949	948	947	946	945	945	944	943	943	942	942	954	949.3	24	
12	12	942	942	942	941	942	941	942	941	941	941	942	941	941	940	940	939	939	938	937	936	936	935	934	933	942	939.4	24	
13	13	932	932	931	931	931	931	931	931	931	931	931	931	932	933	933	934	935	936	936	936	936	937	937	937	937	937	933.2	24
14	14	937	937	937	937	937	936	936	936	936	935	935	935	934	934	934	934	934	934	934	934	934	935	935	936	937	935.3	24	
15	15	937	937	938	939	940	940	941	942	942	943	944	944	944	944	945	945	946	946	947	947	947	948	948	948	948	948	943.4	24
16	16	949	949	950	950	950	950	951	951	951	952	952	952	952	951	951	952	953	953	953	953	953	953	954	954	954	954	951.6	24
17	17	954	954	954	953	953	953	952	952	951	951	949	948	947	946	945	945	945	945	945	944	944	944	944	943	943	954	948.4	24
18	18	943	943	943	943	942	942	941	940	940	940	938	937	936	935	935	936	936	936	936	936	936	936	935	935	943	938.3	24	
19	19	935	935	935	935	934	935	935	935	935	935	934	935	934	934	933	933	934	934	934	934	934	935	935	936	937	937	934.6	24
20	20	937	938	938	939	939	939	939	940	940	940	940	940	939	938	938	937	937	937	936	935	935	933	932	931	940	937.4	24	
21	21	930	928	928	927	925	924	923	922	922	921	921	919	919	918	917	918	918	919	919	919	920	921	921	922	930	921.7	24	
22	22	923	924	924	925	926	927	927	928	928	929	930	930	930	930	930	930	930	930	929	929	929	928	928	928	928	929	928.0	24
23	23	927	927	926	925	925	924	924	923	923	924	924	924	924	924	925	926	926	926	926	927	927	928	928	929	929	925.4	24	
24	24	929	930	930	931	931	931	931	930	931	931	931	930	930	929	929	928	927	926	924	923	922	921	919	919	931	927.6	24	
25	25	917	916	916	915	915	915	915	915	916	917	918	920	921	922	923	924	926	927	929	929	929	930	930	931	931	931	921.5	24
26	26	931	932	932	932	932	931	931	931	931	931	932	931	931	931	931	932	931	932	932	932	933	934	934	935	935	935	931.9	24
27	27	935	935	935	936	936	937	938	939	939	940	940	940	940	939	938	938	938	937	937	936	936	936	936	937	940	937.4	24	
28	28	938	938	939	940	941	942	943	943	944	944	945	945	944	944	943	943	942	941	940	940	938	937	936	935	945	941.0	24	
29	29	934	932	931	930	929	927	926	925	924	923	923	923	923	922	922	922	922	922	921	921	921	921	921	921	934	924.4	24	
30	30	921	920	920	920	921	921	921	921	922	922	923	923	922	923	923	923	923	924	925	925	926	926	926	927	927	927	923.0	24
31	31	927	928	928	928	929	929	929	930	930	930	931	931	931	931	931	931	931	932	932	933	933	933	933	933	933	933	930.6	24
HOURLY MAX		954	954	954	954	954	954	954	954	954	955	956	956	957	957	957	957	957	957	957	957	956	955	954	954				
HOURLY AVG		935	935	935	935	935	935	935	935	935	935	935	935	935	935	935	935	935	935	935	935	935	935	935	935				

STATUS FLAG CODES


S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE



MONTHLY SUMMARY

MAXIMUM 1-HR AVERAGE:	957 MB	@ HOUR(S)	VAR	ON DAY(S)	1
MAXIMUM 24-HR AVERAGE:	954.7 MB			ON DAY(S)	1
VAR-VARIOUS					
CALIBRATION TIME:	0 HRS	OPERATIONAL TIME:	744 HRS		
STANDARD DEVIATION:	9.19	AMD OPERATION UPTIME:	100.0 %		
		MONTHLY AVERAGE:	935 MB		

01 Hour Averages



Vector Wind Speed

IMPERIAL OIL RESOURCES LTD. - COLD LAKE - MASKWA

JANUARY 2012

WIND SPEED hourly averages (km/hr)

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR		
HOURLY MAX	HOURLY AVG	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
DAY																													
1		5.5	5.6	4	2.1	4.3	4.6	1.7	1.6	2.9	5.4	5.3	5.6	4.9	4.3	5.3	4.9	0.6	2.1	0	0	0.3	1.3	0.3	0.5	5.6	2.6	24	
2		1.1	7.4	7.8	6.9	8.6	7	8	8.4	8.1	5.3	5.4	4	3.2	4.2	1.9	1.8	2.3	1.5	1.2	0.8	0.5	0.9	5.2	4.7	8.6	3.8	24	
3		2.7	6.6	4.5	6.5	3.1	3.2	2	2.9	4.6	2.5	4.4	3.1	2.3	3.2	2.3	0.1	0.3	0.1	2.1	0.9	0.4	0.7	0.2	0.9	6.6	2.1	24	
4		0.2	3.7	1	1.7	0.2	0.5	1.2	0.3	0.5	0.6	0.3	0.5	2.3	3.2	3.8	2.4	1.1	2.3	2	1.2	0.8	1.7	0.3	1.1	3.8	0.5	24	
5		0.8	2.4	0.6	1.2	3.6	3.3	4	4.9	4.7	12.2	12.8	10.4	11.2	11.8	12.9	11.2	10.1	12.9	11.9	11.6	12.7	9.7	7	3.2	12.9	7.2	24	
6		4.1	4.8	5.9	7.4	8.6	7.5	7.2	6	5	6.9	7.6	9.2	9.4	11.7	9.5	4.5	4.3	3.7	3.8	3.9	3.3	3.2	1.9	2.3	11.7	5.9	24	
7		2.8	2.7	4	4.7	4	4.4	5.3	4.2	4.1	3.9	4.2	5.7	6.7	6.9	7.1	6.2	6.6	8.2	7.6	6.3	7.2	7.8	9	10.6	10.6	5.7	24	
8		7	10.2	8.1	8.6	8.4	6.1	6.2	6.4	5.5	6.2	6.3	7.6	9.9	11.5	12.7	13.1	10.3	8.9	10.6	9.6	8.4	4.6	5.5	6	13.1	6.9	24	
9		7	6.1	3.8	3.7	5.8	5.6	6.1	6.4	4.8	7	3.3	3.5	4.9	5.4	7.9	6.5	7.5	7.4	5.1	4.1	4.8	7.3	10.9	12.3	12.3	5.3	24	
10		10.3	11.8	12.8	11	8.5	10.4	10.6	10.3	11.5	13.3	12.5	12.7	10.8	12.4	12	12.5	12	12.4	8.7	8.4	6.6	6.9	6.3	5.4	13.3	9.9	24	
11		6.8	6.5	5.9	3.8	2.5	1.7	2.2	2.8	5.1	4.5	6	6.8	6.6	5.8	3.6	2.3	1.1	2	2.2	5.6	4.8	2.6	2.1	4.1	6.8	3	24	
12		4.3	1.9	3.4	6.5	4.8	3.8	4.5	5	3.7	4.2	3.8	3.9	4.2	4.6	4.7	3.7	5.5	4.6	6.7	5.2	4.9	5.2	5	4.7	6.7	4.2	24	
13		4	4.3	3.8	2.8	6.4	5.2	4.8	5.4	7.8	11.9	12.8	12.1	12.7	13	12.8	10.7	11.1	9.5	9.5	8.3	5.3	6	4.4	4.3	13	7.3	24	
14		5.2	2.3	0.5	0.4	1.2	0.9	1	1.3	0.2	0.6	1.2	2.3	3.3	3.2	6.1	5.1	7.1	8.6	9.7	9.4	11.9	13.8	14.1	15	15	4.3	24	
15		14.6	11.1	11.6	10.8	9.3	11.3	10.1	10.5	8.8	9.1	8.3	8.8	9.4	8.3	8	8.1	7.2	6.9	7	5.9	5.8	6.3	5.3	3.7	14.6	8.3	24	
16		3.6	4.8	7.4	7	4.4	4.9	5.7	7.2	6.3	7.3	7.2	7	5.6	6.4	5.5	5.1	2.4	1.4	0.5	1.1	1.8	2.1	4.4	1.9	7.4	4.4	24	
17		0.6	0.9	0.4	0.8	0.7	1.5	1.6	1.6	3	2	3.9	4.6	9.5	8	5.2	4.1	2	2.1	3.4	2.8	3.9	4.3	4.5	3.8	9.5	2.9	24	
18		4.1	4.6	5.4	5.4	4.8	5.1	4.2	4.8	5.3	4.9	5.6	6	6.4	7.2	6.2	5.9	4.9	2.4	2.6	2.8	4.1	4.2	5.4	4.6	7.2	4.6	24	
19		4	4.4	4.9	3.2	3.5	5.2	4.4	4.1	3.6	3.3	4.7	4.4	5.4	8.4	6.7	5.2	3.5	2	2.7	2.8	3	2.6	1.9	1.9	8.4	3.6	24	
20		2.7	3.9	3.4	1.8	2.2	3.2	1.5	2.2	4.3	4.9	3.2	3.1	4.5	6.2	6.1	5.7	3.2	0.4	0.1	0.1	0.4	2.1	1	4.6	6.2	2.2	24	
21		5.2	4.9	4.3	5.9	6.9	7.6	7.2	8	8.7	8.3	8.2	9.5	9.3	9.6	9.7	8.5	6.4	6	6.2	3.7	3.8	2.2	1.2	1.7	9.7	6.2	24	
22		2.2	1.9	1.6	0.7	1.2	3	3.5	5.4	5.6	3.4	4.8	3.5	3.1	4.6	6.2	5.4	1.7	0.3	0.6	0.6	1	1.8	2.1	1.9	6.2	2	24	
23		3.8	3.3	5.1	8.4	6.2	4.9	4.9	5.6	6.4	4.6	4.5	5.9	4.1	4.8	4.1	5.4	3.6	4.4	5.8	4.3	4	4.4	3.5	3.8	8.4	2.9	24	
24		5.1	5.9	5.5	6.3	6.2	5.1	2.6	6.5	5	2.5	5.2	6.5	5.8	5.6	5.1	2.6	2.8	0.9	2	4.8	3.8	3.1	2.4	3	6.5	3.1	24	
25		4.2	3.3	2.1	1.5	1	0.3	0.2	0.6	0.8	1.6	4	3.7	4.5	5.7	7.7	9.2	10.1	14.4	13.4	8.5	8.6	5.6	5.2	3.8	14.4	4.2	24	
26		4.3	5.1	4.2	3.5	4	5.5	6.3	4.4	3.8	4	5.8	4.9	3.8	6.8	7.1	4.6	2.3	1.6	3.1	3.3	3.7	3.5	5.5	6.2	7.1	4.2	24	
27		5.7	4.5	5.2	6.3	13.6	14.1	13.5	10	9.1	8.6	7.9	3.9	5.3	5.2	6.9	8.1	6.8	6	6.4	5.2	2.3	2.8	3.2	4.9	14.1	5.6	24	
28		7.5	9.2	8.9	8.4	7.9	6.6	4.2	5.3	3.8	4.2	3.4	1.3	1.6	1.5	3.1	5.4	0.8	1.7	0.8	1.2	2.1	1.9	4.9	4	9.2	2.3	24	
29		5.3	7.7	7.6	6.9	8.3	8.3	8.6	7.8	6.7	6.1	5.9	5.6	6.4	4	3.4	2.6	2.5	1.7	1.4	0.7	0.4	0.9	0.1	0.2	8.6	4.3	24	
30		0.9	1.3	0.9	0.6	0.6	0.9	0.3	2.9	0.7	0.4	1.1	4.5	3.9	3.5	3.4	4.3	5.6	4.8	5.5	5.5	5.9	5.1	4.3	3.5	5.9	2.6	24	
31		3.8	5.3	3.3	3	5.7	4.3	4.9	6.3	7.7	5.4	6.3	4.9	3.3	3.4	6.7	5.4	1.9	2.8	3	3.3	3.5	5.5	4.7	5.6	7.7	4.5	24	
HOURLY MAX		14.6	11.8	12.8	11.0	13.6	14.1	13.5	10.5	11.5	13.3	12.8	12.7	12.7	13.0	12.9	13.1	12.0	14.4	13.4	11.6	12.7	13.8	14.1	15.0				
HOURLY AVG		4.5	5.1	4.8	4.8	5.0	5.0	4.8	5.1	5.1	5.3	5.7	5.7	5.9	6.5	6.6	5.8	4.8	4.6	4.7	4.3	4.2	4.2	4.3	4.3				


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE


LAST CALIBRATION: November 7, 2011

MONTHLY SUMMARY

MAXIMUM 1-HR AVERAGE:	15.0	KPH	@ HOUR(S)	23	ON DAY(S)	14
MAXIMUM 24-HR AVERAGE:	9.9	KPH			ON DAY(S)	10
CALMS (≤ 1 KPH)	7.80	%	OPERATIONAL TIME:	744	HRS	
MONTHLY CALIBRATION TIME:	0	HRS	AMD OPERATION UPTIME	100.0	%	
STANDARD DEVIATION	3.15		MONTHLY AVERAGE	5.04	KPH	



01 Hour Averages



— LICA30 WSP KPH

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - MASKWA

JANUARY 2012

VECTOR WIND SPEED MAX instantaneous maximum in km/hr

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY
HOUR START		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.
HOUR END		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.
DAY		17.7	17.3	15.4	7.7	11.9	10.6	7	8.4	10.4	12.1	13.2	13.9	13.5	9.5	11.8	11.1	7.8	7.4	2.2	1.6	5	4.3	3	5.2	17.7
2		10	25.7	25	21.5	28.1	18.5	20.3	27.4	24.6	22.9	14.3	14.5	10.9	15.7	10.5	8.6	9.1	12.2	7.5	6.9	5.8	9.7	19.4	18.7	28.1
3		15.3	18.5	20	24.3	12.8	13.4	9.3	9.1	12	8.9	11	9.2	7.9	8.5	6.4	2.8	4.2	2.6	6.2	5.2	3.6	5.9	4.6	6.5	24.3
4		6	8.6	8.6	9.1	3.3	5.1	4.5	2.5	3.4	2.9	3.2	5.1	8.4	10.7	18.6	9.5	7.1	9.8	7.7	7.4	4.6	7.6	4.7	7.1	18.6
5		4	8.4	9.7	5.6	14.7	14.1	14.8	12.1	30.7	34.4	34.3	30	36.4	45.5	40.3	35	28.9	46.8	41.7	38.3	37.4	30.7	27.6	11.8	46.8
6		16.2	15.9	17.8	18.3	25.7	26.4	27.6	19.2	17	22.4	21.9	22.9	32.3	33.6	30.1	15.8	17.8	12.6	11.8	12.6	14.4	12.2	9	9.7	33.6
7		9.1	9.9	13.1	10.4	9.4	14.8	10.5	9.4	10.8	10.6	11.4	12.6	13.4	15.8	15	13.5	14.4	15.9	16.1	13.6	16.1	16.8	20.1	21.5	21.5
8		15.8	23.7	22.5	21.2	26.6	18.8	17.3	20.6	21.9	24.9	27.6	25.4	32.1	39.4	36.8	38.2	40.2	28	29.6	27.5	20.9	16.9	15.9	14.8	40.2
9		16.8	16.4	10.7	8.9	12.6	11.8	13.6	15.7	13.3	16.3	12	15.7	17.1	19.7	22.1	19.7	15.4	16.6	17.1	18.2	22.1	23.1	37.4	41.1	41.1
10		38	34.4	40.7	30.6	23.8	36	45.2	40.5	46.2	44.6	42.9	44.2	36.9	43.4	46.3	42.4	48.8	41.3	36.3	27.6	26.4	32.1	23.2	20.8	48.8
11		21.6	23	25.8	14.2	10.2	10.3	5.3	8.6	12.8	13.8	15.8	18.3	17.5	15.8	13.6	7.8	6.3	9.4	13.7	14.8	13	12.8	7.5	11.3	25.8
12		13.9	7.9	11.3	22.4	17.3	23.5	20.8	11.5	8.9	13.9	11.7	11.7	16.5	10.8	13.1	9.6	13.6	12	18.5	14.1	14	11.9	12	12.4	23.5
13		9.6	11.1	15.3	8.4	13.6	17.2	17.8	26.7	28.1	35.1	38.7	35.6	43.1	41.6	39.7	31.2	40.9	27.4	26.1	27.3	17	21.2	17.6	14.8	43.1
14		20	9	5.5	5.4	6.3	6.3	5.2	8.2	5.2	4.1	10.6	9.2	10.8	9.7	15.9	12.8	19.5	21.1	24.8	24.1	27.5	32	33.6	32.6	33.6
15		35	33	29.6	29.2	28.7	32.8	31.5	41.4	32.3	29.4	27.6	32.5	30.7	27.7	28.7	30.5	29.3	22.2	24.1	20.3	18.5	18.4	19.4	15.2	41.4
16		14.7	15.4	20.1	19.2	14.3	18	21.5	21.6	23.7	19.6	21.5	19.7	16.2	19.1	17.8	19.9	10.1	5	3.9	7.4	8.9	16.6	16.2	7.8	23.7
17		5.8	6.5	6	5.5	6.4	7.2	9.9	7.2	8.6	7.7	13.2	17.1	25	23.7	22.4	17	10.5	10.6	13.2	9.2	10.3	11.1	11	9.8	25
18		10.1	11.9	11.6	15	14.9	12.9	11.3	13.2	16.6	17	21.8	23.6	24.6	28.4	25.6	21.5	24.4	14.2	11.5	13.5	14.5	16.2	19.1	15.5	28.4
19		11.8	12.9	14.5	14	13.1	10.8	7.7	8.7	11.6	10.2	12	12.5	19.6	22.4	22.2	19.9	12.6	8.4	11.1	12.9	10	9.8	9.9	8.3	22.4
20		8.2	9.2	8.8	8.3	10.6	12.2	12.1	9.4	10.3	11.5	11.5	9.4	10.3	12.8	13	11.7	7.6	4.7	2.6	4.6	3.9	7.7	8.8	15.1	15.1
21		17.7	18.7	13.2	17.6	20.4	20.3	25	21.6	26.4	29.3	23.9	33.4	30.8	33.5	28.5	24.6	23.2	19.3	17.8	18	14.3	9.2	6	6.3	33.5
22		6.9	7.2	5.8	4.4	6.8	8.1	9.2	12.9	11.7	11.2	13.2	14.9	8.7	12.2	17.5	10.8	10.1	5	4.6	5.5	11.1	8	7.5	7.3	17.5
23		9.8	11.3	20.3	22.5	21	15.2	15.8	14.5	16.8	13.5	16	17.7	13.5	12.2	10.7	15.2	10.8	9.8	14.7	11.1	11.9	11	13.1	9.2	22.5
24		10.7	13.4	13.3	16.1	16.2	14.2	11.7	15.1	14.4	13	14.7	15.1	14.4	13.8	13.3	7.9	13.5	12.2	20.8	15.5	15.5	10.4	6.9	16.1	20.8
25		12.3	10.2	5.7	8.3	5.5	3.4	2.9	3.8	6.4	8.4	13.4	16.2	21.6	17.6	27.8	27.4	30.8	49.8	46.6	33.7	30.4	22.7	22.2	16.3	49.8
26		24.1	21.1	15.5	13.6	12	14.3	14.4	12.3	10.2	12	12.7	12.9	18.5	20.1	23.1	27.4	11.9	6.7	9.3	10.4	11.8	11.1	13.9	21.4	27.4
27		17	17.3	18.4	23.1	40.7	40.9	45.3	33.4	25.2	27.2	19.7	16.9	15.6	15.8	16.1	15.3	17.2	14.5	12.4	12.7	13.7	11.5	13.5	23.4	45.3
28		18.3	24.4	33.7	28.1	26.1	24.4	16.7	19.9	14.8	13.6	13.9	13.3	8.7	7.4	11	13.8	10.1	4.9	4.2	5.6	7.9	10.1	15	13.4	33.7
29		17.4	20.9	29.7	20.4	23.9	25.5	25.4	25.4	20.4	21.5	17.3	17.5	14.8	12.3	10.4	8.8	8	7.4	8.1	4.9	4.7	4.7	2.9	2.9	29.7
30		5.2	5.4	5.5	6	4.8	5.7	4.9	10	3.9	3.2	5.5	12.1	13.5	12.1	9.4	13.4	14.6	12	13.4	13.4	18.3	17.3	13.6	17.1	18.3
31		14.2	16.4	10.3	10	11.7	12.3	12.7	14.3	16.8	15.1	13.5	13.3	8.7	9.9	13	14.3	6.6	8.4	10.8	8.7	11.4	15.6	12.3	12.2	16.8
PEAK		38.0	34.4	40.7	30.6	40.7	40.9	45.3	41.4	46.2	44.6	42.9	44.2	43.1	45.5	46.3	42.4	48.8	49.8	46.6	38.3	37.4	32.1	37.4	41.1	


STATUS FLAG CODES

S - OUT OF SERVICE	IZS - IZS - DAILY ZERO/SPAN CHECK
N - INVALID DATA	M - MISSING DATA
D - INSTRUMENT DRIFT	P - POWER FAILURE
C - CALIBRATION	NA - NOT APPLICABLE

MONTHLY SUMMARY

MAXIMUM INSTANTANEOUS READING	49.8	KPH	@ HOUR(S)	17
			ON DAY(S)	25

01 Hour Averages



LICA30
WSP / WDR Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 30
Site Name : LICA30
Parameter : WSP
Units : KPH

Wind Parameter : WDR
Instrument Height : 10 Meters

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 6.0	2.55	1.34	2.28	1.20	.94	2.55	2.95	1.20	1.34	6.04	18.54	10.48	9.54	2.68	1.47	2.55	67.74
< 12.0	1.88	.26	.53	.13	2.01	1.74	.80	.13	.00	4.43	2.68	.53	2.28	6.58	1.34	2.41	27.82
< 20.0	.13	.53	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	2.55	.53	.40	4.16
< 29.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 39.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 39.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	4.56	2.15	2.82	1.34	2.95	4.30	3.76	1.34	1.34	10.48	21.23	11.02	11.82	11.82	3.36	5.37	

Calm : .26 %

Total # Operational Hours : 744

Distribution By Samples

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 6.0	19	10	17	9	7	19	22	9	10	45	138	78	71	20	11	19	504
< 12.0	14	2	4	1	15	13	6	1		33	20	4	17	49	10	18	207
< 20.0	1	4												19	4	3	31
< 29.0																	
< 39.0																	
>= 39.0																	
Totals	34	16	21	10	22	32	28	10	10	78	158	82	88	88	25	40	



Calm : .26 %

Total # Operational Hours : 744

Class Limits (KPH)

Period : 01/01/12-01/31/12

Level : 10



Vector Wind Direction

IMPERIAL OIL RESOURCES LTD. - COLD LAKE - MASKWA

JANUARY 2012

WIND DIRECTION hourly averages in degrees

MST

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24-HOUR	24-HOUR AVG		
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	AVG.	QUADRANT	RDGS.	
DAY																												
1	282	280	278	254	230	232	251	250	233	216	220	228	225	207	212	210	224	201	96	336	52	358	323	39	236	SW	24	
2	100	125	130	122	127	115	114	129	127	113	125	136	136	145	138	146	153	160	173	253	353	216	216	226	135	SE	24	
3	238	221	253	296	297	269	259	245	222	234	217	232	242	230	222	264	130	311	206	192	358	122	167	199	240	WSW	24	
4	117	208	210	235	355	190	5	330	1	2	7	39	85	66	135	188	230	230	240	241	209	221	230	221	197	SSW	24	
5	16	201	305	296	5	212	231	216	253	284	294	289	284	285	286	284	281	284	284	280	284	290	284	270	282	W	24	
6	275	278	281	281	282	279	284	279	272	284	285	286	286	291	288	282	279	281	281	281	279	282	271	275	283	W	24	
7	279	271	222	224	233	226	215	225	228	230	221	206	209	214	212	207	206	209	214	213	208	209	203	202	215	SSW	24	
8	203	198	204	206	214	231	229	231	244	253	248	266	276	281	284	282	285	285	287	288	285	275	228	219	255	WSW	24	
9	227	232	238	232	218	216	217	211	218	208	203	182	188	201	214	222	213	215	228	246	262	278	290	284	231	SW	24	
10	282	284	293	297	291	300	318	330	336	336	320	325	334	326	323	349	332	335	332	323	330	328	331	317	320	NW	24	
11	307	312	307	289	274	279	224	208	211	218	219	205	206	188	167	159	176	201	220	216	222	222	243	226	231	SW	24	
12	235	245	268	288	277	259	275	213	229	219	240	242	236	226	222	225	217	225	216	222	219	217	216	218	234	SW	24	
13	225	230	242	247	218	243	247	269	280	285	288	289	292	296	297	289	296	288	286	291	284	287	293	294	281	W	24	
14	318	339	307	307	50	46	181	214	212	3	126	108	118	121	41	44	33	40	40	43	30	22	18	17	31	NNE	24	
15	16	10	2	360	357	358	356	355	345	340	336	325	331	334	322	331	334	328	328	331	342	347	341	328	346	NNW	24	
16	330	347	357	3	352	349	356	357	353	1	353	349	348	347	331	342	344	341	328	280	283	297	317	290	346	NNW	24	
17	268	256	274	284	272	251	267	267	228	252	274	257	288	286	266	266	261	256	247	245	230	229	231	239	260	WSW	24	
18	239	232	219	229	237	230	233	233	241	248	242	254	263	263	261	275	278	266	262	259	276	275	277	272	252	WSW	24	
19	237	230	238	247	243	212	208	229	247	269	234	240	274	290	284	279	274	253	263	261	273	269	261	266	255	WSW	24	
20	248	235	234	256	267	277	272	248	228	220	229	217	199	208	211	213	217	207	333	171	42	37	62	111	221	SW	24	
21	111	108	75	66	77	90	87	89	91	85	87	87	93	93	85	98	91	89	103	104	118	120	155	193	92	E	24	
22	219	208	222	237	250	223	217	207	206	228	225	229	226	198	197	199	197	149	57	57	342	52	47	26	212	SSW	24	
23	36	44	105	123	117	108	105	113	126	136	140	150	161	195	188	215	233	224	219	228	223	219	221	219	160	SSE	24	
24	211	216	219	215	212	218	225	211	215	213	197	201	206	196	200	135	138	88	127	127	101	49	16	66	194	SSW	24	
25	54	35	32	33	31	2	303	243	275	288	238	286	274	283	285	291	287	289	288	280	281	278	270	263	287	WNW	24	
26	257	250	247	256	238	225	220	233	238	243	222	225	256	281	286	270	280	247	249	241	240	245	229	238	246	WSW	24	
27	242	249	255	272	285	290	298	291	284	284	288	263	240	221	207	198	209	200	196	209	255	265	286	281	261	W	24	
28	285	290	307	313	314	319	333	341	326	319	336	293	295	238	215	201	205	110	102	67	57	55	94	96	312	NW	24	
29	97	109	107	101	114	114	114	110	98	112	116	127	147	143	141	145	133	141	134	14	353	358	21	353	115	ESE	24	
30	41	229	228	240	242	13	4	202	359	24	224	217	226	211	237	215	223	232	225	228	235	246	266	256	232	SW	24	
31	252	240	252	247	222	237	233	214	211	218	213	225	232	221	205	213	235	227	231	233	224	221	220	218	224	SW	24	
HOURLY AVG	330	347	357	360	357	358	356	357	359	340	353	349	348	347	331	349	344	341	333	336	358	358	341	353				

STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

LAST CALIBRATION:	November 7, 2011
DECLINATION :	19 DEGREES FROM MAGNETIC NORTH

MONTHLY CALIBRATION TIME:	0	HRS	OPERATIONAL TIME:	744	HRS
STANDARD DEVIATION	82.06		AMD OPERATION UPTIME	100.0	%
			MONTHLY AVERAGE	261	DEG

Standard Deviation Wind Direction

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - MASKWA

JANUARY 2012

STANDARD DEVIATION WIND DIRECTION (STDWDIR) hourly averages in degrees

MST

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00
DAY																								
1	21	22	21	21	15	16	21	23	18	15	18	20	20	18	16	14	32	37	25	8	28	17	17	26
2	41	20	29	30	30	27	28	27	26	34	29	33	38	36	59	48	57	58	61	41	36	52	49	29
3	49	22	29	20	17	23	21	22	13	25	22	25	26	23	30	37	52	30	30	33	11	39	57	38
4	44	30	23	32	21	51	20	19	16	10	15	24	45	32	48	55	38	33	30	28	51	43	32	49
5	34	26	40	44	22	47	26	22	26	22	23	23	25	24	25	24	23	26	23	26	24	22	21	22
6	22	22	23	21	20	23	21	24	26	21	20	20	24	23	21	23	24	19	21	20	21	17	19	22
7	21	20	23	16	18	21	12	16	15	18	19	17	16	16	18	15	15	13	15	16	15	14	14	15
8	18	17	23	17	19	29	25	28	35	39	37	31	29	28	26	25	23	24	21	20	19	24	20	16
9	19	22	20	16	17	15	15	16	18	17	40	50	44	46	21	23	15	18	26	29	27	26	25	23
10	26	24	23	22	21	23	30	33	32	32	31	34	34	32	32	28	33	32	31	30	31	29	29	27
11	26	27	25	21	22	21	21	35	18	21	22	21	21	25	43	54	67	45	37	20	20	26	18	19
12	24	22	21	21	21	23	23	14	17	20	26	25	25	18	19	19	18	26	19	26	22	17	21	23
13	19	20	22	21	13	22	22	25	26	23	24	23	24	24	26	21	25	22	21	22	21	19	21	23
14	25	16	11	13	34	43	37	42	66	27	49	66	49	44	25	26	22	23	23	23	16	17	18	17
15	19	20	23	22	24	24	25	26	28	28	30	31	29	29	28	27	27	27	29	28	25	23	24	25
16	25	20	21	21	20	21	22	22	24	22	24	24	27	26	26	22	14	9	11	15	15	18	22	16
17	17	17	16	14	19	17	18	14	13	17	23	26	21	22	29	28	26	23	22	19	16	14	17	15
18	17	15	15	16	20	16	16	16	26	29	29	30	33	34	34	25	21	23	26	25	22	23	23	26
19	21	19	22	27	26	13	11	12	17	19	17	25	26	22	21	23	22	20	22	21	17	19	19	18
20	16	12	15	17	16	15	19	21	13	17	25	25	19	16	15	13	16	29	19	49	57	25	42	34
21	31	34	29	25	27	26	31	29	28	29	30	30	28	29	27	30	31	28	34	46	48	49	63	40
22	24	35	25	21	25	21	20	16	16	27	24	30	25	27	19	15	16	49	35	35	36	24	21	18
23	18	31	33	27	34	34	34	22	22	37	36	32	42	30	30	24	22	17	16	21	23	18	22	22
24	14	16	17	16	30	27	33	21	24	34	46	19	20	25	18	57	44	38	56	43	41	26	22	26
25	25	21	23	23	23	17	26	31	31	22	25	25	26	20	21	21	24	24	24	25	25	25	26	27
26	29	28	26	26	21	18	16	18	19	23	15	20	29	27	22	27	18	19	19	21	19	23	19	24
27	26	29	28	28	23	21	23	21	21	20	20	27	28	26	20	17	16	20	20	20	28	25	19	19
28	18	21	27	28	25	26	28	23	24	21	24	30	28	48	31	21	57	35	45	33	31	31	36	40
29	30	27	31	30	28	29	31	27	28	32	33	35	26	40	41	57	54	72	69	41	36	16	22	14
30	34	29	37	34	24	41	22	52	14	21	38	23	30	29	25	26	23	17	17	18	23	34	25	29
31	27	22	23	21	14	20	16	15	15	21	17	22	21	22	14	28	37	26	22	20	19	16	20	18


STATUS FLAG CODES

S - OUT OF SERVICE	IZS - IZS - DAILY ZERO/SPAN CHECK
N - INVALID DATA	M - MISSING DATA
D - INSTRUMENT DRIFT	P - POWER FAILURE
C - CALIBRATION	NA - NOT APPLICABLE

LAST CALIBRATION: November 7, 2011

CALIBRATION TIME: 0 HRS OPERATIONAL TIME: 744 HRS

01 Hour Averages



Calibration Reports

Sulphur Dioxide

SO2 Calibration Report
Station Information

Calibration Date	January 4, 2012	Previous Calibration	December 12, 2011
Company	Lakeland Industry & Community Association		
Plant / Location	Cold Lake - Maskwa		
Start Time (MST)	9:06	End Time (MST)	12:43
Reason:	Monthly Calibration		
Barometric Pressure	933 mmHg	Station Temperature	20 Deg C
Cal Gas	48.3 ppm	Gas Cyl. #	LL103831
DAS Output Voltage	0 - 1 Volts	Cal Gas Expiry date	February 28, 2013
		Chart Rec. Output	NA Volts

Equipment Information

Analyzer Make / Model:	API 100E	S/N :	508	Method:	Fluorescent
Converter Make / Model:	NA	S/N :	NA		
Calibrator Make / Model:	EnviroNics 6100	S/N :	4760	Method:	Dilution
DAS Make / Model:	ESC 8832	S/N :	AO 791		
Chart Recorder Make / Model:	NA	S/N:	NA		
Flow Meter:	EnviroNics 6100	S/N :	4760		

Analyzer Settings

Before Calibration		After Calibration	
Concentration Range	0 - 1000		
Sample Flow / Box Temp	591 ccm, 28.6 Deg C	591 ccm, 28 Deg C	
HVPS / Lamp Setting	494, 2696	494, 2695	
PMT / RxCell Temp	7.7 Deg C, 50 Deg C	7.7 Deg C, 50 Deg C	
Converter / IZS Temp	NA Deg C, 45 Deg C	NA Deg C, 45.0 Deg C	
Offset / Slope	38.6, 1.239	39.5, 1.24	

Calibration Data

Dilution Flow Rate	Source Gas Flow Rate	Calculated Concentration	Indicated Conc. (DAS)	Correction Factor
4993	0	0	1	N/A
4993	0	0	0	N/A
4917	77.4	749	750	0.9980
	No Span Adj.			
4954	41.3	399	396	1.0084
4978	17.5	169	168	1.0072
4997	0	0	0	N/A
Sum of Least Squares				1.0006
New Correction Factor				0.9980

	Before Calibration	After Calibration
Auto Zero	1.3	0.8
Auto Span	374.0	374.0
Sample Lines Connected		YES

Percent Change

Previous Month's Calibration Correction Factor:	0.9980
Current Correction Factor Before Span Adjust:	0.9980
Percent Change:	0.0%


Notes: **N/A : Not applicable**

Calibration Performed by: Ting Xu

SO2 Calibration Curve


Calibration Date	January 4, 2012
Company	Lakeland Industry & Community Association
Plant / Location	Cold Lake - Maskwa
Start Time (MST)	9:06
End Time (MST)	12:43

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient Slope Intercept	(≥ 0.995) (0.85 to 1.15) (± 3% F.S.)
0	1	n/a		0.999954
169	168	1.0072		1.000792
399	396	1.0084		-0.775140
749	750	0.9980		



Notes:

01 Minute Averages



Hydrogen Sulphide

H2S Calibration Report

Station Information

Calibration Date	January 3, 2012	Previous Calibration	December 9, 2011
Company	Lakelnad Industry & Community Association		
Plant / Location	Cold Lake - Maskwa		
Start Time (MST)	10:40	End Time (MST)	14:51
Reason:	Monthly Calibration		
Barometric Pressure	937 mBar	Station Temperature	20 Deg C
Cal Gas	10.2 ppm	Gas Cyl. #	BLM00080
DAS Output Voltage	0 - 1 Volts	Cal Gas Expiry date	February 22, 2012
		Chart Rec. Output	NA Volts

Equipment Information

Analyzer Make / Model:	API 101E	S/N :	511	Method:	Fluorescent
Converter Make / Model:	Internal	S/N :	NA		
Calibrator Make / Model:	API 700	S/N :	831	Method:	Dilution
DAS Make / Model:	ESC 8832	S/N :	AO 791		
Chart Recorder Make / Model:	Not in use		S/N:	NA	
Flow Meter:	API 700	S/N :	831		

Analyzer Settings

Before Calibration		After Calibration	
Concentration Range	0 - 100	ppb	
Sample Flow / Box Temp	478 ccm 29.3 Deg C	479 ccm	29.5 Deg C
HVPS / Lamp Setting	552 2579	552	2579
PMT / RxCell Temp	7.9 Deg C 50 Deg C	7.9 Deg C	50 Deg C
Converter / IZS Temp	314.5 Deg C 45 Deg C	315.8 Deg C	45.0 Deg C
Offset / Slope	36.4 0.822	37.6	0.834

Calibration Data

Dilution Flow Rate	Source Gas Flow Rate	Calculated Concentration	Indicated Conc. (DAS)	Correction Factor
4996	0	0	1	NA
4996	0	0	0	NA
4960	39.2	80	79	1.0124
4960	39.2	80	80	1.0000
4976	19.6	40	40	1.0000
4986	11.2	23	24	0.9525
4996	0	0	0	NA
Sum of Least Squares				0.9969
New Correction Factor				1.0000

Before Calibration

After Calibration

Auto Zero	0.2	-0.2
Auto Span	60.3	59.4
Sample Lines Connected		YES

Percent Change

Previous Month's Calibration Correction Factor:	1.0000
Current Correction Factor Before Span Adjust:	1.0124
Percent Change:	-1.2%


Notes: **NA : Not Applicable**

Calibration Performed by: Ting Xu

H₂S Calibration Curve


Calibration Date	January 3, 2012
Company	Lakelnad Industry & Community Association
Plant / Location	Cold Lake - Maskwa
Start Time (MST)	10:40
End Time (MST)	14:51

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient Slope (≥ 0.995) (0.85 to 1.15)	Intercept (± 3% F.S.)
0	0		0.999729	0.995941
23	24	0.9525		
40	40	1.0005		
80	80	0.9998		



Notes:

01 Minute Averages



Total Hydrocarbons

THC Calibration Report

Station Information			
Calibration Date:	January 4, 2012	Previous Calibration	December 12, 2011
Company:	LAKELAND INDUSTRY & COMMUNITY ASSOCIATION		
Plant / Location:	Maskwa		
Start Time (MST)	9:31	End Time (MST)	12:49
Reason:	Monthly Calibration		
Barometric Pressure:	933 mmHg	Station Temperature:	20 Deg C
Calibrator:	API 700	S/N:	831
Cal Gas Concentration:	CH4 980 PPM	C3H8 304 PPM	
	TOTAL CH4 1816.0 PPM	Gas Cyl. # LL84144	Cal Gas Expiry Date: December 3, 2013
DAS make & Model:	ESC 8832	S/N :	AO 791
Chart Recorder:	NA	S/N:	NA
Output Voltage Range:	0 - 1 VDC	Chart Speed:	NA mm/hr

Analyzer Information

Make / Model	Thermo 51C-LT	S/N :	436609738	Method	Flame Ionization
--------------	---------------	-------	-----------	--------	------------------

Analyzer Settings

	Before Calibration		After Calibration	
Concentration Range	0 - 50	ppm	0 - 50	ppm
Sample Pressure	7.5	psi	7.5	psi
Hydrogen Pressure	8	psi	8	psi
Air Pressure	20	psi	20	psi

Calibration Data

Dilution Flow	Source Gas Flow	Calculated Concentration	Indicated Concentration	Correction Factor
3000	0.0	0.0	0.0	NA
	No Zero Adj.			
3000	70.0	41.4	41.0	1.0099
3000	70.0	41.4	41.6	0.9954
3000	35.0	20.9	20.9	1.0000
3000	20.0	12.0	12.0	1.0000
3000	0.0	0.0	-0.1	NA
New Correction Factor:				0.9954

Percent Change

Previous Calibration Correction Factor:	0.9954
Current Correction Factor Before Span Adjust:	1.0099
Percent Change:	-1.4%

IZS Calibration Data

	Before Calibration	After Calibration
Auto Zero	0.0	0.0
Auto Span	34.7	35.0
Sample Lines Connected		YES

Cylinder Pressures			
Span	600 psi	Hydrogen	650 psi
		Zero Air	32 psi


Notes: **NA : Not Applicable**

Calibration Performed by: Ting Xu

THC Calibration Curve


Calibration Date	January 4, 2012		
Company	LAKELAND INDUSTRY & COMMUNITY ASSOCIATION		
Plant / Location	Maskwa		
Start Time (MST)	9:31	End Time (MST)	12:49

Calculated Conc. ppm	Indicated Response ppm	Correction Factor	Correlation Coefficient Slope (0.85 to 1.15)	Correlation Coefficient Intercept (±3% F.S.)
0.0	-0.1	NA	0.999994	1.006923
12.0	12.0	1.0022		-0.12272
20.9	20.9	1.0020		
41.4	41.6	0.9954		



Notes:

01 Minute Averages



Nitrogen Dioxide

NOx - NO- NO2 Calibration Report
Station Information

Calibration Date	January 1, 2012	Previous Calibration	December 9, 2011
Company	LICA	Plant/Location	Maskwa
Start Time (MST)	9:43	End Time (MST)	17:05
Reason:	As Found		
Barometric Pressure	955 mBar	Station Temperature	19 Deg C
Cal Gas Concentration	NOx 49.7 ppm	NO	49.4 ppm
Cal Gas Cylinder #	LL103831	Cal Gas Expiry date	February 28, 2013
DAS Output Voltage	0 - 1 Volts	Chart Rec. Output	NA Volts

Equipment Information

Analyzer Make / Model:	API 200E	S/N :	594	Method:	Chemiluminescent
Calibrator Make / Model:	EnviroNics 6100	S/N:	4760		
DAS Make / Model:	ESC 8832	S/N :	AO 791		
Chart Recorder Make / Model:	Not in use	S/N:	NA		
Flow Meter:	ESC 8832	S/N :	4760		

Analyzer Settings

Before Calibration				After Calibration			
Concentration Range	0 - 1000			ppb			
Sample Flow/Conv. Temp	464 ccm	316.2 Deg C		464 ccm	315 Deg C		
Ozone Flow / Vacuum	80 ccm	5.4 *Hg-A		80 ccm	5.3 *Hg-A		
HVPS / A ZERO	767 Volts	16.3 MV		767 Volts	16.4 MV		
Rx/ Temp / PMT Temp	50.0 Deg C	6.5 Deg C		50.1 Deg C	6.5 Deg C		
Box Temp / IZS Temp	25.3 Deg C	45.2 Deg C		27.5 Deg C	45 Deg C		
Offset	0.9 NOx	0.8 NO		0.9 NOx	0.8 NO		
Slope	1.196 NOx	1.182 NO		1.196 NOx	1.182 NO		
NO ₂ COEF / Conv Efficiency	NA NO ₂	0.994		NA NO ₂	0.994		

Dilution Calibration Data

Dilution Air Flow Rate	Source Flow Rate	O3 Set Point	Calculated Concentration			Indicated Concentration			Correction Factor	
			NOx	NO	NO2	NOx	NO	NO2	NOx	NO
4994	0.0	NA	0	0	NA	1	1	1	NA	NA
4921	75.7	NA	753	748	NA	754	745	10	0.9999	1.0059

Gas Phase Titration Calibration Data

Dilution Air Flow Rate	Source Flow Rate	O3 Set Point	Calculated Concentration			Indicated Concentration			NO ₂ Correction Factor	NO ₂ Conv Efficiency
			NOx	NO	NO2	NOx	NO	NO2		

Linearity OK?	Yes	No	Sum of Least Squares Correction Factors:	NOx= 0.9999	NO= 1.0059	NO2=
				Average Converter Efficiency=		

Before Calibration


After Calibration

Auto Zero	1.2 NOx	1.3 NO2		- NOx	- NO2
Auto Span	585 NOx	575 NO2		- NOx	- NO2
Sample Lines Connected			YES		
Percent Change from Previous Calibration	NOx	0.0%	NO	-0.6%	NO2 #REF!
Notes	NA : Not Applicable				
	Following the as found points, the perm tube was replaced.				
Calibration Performed by:	Ting Xu.				

NO₂ Calibration Curve


Calibration Date	January 1, 2012	Company	LICA
Plant / Location	Maskwa	End Time (MST)	17:05

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient Slope Intercept	(≥ 0.995) (0.85 to 1.15) (± 3% F.S.)	#DIV/0!
0	0	N/A			#DIV/0!
0	0	#DIV/0!			#DIV/0!
0	0	#DIV/0!			#DIV/0!
0	0	#DIV/0!			#DIV/0!



Notes:

01 Minute Averages



— LICA30 HNOX_ PPB

— LICA30 HNO_ PPB

— LICA30 HNO2_ PPB

NOx - NO- NO2 Calibration Report
Station Information

Calibration Date	January 3, 2012	Previous Calibration	January 1, 2012
Company	LICA	Plant/Location	Maskwa
Start Time (MST)	10:40	End Time (MST)	16:38
Reason:	Monthly Calibration		
Barometric Pressure	937 mBar	Station Temperature	20 Deg C
Cal Gas Concentration	NOx 49.7 ppm	NO	49.4 ppm
Cal Gas Cylinder #	LL103831	Cal Gas Expiry date	February 28, 2013
DAS Output Voltage	0 - 1 Volts	Chart Rec. Output	NA Volts

Equipment Information

Analyzer Make / Model:	API 200E	S/N :	594	Method:	Chemiluminescent
Calibrator Make / Model:	Enviroincs 6100	S/N :	4760		
DAS Make / Model:	ESC 8832	S/N :	AO 791		
Chart Recorder Make / Model:	Not in use	S/N :	NA		
Flow Meter:	ESC 8832	S/N :	4760		

Analyzer Settings

Before Calibration				After Calibration			
0 - 1000							
Concentration Range							
Sample Flow/Conv. Temp	454 ccm	314.5 Deg C		452 ccm	315 Deg C		
Ozone Flow / Vacuum	78 ccm	5.2 °Hg-A		79 ccm	5.3 °Hg-A		
HVPS / A ZERO	767 Volts	16.5 MV		767 Volts	16.2 MV		
Rx/ Temp / PMT Temp	49.9 Deg C	6.5 Deg C		50.0 Deg C	6.5 Deg C		
Box Temp / IZS Temp	28.7 Deg C	45.2 Deg C		29.7 Deg C	40.2 Deg C		
Offset	0.9 NOx	0.3 NO		0.9 NOx	0.8 NO		
Slope	1.196 NOx	1.182 NO		1.191 NOx	1.185 NO		
NO ₂ COEF / Conv Efficiency	NA NO ₂	0.994		NA NO ₂	0.994		

Dilution Calibration Data

Dilution Air Flow Rate	Source Flow Rate	O3 Set Point	Calculated Concentration			Indicated Concentration			Correction Factor	
			NOx	NO	NO2	NOx	NO	NO2	NOx	NO
4994	0.0	NA	0	0	NA	0	1	1	NA	NA
	No Zero Adj.									
4921	75.7	NA	753	748	NA	756	745	11	0.9960	1.0059
4921	75.7	NA	753	748	NA	754	748	7	0.9986	1.0000
4961	35.3	NA	351	349	NA	351	348	3	1.0000	1.0058
4975	20.2	NA	201	200	NA	200	199	2	1.0049	1.0089
4994	0.0	NA	0	0	NA	1	1	1	NA	NA

Gas Phase Titration Calibration Data

Dilution Air Flow Rate	Source Flow Rate	O3 Set Point	Calculated Concentration			Indicated Concentration			NO ₂ Correction Factor	NO ₂ Conv Efficiency
			NOx	NO	NO2	NOx	NO	NO2		
4921	75.7	NA	753	748	NA	753	748	5	NA	NA
	No Adj.									
4921	75.7	600	753	NA	540	752	213	540	1.0019	100.00%
4921	75.7	250	753	NA	230	752	523	230	1.0044	100.00%
4921	75.7	140	753	NA	131	753	622	132	1.0000	100.79%

Linearity OK?	Yes	No	Sum of Least Squares Correction Factors:	NOx= 0.997	NO= 1.004	NO2= 1.000
				NOx= 0.9986	NO= 1.0000	NO2= 1.0019
				Average Converter Efficiency= 100.26%		


Before Calibration

Auto Zero	1.3 NOx	1.4 NO2		1.2 NOx	1.0 NO2
Auto Span	900 NOx	884 NO2		623 NOx	611 NO2
Sample Lines Connected: YES					
Percent Change from Previous Calibration		NOx	0.4%	NO	0.0%
		NO2	0.0%		
Notes: NA : Not Applicable					
Calibration Performed by: Ting Xu.					

NO₂ Calibration Curve

Calibration Date	January 3, 2012	Company	LICA
Plant / Location	Maskwa	Start Time (MST)	10:40
End Time (MST)	16:38		

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient Slope	(≥ 0.995)	0.999821
7	5	N/A	Intercept	(± 3% F.S.)	1.43867
126	132	0.9545			
225	230	0.9783			
535	540	0.9907			




Notes:

NOx Calibration Curve

Calibration Date	January 3, 2012	
Company	LICA	
Plant / Location	Maskwa	
Start Time (MST)	10:40	End Time (MST) 16:38

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient (≥ 0.995)	0.999991
0	1	N/A	Slope (0.85 to 1.15)	1.000784
201	200	1.0049	Intercept (± 3% F.S.)	-0.02526
351	351	1.0004		
753	754	0.9986		




Notes:

NO Calibration Curve


Calibration Date	January 3, 2012	
Company	LICA	
Plant / Location	Maskwa	
Start Time (MST)	10:40	End Time (MST) 16:38

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient (≥ 0.995)	0.999994
0	1	N/A	Slope (0.85 to 1.15)	1.000834
200	199	1.0039	Intercept (± 3% F.S.)	-1.5574
349	348	1.0029		
748	748	1.0005		



Notes:

01 Minute Averages



— LICA30 NOX_ PPB

— LICA30 NO_ PPB

— LICA30 NO2_ PPB

Lakeland Industry & Community Association

St. Lina Monitoring Site
Ambient Air Monitoring
Data Report
For
January 2012

Prepared By:



February 22, 2012

Lakeland Industry & Community Association

St. Lina

Ambient Air Monitoring

Table of Contents

	Page		Page
Introduction	3		
Calibration Procedure	4	Calibration Reports	99
Monthly Continuous Summary	5	<ul style="list-style-type: none"> • Sulphur Dioxide • Hydrogen Sulphide • Total Hydrocarbons • Nitrogen Dioxide • Ozone • Particulate Matter 2.5 	100 103 106 112 117 123
General Monthly Summary	6		
Continuous Monitoring	10		
<ul style="list-style-type: none"> • Monthly Summaries, Graphs & Wind Roses 	11		
<ul style="list-style-type: none"> • Air Quality Index • Sulphur Dioxide • Hydrogen Sulphide • Total Hydrocarbons • Ozone • Nitrogen Dioxide • Nitric Oxide • Oxides of Nitrogen • Particulate Matter 2.5 • Temperature • Barometric Pressure • Relative Humidity • Precipitation • Vector Wind Speed • Vector Wind Direction • Standard Deviation Wind Direction 	12 14 22 30 38 46 54 61 69 74 77 80 83 86 93 96		

Introduction

The following Ambient Air Monitoring report was prepared for:

Mr. Mike Bisaga

Lakeland Industry & Community Association

Box 8237

5107W – 50 Street

Bonnyville, Alberta

T9N 2J5

Monitoring Location: St. Lina

Data Period: January 2012

The monthly ambient data report:

- Prepared by Lily Lin
- Reviewed by Craig Snider

Calibration Procedure

The following calibration procedure applies to all calibrations conducted at the Lakeland Industry & Community Association Air Monitoring Station.

Calibration gas concentrations are generated using a dynamic mass flow controlled calibrator. EPA Protocol one gases are diluted with zero air generated on site. The Mass Flow Controllers in the calibrator are referenced using an NIST traceable flow meter once per month. All listed flows are reported as corrected to Standard Temperature and Pressure (STP).

Generated zero gas is introduced to the analyzer first. Three concentrations of calibration gas are then generated in order to introduce points at approximately 50-80%, 25-40% & 10-20% of the analyzer's full-scale range. An auto zero and span are then performed to validate the daily zero and span values recorded to the next multi-point calibration.

All indicated concentrations are taken from the ESC data logger used to collect the data for monthly reporting.

The calibrations conducted at the LICA – St. Lina Air Monitoring Stations conform to the following Maxxam Standard Operation Procedures:

- CAL SOP-00211
- CAL SOP-00209
- CAL SOP-00213
- CAL SOP-00214
- CAL SOP-00208
- CAL SOP-00215

Conformance of each calibration to Alberta Environment regulations is outlined in the individual calibration reports. The slope and correlation coefficient are derived from the calculated and indicated analyzer responses. The percent change is calculated using the previous calibration correction factor and the current correction factor before adjustment. All calibration's and maintenance conforms to the procedures outlined in the *Air Monitoring Directive, Appendix A-10, Section 1.6*.

MONTHLY CONTINUOUS DATA SUMMARY

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION – ST. LINA

Continuous Ambient Monitoring – January 2012

LICA ST. LINA SITE						MAXIMUM VALUES							OPERATIONAL TIME (PERCENT)	
						OBJECTIVES					EXCEEDENCES			MONTHLY AVERAGE
PARAMETER	1-HR	24-HR	1-HR	24-HR	1-HR	24-HR	READING	DAY	HOUR	WIND SPEED (KPH)	WIND DIRECTION (DEGREES)	READING		
SO2 (PPB)	172	48	0	0	0.31	0.31	3	VAR	VAR	VAR	VAR	1.1	22	99.6
H2S (PPB)	10	3	0	0	0.17	0.17	1	VAR	VAR	VAR	VAR	0.9	29	99.6
THC (PPM)	-	-	-	-	2.17	2.17	3.1	1	22	9.6	87(E)	2.5	1	95.4
OZONE (PPB)	82	-	0	-	26.0	26.0	38	9, 25	21, 18	25.3, 14.8	262(W), 286(WNW)	33.7	27	99.7
NOx (PPB)	-	-	-	-	3.80	3.80	40	20	10	7.9	218(SW)	10.4	20	99.6
NO (PPB)	-	-	-	-	0.72	0.72	21	20	10	7.9	218(SW)	2.8	30	99.6
NO ₂ (PPB)	159	-	0	-	3.02	3.02	19	20	10	7.9	218(SW)	7.7	20	99.6
PM2.5 (ug/m3)	-	30	-	0	4.73	4.73	47.1	18	17	15.1	255(WSW)	11.5	22	77.3
TEMPERATURE (DEGREE C)	-	-	-	-	-9.09	-9.09	9.7	8	14	6.8	324(NW)	3.3	8	99.7
BP (MILLIBAR)	-	-	-	-	921	921	943	1	VAR	VAR	VAR	940.3	1	99.7
RH (%)	-	-	-	-	65.70	65.70	89	5	8	13.7	305(WNW)	81.5	29	99.7
PRECIPITATION (MM)	-	-	-	-	0.01	0.01	1.4	5	9	22.9	306(NW)	2.8	5	100.0
VECTOR WS (KPH)	-	-	-	-	10.21	10.21	25.3	9	21	-	262(W)	15.7	18	99.7
VECTOR WD (DEGREES)	-	-	-	-	295(WNW)	295(WNW)	-	-	-	-	-	-	-	99.7

VAR-VARIOUS

General Monthly Summary

Equipment Operation

The following summary outlines the analyzer performance. Any non-conformances, problems or maintenance performed are detailed at the end of each section.

AQM STATION – LICA – St. Lina

Sulphur Dioxide (PPB)

Analyzer make / model - API 100E, S/N: 468

The analyzer was working well throughout the month. The inlet filter was changed before the monthly calibration was started on January 10th. One hour of maximum data was invalidated due to a small power outage on January 5th. Two hourly average data were invalidated on January 13th due to a power failure. Data was corrected using daily zero information.

Hydrogen Sulphide (PPB)

Analyzer make / model - API 101E, S/N: 510

The analyzer was working well throughout the month. The inlet filter was changed before the monthly calibration was started on January 6th. One hour of maximum data was invalidated due to a small power outage on January 5th. Two hourly average data were invalidated on January 13th due to a power failure. Data was corrected using daily zero information.

Total HydroCarbon (PPM)

Analyzer make / model –TECO 51C, S/N: 77021-384

The sample pump failed after a small power outage on January 5th. The pump was restarted on January 5th. Nine hours of data was invalidated due to this event. The inlet filter was changed before the monthly calibration was started on January 6th. The H2 gas cylinder was changed on January 6th. The analyzer fumed out due to a power failure on January 13th. It was re-lit on January 14th at hour of 15. 24 hours of data were invalidated due to this power failure. The sample pump was replaced following the as found point check on January 17th. A post-repair calibration was performed. Data was corrected using daily zero information.

General Monthly Summary

AQM STATION – LICA – St. Lina

Ozone (PPB)

Analyzer make / model –Thermo 49C, S/N: 49C-54926-302

The analyzer was working well throughout the month. The inlet filter was changed before the monthly calibration was started on January 10th. One hour of maximum data was invalidated due to a small power outage on January 5th. Two hourly average data were invalidated on January 13th due to a power failure. The Cell A and Cell B flow sensors were replaced following the as found point check on January 17th. A post-repair calibration was performed after that. Data was corrected using daily zero information.

Nitrogen Dioxide (PPB)

Analyzer make / model - API 200E, S/N: 592

The analyzer was working well throughout the month. The exhaust pump was replaced following the as found point check on January 6th. The inlet filter was changed before the monthly calibration was started on January 6th. One hour of maximum data was invalidated due to a small power outage on January 5th. Two hourly average data were invalidated on January 13th due to a power failure. Data was corrected using daily zero information.

Particulate Matter 2.5 (UG/M3)

Analyzer make / model – Thermo Scientific Series 1405F, S/N: 1405A208301003 replaced to Thermo Scientific Series 1405F, S/N: 1405A207691003

A routine Teom audit was performed on January 6th. Following the audit, the Teom filter and FDMS filter were replaced. It was noticed that the Teom noise level was high during the site visit on January 10th. A new filter was put into the Teom box for conditioning on January 10th, and it was installed on January 11th. It was found that the V-ring seal for the mass transducer was cracked on January 11th. Temporary fixed the crack and then performed a leak check. The result was good. Another Teom audit was performed on January 13th due to many negative readings. The audit result was fine. The V-ring seal was replaced on January 17th, and a post-repair Teom audit was performed. Due to the poor stability of the Teom unit, it was replaced and brought back to Calgary shop for repair on January 19th. The Teom unit used at Portable station was installed. An installation audit was performed on January 19th. Data was corrected using Alberta air quality guideline. If the data was between 0 to -3, the data was corrected to 0. If the data was below -3, the data was invalidated. 162 hours of data were invalidated as the data were above -3 ug/m3. The operational time was 77.3%. The AENV reference #: 255191.

General Monthly Summary

AQM STATION – LICA – St. Lina

Temperature (Degree C)

Analyzer make / model – Met One 060

No operational issue was observed during the month. Two hourly average data were invalidated on January 13th due to a power failure.

Barometric Pressure (Millibar)

Analyzer make / model - Met One 092

No operational issue was observed during this month. Two hourly average data were invalidated on January 13th due to a power failure.

Relative Humidity (%)

Analyzer make / model - Met One 083

No operational issue was observed during this month. Two hourly average data were invalidated on January 13th due to a power failure.

Precipitation (MM)

Analyzer make / model - Met One 387

During the site visit on February 8th, it was found that the heater for the tipping bucket was not working. We are not sure when the heater failed. Although we still recorded some precipitation readings, we are not sure how accurate the readings were. Data should be used with caution.

Vector Wind Speed (KPH) & Vector Wind Direction (DEG)

System make / model – Met 50.5, S/N: H12635

The wind system is reported as vector wind speed and vector wind direction.

The wind system was working well throughout the month. One hour of maximum data was invalidated due to a small power outage on January 5th. Two hourly average data were invalidated on January 13th due to a power failure.

General Monthly Summary

AQM STATION – LICA – St. Lina

Datalogger

System make / model - ESC 8832, S/N: AO717

Software make/version - ESC v 5.51a

The station is connected to a modem to allow for daily polling of the station.

Trailer

No issue was observed this month. The manifold was cleaned on January 10th.

Air Quality Index (AQI)

The AQI data was adjusted to reflect regular monthly and daily calibrations, maintenance, and downtime. One hour of AQI value for PM2.5 recorded in January 2012 was within the Fair range, and others were within the Good range. The highest hourly concentration of Ozone was 38 ppb and an AQI value of 19, on January 9th and 25th, in various hours. The highest hourly concentration of PM2.5 was 47.1 ug/m³ and an AQI value of 34, on January 18, hour of 17.

Continuous Monitoring

Monthly Summaries, Graphs & Wind Roses

Air Quality Index

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION -ST. LINA

JANUARY 2012
AIR QUALITY INDEX (AQI)

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	
DAY	PEAK	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX	
1		16	-	-	-	14	-	-	-	12	10	11	11	-	12	11	12	14	14	-	14	14	13	13	13	16	
2		13	14	14	14	15	-	-	15	14	-	12	12	12	11	11	-	10	10	9	9	9	8	8	8	15	
3		-	11	12	12	13	-	11	10	10	10	9	9	10	10	10	10	11	11	10	9	8	8	8	8	13	
4		8	8	12	11	-	8	8	8	9	10	11	-	-	10	9	8	8	8	8	8	8	8	9	11	12	
5		10	10	10	-	10	10	10	10	15	17	-	-	15	16	-	-	16	-	17	17	18	18	-	18		
6		-	-	-	-	16	16	16	16	-	15	-	-	-	-	-	-	-	16	-	-	16	-	15	27		
7		NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	PM2	
8		-	-	-	-	11	11	10	9	10	10	12	13	14	15	14	-	12	11	11	11	10	10	-	15		
9		NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	18	
10		9	11	9	8	8	7	8	9	9	9	9	8	-	11	-	-	11	-	-	18	19	-	18	19		
11		18	18	18	17	17	16	-	16	-	16	-	18	18	18	17	-	-	-	15	15	-	16	16	31		
12		16	-	-	-	-	-	14	-	13	-	-	15	-	14	14	13	-	-	10	-	9	10	10	16		
13		11	-	10	10	11	12	-	16	-	-	17	-	-	17	-	-	-	-	-	-	-	-	-	12	17	
14		12	13	13	13	12	12	-	13	-	-	-	-	-	14	14	-	-	-	-	-	-	13	12	12	16	
15		13	-	13	13	-	13	13	13	13	13	13	-	-	-	-	-	-	14	-	-	-	13	-	14		
16		13	-	13	13	-	13	13	13	13	13	13	-	-	-	-	-	-	14	-	-	-	13	-	14		
17		13	-	13	13	-	13	13	13	13	13	13	-	-	-	-	-	-	14	12	11	-	12	-	14		
18		12	12	-	11	-	-	-	13	-	14	15	-	-	15	14	14	14	14	14	14	14	14	14	14	34	
19		14	14	14	14	14	14	14	14	14	14	14	15	-	16	16	15	19	15	15	15	15	15	14	14	19	
20		14	14	13	12	13	12	16	13	16	14	22	-	16	14	16	16	16	15	12	12	13	13	12	11	22	
21		12	14	15	15	16	15	15	15	16	16	-	15	15	14	14	14	14	14	14	14	14	14	14	14	13	16
22		14	13	13	12	12	12	13	13	16	-	12	15	11	10	10	10	11	9	10	10	11	11	12	13	20	
23		13	13	13	13	13	14	14	13	-	13	13	14	14	13	13	14	14	14	13	13	14	13	13	13	8	14
24		8	9	11	12	12	12	-	12	13	14	14	14	15	15	15	12	11	11	12	12	12	12	12	13	15	
25		14	12	13	13	13	13	-	12	12	12	12	13	14	17	17	18	19	19	19	19	19	18	18	18	19	
26		18	17	17	17	17	-	17	17	17	17	16	15	16	17	18	18	18	16	14	14	15	16	17	18		
27		17	18	19	18	-	18	18	18	18	18	17	17	17	17	17	17	17	17	17	17	16	16	15	15	19	
28		16	16	16	-	15	15	15	15	15	15	15	15	16	16	16	16	16	16	16	16	16	15	15	15	16	
29		15	15	-	15	15	15	14	14	14	14	14	14	13	12	11	12	12	12	11	12	9	8	11	15		
30		9	-	9	9	8	12	14	12	11	13	11	12	9	10	9	9	9	9	8	9	11	13	14	14		
31		NA	NA	PM2	PM2	PM2	PM2	PM2	PM2	PM2	PM2	PM2	PM2	PM2	PM2	PM2	PM2	PM2	PM2	PM2	PM2	PM2	PM2	PM2	PM2	NA	14
PEAK		18	18	19	18	17	18	18	18	18	18	22	18	18	18	18	18	18	34	19	19	19	19	18	18	18	

STATUS FLAG CODES

NA - NOT APPLICABLE

V - VARIOUS

AQI CLASS	OZONE (O ₃)					PARTICULATE MATTER 2.5 (PM _{2.5})					NITROGEN DIOXIDE (NO ₂)					SULPHUR DIOXIDE (SO ₂)					FREQUENCY	
	HRS	%	MAX AQI	HR	DAY	HRS	%	MAX AQI	HR	DAY	HRS	%	MAX AQI	HR	DAY	HRS	%	MAX AQI	HR	DAY	HRS	%
VERY POOR (101-255)	0	0.0%	-	-	-	0	0.0%	-	-	-	0	0.0%	-	-	-	0	0.0%	-	-	-	0	0.0%
POOR (51-100)	0	0.0%	-	-	-	0	0.0%	-	-	-	0	0.0%	-	-	-	0	0.0%	-	-	-	0	0.0%
FAIR (26-50)	0	0.0%	-	-	-	1	0.1%	34	17	18	0	0.0%	-	-	-	0	0.0%	-	-	-	1	0.1%
GOOD (1-25)	490	65.9%	19	VAR	9, 25	42	5.6%	-	-	-	0	0.0%	-	-	-	0	0.0%	-	-	-	532	71.5%
OVERALL	669	65.9%	-	-	-	43	5.8%	-	-	-	0	0.0%	-	-	-	0	0.0%	-	-	-	533	71.6%
UNAVAILABLE	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	211	28.4%

Sulphur Dioxide

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - ST. LINA

JANUARY 2012

SULPHUR DIOXIDE (SO₂) hourly averages in ppb

MST

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY MAX.	24-HOUR AVG.	RDGS.	
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00				
DAY																												
1	0	0	0	0	0	0	0	IZS	0	1	1	2	2	2	1	1	2	3	2	1	1	0	1	0	3	0.9	24	
2	0	0	0	1	1	1	IZS	0	0	0	0	0	0	0	1	0	0	0	0	0	0	1	1	1	1	0.3	24	
3	1	1	0	0	0	IZS	0	0	0	0	0	1	1	1	1	1	1	1	1	1	0	1	1	0	1	0.6	24	
4	0	0	0	0	IZS	0	0	0	0	0	0	0	1	1	1	1	1	1	1	1	2	2	2	2	2	0.7	24	
5	2	1	1	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0.2	24
6	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
7	0	IZS	0	0	0	1	0	0	0	0	1	0	0	0	0	0	0	1	1	1	1	0	0	0	1	0.3	24	
8	IZS	0	1	1	1	2	2	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	IZS	2	0.5	24
9	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	1	0.1	24	
10	1	1	1	1	1	1	1	1	1	1	1	1	1	0	0	C	C	C	C	0	0	IZS	0	0	1	0.7	24	
11	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	0	0	1	1	IZS	0	0	0	1	0.2	24	
12	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	1	0.0	24	
13	1	2	2	1	1	0	0	0	0	0	0	0	0	0	0	P	P	0	IZS	0	0	0	0	0	2	0.3	22	
14	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0.0	24	
15	0	0	0	0	0	2	1	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	2	0.1	24	
16	0	0	0	0	0	0	0	1	0	0	0	1	1	2	2	IZS	3	1	1	0	0	0	0	0	3	0.5	24	
17	0	0	0	0	0	0	0	0	0	0	1	1	1	C	IZS	1	C	M	0	0	0	0	0	0	1	0.2	23	
18	0	0	0	0	0	0	0	0	0	0	1	1	0	IZS	0	0	0	0	0	0	0	0	0	0	0	1	0.1	24
19	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
20	0	0	0	0	0	0	0	0	0	0	0	IZS	1	1	0	0	0	0	0	0	0	1	1	2	2	2	0.3	24
21	1	1	1	1	1	1	1	1	1	1	IZS	1	2	3	2	1	0	0	0	0	0	0	0	0	3	0.8	24	
22	0	0	0	0	0	1	1	1	2	IZS	3	3	3	3	3	2	1	1	0	1	0	0	0	1	3	1.1	24	
23	0	0	0	0	0	0	0	0	IZS	0	0	0	0	1	1	0	0	0	0	0	0	0	0	1	1	0.1	24	
24	1	2	1	1	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	2	0.3	24
25	1	1	1	1	1	1	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0.3	24	
26	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
27	0	0	0	0	IZS	0	0	0	0	0	0	0	0	1	0	1	1	0	0	0	0	0	0	0	1	0.1	24	
28	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
29	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	0	0	0	0	1	0.1	24	
30	0	IZS	0	0	0	0	0	0	1	1	1	1	1	1	2	1	1	0	0	0	0	0	0	0	2	0.4	24	
31	IZS	0	0	0	0	0	0	0	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	IZS	1	0.3	24	
HOURLY MAX	2	2	2	1	1	2	2	1	2	1	3	3	3	3	3	2	3	3	2	1	2	2	2	2				
HOURLY AVG	0.3	0.3	0.3	0.2	0.2	0.3	0.2	0.2	0.2	0.2	0.3	0.5	0.5	0.6	0.5	0.4	0.4	0.3	0.3	0.2	0.2	0.2	0.3	0.3				

STATUS FLAG CODES


S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

OBJECTIVE LIMIT:


ALBERTA ENVIRONMENT:	1-HR	172	PPB	24-HR	57	PPB
----------------------	------	-----	-----	-------	----	-----

MONTHLY SUMMARY

NUMBER OF 1-HR EXCEEDENCES:	0					
NUMBER OF 24-HR EXCEEDENCES:	0					
NUMBER OF NON-ZERO READINGS:	175					
MAXIMUM 1-HR AVERAGE:	3	PPB	@ HOUR(S)	VAR	ON DAY(S)	VAR
MAXIMUM 24-HR AVERAGE:	1.1	PPB			ON DAY(S)	22
IZS CALIBRATION TIME:	33	HRS	OPERATIONAL TIME:	741 HRS		
MONTHLY CALIBRATION TIME:	6	HRS	AMD OPERATION UPTIME:	99.6 %		
STANDARD DEVIATION:	0.59		MONTHLY AVERAGE:	0.31 PPB		



01 Hour Averages



— LICA31 SO2_ PPB

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - ST. LINA

JANUARY 2012

SULPHUR DIOXIDE MAX instantaneous maximum in ppt

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR		
DAY	HR	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
1		0	0	0	0	0	0	0	IZS	1	2	2	3	3	3	2	2	3	5	3	2	2	1	2	1	5	1.6	24	
2		1	1	1	2	2	1	IZS	1	1	1	1	1	1	1	2	1	2	1	1	1	1	1	3	2	3	1.3	24	
3		2	2	1	1	1	IZS	1	1	1	1	1	2	2	2	2	1	2	2	2	2	1	2	1	1	2	1.5	24	
4		1	1	1	1	IZS	1	1	1	1	1	1	1	1	2	2	2	2	2	2	2	3	3	3	2	3	1.6	24	
5		3	2	2	IZS	1	1	1	1	P	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	3	0.5	23	
6		0	0	IZS	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0.9	24
7		1	IZS	1	1	2	2	1	1	1	1	1	1	1	1	1	1	1	2	2	2	2	1	1	1	2	1.3	24	
8		IZS	1	1	2	2	3	3	3	2	2	1	1	1	1	1	1	1	1	1	1	1	1	1	1	IZS	3	1.5	24
9		1	1	1	1	1	1	1	2	1	1	1	1	1	1	1	1	0	0	0	0	0	0	0	IZS	2	0.9	24	
10		2	2	2	2	2	2	2	2	2	2	1	2	1	1	1	C	C	C	C	1	1	IZS	1	1	2	1.6	24	
11		1	1	1	1	1	1	1	1	1	1	1	1	1	1	2	2	1	1	1	1	2	IZS	1	1	1	2	1.1	24
12		1	1	1	0	0	1	1	0	1	0	1	0	0	0	0	0	1	1	1	1	IZS	1	1	2	2	0.7	24	
13		2	3	3	2	2	1	1	1	1	1	1	1	1	1	P	P	3	IZS	1	1	1	1	1	1	3	1.4	22	
14		1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	IZS	1	1	1	1	1	1	1	1	1.0	24	
15		1	1	1	1	3	3	2	1	1	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	3	0.6	24	
16		0	0	0	0	0	0	1	3	2	1	2	2	1	4	3	IZS	4	2	2	1	1	1	1	1	4	1.4	24	
17		1	1	1	1	1	1	1	1	1	1	1	1	2	C	IZS	2	M	C	1	1	1	1	1	1	1	2	1.1	23
18		1	1	1	1	1	1	1	1	1	1	1	1	1	IZS	1	1	1	1	1	1	1	1	1	1	1	1	1.0	24
19		1	1	1	1	1	1	1	1	1	1	1	1	1	IZS	1	1	1	1	1	1	1	1	1	1	1	1	1.0	24
20		1	1	1	1	1	1	1	1	1	1	1	1	IZS	2	2	1	1	1	1	1	1	2	2	2	3	3	1.3	24
21		2	2	2	2	2	2	2	2	2	2	IZS	2	3	4	3	2	1	1	1	1	1	1	1	1	4	1.8	24	
22		1	1	1	1	1	2	2	2	3	IZS	4	4	4	4	3	2	2	1	2	1	1	1	2	2	4	2.2	24	
23		1	1	1	1	1	1	1	1	IZS	1	1	1	1	2	2	1	1	1	1	1	1	1	1	2	2	1.1	24	
24		3	3	2	2	1	1	0	IZS	0	1	0	1	0	1	1	1	1	1	1	1	1	1	2	2	3	1.2	24	
25		2	2	2	1	1	1	IZS	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0.5	24	
26		0	0	0	0	0	IZS	0	0	0	0	0	0	0	1	0	0	0	0	0	0	1	1	0	0	1	0.2	24	
27		0	0	0	0	IZS	1	1	1	1	1	1	1	1	2	1	2	2	2	1	1	1	1	1	1	2	1.0	24	
28		1	1	1	IZS	1	1	1	1	1	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0.9	24	
29		1	1	IZS	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	2	2	1	1	1	1	2	1.0	24	
30		1	IZS	1	1	1	1	1	1	2	2	2	2	3	2	3	2	2	1	1	1	1	1	1	1	3	1.5	24	
31		IZS	1	1	1	0	0	1	1	2	2	2	2	2	1	1	1	1	1	1	1	1	1	1	1	IZS	2	1.1	24
HOURLY MAX		3	3	3	2	3	3	3	3	3	2	4	4	4	4	4	3	4	5	3	2	3	3	3	3	3			
HOURLY AVG		1.1	1.1	1.1	1.0	1.1	1.2	1.1	1.2	1.2	1.0	1.0	1.2	1.3	1.4	1.3	1.2	1.2	1.3	1.1	1.1	1.0	1.0	1.2	1.2				


STATUS FLAG CODES

S - OUT OF SERVICE	IZS - DAILY ZERO/SPAN CHECK
N - INVALID DATA	M - MISSING DATA
D - INSTRUMENT DRIFT	P - POWER FAILURE
C - CALIBRATION	NA - NOT APPLICABLE

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	597					
MAXIMUM INSTANTANEOUS VALUE:	5	PPB	@ HOUR(S)	17	ON DAY(S)	1
IZS CALIBRATION TIME:	33	HRS		OPERATIONAL TIME:	740	HRS
MONTHLY CALIBRATION TIME:	6	HRS				
STANDARD DEVIATION:	0.77					

01 Hour Averages



LICA31
 SO2_ / WDR Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 31
 Site Name : LICA31
 Parameter : SO2_
 Units : PPB

Wind Parameter : WDR
 Instrument Height : 10 Meters

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 20	6.83	3.13	5.41	6.12	5.27	5.41	7.12	2.13	.85	3.84	8.11	13.39	8.54	4.27	9.11	10.39	100.00
< 60	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 110	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 170	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 340	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 340	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	6.83	3.13	5.41	6.12	5.27	5.41	7.12	2.13	.85	3.84	8.11	13.39	8.54	4.27	9.11	10.39	

Calm : .00 %

Total # Operational Hours : 702

Distribution By Samples

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 20	48	22	38	43	37	38	50	15	6	27	57	94	60	30	64	73	702
< 60																	
< 110																	
< 170																	
< 340																	
>= 340																	
Totals	48	22	38	43	37	38	50	15	6	27	57	94	60	30	64	73	



Calm : .00 %

Total # Operational Hours : 702


Class Limits (PPB)

Period : 01/01/12-01/31/12

Level : 10



Calibration Graph for Site: LICA30 Parameter: S02_ Sequence: S02 Phase: SPAll



Hydrogen Sulphide

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - ST. LINA

JANUARY 2012

HYDROGEN SULPHIDE (H₂S) hourly averages in ppb

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	DAILY 24-HOUR			
DAY	HOURLY MAX	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.		
1		0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
2		0	0	0	0	0	0	IZS	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0.7	24	
3		1	1	1	1	1	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0.2	24	
4		0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	1	1	1	1	0.2	24	
5		1	1	1	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1.0	24	
6		0	0	IZS	0	0	0	0	0	0	0	C	C	C	C	0	0	0	0	0	0	0	0	0	0	0	0.0	24		
7		0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
8		IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0.0	24	
9		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0.0	24	
10		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	M	0	0	IZS	0	1	1	0.0	23	
11		0	1	0	0	1	1	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0.7	24	
12		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	IZS	0	0	0	0	1	0.1	24	
13		0	0	0	0	0	0	0	0	0	0	0	0	0	0	P	P	0	0	IZS	0	0	0	0	0	0	0	0.0	22	
14		0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	IZS	0	0	0	0	0	0	0	1	0.6	24	
15		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0.0	24	
16		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0.0	24	
17		0	0	0	0	0	0	0	0	0	0	0	0	0	C	IZS	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
18		0	0	0	0	0	1	0	0	1	0	1	1	1	IZS	0	0	0	0	0	0	0	0	0	0	0	0	1	0.2	24
19		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0.0	24	
20		0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
21		0	0	0	0	1	0	0	1	1	1	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0.2	24	
22		0	0	0	0	0	0	0	0	0	IZS	0	0	1	0	0	0	0	0	0	0	0	1	0	0	1	1	0.1	24	
23		1	1	1	1	1	1	1	1	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0.3	24	
24		0	0	0	0	0	0	0	IZS	0	0	0	1	0	0	1	1	1	1	1	1	1	1	1	1	1	1	0.5	24	
25		1	1	1	1	1	1	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0.3	24	
26		0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
27		0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
28		0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
29		0	0	IZS	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0.9	24	
30		1	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0.0	24	
31		IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0.0	24	
HOURLY MAX		1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1			
HOURLY AVG		0.2	0.2	0.1	0.1	0.2	0.2	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.2				

STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE


OBJECTIVE LIMIT:

ALBERTA ENVIRONMENT: 1-HR 10 PPB 24-HR 3 PPB


MONTHLY SUMMARY

NUMBER OF 1-HR EXCEEDENCES:	0
NUMBER OF 24-HR EXCEEDENCES:	0
NUMBER OF NON-ZERO READINGS:	120
MAXIMUM 1-HR AVERAGE:	1 PPB @ HOUR(S) VAR ON DAY(S) VAR
MAXIMUM 24-HR AVERAGE:	0.9 PPB VAR ON DAY(S) VAR 29
	VAR-VARIOUS
IZS CALIBRATION TIME:	33 HRS
MONTHLY CALIBRATION TIME:	5 HRS
OPERATIONAL TIME:	741 HRS
AMD OPERATION UPTIME:	99.6 %
STANDARD DEVIATION:	0.38
MONTHLY AVERAGE:	0.17 PPB

24 HOUR AVERAGES FOR JANUARY 2012



01 Hour Averages



LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - ST. LINA

JANUARY 2012

HYDROGEN SULPHIDE MAX instantaneous maximum in ppb

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR		
DAY	HR	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
1		0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
2		0	0	0	1	1	1	IZS	1	1	1	1	1	1	1	1	1	2	2	1	2	2	2	2	2	2	2	1.1	24
3		1	1	1	1	1	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0.2	24
4		0	0	0	0	IZS	0	0	0	0	0	0	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0.6	24
5		1	1	1	IZS	0	0	0	0	P	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0.1	23
6		0	0	IZS	0	0	0	0	0	0	0	C	C	C	C	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
7		0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
8		IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
9		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0.0	24
10		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	M	0	0	IZS	1	1	1	1	0.1	23
11		1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	IZS	0	0	1	1	0.9	24
12		1	1	0	0	0	1	0	0	0	1	0	1	1	0	1	1	1	1	1	IZS	0	0	0	0	1	1	0.5	24
13		0	0	0	0	0	0	0	0	0	0	0	0	0	0	P	P	5	IZS	0	0	1	0	1	5	5	0.3	22	
14		1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	IZS	0	0	0	0	0	0	0	1	0.7	24
15		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0.0	24
16		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0.0	24
17		0	0	0	0	0	0	0	0	0	0	0	0	0	C	IZS	0	0	0	1	1	1	1	1	1	0	1	0.2	24
18		1	1	1	1	1	1	1	1	1	1	1	1	1	IZS	0	0	0	0	0	0	0	0	0	0	0	1	0.6	24
19		0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
20		0	0	0	0	0	0	0	0	0	0	1	IZS	0	0	0	0	0	0	0	0	0	0	0	0	1	1	0.1	24
21		1	1	1	1	1	1	1	1	1	1	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0.4	24
22		0	0	0	0	0	0	0	0	0	0	IZS	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0.6	24
23		1	1	1	1	1	1	1	1	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0.3	24
24		0	0	0	0	0	0	0	IZS	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0.7	24
25		1	2	2	1	2	2	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0.4	24
26		0	0	0	0	0	IZS	1	1	1	0	1	1	1	1	1	1	0	0	1	0	0	0	0	0	0	1	0.5	24
27		0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
28		0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	0.0	24
29		1	1	IZS	1	1	1	1	1	1	1	1	2	2	1	1	1	1	1	1	1	1	1	1	1	1	2	1.1	24
30		1	IZS	0	0	0	0	1	0	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	1	0.3	24
31		IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0.0	24
HOURLY MAX		1	2	2	1	2	2	1	1	1	1	1	2	2	1	1	1	1	5	2	1	2	2	2	2	2			
HOURLY AVG		0.4	0.4	0.3	0.3	0.3	0.3	0.2	0.3	0.3	0.3	0.4	0.4	0.4	0.3	0.3	0.3	0.3	0.4	0.3	0.3	0.2	0.3	0.3	0.4				


STATUS FLAG CODES

S - OUT OF SERVICE	IZS - IZS - DAILY ZERO/SPAN CHECK
N - INVALID DATA	M - MISSING DATA
D - INSTRUMENT DRIFT	P - POWER FAILURE
C - CALIBRATION	NA - NOT APPLICABLE

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	210					
MAXIMUM INSTANTANEOUS VALUE:	5	PPB	@ HOUR(S)	17	ON DAY(S)	13
IZS CALIBRATION TIME:	33	HRS	OPERATIONAL TIME:	740	HRS	
MONTHLY CALIBRATION TIME:	5	HRS				
STANDARD DEVIATION:	0.53					

01 Hour Averages



LICA31
H2S_ / WDR Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 31
Site Name : LICA31
Parameter : H2S_
Units : PPB

Wind Parameter : WDR
Instrument Height : 10 Meters

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 3	7.25	2.98	5.26	5.97	5.12	5.40	7.11	2.13	.85	3.84	8.10	13.37	8.53	4.26	9.24	10.52	100.00
< 10	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 50	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 50	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	7.25	2.98	5.26	5.97	5.12	5.40	7.11	2.13	.85	3.84	8.10	13.37	8.53	4.26	9.24	10.52	

Calm : .00 %

Total # Operational Hours : 703



Distribution By Samples

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 3	51	21	37	42	36	38	50	15	6	27	57	94	60	30	65	74	703
< 10																	
< 50																	
>= 50																	
Totals	51	21	37	42	36	38	50	15	6	27	57	94	60	30	65	74	


Calm : .00 %

Total # Operational Hours : 703

Class Limits (PPB)



Calibration Graph for Site: LICA31 Parameter: H2S_ Sequence: H2S Phase: SPAll



Total Hydrocarbons

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - ST. LINA


JANUARY 2012

TOTAL HYDROCARBONS hourly averages in ppm

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR		
DAY	HOURLY MAX	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
1		2.3	2.3	2.4	2.5	2.4	2.5	2.5	IZS	2.4	2.4	2.5	2.5	2.5	2.4	2.4	2.5	2.5	2.3	2.3	2.4	2.6	2.6	3.1	2.9	3.1	2.5	24	
2		2.7	2.6	2.5	2.4	2.4	2.2	IZS	2.2	2.2	2.3	2.3	2.2	2.2	2.1	2.2	2.3	2.4	2.4	2.2	2.2	2.2	2.1	2.1	2.2	2.7	2.3	24	
3		2.2	2	2	2	2	IZS	2.3	2.6	2.5	2.4	2.5	2.5	2.5	2.4	2.3	2.4	2.4	2.4	2.3	2.5	2.4	2.4	2.5	2.4	2.6	2.3	24	
4		2.4	2.5	2.5	2.6	IZS	2.2	2.2	2.2	2.2	2.1	2.1	2	2	2	2.1	2	2	2	2.1	2.3	2.2	2.2	2.1	1.9	2.6	2.2	24	
5		1.8	1.9	1.8	IZS	1.8	1.8	1.9	1.9	N	N	N	N	N	N	N	N	N	N	C	1.6	1.9	2	2	2	2	2.0	15	
6		2	2	IZS	2	2	2	2	2	2	2.1	2.1	2.1	2.1	2.1	C	C	C	C	2	2	2	2	2	2	2.1	2.0	24	
7		2.1	IZS	2.1	2.2	2.2	2.3	2.3	2.4	2.4	2.5	2.6	2.5	2.4	2.4	2.3	2.3	2.4	2.4	2.3	2.2	2.3	2.5	2.4	2.3	2.6	2.3	24	
8		IZS	2.1	2	2	2	2	2	2	1.9	1.9	1.9	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.9	1.9	IZS	2.1	1.9	24	
9		2.3	2.2	2.3	2.3	2.4	2.4	2.3	2.2	2.3	2.2	2.2	2.2	2.2	2.2	2.2	2.3	2	1.9	1.9	1.9	IZS	2	2.4	2.2	24			
10		2	2	2	2	2	2	2	2	2	2.1	2.1	2.1	2.1	2.1	2.2	2.2	2.2	2.3	M	2.3	2.3	IZS	2.1	2.1	2.3	2.1	23	
11		2.1	2.1	2.1	2.1	2.1	2.1	2.3	2.1	2.2	2.2	2.2	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.2	2.3	IZS	2.3	2.2	2.2	2.3	2.2	24	
12		2.2	2.1	1.9	1.9	1.8	1.8	1.8	1.9	1.9	1.9	1.9	1.9	1.8	1.8	1.8	1.9	1.9	1.9	1.9	IZS	2.3	2.1	2.2	2.2	2.3	1.9	24	
13		2.2	2.3	2.4	2.4	2.5	2.4	2.2	2.1	2	2	2	2	1.9	2	2	P	P	N	N	N	N	N	N	N	2.5	2.2	15	
14		N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	C	2.5	IZS	2.4	2.3	2.4	2.1	2	2.1	2.5	2.3	9	
15		2.1	2	2	2	2.1	2.1	2.1	2	2	2.1	2.1	2.1	2.1	2.1	2.1	2.1	IZS	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	24	
16		2.1	2.2	2.1	2.1	2.1	2.1	2.1	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	IZS	2.2	2.2	2.2	2.2	2.2	2.2	2.3	2.3	2.3	2.2	24	
17		2.2	2.2	2.2	2.2	2.2	2.2	2.3	2.2	2.2	2.3	C	C	C	C	C	C	C	C	2	2	2	2	2	2	1.9	2.3	2.1	24
18		1.9	2	2	2.1	2.1	2.1	2	2	2	2	2	1.9	1.9	IZS	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.0	24	
19		2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	IZS	2	2	2	2	2.1	2.1	2.1	2	2.1	2.1	2.1	2.1	2.1	2.1	24
20		2.2	2.1	2.1	2.2	2.2	2.2	2.2	2.3	2.3	2.4	2.4	IZS	2.2	2.1	2.1	2.1	2.1	2.1	2.6	2.8	2.5	2.5	2.7	3	3.0	2.3	24	
21		2.8	2.5	2.2	2.2	2.2	2.2	2.2	2.1	2	2.1	IZS	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.2	2.2	2.1	2.1	2.2	2.1	2.8	2.2	24	
22		2.1	2.2	2.3	2.2	2.2	2.3	2.3	2.3	2.3	2.3	IZS	2.3	2.4	2.4	2.4	2.3	2.4	2.3	2.3	2.3	2.4	2.5	2.5	2.5	2.5	2.3	24	
23		2.5	2.7	2.6	2.6	2.5	2.3	2.3	2.3	IZS	2.3	2.2	2.1	2.1	2.1	2.1	2.2	2.1	2.1	2.2	2.2	2.2	2.2	2.2	2.3	2.7	2.3	24	
24		2.3	2.2	2.2	2.2	2.2	2.2	2.3	IZS	2.2	2.2	2.2	2.2	2.2	2.2	2.1	2.1	2.6	2.8	2.7	2.7	2.6	2.5	2.4	2.3	2.8	2.3	24	
25		2.2	2.6	2.6	2.5	2.4	2.3	IZS	2.2	2.2	2.2	2.3	2.3	2.2	2.2	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.6	2.2	24
26		2.1	2.2	2.2	2.2	2.2	IZS	2	2	2	2.1	2.1	2.1	2.1	2.1	2	2.1	2.1	2.1	2.1	2.2	2.2	2.1	2.1	2.1	2.2	2.1	24	
27		2.1	2.1	2.1	2.1	IZS	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2.1	2.0	24
28		2	2	2	IZS	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2.2	2.3	2.2	2.3	2.0	24		
29		2.3	2.3	IZS	2.3	2.2	2.1	2.1	2.2	2.2	2.2	2.2	2.2	2.1	2.1	2.1	2.1	2	2	2	2	2	2	2.1	2.1	2.3	2.1	24	
30		2.1	IZS	2.1	2.1	2.2	2.2	2.2	2.2	2.3	2.4	2.3	2.3	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.3	2.3	2.2	2.1	2	2.4	2.2	24
31		IZS	2.1	2.1	2.1	2.1	2.1	2.1	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.3	2.3	2.3	IZS	2.3	2.2	24	
HOURLY MAX		2.8	2.7	2.6	2.6	2.5	2.5	2.5	2.6	2.5	2.5	2.6	2.5	2.5	2.4	2.4	2.5	2.6	2.8	2.7	2.8	2.6	2.6	3.1	3.0				
HOURLY AVG		2.2	2.2	2.2	2.2	2.2	2.2	2.1	2.1	2.2	2.2	2.2	2.2	2.1	2.1	2.1	2.1	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2			

STATUS FLAG CODES


S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE



MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	663					
MAXIMUM 1-HR AVERAGE:	3.1	PPM	@ HOUR(S)	22	ON DAY(S)	1
MAXIMUM 24-HR AVERAGE:	2.5	PPM			ON DAY(S)	1
					VAR- VARIOUS	
IZS CALIBRATION TIME:	31	HRS	OPERATIONAL TIME:	710	HRS	
MONTHLY CALIBRATION TIME:	16	HRS	AMD OPERATION UPTIME:	95.4	%	
STANDARD DEVIATION:	0.19		MONTHLY AVERAGE:	2.17	PPM	

01 Hour Averages



— LICA31 THC PPM

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - ST. LINA

JANUARY 2012

TOTAL HYDROCARBONS MAX instantaneous maximum in ppr

MST																										DAILY	24-HOUR		
HOURLY MAX	HOURLY AVG	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.
DAY																													
1		2.4	2.4	2.4	2.7	2.5	2.5	2.6	IZS	2.6	2.5	2.5	2.5	2.5	2.5	2.5	2.5	2.5	3.2	3.5	2.6	2.7	2.9	3.2	3	3.5	2.7	24	
2		2.8	2.7	2.5	2.5	2.5	2.3	IZS	2.3	2.2	2.3	2.3	2.3	2.2	2.2	2.3	2.4	2.5	2.4	2.3	2.2	2.2	2.2	2.2	2.2	2.2	2.8	2.3	24
3		2.2	2.2	2	2	2	IZS	2.5	2.7	2.7	2.5	2.7	2.6	2.6	2.5	2.4	3.6	3.6	3.4	2.4	2.6	2.6	2.5	2.5	2.5	3.6	2.6	24	
4		2.5	2.5	2.6	2.6	IZS	2.3	2.3	2.3	2.2	2.2	2.2	2.1	2	2.1	2.1	2.1	2.1	2.1	2.3	2.5	2.5	2.3	2.2	2	2.6	2.3	24	
5		1.9	1.9	1.9	IZS	1.9	1.9	2.1	2	N	N	N	N	N	N	N	N	N	C	C	2	2	2	2	2	2	2.1	2.0	15
6		2	2	IZS	2	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	C	C	C	C	C	2.1	2.1	2.1	2.1	2.1	2.1	2.2	2.2	2.1	24
7		2.1	IZS	2.2	2.3	2.3	2.3	2.4	2.4	2.4	2.6	2.8	2.6	2.5	2.4	2.4	2.4	2.4	2.5	2.4	2.3	2.4	2.5	2.5	2.4	2.8	2.4	24	
8		IZS	2.1	2.1	2	2.1	2	2	2	2	1.9	1.9	1.9	1.8	1.8	1.8	1.8	1.8	1.8	1.9	1.9	1.9	1.9	2	IZS	2.1	1.9	24	
9		2.4	2.4	2.4	2.4	2.4	2.4	2.4	2.3	2.3	2.3	2.2	2.3	2.2	2.2	2.2	2.3	2.3	2.5	2.2	1.9	1.9	1.9	IZS	2	2.5	2.3	24	
10		2	2	2	2	2	2	2	2.1	2.1	2.1	2.1	2.1	2.2	2.2	2.2	2.2	2.3	2.4	M	2.3	2.3	IZS	2.1	2.1	2.4	2.1	23	
11		2.1	2.2	2.2	2.1	2.2	2.2	2.6	2.2	2.3	2.3	2.3	2.1	2.1	2.1	2.1	2.1	2.1	2.2	2.3	2.4	IZS	2.4	2.2	2.2	2.6	2.2	24	
12		2.2	2.2	2	1.9	1.8	1.8	1.9	2	2	1.9	1.9	1.9	1.9	1.8	1.9	2	2	2	2	IZS	2.4	2.2	2.2	2.2	2.4	2.0	24	
13		2.3	2.4	2.4	2.5	2.6	2.4	2.4	2.1	2.1	2.1	2	2	2	2	2	P	P	N	N	N	N	N	N	N	2.6	2.2	15	
14		N	N	N	N	N	N	N	N	N	N	N	N	N	N	C	C	C	C	2.6	2.6	2.5	2.3	2.1	2.1	2.6	2.4	9	
15		2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	IZS	2.1	2.1	2.1	2.2	2.2	2.2	2.2	2.2	2.1	24	
16		2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	IZS	2.2	2.3	2.3	2.3	2.3	2.2	2.3	2.4	2.4	2.2	24	
17		2.2	2.2	2.2	2.2	2.2	2.3	2.3	2.3	2.3	2.3	C	C	C	C	C	C	C	C	C	2	2	2	2	2	2	2.3	2.2	24
18		2	2	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2	2	2	2	IZS	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	24
19		2.1	2.1	2.2	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	IZS	2.2	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.2	2.1	24
20		2.2	2.2	2.2	2.2	2.2	2.3	2.3	2.3	2.3	2.4	2.5	IZS	2.3	2.2	2.1	2.1	2.1	2.1	2.3	2.9	3	2.7	2.8	3.3	3.3	3.3	2.4	24
21		3.1	2.7	2.3	2.5	2.5	2.4	2.5	2.3	2.2	2.3	IZS	2.3	2.4	2.3	2.4	2.6	2.6	2.6	2.6	2.6	2.8	2.7	2.1	2.7	2.2	3.1	2.5	24
22		2.1	2.3	2.3	2.3	2.3	2.4	2.4	2.3	2.3	IZS	2.4	2.4	2.5	2.4	2.4	2.6	2.4	2.4	2.3	2.3	2.4	2.6	2.5	2.5	2.6	2.4	24	
23		2.6	2.7	2.6	2.6	2.6	2.5	2.3	2.4	IZS	2.4	2.3	2.2	2.1	2.2	2.2	2.2	2.4	2.2	2.3	2.2	2.2	2.2	2.2	2.4	2.7	2.3	24	
24		2.3	2.2	2.2	2.2	2.2	2.3	2.3	IZS	2.3	2.3	2.2	2.2	2.2	2.2	2.1	2.3	2.8	2.8	2.8	2.8	2.8	2.7	2.5	2.5	2.3	2.8	2.4	24
25		3	3.4	3.3	3.2	2.6	2.4	IZS	2.3	2.3	2.3	2.3	2.4	2.3	2.2	2.1	2.1	2.2	2.1	2.1	2.1	2.1	2.1	2.1	2.2	3.4	2.4	24	
26		2.2	2.2	2.2	2.2	IZS	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.2	2.2	2.2	2.1	2.1	2.2	2.1	24	
27		2.1	2.1	2.1	2.1	IZS	2	2	2	2	2	2	2	2	2	2	2	2	2	2.2	2	2.1	2.1	2	2	2.1	2.2	2.0	24
28		2.1	2	2.1	IZS	2.1	2.1	2.1	2.1	2.1	2.2	2.2	2.1	2	2	2	2.1	2.6	2.1	2	2.1	2.3	2.4	2.4	2.2	2.6	2.1	24	
29		2.3	2.4	IZS	2.4	2.3	2.2	2.2	2.2	2.3	2.3	2.2	2.2	2.1	2.1	2.1	2	2.3	2	2	2	2.1	2.1	2.1	2.1	2.4	2.2	24	
30		2.1	IZS	2.1	2.2	2.2	2.2	2.2	2.3	2.4	2.4	2.4	2.3	2.3	2.3	2.3	2.2	2.2	2.2	2.3	2.3	2.3	2.2	2.1	2.1	2.4	2.2	24	
31		IZS	2.1	2.2	2.1	2.1	2.1	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.3	2.2	2.2	2.2	2.2	2.2	2.3	2.3	2.3	2.4	2.4	IZS	2.4	2.2	24
HOURLY MAX		3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	4	4	3	4	3	3	3	3	3				
HOURLY AVG		2.3	2.3	2.3	2.3	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.3	2.3	2.3	2.3	2.3	2.3	2.3	2.3					


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE
BB	- BELOW BACKGROUND OF 1.5 PPM		

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	660					
MAXIMUM INSTANTANEOUS VALUE:	3.6	PPM	@ HOUR(S)	15, 16	ON DAY(S)	3
IZS CALIBRATION TIME:	30	HRS	OPERATIONAL TIME:	710	HRS	
MONTHLY CALIBRATION TIME:	20	HRS				
STANDARD DEVIATION:	0.25					

01 Hour Averages



— LICA31 THCMAX PPM

LICA31
 THC / WDR Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 31
 Site Name : LICA31
 Parameter : THC
 Units : PPM

Wind Parameter : WDR
 Instrument Height : 10 Meters

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 3.0	6.93	2.71	5.42	6.33	4.67	5.27	7.39	2.26	.90	4.07	8.44	13.12	8.59	3.61	9.20	10.70	99.69
< 10.0	.00	.00	.00	.00	.30	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.30
< 50.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 50.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	6.93	2.71	5.42	6.33	4.97	5.27	7.39	2.26	.90	4.07	8.44	13.12	8.59	3.61	9.20	10.70	

Calm : .00 %

Total # Operational Hours : 663

Distribution By Samples

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 3.0	46	18	36	42	31	35	49	15	6	27	56	87	57	24	61	71	661
< 10.0					2												2
< 50.0																	
>= 50.0																	
Totals	46	18	36	42	33	35	49	15	6	27	56	87	57	24	61	71	


Calm : .00 %

Total # Operational Hours : 663


Class Limits (PPM)

Period : 01/01/12-01/31/12

Level : 10




Calibration Graph for Site: LICA31 Parameter: THC Sequence: THC Phase: SPAll



Ozone

01 Hour Averages



— LICA31_03_ PPB

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - ST. LINA

JANUARY 2012

OZONE MAX instantaneous maximum in ppb

MST

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR		
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
DAY																												
1	32	32	32	31	30	29	29	IZS	28	25	21	22	23	24	24	23	26	30	29	28	28	28	25	26	32	27.2	24	
2	26	28	29	29	29	30	IZS	30	30	28	27	26	25	24	23	22	22	21	21	20	19	18	17	16	30	24.3	24	
3	18	23	25	25	28	IZS	26	19	20	21	21	20	19	20	20	21	20	22	23	22	20	17	15	21	28	21.1	24	
4	21	14	13	11	IZS	17	17	18	18	19	21	23	23	23	21	19	17	17	16	16	16	18	20	22	23	18.3	24	
5	22	20	21	IZS	21	26	22	27	P	35	34	32	31	31	32	33	34	35	35	35	35	36	35	35	36	30.3	23	
6	34	33	IZS	32	32	32	33	32	31	31	32	34	34	34	34	34	33	32	32	32	32	33	33	31	34	32.7	24	
7	31	IZS	31	29	29	24	23	21	19	20	22	25	28	28	30	29	27	25	23	23	23	21	21	22	31	25.0	24	
8	IZS	24	22	23	24	27	27	28	29	29	32	32	33	35	36	35	34	34	33	33	31	29	28	IZS	36	29.9	24	
9	19	23	22	18	16	15	17	19	20	19	18	19	19	17	20	21	22	25	32	35	35	39	IZS	37	39	22.9	24	
10	36	35	35	35	34	33	32	33	33	35	36	36	36	35	35	C	C	C	C	30	31	IZS	33	32	36	33.9	20	
11	32	31	30	31	31	31	30	29	28	26	29	30	30	29	28	28	27	25	24	21	IZS	18	19	19	32	27.2	24	
12	21	28	32	32	34	34	33	31	32	32	32	33	34	35	35	33	32	31	30	IZS	31	30	28	26	35	31.3	24	
13	22	21	20	19	27	27	32	33	33	33	33	33	34	34	34	35	P	P	34	IZS	33	33	33	32	32	35	30.2	22
14	32	31	30	29	29	27	27	27	29	30	30	30	29	28	27	25	21	IZS	22	24	26	26	25	24	32	27.3	24	
15	26	27	26	27	25	25	28	28	28	27	27	27	28	29	29	29	IZS	28	27	27	27	26	26	26	29	27.1	24	
16	26	25	26	26	26	26	26	26	26	26	26	27	27	28	28	IZS	28	27	27	28	27	27	26	26	28	26.6	24	
17	26	26	26	26	26	25	25	25	25	26	C	C	C	C	C	C	C	C	24	23	23	24	25	25	26	25.0	24	
18	25	25	23	22	21	21	25	25	25	26	27	29	29	IZS	30	30	29	28	28	28	28	28	28	28	30	26.4	24	
19	28	28	28	28	28	28	28	28	28	28	29	30	IZS	32	33	32	30	31	30	29	30	30	28	28	33	29.2	24	
20	28	27	27	26	26	26	19	15	13	14	15	IZS	25	31	33	32	31	31	27	25	26	26	25	23	33	24.8	24	
21	26	30	30	31	32	32	29	31	32	31	IZS	31	31	30	29	28	28	28	28	28	28	27	27	27	32	29.3	24	
22	27	27	26	24	24	22	19	14	11	IZS	17	19	19	19	20	20	18	20	21	19	23	23	23	26	27	20.9	24	
23	27	25	25	25	26	27	27	27	IZS	26	27	27	27	27	27	26	28	27	26	25	28	28	26	22	28	26.3	24	
24	14	18	23	24	24	24	24	IZS	24	26	27	28	28	29	30	30	26	23	23	24	24	25	25	26	30	24.7	24	
25	27	26	25	26	27	26	IZS	25	25	23	24	25	27	30	34	34	36	38	38	37	37	36	35	35	38	30.3	24	
26	35	34	34	34	35	IZS	34	35	34	34	33	32	31	33	35	35	35	35	34	29	28	30	32	34	35	33.3	24	
27	34	36	37	37	IZS	36	36	36	35	35	35	34	34	33	34	34	33	33	34	33	33	32	31	30	37	34.1	24	
28	31	31	31	IZS	30	29	30	30	30	29	30	30	31	32	33	32	32	31	31	31	31	30	30	30	33	30.7	24	
29	29	29	IZS	30	30	29	29	29	29	28	28	28	27	26	26	24	24	24	24	24	22	25	24	17	16	30	26.0	24
30	16	IZS	16	15	14	13	13	10	7	6	11	14	18	18	18	18	17	18	19	17	19	24	27	28	28	16.3	24	
31	IZS	26	26	27	27	27	24	23	24	25	25	25	25	26	26	26	26	25	24	22	21	18	15	IZS	27	24.3	24	
HOURLY MAX	36	36	37	37	35	36	36	36	35	35	36	36	36	35	36	35	36	38	38	37	37	39	35	37				
HOURLY AVG	26.6	27.0	26.6	26.6	27.1	26.5	26.4	26.0	25.7	26.4	26.5	27.7	27.8	28.2	28.8	27.9	27.3	27.8	27.1	26.6	27.3	26.8	25.9	26.7				


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	697					
MAXIMUM INSTANTANEOUS VALUE:	39	PPB	@ HOUR(S)	21	ON DAY(S)	9
IZS CALIBRATION TIME:	32	HRS	OPERATIONAL TIME:	737	HRS	
MONTHLY CALIBRATION TIME:	12	HRS				
STANDARD DEVIATION	5.56					

01 Hour Averages



— LICA31 O3MAX PPB

LICA31
 O3_ / WDR Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 31
 Site Name : LICA31
 Parameter : O3
 Units : PPB

Wind Parameter : WDR
 Instrument Height : 10 Meters

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	6.86	3.14	5.43	6.15	5.29	5.43	7.15	2.14	.85	3.86	8.15	13.01	8.58	4.29	9.29	10.30	100.00
< 110	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	6.86	3.14	5.43	6.15	5.29	5.43	7.15	2.14	.85	3.86	8.15	13.01	8.58	4.29	9.29	10.30	

Calm : .00 %

Total # Operational Hours : 699



Distribution By Samples

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	48	22	38	43	37	38	50	15	6	27	57	91	60	30	65	72	699
< 110																	
< 210																	
>= 210																	
Totals	48	22	38	43	37	38	50	15	6	27	57	91	60	30	65	72	


Calm : .00 %

Total # Operational Hours : 699

Class Limits (PPB)



Calibration Graph for Site: LICA31 Parameter: 03_ Sequence: 03 Phase: SPAN



Nitrogen Dioxide

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - ST. LINA

JANUARY 2012

NITROGEN DIOXIDE hourly averages in ppb

MST	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR		
HOUR START	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
DAY																												
1	0	0	0	1	1	1	1	IZS	3	5	9	9	9	8	8	8	7	6	5	5	5	4	5	5	9	4.6	24	
2	4	3	3	3	3	2	IZS	1	1	1	1	1	1	2	2	2	3	3	3	3	3	3	5	4	5	2.5	24	
3	5	3	3	2	2	IZS	3	4	3	3	4	7	8	9	9	7	8	6	4	5	5	7	7	7	9	5.3	24	
4	7	8	8	10	IZS	5	5	5	4	5	4	3	3	3	4	4	5	6	7	8	8	8	6	4	10	5.7	24	
5	4	4	3	IZS	2	3	2	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	4	0.9	24	
6	0	0	IZS	0	0	0	0	0	0	0	0	C	C	C	C	C	C	C	1	1	1	1	1	2	2	0.5	24	
7	2	IZS	0	1	2	6	7	8	9	8	8	6	4	3	3	3	4	6	7	6	5	5	4	4	9	4.8	24	
8	IZS	3	4	4	4	3	4	3	2	2	1	1	0	0	0	0	0	0	0	0	1	1	1	1	IZS	4	1.5	24
9	5	4	5	7	6	6	6	5	4	4	5	4	4	4	4	5	5	5	2	1	0	0	IZS	0	7	4.0	24	
10	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	M	0	0	IZS	0	0	0	0.0	23	
11	0	0	1	0	0	0	1	1	1	2	2	1	1	2	2	3	3	4	5	6	IZS	8	8	8	8	2.6	24	
12	7	5	2	1	1	1	1	1	1	1	1	1	1	1	1	2	3	2	2	IZS	2	2	3	4	7	2.0	24	
13	6	7	9	9	7	5	3	1	1	1	0	0	0	0	0	P	P	0	IZS	0	0	0	0	0	9	2.3	22	
14	0	1	1	1	1	1	1	1	2	2	1	1	1	1	2	4	5	IZS	6	6	2	1	0	0	6	1.8	24	
15	1	0	1	1	1	2	1	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	2	0.3	24	
16	0	0	0	0	0	0	0	1	0	1	1	1	0	1	1	IZS	1	1	1	1	1	1	1	2	2	2	0.7	24
17	1	1	1	1	2	2	2	2	2	2	2	2	2	C	IZS	0	0	1	1	2	2	1	0	0	2	1.3	24	
18	0	1	1	2	2	2	1	0	0	0	0	0	0	IZS	2	2	2	3	3	3	3	3	2	2	3	1.5	24	
19	2	2	3	2	2	2	2	2	2	2	2	2	IZS	1	1	2	2	3	3	3	3	3	4	3	4	2.3	24	
20	4	4	4	6	5	6	12	15	17	17	19	IZS	11	6	3	3	3	3	7	8	6	5	6	7	19	7.7	24	
21	6	4	2	2	2	2	1	1	1	1	IZS	2	2	2	2	2	3	2	2	2	2	2	2	2	6	2.2	24	
22	2	2	3	3	3	4	7	11	13	IZS	6	5	5	5	6	6	7	7	6	6	6	5	4	13	5.6	24		
23	3	4	3	3	3	2	2	2	IZS	2	2	1	2	3	4	4	3	3	4	4	4	4	4	6	14	14	3.6	24
24	16	12	7	4	4	4	3	IZS	4	5	4	5	3	3	4	4	8	9	8	7	6	5	5	4	16	5.8	24	
25	3	3	3	3	3	3	IZS	3	3	4	4	4	3	3	1	1	1	0	0	0	0	0	0	4	2.0	24		
26	0	0	1	1	0	IZS	1	2	2	2	2	3	4	3	2	2	2	2	4	6	6	5	3	2	6	2.4	24	
27	2	1	1	1	IZS	0	0	0	0	0	0	1	1	2	3	2	3	3	2	2	2	2	3	3	3	1.5	24	
28	2	1	1	IZS	0	1	1	0	0	0	0	0	0	0	0	0	1	1	1	1	1	2	2	2	2	0.7	24	
29	2	1	IZS	2	2	2	2	2	2	2	2	2	2	2	4	5	4	3	4	4	3	4	4	5	5	2.8	24	
30	5	IZS	3	4	4	5	6	9	11	14	12	9	7	7	7	9	10	9	9	11	9	7	4	2	14	7.5	24	
31	IZS	3	3	2	3	2	3	4	5	5	5	5	5	5	5	6	7	8	10	11	12	13	18	IZS	18	6.4	24	
HOURLY MAX	16	12	9	10	7	6	12	15	17	17	19	9	11	9	9	9	10	9	10	11	12	13	18	14				
HOURLY AVG	3.1	2.7	2.6	2.6	2.2	2.5	2.7	3.0	3.1	3.0	3.3	2.6	2.7	2.7	2.8	3.1	3.6	3.3	3.7	3.7	3.3	3.4	3.5	3.1				

STATUS FLAG CODES


S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

OBJECTIVE LIMIT:


ALBERTA ENVIRONMENT: 1-HR 159 PPB

MONTHLY SUMMARY

NUMBER OF 1-HR EXCEEDENCES:	0					
NUMBER OF NON-ZERO READINGS:	555					
MAXIMUM 1-HR AVERAGE:	19	PPB	@ HOUR(S)	10	ON DAY(S)	20
MAXIMUM 24-HR AVERAGE:	7.7	PPB			ON DAY(S)	20
IZS CALIBRATION TIME:	33	HRS	OPERATIONAL TIME:	741	HRS	
MONTHLY CALIBRATION TIME:	9	HRS	AMD OPERATION UPTIME:	99.6	%	
STANDARD DEVIATION:	3.00		MONTHLY AVERAGE:	3.02	PPB	



01 Hour Averages



— LICA31 IIO2_ PPB

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - ST.LINA

JANUARY 2012

NITROGEN DIOXIDE MAX instantaneous maximum in ppb

MST

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR	
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.
DAY																											
1	1	1	1	1	2	2	2	IZS	4	9	10	9	10	9	9	9	8	7	6	6	6	6	6	6	10	5.7	24
2	5	4	3	3	3	3	IZS	1	1	2	2	2	2	3	3	3	3	3	3	3	3	4	7	6	7	3.1	24
3	6	5	4	3	2	IZS	4	5	4	4	6	9	9	10	10	9	9	8	5	6	6	8	8	8	10	6.4	24
4	7	8	9	11	IZS	6	14	6	5	5	6	4	4	4	4	5	6	7	9	10	9	9	8	6	14	7.0	24
5	5	5	4	IZS	3	3	3	3	P	0	0	0	0	0	0	5	7	0	0	0	0	0	0	0	7	1.7	23
6	0	0	IZS	1	1	1	1	1	1	1	C	C	C	C	C	C	C	C	2	2	2	2	2	2	2	1.3	24
7	3	IZS	1	2	5	8	8	9	10	9	9	7	5	4	4	10	17	8	8	7	6	6	6	5	17	6.8	24
8	IZS	4	4	4	5	4	4	4	3	3	2	2	1	1	1	1	1	1	1	1	2	2	3	IZS	5	2.5	24
9	6	6	8	8	7	7	7	6	5	5	6	6	5	5	5	6	13	7	4	2	1	1	IZS	1	13	5.5	24
10	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	M	1	1	IZS	0	1	1	1.0	23
11	1	1	1	1	1	1	1	3	2	3	3	3	3	11	4	4	5	6	8	IZS	10	10	9	11	4.1	24	
12	9	7	3	2	2	2	2	2	2	2	2	2	4	2	1	2	4	3	3	IZS	3	3	4	6	9	3.1	24
13	7	9	9	10	9	6	5	2	2	1	1	1	1	1	1	P	P	1	IZS	1	1	1	1	1	10	3.4	22
14	1	1	2	2	2	2	2	2	3	3	2	2	2	2	3	7	7	IZS	7	7	4	2	1	1	7	2.9	24
15	1	1	2	2	2	3	2	1	1	1	1	1	1	1	1	1	IZS	1	1	1	1	1	1	1	3	1.3	24
16	1	1	1	1	1	1	1	1	1	1	1	2	1	1	1	IZS	2	3	2	2	2	3	2	3	3	1.5	24
17	2	2	2	2	2	3	3	16	3	3	4	4	3	C	IZS	1	1	2	3	3	2	2	1	1	16	3.0	24
18	1	2	2	3	3	3	3	1	1	1	0	0	0	IZS	2	3	3	4	4	4	3	3	3	3	4	2.3	24
19	3	3	4	3	3	3	3	3	4	3	3	3	IZS	2	2	3	3	4	3	4	3	3	4	4	4	3.2	24
20	6	5	5	7	7	10	13	16	18	20	20	IZS	13	8	4	4	4	5	10	10	7	6	7	8	20	9.3	24
21	7	5	3	4	3	3	3	2	2	2	IZS	2	3	3	3	3	4	3	3	3	3	3	3	3	7	3.2	24
22	3	3	4	4	3	6	10	13	14	IZS	7	6	6	7	7	7	8	8	8	8	7	7	6	6	14	6.9	24
23	4	5	4	4	3	3	3	3	IZS	2	2	2	3	5	5	5	4	4	5	5	5	6	9	18	18	4.7	24
24	18	15	10	6	4	4	4	IZS	6	6	7	19	4	4	4	5	9	9	15	8	7	6	6	4	19	7.8	24
25	4	5	4	4	4	4	IZS	4	4	5	5	11	4	4	3	2	2	1	1	1	1	1	1	1	11	3.3	24
26	1	1	1	1	1	IZS	2	3	2	3	3	14	5	4	3	11	3	3	12	7	8	6	4	3	14	4.4	24
27	2	2	2	2	IZS	0	1	1	1	1	1	2	2	3	3	3	4	4	8	2	3	3	4	3	8	2.5	24
28	2	2	1	IZS	1	2	2	1	1	1	1	1	1	1	1	1	2	2	1	2	2	3	3	2	3	1.6	24
29	2	2	IZS	3	2	3	3	3	2	3	3	3	3	3	5	7	5	4	4	5	4	4	5	6	7	3.7	24
30	6	IZS	4	5	5	6	8	12	19	16	14	11	9	16	8	11	11	11	11	12	11	9	5	3	19	9.7	24
31	IZS	4	4	3	4	3	5	5	9	6	6	6	15	6	7	7	8	9	11	12	13	17	19	IZS	19	8.1	24
HOURLY MAX	18	15	10	11	9	10	14	16	19	20	20	19	15	16	11	11	17	11	15	12	13	17	19	18			
HOURLY AVG	4.0	3.8	3.6	3.6	3.1	3.6	4.1	4.5	4.5	4.1	4.4	4.7	4.1	4.0	3.9	4.9	5.5	4.4	5.4	4.8	4.2	4.6	4.6	4.2			


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	678					
MAXIMUM INSTANTANEOUS VALUE:	20	PPB	@ HOUR(S)	9, 10	ON DAY(S)	20
IZS CALIBRATION TIME:	33	HRS	OPERATIONAL TIME:	740	HRS	
MONTHLY CALIBRATION TIME:	9	HRS				
STANDARD DEVIATION	3.57					

01 Hour Averages



— LICA31 HO2MAX PPB

LICA31
 NO2_ / WDR Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 31
 Site Name : LICA31
 Parameter : NO2_
 Units : PPB

Wind Parameter : WDR
 Instrument Height : 10 Meters

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	7.29	2.86	5.15	6.00	5.00	5.43	7.01	2.14	.85	3.86	8.15	13.44	8.58	4.29	9.29	10.58	100.00
< 110	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	7.29	2.86	5.15	6.00	5.00	5.43	7.01	2.14	.85	3.86	8.15	13.44	8.58	4.29	9.29	10.58	

Calm : .00 %

Total # Operational Hours : 699

Distribution By Samples

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	51	20	36	42	35	38	49	15	6	27	57	94	60	30	65	74	699
< 110																	
< 210																	
>= 210																	
Totals	51	20	36	42	35	38	49	15	6	27	57	94	60	30	65	74	



Calm : .00 %

Total # Operational Hours : 699


Class Limits (PPB)

Period : 01/01/12-01/31/12

Level : 10



Calibration Graph for Site: LICA31 Parameter: NO2_ Sequence: NO2 Phase: SPAN



Nitric Oxide

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - ST. LINA

JANUARY 2012

NITRIC OXIDE hourly averages in ppb

MST

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY 24-HOUR			
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
DAY																												
1	0	0	0	0	0	0	0	IZS	1	1	4	5	5	4	3	1	1	0	0	0	0	0	0	0	0	5	1.1	24
2	0	0	0	0	0	0	0	IZS	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0.0	24
3	0	0	0	0	0	0	IZS	1	0	0	0	2	3	3	3	1	0	0	0	0	0	0	0	0	0	3	0.7	24
4	0	0	0	0	0	IZS	1	0	0	0	0	1	1	1	1	1	1	0	0	0	0	0	0	0	0	1	0.3	24
5	0	0	0	IZS	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	0.9	24
6	1	1	IZS	1	1	1	1	1	1	1	1	C	C	C	C	C	C	C	C	1	1	1	1	1	1	1	1.0	24
7	1	IZS	1	1	1	1	1	1	2	3	4	4	3	2	2	1	1	1	1	1	1	1	1	1	1	4	1.6	24
8	IZS	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0.0	24
9	1	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	0	0	0	0	0	0	0	0	IZS	2	0.4	24
10	1	1	1	1	1	1	1	1	1	1	0	0	1	1	1	1	1	0	M	0	0	IZS	1	0	1	0.7	23	
11	0	0	0	0	0	0	0	0	0	0	0	0	1	0	1	0	0	0	0	0	0	IZS	2	1	1	2	0.3	24
12	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	1	0	0	0	1	0.0	24
13	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	P	P	0	IZS	1	0	0	0	0	0	1	0.1	22
14	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	1	0	0	0	0	0	1	0.0	24
15	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	2	1	1	1	1	1	1	1	2	0.3	24
16	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	IZS	1	0	0	0	0	0	0	0	0	1	0.7	24
17	0	0	0	0	0	0	0	0	0	0	1	1	0	C	IZS	1	0	0	0	0	0	0	0	0	0	1	0.1	24
18	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	1	0	0	0	0	0	0	0	0	0	0	1	0.0	24
19	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	2	1	1	1	1	1	1	1	1	1	1	2	0.5	24
20	1	1	1	1	1	1	2	3	4	10	21	IZS	11	4	1	0	0	0	0	0	0	0	0	0	0	21	2.7	24
21	0	0	0	0	0	0	0	0	0	0	IZS	2	1	1	1	1	1	1	0	0	1	0	1	1	1	2	0.5	24
22	1	1	0	1	1	1	1	2	3	IZS	6	5	5	5	5	2	1	0	0	0	0	0	0	0	0	6	1.7	24
23	0	0	0	0	0	0	0	0	IZS	1	1	1	1	2	2	1	0	0	0	0	0	0	0	0	1	2	0.4	24
24	1	1	0	0	0	0	0	0	IZS	1	1	2	3	1	1	1	0	1	0	0	0	0	0	0	0	3	0.6	24
25	0	0	0	0	0	0	IZS	0	0	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	1	0.2	24
26	0	0	0	0	0	0	IZS	1	1	1	1	1	2	2	1	1	1	0	1	1	1	1	1	1	1	2	0.8	24
27	0	0	0	0	IZS	1	1	0	1	1	1	1	1	2	1	1	1	1	1	0	1	1	1	0	2	0.7	24	
28	0	0	0	IZS	2	1	1	0	1	1	1	1	1	0	1	0	0	0	0	0	1	1	1	1	1	2	0.6	24
29	0	1	IZS	1	1	1	1	0	0	1	1	1	1	1	2	1	1	0	1	1	0	1	1	0	2	0.7	24	
30	1	IZS	2	1	1	1	1	1	3	8	9	8	6	6	4	4	2	1	1	1	1	1	1	0	9	2.8	24	
31	IZS	1	1	1	0	1	1	1	1	2	2	3	4	3	2	2	2	1	1	1	1	2	2	IZS	4	1.6	24	
HOURLY MAX	1	1	2	1	2	1	2	3	4	10	21	8	11	6	5	4	2	2	1	1	1	2	2	2				
HOURLY AVG	0.3	0.3	0.3	0.3	0.4	0.4	0.5	0.5	0.7	1.1	2.1	1.6	1.8	1.5	1.3	0.8	0.6	0.3	0.4	0.3	0.4	0.5	0.5	0.4				


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE


MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	320					
MAXIMUM 1-HR AVERAGE:	21	PPB	@ HOUR(S)	10	ON DAY(S)	20
MAXIMUM 24-HR AVERAGE:	2.8	PPB			ON DAY(S)	30
IZS CALIBRATION TIME:	33	HRS	OPERATIONAL TIME:	741	HRS	
MONTHLY CALIBRATION TIME:	9	HRS	AMD OPERATION UPTIME:	99.6	%	
STANDARD DEVIATION:	1.41		MONTHLY AVERAGE:	0.72	PPB	

24 HOUR AVERAGES FOR JANUARY 2012



01 Hour Averages



— LICA31 NO_ PPB

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - ST. LINA

JANUARY 2012

NITRIC OXIDE MAX instantaneous maximum in ppb

MST

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR			
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.		
DAY																													
1	0	0	0	0	0	0	0	IZS	2	3	5	5	6	5	4	2	1	1	1	1	1	1	1	1	1	6	1.7	24	
2	1	1	1	0	0	1	IZS	2	1	0	0	1	1	1	1	0	0	0	1	0	1	1	1	1	1	2	0.7	24	
3	1	0	1	0	0	IZS	2	1	1	1	3	4	4	4	4	2	1	1	1	1	1	1	1	1	1	4	1.6	24	
4	1	1	1	1	IZS	2	23	1	1	1	2	1	2	2	2	1	2	1	1	1	1	1	1	1	1	23	2.2	24	
5	0	0	0	IZS	3	1	2	1	P	1	2	1	1	2	1	10	2	1	1	1	1	1	1	1	1	10	1.5	23	
6	1	1	IZS	3	2	1	1	1	2	2	C	C	C	C	C	C	C	C	2	1	2	1	1	1	3	1.5	24		
7	1	IZS	3	2	2	2	2	2	4	4	6	6	3	3	3	7	17	4	2	2	2	2	2	2	2	17	3.6	24	
8	IZS	2	1	1	1	0	1	0	0	0	1	1	0	0	0	1	0	0	0	0	1	0	0	0	IZS	2	0.5	24	
9	2	1	1	1	1	1	1	1	1	1	3	3	1	2	2	2	12	2	1	0	1	0	0	IZS	3	12	1.9	24	
10	2	2	1	1	1	2	2	1	1	2	1	1	1	2	1	1	2	1	M	1	1	IZS	3	0	3	1.4	23		
11	1	0	0	0	1	0	1	0	1	1	1	3	2	1	15	1	1	1	2	1	2	1	IZS	3	1	1	15	1.7	24
12	1	1	0	0	0	0	0	0	0	1	1	1	2	1	0	2	1	1	0	IZS	2	1	1	1	1	2	0.7	24	
13	1	1	1	1	1	1	1	1	0	0	0	0	0	1	0	P	P	9	IZS	2	1	0	0	0	1	9	1.0	22	
14	0	0	1	0	1	1	0	0	1	1	1	1	1	1	1	1	1	IZS	2	1	1	1	1	0	2	0.8	24		
15	0	0	0	0	0	1	1	0	0	1	0	1	1	0	1	1	IZS	5	2	2	1	1	2	1	2	1	5	0.9	24
16	1	1	1	1	1	2	2	2	2	2	2	3	2	2	1	IZS	3	1	1	0	1	1	1	0	3	1.4	24		
17	1	0	0	0	0	1	1	4	1	1	3	7	1	C	IZS	2	0	0	0	0	0	0	0	0	0	7	1.0	24	
18	0	0	0	0	0	0	0	0	0	2	0	1	1	IZS	4	1	1	0	2	1	1	1	1	0	4	0.7	24		
19	0	0	1	0	0	0	0	0	1	1	1	1	1	IZS	3	2	2	2	2	2	1	2	1	1	1	3	1.0	24	
20	1	2	1	2	2	2	3	3	6	17	24	IZS	15	7	3	1	1	1	1	1	1	1	1	1	1	24	4.2	24	
21	1	0	0	0	1	0	0	0	0	0	IZS	4	2	2	2	1	1	1	1	1	1	1	1	1	1	4	0.9	24	
22	1	1	1	1	2	2	2	2	4	IZS	8	7	6	7	6	4	3	1	1	1	1	1	1	1	1	8	2.8	24	
23	0	1	0	0	1	0	0	0	IZS	2	2	2	2	4	3	2	1	1	0	0	1	1	1	1	2	4	1.1	24	
24	2	2	1	1	1	1	1	IZS	15	3	6	24	2	2	2	1	1	1	7	1	1	1	0	0	24	3.3	24		
25	0	1	1	0	1	0	IZS	2	9	2	2	10	1	2	1	0	0	0	0	0	0	0	0	0	10	1.4	24		
26	0	0	0	0	0	IZS	3	2	1	1	2	14	3	2	2	16	1	2	14	2	2	2	1	1	16	3.1	24		
27	1	1	1	1	IZS	3	1	1	1	1	1	1	2	3	2	2	2	9	1	2	1	1	1	1	9	1.8	24		
28	1	1	1	IZS	3	2	1	1	2	1	1	2	1	1	1	1	1	1	1	1	1	1	1	1	1	3	1.2	24	
29	1	1	IZS	2	1	1	1	1	1	1	1	1	1	2	4	2	3	1	1	1	1	1	1	1	1	4	1.3	24	
30	1	IZS	3	2	2	2	2	2	27	12	12	9	7	26	5	5	4	2	2	2	2	2	2	1	1	27	5.8	24	
31	IZS	3	1	1	1	1	1	1	3	3	3	4	14	6	6	2	5	2	2	2	2	2	3	3	IZS	14	3.1	24	
HOURLY MAX	2	3	3	3	3	3	23	4	27	17	24	24	15	26	15	16	17	9	14	2	2	3	3	3					
HOURLY AVG	0.8	0.8	0.8	0.7	1.0	1.0	1.9	1.1	3.0	2.3	3.2	4.1	2.9	3.4	2.7	2.6	2.5	1.6	2.1	1.0	1.2	1.0	1.0	0.9					


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	556					
MAXIMUM INSTANTANEOUS VALUE:	27	PPB	@ HOUR(S)	8	ON DAY(S)	30
IZS CALIBRATION TIME:	33	HRS	OPERATIONAL TIME:	740	HRS	
MONTHLY CALIBRATION TIME:	9	HRS				
STANDARD DEVIATION	2.98					

01 Hour Averages



— LICA31 NOMAX PPB

LICA31
 NO_ / WDR Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 31
 Site Name : LICA31
 Parameter : NO
 Units : PPB

Wind Parameter : WDR
 Instrument Height : 10 Meters

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	7.29	2.86	5.15	6.00	5.00	5.43	7.01	2.14	.85	3.86	8.15	13.44	8.58	4.29	9.29	10.58	100.00
< 110	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	7.29	2.86	5.15	6.00	5.00	5.43	7.01	2.14	.85	3.86	8.15	13.44	8.58	4.29	9.29	10.58	

Calm : .00 %

Total # Operational Hours : 699

Distribution By Samples

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	51	20	36	42	35	38	49	15	6	27	57	94	60	30	65	74	699
< 110																	
< 210																	
>= 210																	
Totals	51	20	36	42	35	38	49	15	6	27	57	94	60	30	65	74	



Calm : .00 %

Total # Operational Hours : 699

Class Limits (PPB)

Period : 01/01/12-01/31/12

Level : 10



Oxides of Nitrogen

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - ST. LINA

JANUARY 2012

OXIDES OF NITROGEN hourly averages in ppb

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR		
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
DAY																												
1	0	0	0	1	1	1	1	IZS	3	6	12	13	13	11	10	8	7	5	5	4	4	4	5	4	13	5.1	24	
2	3	2	2	2	1	1	IZS	2	2	2	3	3	3	3	3	4	4	4	4	4	4	4	6	6	6	6	3.1	24
3	6	5	4	4	3	IZS	4	5	4	4	6	10	12	12	12	8	8	6	5	5	6	7	8	8	12	6.6	24	
4	7	8	9	10	IZS	7	6	5	5	5	6	4	4	5	5	6	6	8	9	9	9	9	7	5	10	6.5	24	
5	4	5	3	IZS	3	3	3	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	5	1.0	24	
6	0	0	IZS	1	0	0	0	0	0	0	C	C	C	C	C	C	C	C	2	2	2	1	1	2	2	0.7	24	
7	2	IZS	2	2	3	8	8	10	11	11	13	10	7	5	5	5	6	8	8	7	6	6	5	13	6.8	24		
8	IZS	4	4	4	4	4	4	3	2	2	1	1	1	0	0	0	0	0	0	0	1	1	1	IZS	4	1.7	24	
9	6	4	5	7	7	7	6	5	4	5	6	6	5	6	6	6	6	6	3	1	1	0	IZS	1	7	4.7	24	
10	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	M	0	0	IZS	1	0	1	0.0	23	
11	0	0	1	0	1	0	1	2	1	2	3	2	2	2	3	4	4	4	5	7	IZS	10	9	9	10	3.1	24	
12	8	5	2	1	1	0	1	1	1	1	1	1	1	1	1	2	3	3	2	IZS	3	3	3	5	8	2.2	24	
13	6	8	9	9	7	5	3	1	1	1	0	0	0	0	P	P	1	IZS	1	0	0	0	0	9	2.5	22		
14	0	1	1	1	1	1	1	2	2	2	2	2	2	2	2	4	6	IZS	7	6	3	1	1	1	7	2.2	24	
15	1	0	1	1	2	2	1	0	0	0	0	0	0	0	0	0	IZS	2	1	1	1	1	1	1	2	0.7	24	
16	1	1	1	1	1	1	1	2	1	2	2	2	2	2	2	IZS	2	1	1	0	0	1	1	1	2	1.3	24	
17	1	1	0	1	1	1	2	2	2	2	2	2	2	C	IZS	3	3	4	4	4	4	4	3	3	4	2.3	24	
18	3	3	4	4	5	5	4	3	3	3	3	3	3	IZS	3	2	2	2	3	2	2	2	2	2	5	3.0	24	
19	2	2	2	2	1	1	1	2	2	2	2	2	IZS	2	2	2	3	3	3	3	3	3	3	4	4	4	2.3	24
20	4	5	5	6	6	6	13	17	20	26	40	IZS	22	11	4	4	3	4	7	9	7	6	7	8	40	10.4	24	
21	6	4	3	3	3	2	2	1	1	IZS	3	3	3	3	3	3	3	3	2	2	2	2	2	2	6	2.6	24	
22	2	2	3	3	3	3	4	8	12	15	IZS	13	11	11	11	11	9	9	8	6	7	7	7	6	5	15	7.5	24
23	4	4	4	3	3	2	2	2	IZS	3	3	3	4	5	6	6	4	4	4	4	4	4	5	7	15	15	4.4	24
24	18	13	7	5	4	4	4	IZS	6	7	6	8	5	5	5	5	9	9	9	8	6	6	5	4	18	6.9	24	
25	3	4	4	3	3	3	IZS	4	4	6	6	6	4	4	2	1	1	0	0	0	0	0	0	0	6	2.5	24	
26	1	1	1	1	0	IZS	2	2	2	2	3	5	5	3	3	2	2	2	4	6	6	5	3	3	6	2.8	24	
27	2	2	1	1	IZS	1	0	0	0	0	1	1	2	3	3	3	3	3	2	2	2	2	3	3	3	1.7	24	
28	2	1	1	IZS	1	2	1	0	0	1	1	0	0	0	0	1	1	1	1	2	2	2	2	2	2	1.0	24	
29	2	2	IZS	3	2	2	2	2	2	2	3	3	3	3	5	5	4	4	4	4	3	4	4	5	5	3.2	24	
30	5	IZS	5	5	5	5	7	10	14	22	20	17	13	12	11	13	12	10	10	12	10	7	4	3	22	10.1	24	
31	IZS	3	3	3	3	3	3	5	6	6	7	8	8	8	7	7	8	8	10	12	13	14	19	IZS	19	7.5	24	
HOURLY MAX	18	13	9	10	7	8	13	17	20	26	40	17	22	12	12	13	12	10	10	12	13	14	19	15				
HOURLY AVG	3.4	3.1	3.0	3.0	2.6	2.8	3.1	3.6	3.8	4.2	5.7	4.3	4.7	4.3	3.9	4.0	4.3	3.8	4.1	4.1	3.7	3.9	4.0	3.7				


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE


MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	596					
MAXIMUM 1-HR AVERAGE:	40	PPB	@ HOUR(S)	10	ON DAY(S)	20
MAXIMUM 24-HR AVERAGE:	10.4	PPB			ON DAY(S)	20
IZS CALIBRATION TIME:	33	HRS	OPERATIONAL TIME:	741	HRS	
MONTHLY CALIBRATION TIME:	9	HRS	AMD OPERATION UPTIME:	99.6	%	
STANDARD DEVIATION:	3.89		MONTHLY AVERAGE:	3.80	PPB	

24 HOUR AVERAGES FOR JANUARY 2012



01 Hour Averages



— LICA31 NOX_ PPB

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - ST. LINA

JANUARY 2012

OXIDES OF NITROGEN MAX instantaneous maximum in ppb

MST

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR		
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
DAY																												
1	1	1	1	1	2	2	2	IZS	4	10	13	13	14	14	12	10	8	7	6	5	5	5	6	5	14	6.4	24	
2	4	3	3	2	2	2	IZS	4	3	3	3	3	3	4	4	4	4	4	4	4	5	5	8	8	8	3.9	24	
3	7	6	5	5	4	IZS	5	6	4	5	8	13	13	14	13	10	9	8	5	6	7	9	9	9	14	7.8	24	
4	8	9	10	12	IZS	9	34	6	6	6	7	5	5	5	6	6	8	8	10	10	10	10	8	6	34	8.9	24	
5	5	6	5	IZS	4	3	3	3	P	0	0	0	0	0	0	14	8	0	0	0	0	0	0	0	14	2.3	23	
6	0	0	IZS	2	1	1	1	1	1	2	C	C	C	C	C	C	C	C	2	2	3	2	2	2	3	1.5	24	
7	2	IZS	3	3	6	10	10	11	13	12	14	13	8	6	6	14	31	12	10	9	8	7	7	6	31	9.6	24	
8	IZS	5	4	5	5	4	5	4	3	3	3	2	1	1	1	1	1	1	1	1	2	2	2	3	IZS	5	2.7	24
9	7	6	8	8	8	8	7	6	5	6	9	9	6	7	7	6	21	9	5	2	1	1	IZS	2	21	6.7	24	
10	1	1	1	0	1	1	1	1	1	1	1	0	1	1	1	2	0	M	1	1	IZS	2	1	2	1.0	23		
11	1	1	1	1	1	1	2	3	3	4	4	6	4	3	23	5	5	6	7	8	IZS	11	10	10	23	5.2	24	
12	10	7	4	2	2	1	2	2	2	2	2	4	6	2	1	4	5	4	3	IZS	4	3	4	7	10	3.6	24	
13	7	9	10	10	10	7	5	2	2	1	2	1	1	1	1	P	P	9	IZS	2	1	1	1	1	10	4.0	22	
14	1	1	2	2	3	3	2	2	3	3	2	2	2	3	3	8	8	IZS	8	8	4	3	1	2	8	3.3	24	
15	1	1	2	2	3	3	2	1	0	1	1	2	1	1	1	1	IZS	5	2	2	2	2	2	2	5	1.7	24	
16	2	2	2	2	2	2	2	3	3	3	3	5	3	3	3	IZS	3	3	2	1	1	2	2	2	5	2.4	24	
17	2	1	1	1	1	2	2	18	3	3	5	4	3	C	IZS	7	5	5	6	5	5	5	4	3	18	4.1	24	
18	4	4	5	5	6	6	6	4	4	5	4	4	3	IZS	4	2	2	3	5	3	3	2	3	2	6	3.9	24	
19	2	2	3	2	2	2	2	2	3	2	2	3	IZS	3	3	4	3	5	4	4	3	4	5	4	5	3.0	24	
20	6	5	5	8	7	11	15	18	22	36	43	IZS	28	16	6	5	5	5	11	11	8	6	8	9	43	12.8	24	
21	7	6	4	4	4	3	3	3	2	2	IZS	4	3	4	4	4	4	4	3	3	3	3	3	3	7	3.6	24	
22	3	3	5	4	4	6	10	14	16	IZS	15	13	11	13	13	11	11	9	9	8	8	8	7	6	16	9.0	24	
23	5	5	4	4	4	3	3	3	IZS	4	4	4	5	8	8	7	5	5	5	5	5	7	10	20	20	5.8	24	
24	19	16	11	6	5	5	5	IZS	16	9	13	41	6	6	6	7	11	11	23	8	7	6	6	5	41	10.8	24	
25	4	5	5	4	4	4	4	IZS	6	14	7	7	20	6	5	4	2	2	1	1	2	1	1	1	20	4.7	24	
26	2	1	1	2	1	IZS	4	3	3	3	4	27	6	5	4	25	3	3	21	7	8	6	4	3	27	6.3	24	
27	3	2	2	2	IZS	2	1	0	1	1	2	3	3	5	4	4	5	4	13	3	3	3	4	4	13	3.2	24	
28	2	2	1	IZS	3	2	2	1	1	2	1	1	2	2	1	1	1	1	1	2	3	3	3	2	3	1.7	24	
29	2	2	IZS	4	3	3	3	3	3	3	3	3	3	5	8	8	7	4	5	5	5	5	5	6	8	4.3	24	
30	6	IZS	6	6	6	6	8	13	42	25	25	18	15	32	12	14	13	12	12	13	12	9	5	3	42	13.6	24	
31	IZS	4	4	3	4	3	5	6	10	8	9	9	23	12	12	8	12	10	12	13	15	18	21	IZS	23	10.0	24	
HOURLY MAX	19	16	11	12	10	11	34	18	42	36	43	41	28	32	23	25	31	12	23	13	15	18	21	20				
HOURLY AVG	4.3	4.0	4.1	3.9	3.7	4.0	5.2	5.1	6.7	5.7	7.2	8.0	6.4	6.5	5.9	6.9	7.2	5.4	6.8	5.1	4.8	5.0	5.1	4.6				


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	678
MAXIMUM INSTANTANEOUS VALUE:	43 PPB @ HOUR(S) 10 ON DAY(S) 20
IZS CALIBRATION TIME:	33 HRS
MONTHLY CALIBRATION TIME:	9 HRS
OPERATIONAL TIME:	740 HRS
STANDARD DEVIATION:	5.49

01 Hour Averages



— LICA31 NOXMAX PPB

LICA31
 NOX_ / WDR Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 31
 Site Name : LICA31
 Parameter : NOX_
 Units : PPB

Wind Parameter : WDR
 Instrument Height : 10 Meters

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	7.29	2.86	5.15	6.00	5.00	5.43	7.01	2.14	.85	3.86	8.15	13.44	8.58	4.29	9.29	10.58	100.00
< 110	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	7.29	2.86	5.15	6.00	5.00	5.43	7.01	2.14	.85	3.86	8.15	13.44	8.58	4.29	9.29	10.58	

Calm : .00 %

Total # Operational Hours : 699

Distribution By Samples

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	51	20	36	42	35	38	49	15	6	27	57	94	60	30	65	74	699
< 110																	
< 210																	
>= 210																	
Totals	51	20	36	42	35	38	49	15	6	27	57	94	60	30	65	74	



Calm : .00 %

Total # Operational Hours : 699


Class Limits (PPB)

Period : 01/01/12-01/31/12

Level : 10



Calibration Graph for Site: LICA31 Parameter: NOX_ Sequence: NO2 Phase: SPAN



Particulate Matter 2.5

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - ST. LINA

JANUARY 2012

PARTICULATE MATTER 2.5 (PM2.5) hourly averages in ug/m³

MST

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	DAILY	24-HOUR	
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
DAY																												
1	N	1	N	N	N	1.5	N	0	N	6	8.5	5.5	0	N	6.5	5.1	1.5	1	1	N	0	0	0	0	0	8.5	2.4	16
2	0	0	0	0	N	0.5	N	N	0	0.5	N	N	3	0	0	0	4	N	0	0	5.1	2	3.5	2.5	2.5	5.1	1.2	18
3	N	2.5	0	0.5	2.5	2.5	0	4.5	4	8	4.5	4.1	0	3.5	0	7	1	4	1.5	3	1.5	9.6	2.5	4.5	9.6	3.1	23	
4	4.5	9.1	14.6	13	9.6	8.5	5.1	5.5	3.5	3.6	1.5	4.5	N	N	1.5	0	0	0	3.5	1	N	6	3.5	3.5	14.6	4.9	21	
5	5.5	0	2	0	1.5	0	0	1.5	0	2.6	N	N	0	0	N	N	4	N	0	1.3	0	0	N	5.5	1.1	17		
6	N	N	N	N	0	2.1	0	0	N	0	15.6	16	0	25.3	C	12.3	14.9	31.8	0.3	N	N	0	N	0	31.8	7.9	16	
7	N	N	N	N	N	0	2.3	4.1	7.3	0	1.8	0	5.7	0.3	0.8	0	N	0	0.6	2.1	0	0	1.5	N	7.3	1.6	17	
8	7	N	N	2.5	N	0	6.1	0	1.5	5.5	N	N	1	N	0	0	0	0	0	N	0	N	10	0	10.0	2.1	16	
9	9.6	8	2.5	6.5	5.1	8	4.5	0.5	2.5	2.5	N	5.5	2	3.5	N	N	6.5	N	N	N	14.6	0	18.5	1.5	18.5	5.7	18	
10	0.5	7	0	2.5	8	1	N	N	0	N	N	0	1.5	5	0	40	M	25.5	35.5	0	5	2	6.5	1	40.0	7.4	19	
11	0	N	N	N	N	N	N	1	N	0.5	N	N	2.5	N	0	0	0	M	M	10.9	0	2.5	0	0	10.9	1.5	12	
12	N	0	9	5	N	N	N	N	N	0	N	N	N	N	N	N	N	N	N	N	N	N	N	0	9.0	2.8	5	
13	0.5	N	0.5	0	N	0	N	0	N	N	C	8.5	N	N	16	P	P	5.8	0	1	N	N	N	N	16.0	3.2	11	
14	N	N	0	N	N	N	N	N	0	N	N	N	N	0	N	0	N	0	N	N	N	0.4	2.7	0	2.7	0.4	8	
15	0	3.1	0.1	0	0	0	N	N	N	0	N	N	N	N	3.9	4	N	N	N	N	N	6.3	N	0	6.3	1.6	11	
16	1.3	N	2.5	0	N	3.1	0.6	5.8	2.3	6.1	5.2	N	N	N	N	N	N	0	N	4.4	0	N	N	6.1	2.6	12		
17	N	N	N	N	N	N	N	N	N	N	M	M	C	C	6.2	3.9	N	N	16.9	7.9	3.7	N	5.2	N	16.9	7.3	8	
18	N	2.1	1.5	N	0	N	N	N	N	0	N	0	0	0.5	N	N	12.6	47.1	4	3.1	4.6	3.1	4.6	3.1	47.1	5.8	15	
19	3.6	3.6	5.1	3.6	0.6	3.6	2.6	2.6	4.6	2.6	1.5	4	4.6	C	2.6	3.6	7.1	22.6	8.6	4.6	6.1	3.6	6.6	8.6	22.6	5.1	24	
20	7.6	6.1	6.6	12.6	11.6	9.6	18.6	15.1	19.6	16.6	26.6	25.1	19.6	9.1	4.6	4	4.6	4.6	5.5	8.1	7.6	5.5	9.6	7.1	26.6	11.1	24	
21	4	4.6	3.6	4	4.6	6.1	8.6	6.1	5.1	6.1	5.5	5.1	2.6	5.1	4	3.6	6.6	6.1	9.6	2.1	4	4	4.6	4	9.6	5.0	24	
22	7.6	6.6	7.1	11.1	10.1	14.1	15.6	15.6	18.6	23.6	14.6	17.5	13.1	12.1	10	10.5	13.1	8	4.6	7.1	6.6	12.1	10.1	7.1	23.6	11.5	24	
23	6.1	7.6	7.1	8.1	5.5	4.6	5.1	4.6	6.1	4.6	7.6	3.6	4.6	2.1	6.1	5.5	7.6	3	8.1	7.1	5.5	4.6	7.1	6.6	8.1	5.8	24	
24	9.1	5.5	6.1	4	4.6	5.1	3	2.6	5.1	1.1	2.1	3.6	1.5	4	0	3.1	2.1	3.1	3.6	6.1	0	3.6	8.6	4.6	9.1	3.8	24	
25	6.1	3	4.6	3.6	1.5	3.6	3.6	7.6	8.6	3	6.6	6.1	7.1	5.1	3	3	1.5	0	0	1.5	0.5	1.5	0	3.1	8.6	3.5	24	
26	2.6	1.1	2.6	4.6	0	3	3	0	0	2.6	2.6	2.1	5.1	5.1	1.5	2.1	2.6	0	0	5.1	5.1	3	2.6	4	5.1	2.5	24	
27	1.5	1.1	1.1	3.6	1.5	3.1	1.5	1.5	1.5	1.5	3.6	2.6	4	2.6	2.6	0	0.5	0	0	4.6	2.1	4.6	3	5.5	5.5	2.2	24	
28	3.6	3.1	1.1	3.6	0	2.1	0	2.1	3	1.1	3.5	3.1	2.1	2.1	0.1	4.5	1.1	3	0.5	2.1	1.5	3.1	0.5	3	4.5	2.1	24	
29	2.1	3.6	3.6	3.1	0.2	4	1.1	1.6	4.9	4	0.1	1.5	1.9	5.5	4.4	5.1	2.1	5.9	4.4	4.3	3	9.4	8.2	12.9	12.9	4.0	24	
30	10.2	12	10.5	11.1	9.9	14.1	16.9	14.7	12.9	15.8	12.8	14.4	11.1	12.2	11.4	10.2	10.5	6.8	8.4	9.6	9.6	7.6	6.1	1.7	16.9	10.9	24	
31	3.1	3.2	3.8	2.1	4.9	1.2	2.4	5.2	8.7	9.4	7.3	6.6	5.7	7.6	4.2	5.1	3	4.6	7.3	9.5	14.8	12.8	16	13.6	16.0	6.8	24	
HOURLY MAX	10	12	15	13	12	14	19	16	20	24	27	25	20	25	16	40	15	47	36	11	15	13	19	14				
HOURLY AVG	4.2	4.1	3.8	4.4	3.9	3.9	4.8	4.3	5.2	4.7	6.9	6.3	4.1	5.3	3.7	5.3	4.7	7.8	5.0	4.4	4.3	4.0	5.4	3.8				

STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE


OBJECTIVE LIMIT:

ALBERTA ENVIRONMENT:


1-HR	-	ug/m3	24-HR	30	ug/m3
------	---	-------	-------	----	-------

MONTHLY SUMMARY

NUMBER OF 1-HR EXCEEDENCES:	-			
NUMBER OF 24-HR EXCEEDENCES:	0	PROPOSED CANADA WIDE GUIDELINE		
NUMBER OF NON-ZERO READINGS:	460			
MAXIMUM 1-HR AVERAGE:	47.1	UG/M ³	@ HOUR(S)	17 ON DAY(S)
MAXIMUM 24-HR AVERAGE:	11.5	UG/M ³		ON DAY(S)
IZS CALIBRATION TIME:	0	HRS	OPERATIONAL TIME:	575 HRS
MONTHLY CALIBRATION TIME:	5	HRS	AMD OPERATION UPTIME:	77.3 %
STANDARD DEVIATION:	5.45		MONTHLY AVERAGE:	4.73 UG/M ³



01 Hour Averages



LICA31
 PM2 / WDR Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 31
 Site Name : LICA31
 Parameter : PM2
 Units : UG/M3

Wind Parameter : WDR
 Instrument Height : 10 Meters

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 30.0	6.66	3.50	6.31	7.36	5.26	4.03	6.14	2.10	.70	3.15	7.36	12.98	7.19	4.91	9.47	12.10	99.29
< 60.0	.17	.17	.00	.00	.00	.00	.17	.00	.00	.00	.00	.17	.00	.00	.00	.00	.70
< 80.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 120.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 240.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 240.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	6.84	3.68	6.31	7.36	5.26	4.03	6.31	2.10	.70	3.15	7.36	13.15	7.19	4.91	9.47	12.10	

Calm : .00 %



Total # Operational Hours : 570

Distribution By Samples

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 30.0	38	20	36	42	30	23	35	12	4	18	42	74	41	28	54	69	566
< 60.0	1	1					1					1					4
< 80.0																	
< 120.0																	
< 240.0																	
>= 240.0																	
Totals	39	21	36	42	30	23	36	12	4	18	42	75	41	28	54	69	

Calm : .00 %

Total # Operational Hours : 570



Temperature

01 Hour Averages



— LICA31 TPX DGC

Barometric Pressure

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - ST. LINA

JANUARY 2012


BAROMETRIC PRESSURE hourly averages (millibar)

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	DAILY	24-HOUR	
HOUR START	HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
DAY																													
1		937	938	939	939	939	939	939	940	940	941	942	942	942	942	943	943	942	942	941	940	940	938	937	943	940.3	24		
2		935	934	933	931	929	928	927	925	924	922	921	921	920	918	918	917	916	915	915	915	915	915	915	916	935	921.9	24	
3		916	918	918	919	920	921	922	922	923	924	925	925	926	925	925	925	924	924	923	924	924	924	923	926	926	922.7	24	
4		922	922	922	923	922	922	922	921	920	920	920	918	917	917	916	917	917	917	917	916	916	916	915	914	923	918.7	24	
5		913	913	912	912	912	912	911	912	913	913	914	915	915	915	916	916	917	917	917	918	919	919	919	920	920	915.0	24	
6		920	920	921	921	921	922	923	923	923	924	925	925	925	925	926	926	926	926	926	926	927	927	926	926	927	924.2	24	
7		926	926	926	926	926	926	926	926	926	926	926	926	926	926	926	926	925	924	923	923	922	921	920	926	925.0	24		
8		920	919	918	918	918	918	919	919	919	919	919	920	920	920	921	922	922	922	922	922	922	922	922	922	922	920.2	24	
9		922	922	922	922	922	921	921	920	919	918	917	916	916	916	916	917	917	917	917	918	918	919	919	919	920	918.9	24	
10		919	919	920	920	921	922	923	924	925	927	928	929	930	931	932	933	935	936	937	938	938	939	939	939	939	929.3	24	
11		939	939	939	939	939	939	938	938	937	937	936	935	934	934	933	932	931	931	931	930	930	929	929	929	939	934.5	24	
12		929	929	930	930	930	930	930	929	929	929	929	928	928	928	928	927	926	926	925	924	923	922	921	930	927.2	24		
13		920	920	920	920	920	919	920	919	920	920	920	921	921	922	923	P	P	924	925	925	925	925	925	925	924	925	921.7	22
14		924	924	924	923	922	922	921	921	921	921	921	920	920	920	919	919	919	919	919	919	920	920	921	921	924	920.8	24	
15		922	923	923	924	925	926	926	927	928	929	929	929	930	930	930	930	931	931	931	931	932	932	932	932	932	928.5	24	
16		932	933	933	933	933	933	934	934	934	935	935	935	935	935	935	935	935	936	936	936	936	936	936	936	936	934.6	24	
17		936	936	935	935	935	935	934	934	933	933	932	932	931	930	929	929	928	928	928	927	927	927	926	926	936	931.1	24	
18		926	926	926	926	926	925	925	925	924	924	923	922	921	921	920	920	920	920	920	920	920	920	920	920	926	922.5	24	
19		920	919	919	919	919	919	919	919	919	919	919	919	919	919	919	919	919	919	919	919	920	920	921	921	921	919.3	24	
20		922	922	922	923	923	923	923	923	924	924	924	924	923	923	922	922	921	920	919	918	917	916	915	914	924	921.1	24	
21		912	911	910	909	908	907	906	905	904	904	903	902	902	901	901	902	902	903	903	904	905	906	906	907	912	905.1	24	
22		908	909	909	910	911	912	912	913	913	914	915	915	916	916	916	917	916	916	915	915	914	914	914	913	917	913.5	24	
23		912	911	910	910	909	909	908	908	908	909	909	909	910	910	911	913	914	914	914	915	915	915	916	916	916	911.5	24	
24		917	917	917	917	917	917	917	917	917	917	916	916	915	915	914	913	912	910	909	907	906	905	904	917	913.7	24		
25		902	902	901	901	901	901	902	902	903	905	906	908	910	912	913	915	916	917	918	918	918	919	919	919	919	909.5	24	
26		920	920	920	920	919	919	918	918	918	918	919	919	918	919	919	920	920	920	920	920	921	921	922	923	923	919.7	24	
27		923	923	924	924	925	926	926	927	927	927	927	927	927	926	926	925	925	924	924	924	924	924	924	924	925	927	925.0	24
28		926	927	927	928	928	929	929	930	930	930	931	931	930	930	929	928	927	926	925	924	923	921	920	919	931	927.0	24	
29		918	917	916	914	913	912	910	910	909	909	909	909	909	909	909	909	910	910	910	910	910	909	909	918	910.8	24		
30		908	908	908	908	909	908	909	909	909	910	910	911	911	911	911	912	913	913	914	914	915	915	915	916	916	911.1	24	
31		916	916	916	916	917	917	917	917	917	917	918	918	919	919	919	920	920	920	920	921	921	921	921	921	921	918.5	24	
HOURLY MAX		939	939	939	939	939	939	939	940	940	941	942	942	942	942	943	943	942	942	941	940	940	939	939					
HOURLY AVG		921	921	921	921	921	921	921	921	921	921	922	922	921	921	921	922	922	922	922	921	921	921	921	921				

STATUS FLAG CODES

S	- OUT OF SERVICE	I	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE


24 HOUR AVERAGES FOR JANUARY 2012



MONTHLY SUMMARY

MAXIMUM 1-HR AVERAGE:	943	MB	@ HOUR(S)	VAR	ON DAY(S)	1
MAXIMUM 24-HR AVERAGE:	940.3	MB			ON DAY(S)	1
					VAR-VARIOUS	
CALIBRATION TIME:	0	HRS	OPERATIONAL TIME:	742	HRS	
			AMD OPERATION UPTIME:	99.7	%	
STANDARD DEVIATION:	8.54		MONTHLY AVERAGE:	921	MB	

01 Hour Averages



Relative Humidity

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - ST. LINA

JANUARY 2012


RELATIVE HUMIDITY hourly averages (%)

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR		
HOUR START	HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
DAY																													
1		61	62	62	65	68	68	65	66	65	60	57	50	46	42	41	45	50	41	45	47	48	51	57	60	68	55.1	24	
2		61	60	58	58	59	57	57	59	61	64	65	66	66	67	69	71	73	74	75	76	77	76	69	71	77	66.2	24	
3		72	65	67	68	68	72	75	77	78	73	69	69	68	67	67	69	73	73	71	73	74	71	73	76	78	71.2	24	
4		79	82	84	86	86	83	81	80	78	73	71	68	66	62	66	69	70	71	69	68	67	66	66	67	86	73.3	24	
5		70	71	70	71	72	73	73	78	89	88	86	79	70	61	58	55	55	60	52	50	50	50	52	55	89	66.2	24	
6		58	61	63	65	63	64	68	69	68	66	66	66	57	52	50	51	53	57	60	61	61	60	60	61	65	69	60.8	24
7		66	64	64	68	66	65	67	65	67	64	60	56	53	51	51	55	59	61	62	61	64	67	66	64	68	61.9	24	
8		60	59	60	59	64	67	64	60	60	59	55	51	49	45	42	46	51	53	57	60	63	66	71	74	74	58.1	24	
9		74	71	74	76	77	77	74	71	72	73	71	70	70	70	62	57	60	63	55	50	46	31	30	32	77	62.8	24	
10		39	45	55	65	73	86	86	81	79	69	61	54	51	49	51	56	59	56	57	60	58	53	54	56	86	60.5	24	
11		57	60	63	64	61	62	64	64	67	66	64	56	55	57	56	56	60	62	64	66	66	62	60	60	67	61.3	24	
12		58	58	71	84	85	81	79	77	74	67	65	62	58	51	56	60	63	65	64	69	72	73	73	71	85	68.2	24	
13		68	61	61	64	64	65	62	60	59	59	64	77	65	61	53	P	P	54	55	58	59	62	65	66	77	61.9	22	
14		68	73	73	75	75	79	79	77	76	73	72	71	71	70	73	78	82	83	84	84	84	83	81	79	84	76.8	24	
15		77	76	75	74	73	72	72	71	70	69	67	63	60	58	58	59	61	63	65	65	66	66	67	67	77	67.3	24	
16		67	67	66	65	64	64	64	63	62	60	57	55	53	51	53	55	57	60	61	62	64	64	64	64	67	60.9	24	
17		63	63	63	62	62	62	61	61	60	59	57	56	54	51	52	55	58	61	62	62	62	62	60	60	63	59.5	24	
18		59	60	60	60	60	60	60	60	60	58	56	53	51	50	50	51	54	56	58	61	63	64	65	66	66	58.1	24	
19		67	67	67	67	67	67	67	67	67	65	63	59	58	57	55	56	60	65	67	69	69	69	69	69	69	64.7	24	
20		70	69	69	70	69	69	69	69	69	66	64	62	61	55	53	57	61	63	64	64	64	64	66	67	70	64.8	24	
21		66	63	61	63	65	69	71	72	72	72	72	72	72	72	72	73	74	74	74	74	74	74	74	74	74	70.7	24	
22		74	75	75	75	75	74	74	74	74	73	70	68	66	64	59	62	67	72	74	72	72	71	67	65	75	70.5	24	
23		68	71	72	73	73	73	76	78	78	71	69	62	61	57	55	56	61	68	70	70	67	68	63	64	78	67.7	24	
24		67	66	67	65	66	64	65	64	60	55	51	46	46	49	46	46	52	57	61	61	63	65	67	67	67	59.0	24	
25		68	74	76	77	77	78	74	71	71	68	69	66	67	61	45	44	45	43	37	42	40	40	45	45	78	59.3	24	
26		47	52	55	58	60	65	67	69	70	62	61	58	54	47	48	48	52	62	69	71	71	69	61	56	71	59.7	24	
27		55	56	54	53	54	54	56	57	59	57	54	55	60	65	75	81	82	83	82	82	80	81	81	80	83	66.5	24	
28		81	81	81	82	82	81	80	79	79	78	74	68	66	64	64	67	70	73	72	72	73	74	70	75	82	74.4	24	
29		78	74	71	77	80	81	80	81	82	81	82	80	79	80	82	86	86	84	84	84	84	85	87	87	86	87	81.5	24
30		84	85	82	83	83	83	83	83	84	84	82	80	76	76	75	75	80	79	77	77	76	74	71	71	85	79.3	24	
31		74	74	76	72	77	79	77	76	74	71	68	63	60	58	57	58	58	61	63	64	68	69	71	75	79	68.5	24	
HOURLY MAX		84	85	84	86	86	86	86	83	89	88	86	80	79	80	82	86	86	84	84	84	84	85	87	87	86			
HOURLY AVG		66.3	66.6	67.6	69.2	69.9	70.8	70.6	70.3	70.5	67.8	65.9	63.0	60.8	58.6	57.9	59.9	63.0	64.5	64.9	65.6	66.0	65.5	65.4	66.0				

STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE


24 HOUR AVERAGES FOR JANUARY 2012



MONTHLY SUMMARY

MAXIMUM 1-HR AVERAGE:	89	%	@ HOUR(S)	8	ON DAY(S)	5
MAXIMUM 24-HR AVERAGE:	81.5	%			ON DAY(S)	29
					VAR-VARIOUS	
CALIBRATION TIME:	0	HRS	OPERATIONAL TIME:	742	HRS	
STANDARD DEVIATION:	9.98		AMD OPERATION UPTIME:	99.7	%	
			MONTHLY AVERAGE:	65.70	%	

01 Hour Averages



Precipitation

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - ST. LINA

JANUARY 2012

PRECIPITATION hourly averages (mm)

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	DAILY	
HOURLY MAX	HOURLY END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	TOTAL	RDGS.
DAY																												
1		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
2		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
3		0	0	0	0	0	0	0	0	0	0	0	0	0	0.3	0.2	0.1	0.1	0	0	0	0	0	0	0	0.3	0.7	24
4		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.1	0	0	0	0	0	0.1	0	0	0.1	0.2	24
5		0	0	0	0	0	0	0	1.2	0.1	1.4	0	0	0	0.1	0	0	0	0	0	0	0	0	0	0	1.4	2.8	24
6		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
7		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
8		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
9		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
10		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
11		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
12		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
13		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
14		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
15		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
16		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
17		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
18		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
19		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
20		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
21		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
22		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
23		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
24		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
25		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.2	0.4	0.2	0	0	0	0	0	0	0	0.4	0.8	24
26		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
27		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
28		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24
29		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.1	0.9	0.6	0.1	0.1	0.9	1.8
30		0	0	0	0	0	0	0	0	0	0	0	0	0.2	0.2	0.1	0.1	0	0.1	0	0	0	0	0	0	0.2	0.7	24
31		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	0.0	24


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	MD	-MISSING DATA


MONTHLY SUMMARY

MAXIMUM 1-HR AVERAGE:	1.4	MM	HOUR(S)	9	ON DAY(S)	5
MAXIMUM DAILY TOTAL	2.8	MM			ON DAY(S)	5
MONTHLY TOTAL	7.0	MM				
CALIBRATION TIME:	0	HRS	OPERATIONAL TIME:	744	HRS	
STANDARD DEVIATION:	0.08		AMD OPERATION UPTIME:	100.0	%	
			MONTHLY AVERAGE:	0.01	MM	

DAILY TOTALS FOR JANUARY 2012



01 Hour Averages



Vector Wind Speed

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - ST. LINA

JANUARY 2012

WIND SPEED hourly averages (km/hr)

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR		
HOURLY MAX	HOURLY AVG	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
DAY																													
1		5.2	12.3	12.1	11.7	11.8	12.5	13.4	13.9	12.9	12.5	12.5	9.6	8.2	8	6	10.7	10.8	11.2	7.9	11.1	14.9	8.3	9.6	10.6	14.9	3.4	24	
2		13.3	10.1	11.5	11.6	7.8	8.7	7.4	7.8	6.3	5.3	6.1	6.7	5.6	7.1	10.5	11.1	8.2	7	7.8	8.7	10.4	10.2	10.3	5	13.3	5.1	24	
3		10.7	11.5	11.1	11.5	12.8	11.1	12.1	10.9	9.2	8.8	8.3	5.7	5.4	5.8	4.5	4.3	5.5	8.9	9.6	8.8	11.5	10	6.3	1.2	12.8	5.6	24	
4		8.1	10.4	10.9	11.1	5.9	8.8	8.5	9.2	8.4	8	8.8	4.5	3.5	6.8	7.5	11.8	11.1	11.1	14.4	14.4	12.5	15.3	12	12.4	15.3	6.9	24	
5		10.9	10.9	12.4	12.1	4.4	6.6	6.9	7.4	13.7	22.9	12.5	1.1	2.4	1.9	3.3	4.5	3.3	3.2	5.9	7.5	8.5	10.3	9	4.7	22.9	6.7	24	
6		2.8	4.4	3.7	3.1	2	2	5.2	4.1	3.9	3.6	4.6	3.5	7.5	5.2	3.8	6.6	6.6	5.1	3.7	6.3	6.1	6.9	6	5.6	7.5	3.9	24	
7		6.1	8.8	11.3	13.4	8.9	6.3	6	5.2	5.9	9.2	10.1	6.7	7	11.5	9.7	11.3	12.5	14.7	17	14.9	16.5	17.1	16.5	15.6	17.1	10.8	24	
8		16.5	16.1	14.7	16.5	15	13.4	10.1	6.9	6.1	8.8	11.2	14.1	10	4.5	6.8	2.1	3.7	5.2	5.1	6.2	5.7	7.5	13.5	14.9	16.5	6.5	24	
9		11.7	8.3	14.1	14.2	4.8	9.2	10.9	10.3	6.2	3.4	4.6	3.8	8.3	11.1	14.1	12.5	15.2	14.1	18.8	16.9	17.1	25.3	23.4	17.7	25.3	6.1	24	
10		1.3	0.9	9.1	10.3	11.2	11.2	15.2	17.7	17.7	23.1	23.2	19.5	20	17.1	16.8	18.6	25.2	23.9	17.2	14.7	13.8	14.8	13.3	11.1	25.2	14.8	24	
11		10	4.5	8.5	6.2	7.1	4.6	7.8	3.6	9.5	7.6	6.8	5.7	7.3	6	7	7.9	9	9.8	11.3	13.6	13.4	16.6	17	16.6	17	7.9	24	
12		15.1	13.9	12.4	1.8	4.8	4.3	4.3	5.5	4.4	3.3	4.7	4.6	5.7	7.3	9.3	12.2	11.2	9.4	12.1	8.1	12.6	15.8	14.6	11.3	15.8	4.8	24	
13		11.3	16.3	9.4	9.7	11.2	12.8	14	15.1	13	4.1	0.8	7.2	10.8	12	11.4	P	P	12.9	12.2	12.4	11.7	11.1	10.3	9.9	16.3	8.7	22	
14		8.4	10.2	10.6	9.6	6.6	11	12.9	11.8	14.1	7.9	9.3	9.9	8.7	9.8	8.4	6.9	9.7	6.9	9.9	9.4	8.9	7.5	9.9	6.2	14.1	2.9	24	
15		2.6	3.3	2.3	3.9	5.9	4.7	6.2	7.4	10.2	10.7	9.6	9.2	10.7	8.5	11	9.7	9.7	10	9.7	10.5	11.4	11.5	9.7	9.6	11.5	7.4	24	
16		10.7	8.1	10.6	9.5	8.9	8.9	9.8	9.7	8.4	7.6	5.4	5.6	8.9	7.9	8.5	9.8	11.1	12.1	12.7	7.3	6.9	6.3	10	12.7	12.7	8.5	24	
17		7.4	8.6	9.1	9.6	10.3	8.6	9.2	9.5	9.7	9.9	9.5	10.4	10.9	9.6	7	12.9	12.3	12.3	10.1	10.3	9.1	8.9	10.5	11	12.9	8.9	24	
18		10.8	12.7	12.8	15.5	15.1	13.5	14.8	15.4	16.5	18	18.3	19.7	22.3	23	22.5	20	17.1	15.1	14.1	13.3	11.3	11.7	14.6	13.4	23	15.7	24	
19		13.7	12.2	12	13.3	12.9	13.5	12	12.9	13.5	14.5	14.9	15.6	15	13.9	15	12.6	10.2	10.4	10.9	10.3	10.7	10.8	11.9	11.3	15.6	12.5	24	
20		10.7	12.1	11.1	9.9	12.6	10.4	9.7	9.7	10	8.7	7.9	5.8	12	10.9	10.4	13.2	12.2	13.5	12	11.3	12.9	11.2	11.7	14	14	2.3	24	
21		14.8	16.3	17.3	8.4	4.9	2.7	15.9	20.2	13.4	6.2	5.7	6.8	3.4	5.8	12.1	12.4	11.5	12.6	11	9.6	6.6	10.5	6.9	13.7	20.2	8.8	24	
22		2.7	5.9	3.6	12	13.2	12.9	13	12	12.2	11.4	11.6	11	11	12.2	11.1	10.4	8.6	8.5	6.4	5.6	7.3	7.6	8.1	11.1	13.2	6.8	24	
23		13.6	12.8	8.7	7.8	8	6.4	7.2	9.9	7.4	8.4	6.1	9.2	13.5	13.6	18.2	15.1	8.5	8.4	9.8	9.2	9	12	14.7	12.9	18.2	5.3	24	
24		10.1	10.5	9.6	9.2	9.3	8.9	7.7	7.3	8.3	9.5	9	9.9	9.9	9.3	9.7	6.8	6.8	5.4	5.2	4	4.7	6.6	5.9	6.2	10.5	6.3	24	
25		6.9	9.8	9.4	7.6	2.7	14.2	15.9	13.8	11.9	13.1	9.9	9.3	9.5	14.3	17.2	13.1	15.3	17.5	14.8	11.4	13.7	15.8	13.6	14.8	17.5	8.8	24	
26		14.7	15.9	13.9	11.9	12.7	9.2	10.5	8	10.2	10.6	9.1	7.5	5.4	13.6	16.6	14.6	13.3	12.4	11.3	12.7	9.6	11	16.8	15.9	16.8	10.8	24	
27		12.6	17.5	3.6	4.9	6	5.9	3.6	3.3	4.9	5.2	5.3	10.3	12.7	10.9	9	9.7	8.1	5.9	4.5	8.4	10.2	8.4	6.9	8.7	17.5	3	24	
28		8.5	8.1	8.1	8	8.6	9.4	10.6	10.8	13.5	12.5	3.1	4.8	8.2	5.4	14.9	14.1	9.3	10.7	12.4	12.6	12.3	13.3	13.6	15.2	15.2	6.4	24	
29		15.1	12.2	11.5	11.7	10.9	9.7	9.6	10.5	11.3	8.3	8.2	6.9	11.5	11.5	10.5	11	9.5	9.8	8	11.6	4.7	8.1	6.3	9.8	15.1	4.5	24	
30		9.4	9.6	11	7.5	8.4	7.5	11.4	11.2	11	11.3	11.7	12.6	10.3	9.7	14.4	15.2	13.9	15	12.7	12.2	12.5	14.4	9.5	9.6	15.2	8.2	24	
31		9	9	9.1	8.4	7.4	9.8	9.7	8.5	11.6	11.1	11.9	11.6	12.3	12	12.7	10.9	12.2	14.2	14.2	15.2	13.8	14.2	14.4	11.1	15.2	9.4	24	
HOURLY MAX		16.5	17.5	17.3	16.5	15.1	14.2	15.9	20.2	17.7	23.1	23.2	19.7	22.3	23.0	22.5	20.0	25.2	23.9	18.8	16.9	17.1	25.3	23.4	17.7				
HOURLY AVG		9.8	10.4	10.2	9.7	8.8	9.0	10.0	10.0	10.2	9.9	9.1	8.7	9.6	9.9	11.0	11.1	10.7	10.9	10.7	10.6	10.7	11.6	11.5	11.1				


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE


LAST CALIBRATION: June 17, 2010

MONTHLY SUMMARY

MAXIMUM 1-HR AVERAGE:	25.3	KPH	@ HOUR(S)	21	ON DAY(S)	9
MAXIMUM 24-HR AVERAGE:	15.7	KPH			ON DAY(S)	18
CALMS (≤ 0 KPH)	0.13	%	OPERATIONAL TIME:	742	HRS	
MONTHLY CALIBRATION TIME:	0	HRS	AMD OPERATION UPTIME	99.7	%	
STANDARD DEVIATION	3.95		MONTHLY AVERAGE	10.21	KPH	



01 Hour Averages



— LICA31 WSP KPH

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - ST. LINA

JANUARY 2012

VECTOR WIND SPEED MAX instantaneous maximum in km/hr

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	
HOUR START	HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	
DAY																											
1		23.4	23	15.8	14.5	14.7	16	18.6	19.1	21.7	17.6	15.8	15.8	13.2	12.1	13.8	21.7	21.3	18	19.1	24.1	33.8	29.2	26.5	27.4	33.8	
2		33.3	32.7	31.1	29.8	27.4	30.3	22.1	24.8	22.1	21.9	24.1	19.1	18.6	18.2	21.7	18.6	19.5	19.1	16.2	18.6	17.1	17.3	18.8	18.9	33.3	
3		26.5	23.9	25.2	23.4	24.8	16	16.9	13.6	12.7	11.7	11	11.8	10.1	12.9	18.9	9	9.4	16.2	18.8	17.8	23.2	17.5	11.2	21	26.5	
4		14.2	19.7	23.2	24.5	22.8	13.6	13.8	16.2	16.4	17.1	19.1	17.1	16.6	27.4	28	19.9	14.7	16.3	19.3	21	16.4	21.2	18.9	18.2	28	
5		16.4	14.7	16.2	18.4	22.1	18.2	18.6	0	0	55.2	32.9	23.4	26.5	36.3	35.5	34.6	30.7	43.1	36.6	36.6	36.2	49.2	47.3	21.9	55.2	
6		14.2	13	16.4	9.9	11.8	15.6	26.5	14.2	14.9	14	12.9	25.6	28.3	28.5	19.5	18.8	14.2	12.8	11.4	15.1	13.6	14.7	14.9	10.5	28.5	
7		11	14.1	22.8	22.8	16	17.1	15.8	13.6	11	15.4	15.8	11.8	14.7	18.4	19.5	17.4	19.3	19.3	25.6	22.6	26.7	28.5	27.8	29.1	29.1	
8		29.6	31.6	27.6	36.4	28.7	27.4	26.7	28.7	21.2	34	40.7	43.6	37.4	39.2	36.8	31.8	17.1	16	13.4	14	12.5	15.8	19.7	21.7	43.6	
9		15.9	13.6	20.8	23.7	23.2	16.5	18.6	18.2	27.2	15.8	25.8	18.8	24.7	19.1	22.5	23.2	22.2	23.9	34.6	35	42.9	67	53	59.1	67	
10		36.1	21	34.4	34.8	30	32.2	43.4	49.3	49.9	58.9	63.1	53.4	51.4	55.6	52.5	46	55	66.3	41.2	30.5	30.1	32	29.6	23	66.3	
11		18.7	14.9	14.9	13.2	11	29.8	12.7	19.7	20.4	17.6	19.1	16.2	18.6	16.9	18	16.7	16.2	14.3	14.7	18	19.3	21.9	21.3	21	29.8	
12		18.4	20.6	25.8	25.8	15.8	14.5	9.7	12.7	11.8	9.3	11.8	12.5	14.2	17.6	20.6	16.4	15.8	14	20	14	16.9	24.1	21.2	22.1	25.8	
13		20.2	22.8	17.1	13.8	18.6	21.9	31.3	29.8	46.2	16.9	37.4	35.7	41.4	44.4	43.8	P	P	28.7	25.6	24.8	25.8	18.2	19.5	19.3	46.2	
14		15.6	13.6	13.2	12.3	9.5	21.7	23	21.3	20.9	16.7	20.2	19.5	16.3	18	16.2	14	19.1	18.2	16.9	17.3	20.2	41.8	26.1	43.4	43.4	
15		43.6	38.1	44.9	43.8	44	48	44.7	44.5	35.7	27.8	30.9	39.2	27.4	35.3	28.9	25.9	25.7	22.8	22.6	20	19.8	18.3	19.3	20.4	48	
16		17.8	17.8	23.3	21.1	22.8	22.8	23.7	23.3	22.2	24.4	22.6	22.2	22.6	23.1	22.4	24.8	21.8	18.3	18.2	18.5	15.6	23.1	17.8	17.8	24.8	
17		30.1	19.6	17.6	20.7	19.8	15.6	16.5	20.7	20.7	17.2	17	18.3	18.3	21.7	16.7	17.2	15.4	18.3	19.8	17.8	19.6	21.4	23.3	19.4	30.1	
18		17.6	18.5	16.5	20.5	20.2	18.3	20.2	20.9	22.6	26.6	27.9	33.2	34.7	41	37.5	34.9	25.9	25	25.3	23.5	23.3	22.2	26.1	25	41	
19		18.2	19.6	15.4	17.1	22.9	18	16.5	16.3	18.7	20.9	24.1	30.3	30.3	30.7	32.5	24.8	14.3	17.4	17.8	19.8	20.2	18.9	20.2	20.6	32.5	
20		13.2	18.9	18.1	13.4	21.7	18.9	12.3	11.7	12.1	11	11.4	18.2	20.6	22.2	23.9	24.4	18.2	19.5	18.7	18.5	20.9	23.3	23	27.4	27.4	
21		29.8	30.3	33.4	35.5	21.5	17.4	33.1	39.3	34.9	20.4	24.6	22.6	21.3	32.7	26.5	30.7	27.2	28.1	23.7	21.5	18.9	23	41	31	41	
22		23.3	8.4	20.2	17.6	17.8	18.7	17.6	17.1	18.7	15.4	17.4	20.2	16.3	15.8	15.8	17.8	18.9	19.4	16.5	14.7	17	17.1	21.9	33.1	33.1	
23		28.3	27.8	22.6	22.6	20.4	16.5	17.8	16.7	17.4	18.7	18.7	17.6	21.3	21.7	23.9	26.3	23	14.7	15.8	12.8	16.5	20.4	21.9	23.2	28.3	
24		13.6	15.4	17.1	22.8	14.3	16.5	16.3	15.2	14.7	17.6	17.4	18.9	18.4	19.3	19.3	15.8	16.2	15.4	15.4	17.1	17.8	17.8	17.4	16.3	22.8	
25		18	17.8	20	12.3	16.5	27.9	28.6	23.9	26.5	25.7	16.7	18.7	22.6	40.5	40.8	29.6	40.3	49.1	38.6	22.4	32.2	26.8	28.1	27.6	49.1	
26		24.1	26.8	24.4	17.6	22.8	16.7	18.2	13	15.6	15.6	12.3	9.7	17.1	18.4	21.9	24.1	28.1	21.5	17.6	23.3	17.8	19.1	34.4	29.4	34.4	
27		23.2	33.1	33.6	41	30.1	50.6	22.2	15.4	11.2	11.2	13.6	18.4	20.2	24.3	19.3	25.9	23	14.3	14.3	14.3	17.4	15.2	14.8	23.5	50.6	
28		21.9	22.8	19.7	18.2	16.7	20.5	19.5	20.9	22.6	22.8	21.3	18	29.6	24.8	25.2	21.5	20.2	20.2	22.4	24.1	23	25.5	27.8	29.4	29.6	
29		28.7	30.1	25.2	24.8	26.7	23.3	21.3	18.2	17.6	17.8	15.4	18.9	21.3	21	19.1	18.7	18	16.7	17.8	19.6	21.3	20	11.9	14.5	30.1	
30		13.3	13.8	16.5	12.5	14.3	11.7	19.1	17.3	15.6	16.9	19.5	20	20.6	19.1	22.6	20.4	16.7	18.2	18.9	19.5	15.8	20.4	18.4	16.5	22.6	
31		14.3	16	13	12.7	17.5	14	13	14.1	16.9	16.9	15.6	15.6	18.9	18	19.7	18.4	17.8	19.7	19.7	20.8	18.9	17.8	18.4	15.6	20.8	
PEAK		43.6	38.1	44.9	43.8	44.0	50.6	44.7	49.3	49.9	58.9	63.1	53.4	51.4	55.6	52.5	46.0	55.0	66.3	41.2	36.6	42.9	67.0	53.0	59.1		


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

MONTHLY SUMMARY

MAXIMUM INSTANTANEOUS READING	67	KPH	@ HOUR(S)	21
			ON DAY(S)	9

01 Hour Averages



LICA31
WSP / WDR Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 31
Site Name : LICA31
Parameter : WSP
Units : KPH

Wind Parameter : WDR
Instrument Height : 10 Meters

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 6.0	1.34	.67	1.07	2.02	1.07	1.21	1.61	.53	.40	.67	.53	.80	.80	.67	.67	.53	14.69
< 12.0	3.36	1.88	3.50	2.83	3.36	2.56	2.83	1.21	.26	2.69	6.06	6.60	4.58	1.48	3.77	6.87	53.90
< 20.0	1.48	.80	.80	.94	.67	1.48	2.96	.26	.13	.40	1.48	5.66	2.42	2.42	4.58	2.96	29.51
< 29.0	.67	.00	.00	.13	.00	.00	.00	.00	.00	.00	.00	.53	.26	.00	.13	.00	1.75
< 39.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 39.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	6.87	3.36	5.39	5.92	5.12	5.25	7.41	2.02	.80	3.77	8.08	13.61	8.08	4.58	9.16	10.37	

Calm : .13 %

Total # Operational Hours : 742

Distribution By Samples

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 6.0	10	5	8	15	8	9	12	4	3	5	4	6	6	5	5	4	109
< 12.0	25	14	26	21	25	19	21	9	2	20	45	49	34	11	28	51	400
< 20.0	11	6	6	7	5	11	22	2	1	3	11	42	18	18	34	22	219
< 29.0	5			1								4	2		1		13
< 39.0																	
>= 39.0																	
Totals	51	25	40	44	38	39	55	15	6	28	60	101	60	34	68	77	



Calm : .13 %

Total # Operational Hours : 742

Class Limits (KPH)


Period : 01/01/12-01/31/12

Level : 10



Vector Wind Direction

01 Hour Averages



Standard Deviation Wind Direction

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - ST.LINA

JANUARY 2012

STANDARD DEVIATION WIND DIRECTION (STDWDIR) hourly averages in degrees

MST

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	
DAY																									
1	37	5	5	3	3	3	4	3	5	3	4	5	7	5	8	44	11	6	22	12	16	30	28	26	
2	23	29	24	28	35	40	35	34	42	48	42	38	35	30	22	9	32	31	20	15	12	21	13	39	
3	27	34	13	19	13	8	4	3	4	5	7	11	10	12	11	17	8	11	10	10	10	7	11	45	
4	8	7	10	7	28	9	10	19	21	22	22	47	51	33	32	9	7	5	4	10	4	6	7	6	
5	7	7	6	6	36	16	44	46	44	15	49	85	82	88	82	71	63	54	63	50	41	38	43	53	
6	64	36	29	42	68	67	44	28	36	40	34	49	34	58	64	36	24	23	36	19	19	18	14	14	
7	13	6	15	13	10	22	30	23	15	8	8	15	17	9	17	9	7	7	13	9	26	24	21	29	
8	15	26	18	21	15	13	20	29	33	25	24	20	29	73	61	81	59	43	29	29	23	13	8	6	
9	8	7	10	12	49	21	9	16	33	46	39	53	32	15	31	36	6	6	25	33	32	26	28	43	
10	83	76	41	37	28	28	23	20	24	18	18	21	22	29	24	23	18	21	19	16	18	16	17	17	
11	14	34	10	10	7	20	3	26	14	26	38	40	29	37	30	21	14	7	5	4	3	4	6	6	
12	4	18	14	44	46	24	27	17	20	27	21	26	28	23	13	5	8	11	7	13	5	21	8	38	
13	11	10	7	5	6	7	10	10	28	46	68	52	43	39	37	P	P	14	14	14	14	9	9	11	
14	10	4	5	5	6	32	11	11	10	16	8	11	12	11	10	10	9	14	13	16	20	33	29	44	
15	76	68	77	68	51	67	51	47	32	27	34	33	28	36	27	29	24	21	21	19	15	14	21	19	
16	16	37	15	20	26	24	17	20	29	43	59	56	28	39	32	20	14	8	9	23	16	15	27	7	
17	33	23	18	17	12	6	5	10	11	7	7	7	8	10	33	5	4	19	5	5	10	11	9	4	
18	4	4	4	4	4	4	4	4	4	4	6	7	8	8	8	7	8	6	6	7	5	7	7	6	5
19	4	5	5	3	4	4	4	4	4	5	6	9	11	15	13	8	5	5	4	5	6	3	3	4	
20	3	3	4	3	5	4	4	4	4	5	4	32	8	16	15	11	7	8	12	14	12	18	10	10	
21	10	10	10	47	51	66	21	10	26	45	47	43	67	58	33	11	12	11	10	10	12	8	46	28	
22	12	6	13	6	6	6	6	7	7	7	9	9	8	7	7	8	35	35	40	28	21	24	29	28	
23	18	19	27	28	26	32	27	14	25	33	40	19	9	7	7	34	22	9	7	8	11	28	8	9	
24	7	6	14	14	8	11	18	20	14	11	14	11	14	23	21	24	26	30	36	49	43	29	33	29	
25	26	10	10	9	35	12	35	14	18	12	9	8	19	16	13	16	15	15	14	9	12	9	8	8	
26	6	7	7	6	8	9	7	6	6	5	6	5	29	6	8	34	30	8	7	8	10	8	8	7	
27	7	10	75	62	60	54	63	59	18	21	26	14	12	17	15	14	19	22	40	15	9	11	19	22	
28	25	28	23	23	17	17	15	14	9	10	41	23	21	39	17	8	20	10	11	11	12	11	12	12	
29	13	16	18	19	20	24	22	18	14	18	13	44	19	13	15	10	14	13	15	10	53	29	12	9	
30	6	6	7	8	8	8	26	6	8	7	5	7	14	12	26	24	3	3	7	5	3	18	9	8	
31	5	4	5	7	32	8	6	9	6	6	5	6	5	10	7	10	8	7	5	4	5	3	4	4	


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

LAST CALIBRATION: June 17, 2010

CALIBRATION TIME: 0 HRS OPERATIONAL TIME: 742 HRS

01 Hour Averages



— LICA31 STDWDIR DEG

Calibration Reports

Sulphur Dioxide

SO2 Calibration Report

Station Information

Calibration Date	January 10, 2012	Previous Calibration	December 14, 2011
Company	LAKELAND INDUSTRY & COMMUNITY ASSOCIATION		
Plant / Location	ST. LINA		
Start Time (MST)	15:27	End Time (MST)	18:51
Reason:	Monthly Calibration		
Barometric Pressure	933 mBar	Station Temperature	21 Deg C
Cal Gas	48.3 ppm	Gas Cyl. #	LL103831
DAS Output Voltage	0 - 1 Volts	Cal Gas Expiry date	February 28, 2013
		Chart Rec. Output	NA Volts

Equipment Information

Analyzer Make / Model:	API 100E	S/N :	468	Method:	Fluorescent
Converter Make / Model:	NA	S/N :	NA		
Calibrator Make / Model:	API 700	S/N :	831	Method:	Dilution
DAS Make / Model:	ESC 8832	S/N :	AO717		
Chart Recorder Make / Model:	NA	S/N:	NA		
Flow Meter:	API 700	S/N :	831		

Analyzer Settings

Before Calibration		After Calibration	
Concentration Range	0 - 1000		
Sample Flow / Box Temp	533 ccm, 28.3 Deg C	534 ccm, 28.1 Deg C	
HVPS / Lamp Setting	540, 2339	540, 2338	
PMT / RxCell Temp	7.8 Deg C, 50 Deg C	7.9 Deg C, 50 Deg C	
Converter / IZS Temp	NA Deg C, 40 Deg C	NA Deg C, 40.0 Deg C	
Offset / Slope	78.4, 1.038	78.4, 1.038	

Calibration Data

Dilution Flow Rate	Source Gas Flow Rate	Calculated Concentration	Indicated Conc. (DAS)	Correction Factor
4996	0	0	0	N/A
4919	No Zero Adj. 77.6	750	747	1.0042
	No Span Adj.			
4954	41.4	400	401	0.9982
4981	17.6	170	170	1.0000
4997	0	0	0	N/A
Sum of Least Squares				1.0028
New Correction Factor				1.0042

	Before Calibration	After Calibration
Auto Zero	1.6	0.4
Auto Span	278.0	267.0
Sample Lines Connected		YES

Percent Change

Previous Month's Calibration Correction Factor:	1.0015
Current Correction Factor Before Span Adjust:	1.0042
Percent Change:	-0.3%


Notes: **N/A : Not applicable**

Calibration Performed by: Ting Xu

SO2 Calibration Curve


Calibration Date	January 10, 2012
Company	LAKELAND INDUSTRY & COMMUNITY ASSOCIATION
Plant / Location	ST. LINA
Start Time (MST)	15:27
End Time (MST)	18:51

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient Slope Intercept	(≥ 0.995) (0.85 to 1.15) (± 3% F.S.)
0	0	n/a		0.999988
170	170	1.0004		0.996033
400	401	0.9982		0.688936
750	747	1.0042		



Notes:

01 Minute Averages



Hydrogen Sulphide

H2S Calibration Report

Station Information

Calibration Date	January 6, 2012	Previous Calibration	December 13, 2011
Company	LAKELAND INDUSTRY & COMMUNITY ASSOCIATION		
Plant / Location	ST.LINA		
Start Time (MST)	10:07	End Time (MST)	13:40
Reason:	Monthly Calibration		
Barometric Pressure	924 mmHg	Station Temperature	20 Deg C
Cal Gas	10.2 ppm	Gas Cyl. #	bim000804
DAS Output Voltage	0 - 1 Volts	Cal Gas Expiry date	February 2, 2012
		Chart Rec. Output	NA Volts

Equipment Information

Analyzer Make / Model:	API 101E	S/N :	510	Method:	Fluorescent
Converter Make / Model:	NA	S/N :	NA		
Calibrator Make / Model:	API 700	S/N :	831	Method:	Dilution
DAS Make / Model:	ESC 8832	S/N :	A0717		
Chart Recorder Make / Model:	NA	S/N:	NA		
Flow Meter:	API 700	S/N :	831		

Analyzer Settings

Before Calibration		After Calibration	
Concentration Range	0 - 100	ppb	
Sample Flow / Box Temp	537 ccm	31.3 Deg C	538 ccm
HV/PS / Lamp Setting	518	2447	518
PMT / RxCell Temp	8.4 Deg C	50 Deg C	8.4 Deg C
Converter / IZS Temp	315.1 Deg C	45 Deg C	315.2 Deg C
Offset / Slope	73.4	1.037	74.2
			1.043

Calibration Data

Dilution Flow Rate	Source Gas Flow Rate	Calculated Concentration	Indicated Conc. (DAS)	Correction Factor
4996	0	0	1	NA
4996	0	0	0	1.0000
4959	39.2	80	80	1.0000
	No Span Adj.			
4980	19.6	40	41	0.9753
4986	11.2	23	24	0.9525
4996	0	0	0	NA
Sum of Least Squares				0.9922
New Correction Factor				

Before Calibration		After Calibration	
Auto Zero	1.1		0.6
Auto Span	40.9		40.0
Sample Lines Connected			YES

Percent Change

Previous Month's Calibration Correction Factor:	1.0000
Current Correction Factor Before Span Adjust:	1.0000
Percent Change:	0.0%


Notes: **NA : Not Applicable**

Calibration Performed by: Ting Xu

H₂S Calibration Curve


Calibration Date	January 6, 2012
Company	LAKELAND INDUSTRY & COMMUNITY ASSOCIATION
Plant / Location	ST.LINA
Start Time (MST)	10:07
End Time (MST)	13:40

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient Slope	Intercept	(≥ 0.995) (0.85 to 1.15) (± 3% F.S.)
0	0				0.999667
23	24	0.9525			0.997027
40	41	0.9753			0.644961
80	80	1.0000			



Notes:

01 Minute Averages



Total Hydrocarbons

THC Calibration Report

Station Information					
Calibration Date:	January 6, 2012	Previous Calibration	December 14, 2011		
Company:	LAKELAND INDUSTRY & COMMUNITY ASSOCIATION				
Plant / Location:	ST. LINA				
Start Time (MST)	13:03	End Time (MST)	17:23		
Reason:	Monthly Calibration				
Barometric Pressure:	924	mBar	Station Temperature:	20	Deg C
Calibrator:	API 700		S/N:	831	
Cal Gas Concentration:	CH4 980 PPM	C3H8 304 PPM			
	TOTAL CH4 1816.0 PPM	Gas Cyl. # LL84144	Cal Gas Expiry Date:	December 3, 2013	
DAS make & Model:	ESC 8832	S/N :	AO 717		
Chart Recorder:	NA	S/N:	NA		
Output Voltage Range:	0 - 10	VDC	Chart Speed:	NA mm/hr	

Analyzer Information			
Make / Model	TECO 51C	S/N :	77021-384
Method	Flame Ionization		

Analyzer Settings				
	Before Calibration		After Calibration	
Concentration Range	0 - 50	ppm	0 - 50	ppm
Sample Pressure	6.9	psi	6.9	psi
Hydrogen Pressure	8	psi	8	psi
Air Pressure	21	psi	21	psi

Calibration Data				
Dilution Flow	Source Gas Flow	Calculated Concentration	Indicated Concentration	Correction Factor
3000	0.0	0.0	-1.4	NA
3000	0.0	0.0	0.0	1.0000
3000	70.0	41.4	39.9	1.0378
3000	70.0	41.4	41.7	0.9930
3000	35.0	20.9	20.9	1.0000
3000	20.0	12.0	12.2	0.9858
3000	0.0	0.0	0.0	NA
New Correction Factor:				0.9930

Percent Change	
Previous Calibration Correction Factor:	0.9930
Current Correction Factor Before Span Adjust:	1.0378
Percent Change:	-4.3%

IZS Calibration Data		
	Before Calibration	After Calibration
Auto Zero	-0.3	-0.1
Auto Span	32.5	32.8
Sample Lines Connected	YES	

Cylinder Pressures			
Span	1600 psi	Hydrogen	1900 psi
Zero Air	34 psi		


Notes: **NA : Not Applicable**

Calibration Performed by: Ting Xu

THC Calibration Curve


Calibration Date	January 6, 2012		
Company	LAKELAND INDUSTRY & COMMUNITY ASSOCIATION		
Plant / Location	ST. LINA		
Start Time (MST)	13:03	End Time (MST)	17:23

Calculated Conc. ppm	Indicated Response ppm	Correction Factor	Correlation Coefficient Slope (0.85 to 1.15)	Correlation Coefficient Intercept (±3% F.S.)
0.0	0.0	NA	0.99956	1.005948
12.0	12.2	0.9858		-0.00460
20.9	20.9	1.0020		
41.4	41.7	0.9930		



Notes:

01 Minute Averages



THC Calibration Report

Station Information			
Calibration Date:	January 17, 2012	Previous Calibration	January 6, 2012
Company:	LAKELAND INDUSTRY & COMMUNITY ASSOCIATION		
Plant / Location:	ST. LINA		
Start Time (MST)	14:10	End Time (MST)	17:00
Reason:	Monthly Calibration		
Barometric Pressure:	705.13 mmHg	Station Temperature:	23 Deg C
Calibrator:	API 700	S/N:	831
Cal Gas Concentration:	CH4 980 PPM	C3H8 304 PPM	
	TOTAL CH4 1816.0 PPM	Gas Cyl. # LL84144	Cal Gas Expiry Date: December 3, 2013
DAS make & Model:	ESC 8832	S/N :	AO 717
Chart Recorder:	NA	S/N:	NA
Output Voltage Range:	0 - 10 VDC	Chart Speed:	NA mm/hr

Analyzer Information

Make / Model	TECO 51C	S/N :	77021-384	Method	Flame Ionization
--------------	----------	-------	-----------	--------	------------------

Analyzer Settings

	Before Calibration		After Calibration	
Concentration Range	0 - 50	ppm	0 - 50	ppm
Sample Pressure	6.9	psi	6.9	psi
Hydrogen Pressure	8	psi	10	psi
Air Pressure	21	psi	21	psi

Calibration Data

Dilution Flow	Source Gas Flow	Calculated Concentration	Indicated Concentration	Correction Factor
3000	0.0	0.0	0.0	NA
	No Zero Adj.			
3000	70.0	41.4	41.7	0.9930
	No Span Adj.			
3000	35.0	20.9	20.9	1.0000
3000	20.0	12.0	12.0	1.0000
3000	0.0	0.0	0.0	NA
New Correction Factor:				0.9930

Percent Change

Previous Calibration Correction Factor:	0.9930
Current Correction Factor Before Span Adjust:	0.9930
Percent Change:	0.0%

IZS Calibration Data

	Before Calibration	After Calibration
Auto Zero	-0.1	-0.1
Auto Span	32.8	32.1
Sample Lines Connected		YES

Cylinder Pressures			
Span	1500 psi	Hydrogen	1800 psi
		Zero Air	34 psi


Notes: **NA : Not Applicable**
 Replaced the Sample pump following a post-repair calibration
 Changed H2 pressure from 8 psi to 10psi.

Calibration Performed by: Limin Li / Theo McLaren

THC Calibration Curve


Calibration Date	January 17, 2012		
Company	LAKELAND INDUSTRY & COMMUNITY ASSOCIATION		
Plant / Location	ST. LINA		
Start Time (MST)	14:10	End Time (MST)	17:00

Calculated Conc. ppm	Indicated Response ppm	Correction Factor	Correlation Coefficient Slope (0.85 to 1.15)	Correlation Coefficient Intercept (±3% F.S.)
0.0	0.0	NA	1.007384	-0.08130
12.0	12.0	1.0022		
20.9	20.9	1.0020		
41.4	41.7	0.9930		



Notes:

01 Minute Averages



Nitrogen Dioxide

NOx - NO- NO2 Calibration Report
Station Information

Calibration Date	January 6, 2012	Previous Calibration	December 13, 2011
Company	LICA	Plant/Location	St. Lina
Start Time (MST)	10:07	End Time (MST)	11:15
Reason:	As Found		
Barometric Pressure	924 mmHg	Station Temperature	20 Deg C
Cal Gas Concentration	NOx 49.7 ppm	NO 49.4 ppm	Cal Gas Expiry date February 28, 2013
Cal Gas Cylinder #	LL103831	MFC#	1
DAS Output Voltage	0 - 1 Volts	Chart Rec. Output	NA Volts

Equipment Information

Analyzer Make / Model:	TAPI 200E	S/N :	592	Method:	Chemiluminescent
Calibrator Make / Model:	Envionics 6100	S/N :	4760		
DAS Make / Model:	ESC 8832	S/N :	AO717		
Chart Recorder Make / Model:	NA	S/N :	NA		
Flow Meter:	Envionics 6100	S/N :	4760		

Analyzer Settings

Before Calibration			After Calibration			
Concentration Range	0 - 1000			ppb		
Sample Flow/Conv. Temp	477 ccm	316 Deg C	477 ccm	316 Deg C		
Ozone Flow / Vacuum	72 ccm	4.0 °Hg-A	72 ccm	4 °Hg-A		
HVPS / A ZERO	662 Volts	18.9 MV	662 Volts	18.9 MV		
Rx/ Temp / PMT Temp	50.0 Deg C	6.8 Deg C	50.0 Deg C	6.8 Deg C		
Box Temp / IZS Temp	28.0 Deg C	45.0 Deg C	28 Deg C	45 Deg C		
Offset	0.9 NOx	0.5 NO	0.9 NOx	0.5 NO		
Slope	1.282 NOx	1.264 NO	1.282 NOx	1.264 NO		
NO2 COEF / Conv Efficiency	NA NO2	0.993	NA NO2	0.993		

Dilution Calibration Data

Dilution Air Flow Rate	Source Flow Rate	O3 Set Point	Calculated Concentration			Indicated Concentration			Correction Factor	
			NOx	NO	NO2	NOx	NO	NO2	NOx	NO
4994	0.0	NA	0	0	NA	0	0	1	NA	NA
	No Zero Adj.									
4920	75.7	NA	753	749	NA	715	710	5	1.0533	1.0543
	No Span Adj.									

Gas Phase Titration Calibration Data

Dilution Air Flow Rate	Source Flow Rate	O3 Set Point	Calculated Concentration			Indicated Concentration			NO2 Correction Factor	NO2 Conv Efficiency
			NOx	NO	NO2	NOx	NO	NO2		

Linearity OK?	Yes	No	Sum of Least Squares Correction Factors:	NOx= #VALUE! NOx= 1.0533	NO= #VALUE! NO= 1.0543	NO2= #VALUE! NO2=
Average Converter Efficiency=						

		Before Calibration			After Calibration		
Auto Zero	0.8	NOx	1.1	NO2	-	NOx	-
Auto Span	804	NOx	768	NO2	-	NOx	-
		Sample Lines Connected YES					

Percent Change from Previous Calibration	NOx	-5.2%	NO	-5.2%	NO2	#REF!
--	-----	-------	----	-------	-----	-------


Notes: **NA : Not Applicable**
Following the as found points, the exhausting pump was rebuilt.

Calibration Performed by: Ting Xu

NO2 Calibration Curve

Calibration Date	January 6, 2012
Company	LICA
Plant / Location	St. Lina
Start Time (MST)	10:07
End Time (MST)	11:15

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient Slope	(≥ 0.995) (0.85 to 1.15)	#DIV/0!
0	0	N/A	Intercept	(± 3% F.S.)	#DIV/0!
0	0	#DIV/0!			#DIV/0!
0	0	#DIV/0!			#DIV/0!
0	0	#DIV/0!			#DIV/0!



Notes:

NOx - NO- NO2 Calibration Report
Station Information

Calibration Date	January 6, 2012	Previous Calibration	December 13, 2011
Company	LICA	Plant/Location	St. Lina
Start Time (MST)	11:40	End Time (MST)	17:40
Reason:	As Found		
Barometric Pressure	924 mmHg	Station Temperature	20 Deg C
Cal Gas Concentration	NOx 49.7 ppm	NO 49.4 ppm	Cal Gas Expiry date February 28, 2013
Cal Gas Cylinder #	LL103831	MFCF	1
DAS Output Voltage	0 - 1 Volts	Chart Rec. Output	NA Volts

Equipment Information

Analyzer Make / Model:	TAPI 200E	S/N :	592	Method:	Chemiluminescent
Calibrator Make / Model:	Envionics 6100	S/N :	4760		
DAS Make / Model:	ESC 8832	S/N :	AO717		
Chart Recorder Make / Model:	NA	S/N :	NA		
Flow Meter:	Envionics 6100	S/N :	4760		

Analyzer Settings

Before Calibration		After Calibration	
Concentration Range	0 - 1000	ppb	
Sample Flow/Conv. Temp	474 ccm 316.5 Deg C	475 ccm 316 Deg C	
Ozone Flow / Vacuum	73 ccm 5.7 Hg-A	73 ccm 5 Hg-A	
HVPS / A ZERO	662 Volts 18.9 MV	662 Volts 18.5 MV	
Rx/ Temp / PMT Temp	50.0 Deg C 6.8 Deg C	50.0 Deg C 6.9 Deg C	
Box Temp / IZS Temp	27.3 Deg C 45.0 Deg C	28.1 Deg C 45.3 Deg C	
Offset	0.9 NOx 0.5 NO	0.9 NOx 0.5 NO	
Slope	1.111 NOx 1.096 NO	1.235 NOx 1.222 NO	
NO2 COEF / Conv Efficiency	NA NO2 0.993	NA NO2 0.993	

Dilution Calibration Data

Dilution Air Flow Rate	Source Flow Rate	O3 Set Point	Calculated Concentration			Indicated Concentration			Correction Factor	
			NOx	NO	NO2	NOx	NO	NO2	NOx	NO
4994	0.0	NA	0	0	NA	0	1	0	NA	NA
	No Zero Adj.									
4920	75.7	NA	753	749	NA	755	748	5	0.9975	1.0021
	No Span Adj.									
4960	35.3	NA	351	349	NA	351	349	2	1.0000	1.0000
4977	17.2	NA	171	170	NA	171	170	2	1.0000	1.0000
4994	0.0	NA	0	0	NA	0	1	0	NA	NA

Gas Phase Titration Calibration Data

Dilution Air Flow Rate	Source Flow Rate	O3 Set Point	Calculated Concentration			Indicated Concentration			NO2 Correction Factor	NO2 Conv Efficiency
			NOx	NO	NO2	NOx	NO	NO2		
4920	75.7	NA	753	749	NA	756	750	6	NA	NA
4920	75.7	600	753	NA	534	756	222	534	1.0000	100.00%
	No Span Adj.									
4920	75.7	300	753	NA	271	756	485	271	1.0000	100.00%
4920	75.7	120	753	NA	112	756	644	112	1.0000	100.00%

Linearity	Sum of Least Squares	NOx= 0.998	NO= 1.001	NO2= 1.000
OK?	Correction Factors:	NOx= 0.9975	NO= 1.0021	NO2= 1.0000
	Average Converter Efficiency=			

	Before Calibration			After Calibration		
	Auto Zero	0.8 NOx	1.1 NO2		-0.1 NOx	0.2 NO2
Auto Span	804 NOx	768 NO2		827 NOx	793 NO2	
	Sample Lines Connected YES					
Percent Change from Previous Calibration	NOx	0.1%	NO	-0.2%	NO2	0.2%


Notes: **NA : Not Applicable**
Additional GPT was done for O3 clibration. O3 set point 450, NO=351, NO2=404, NOx=755

Calibration Performed by: Ting Xu

NO2 Calibration Curve

Calibration Date	January 6, 2012	Company	LICA
Plant / Location	St. Lina	Start Time (MST)	11:40
End Time (MST)	17:40		

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient Slope	(≥ 0.995)	1.000000
0	6	N/A	Intercept	(± 3% F.S.)	6.00000
106	112	0.9464			
265	271	0.9779			
528	534	0.9888			




Notes:

NOx Calibration Curve

Calibration Date January 6, 2012
 Company LICA
 Plant / Location St. Lina
 Start Time (MST) 11:40 End Time (MST) 17:40

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient (≥ 0.995)	0.999997
0	0	N/A	Slope (0.85 to 1.15)	1.002684
171	171	1.0010	Intercept (± 3% F.S.)	-0.47690
351	351	1.0006		
753	755	0.9975		




Notes:

NO Calibration Curve


Calibration Date January 6, 2012
 Company LICA
 Plant / Location St. Lina
 Start Time (MST) 11:40 End Time (MST) 17:40

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient (≥ 0.995)	0.999999
0	1	N/A	Slope (0.85 to 1.15)	0.999190
170	170	1.0008	Intercept (± 3% F.S.)	0.3165
349	349	1.0003		
749	748	1.0007		



Notes:

01 Minute Averages



— LICA31 IIOX_ PPB

— LICA31 IIO_ PPB

— LICA31 IIO2_ PPB

Ozone

O₃ Calibration Report

Station Information

Calibration Date	January 10, 2012	Previous Calibration	December 14, 2011
Company	Lakeland Industry & Community Association		
Plant / Location	St. Lina		
Start Time (MST)	15:27	End Time (MST)	18:51
Reason:	Monthly Calibration		
Barometric Pressure	933 mBar	Station Temperature	21 Deg C
DAS Output Voltage	0 - 10 Volts		

Equipment Information

Analyzer Make / Model:	Thermo 49C	S/N :	49C-54926-302	Method:	Fluorescent
Calibrator Make / Model:	Enviroics 6100	S/N :	4760	Method:	GPT
DAS Make / Model:	ESC 8832	S/N :	AO 717		

Analyzer Settings

	Before Calibration		After Calibration					
	0 - 500		ppb					
Concentration Range	NA	ccm	759	ccm	NA	ccm	765	ccm
Cell A Flow / Cell B Flow	702.8 mmHg		711 mmHg					
Pressure	55.3 Deg C		55.2 Deg C					
Bench Temp	80 Deg C		29.5 Deg C		80 Deg C		28.4 Deg C	
O3 Lamp / Box Temp	0.1		0.986		0.1		0.986	
Offset / Slope								

Calibration Data

Dilution Flow Rate	Ozone Set Point	Calculated Concentration	Indicated Conc. (DAS)	Correction Factor
4994	0	0	0	NA
	No Zero Adj			
4994	450	399	399	1.0000
	No Span Adj.			
4994	300	265	270	0.9815
4994	120	106	110	0.9636
4994	0	0	0	N/A
Sum of Least Squares				N/A
New Correction Factor				0.0000

	Before Calibration	After Calibration
Auto Zero	1.3	1.1
Auto Span	362	355
Sample Lines Connected		YES
Percent Change from Previous Calibration		-0.2%


Note: Cell A flow sensor was damaged, will replace it when the part is available.

Calibration Performed by: Ting Xu

O₃ Calibration Curve


Calibration Date	January 10, 2012		
Company	Lakeland Industry & Community Association		
Plant / Location	St. Lina		
Start Time (MST)	15:27	End Time (MST)	18:51

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient Slope (≥ 0.995) (0.85 to 1.15)	0.999776
0	0	n/a	Intercept (± 3% F.S.)	1.000178
106	110	0.9636		
265	270	0.9815		
399	399	1.0000		2.215639



Notes:

01 Minute Averages



O₃ Calibration Report

Station Information

Calibration Date	January 17, 2012	Previous Calibration	January 10, 2012
Company	Lakeland Industry & Community Association		
Plant / Location	St. Lina		
Start Time (MST)	14:10	End Time (MST)	17:30
Reason:	Post-Repair Calibration		
Barometric Pressure	705.13 mmHg	Station Temperature	23 Deg C
DAS Output Voltage	0 - 10 Volts		

Equipment Information

Analyzer Make / Model:	Thermo 49C	S/N :	49C-54926-302	Method:	Fluorescent
Calibrator Make / Model:	Enviroics 6100	S/N :	4760	Method:	GPT
DAS Make / Model:	ESC 8832	S/N :	AO 717		

Analyzer Settings

	Before Calibration				After Calibration			
	0 - 500				ppb			
Concentration Range	NA	ccm	759	ccm	842	ccm	872	ccm
Cell A Flow / Cell B Flow	702.8 mmHg				710.3 mmHg			
Pressure	55.3 Deg C				56.8 Deg C			
Bench Temp	80	Deg C	29.5	Deg C	80	Deg C	31.9	Deg C
O3 Lamp / Box Temp	0.1				0.986			
Offset / Slope	0.1				0.986			

Calibration Data

Dilution Flow Rate	Ozone Set Point	Calculated Concentration	Indicated Conc. (DAS)	Correction Factor
4994	0	0	0	NA
	No Zero Adj			
4994	460	405	409	0.9902
	No Span Adj.			
4994	300	265	268	0.9888
4994	120	106	108	0.9815
4994	0	0	0	N/A
Sum of Least Squares				N/A
New Correction Factor				0.0000

	Before Calibration	After Calibration
Auto Zero	1.1	0.0
Auto Span	355	321
Sample Lines Connected		YES
Percent Change from Previous Calibration		1.0%


Note: Replaced the Flow A/B sensors

Calibration Performed by: Limin Li / theo McLaren

O₃ Calibration Curve


Calibration Date	January 17, 2012		
Company	Lakeland Industry & Community Association		
Plant / Location	St. Lina		
Start Time (MST)	14:10	End Time (MST)	17:30

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient Slope (≥ 0.995) (0.85 to 1.15)	
0	0	n/a	Intercept (± 3% F.S.)	0.999994
106	108	0.9815		1.009279
265	268	0.9888		
405	409	0.9902		0.449806



Notes:

01 Minute Averages



Particulate Matter 2.5

TEOMÒ 1405F Audit

	<u>Station</u>		<u>Audit Transfer Standard</u>
Date:	January 6, 2012	Make/Model:	Streamline FTS
Station Name:	Lica St. Lina (CASA # 31)	Serial Number:	LO 091099, Hi 091001
Location:	St. Lina Station	Cell s/n:	NA
Operator:	LICA	Thermometer s:	Station Temp. Sensor

	<u>Sampler</u>		<u>Set-up and current Sampler readings</u>
Make/Model	Thermo Scientific Series 1405F	F-Main Set Pt (l/min)	3.00
Unit #	NA	F-Aux Set Pt (l/min)	13.67
Unit s/n	1405A208301003	Filter Load (%)	26.3%
Firmware Ver.	1.52	K _o Factor	13125.0
Parameter	PM 2.5 (with FDMS)	Temp (°C)	2.0
		Press (ATM)	0.919

Conversion from mmHg or "Hg to ATM (Atmospheres)

ATM = (mmHg) X (1.316 X 10⁻³) or ATM = ("Hg) X (3.34207 X 10⁻²)

Note: Tolerances are noted as BOLD in Brackets

Audit

Status			
Noise <0.10ug	0.012	Warnings	None
Pump Vacuum <0.4atm	0.36	Pump Gauge (inHg)	19
Temperature/Pressure			
Measured Temp (± 2 °C)	2.3	D °C	-0.3
Measured Press (± 0.01atm)	0.913	DATM	0.006
Flow Audit			
Indicated Main Flow (l/min)	3.00	Main Flow Drift (±10.0%)	0.22%
Measured Main Flow (l/min)	3.01	Flow Adjusted to Measured?	YES
Indicated Bypass Flow (l/min)	13.67	Bypass Flow Drift (±10.0%)	2.46%
Measured Bypass Flow (l/min)	13.75	Flow Adjusted to Measured?	YES
Leak Check		Instrument Setup	
Main (< 0.15 l/min)	NA	Flow Control = Active	
Aux (< 0.6 l/min)	NA	Report Conditions = Actual	
K_o Factor			
Measured	NA		
K _o Difference (± 2.5%)	NA		

Start Time: 14:10 **Finish Time:** 15:48

Sample Inlet Cleaned: Yes **New Filters Installed:** Yes
New Filter Loading %: 20.2%

Comments: _____

Auditor/s: Ting Xu

TEOMÒ 1405F Audit

	<u>Station</u>		<u>Audit Transfer Standard</u>
Date:	<u>January 13, 2012</u>	Make/Model:	<u>Streamline FTS</u>
Station Name:	<u>Lica St. Lina (CASA # 31)</u>	Serial Number:	<u>LO 091099, Hi 091001</u>
Location:	<u>St. Lina Station</u>	Cell s/n:	<u>NA</u>
Operator:	<u>LICA</u>	Thermometer s:	<u>Station Temp. Sensor</u>

	<u>Sampler</u>		<u>Set-up and current Sampler readings</u>
Make/Model	<u>Thermo Scientific Series 1405F</u>	F-Main Set Pt (l/min)	<u>3.00</u>
Unit #	<u>NA</u>	F-Aux Set Pt (l/min)	<u>13.67</u>
Unit s/n	<u>1405A208301003</u>	Filter Load (%)	<u>31.0%</u>
Firmware Ver.	<u>1.52</u>	K _o Factor	<u>13125.0</u>
Parameter	<u>PM 2.5 (with FDMS)</u>	Temp (°C)	<u>-1.3</u>
		Press (ATM)	<u>0.915</u>

Conversion from mmHg or "Hg to ATM (Atmospheres)

ATM = (mmHg) X (1.316 X 10⁻³) or ATM = ("Hg) X (3.34207 X 10⁻²)

Note: Tolerances are noted as BOLD in Brackets

Audit

Status			
Noise <0.10ug	<u>0.005</u>	Warnings	<u>None</u>
Pump Vacuum <0.4atm	<u>0.36</u>	Pump Gauge (inHg)	<u>19</u>
Temperature/Pressure			
Measured Temp (± 2 °C)	<u>-1.5</u>	D °C	<u>0.2</u>
Measured Press (± 0.01atm)	<u>0.908</u>	DATM	<u>0.007</u>
Flow Audit			
Indicated Main Flow (l/min)	<u>3.00</u>	Main Flow Drift (±10.0%)	<u>0.38%</u>
Measured Main Flow (l/min)	<u>3.02</u>	Flow Adjusted to Measured?	<u>YES</u>
Indicated Bypass Flow (l/min)	<u>13.67</u>	Bypass Flow Drift (±10.0%)	<u>3.47%</u>
Measured Bypass Flow (l/min)	<u>13.85</u>	Flow Adjusted to Measured?	<u>YES</u>
Leak Check		Instrument Setup	
Main (< 0.15 l/min)	<u>Base=-0.02 Ref=-0.01</u>	<u>Flow Control = Active</u>	
Aux (< 0.6 l/min)	<u>Base=0.00 Ref=0.00</u>	<u>Report Conditions = Actual</u>	
K_o Factor			
Measured	<u>NA</u>		
K _o Difference (± 2.5%)	<u>NA</u>		

Start Time: 10:45 **Finish Time:** 11:35

Sample Inlet Cleaned: Yes **New Filters Installed:** No
New Filter Loading %: 31.0%

Comments: Performed another Teom audit due to many negative readings.

Auditor/s: Ting Xu

TEOMÒ 1405F Audit

	<u>Station</u>		<u>Audit Transfer Standard</u>
Date:	January 17, 2012	Make/Model:	Streamline FTS
Station Name:	Lica St. Lina (CASA # 31)	Serial Number:	LO 091099, Hi 091001
Location:	St. Lina Station	Cell s/n:	NA
Operator:	LICA	Thermometer s:	Station Temp. Sensor

	<u>Sampler</u>		<u>Set-up and current Sampler readings</u>
Make/Model	Thermo Scientific Series 1405F	F-Main Set Pt (l/min)	3.00
Unit #	NA	F-Aux Set Pt (l/min)	13.67
Unit s/n	1405A208301003	Filter Load (%)	39.7%
Firmware Ver.	1.52	K _o Factor	13125.0
Parameter	PM 2.5 (with FDMS)	Temp (°C)	-31.2
		Press (ATM)	0.928

Conversion from mmHg or "Hg to ATM (Atmospheres)

ATM = (mmHg) X (1.316 X 10⁻³) or ATM = ("Hg) X (3.34207 X 10⁻²)

Note: Tolerances are noted as BOLD in Brackets

Audit

Status			
Noise <0.10ug	0.010	Warnings	None
Pump Vacuum <0.4atm	0.37	Pump Gauge (inHg)	19
Temperature/Pressure			
Measured Temp (± 2 °C)	-30.7	D °C	-0.5
Measured Press (± 0.01atm)	0.925	DATM	0.003
Flow Audit			
Indicated Main Flow (l/min)	3.00	Main Flow Drift (±10.0%)	1.33%
Measured Main Flow (l/min)	3.04	Flow Adjusted to Measured?	YES
Indicated Bypass Flow (l/min)	13.67	Bypass Flow Drift (±10.0%)	3.09%
Measured Bypass Flow (l/min)	14.09	Flow Adjusted to Measured?	YES
Leak Check		Instrument Setup	
Main (< 0.15 l/min)	NA	Flow Control = Active	
Aux (< 0.6 l/min)	NA	Report Conditions = Actual	
K_o Factor			
Measured	NA		
K _o Difference (± 2.5%)	NA		

Start Time: 16:50 **Finish Time:** 18:00

Sample Inlet Cleaned: Yes **New Filters Installed:** No
New Filter Loading %: 31.0%

Comments: Replaced the V-seal O-ring following a Teom audit.

Auditor/s: Limin Li / Theo McLaren

TEOMÒ 1405F Audit

	<u>Station</u>		<u>Audit Transfer Standard</u>
Date:	January 19, 2012	Make/Model:	Streamline FTS
Station Name:	Lica St. Lina (CASA # 31)	Serial Number:	LO 091099, Hi 091001
Location:	St. Lina Station	Cell s/n:	NA
Operator:	LICA	Thermometer s:	Station Temp. Sensor

	<u>Sampler</u>		<u>Set-up and current Sampler readings</u>
Make/Model	Thermo Scientific Series 1405F	F-Main Set Pt (l/min)	3.00
Unit #	NA	F-Aux Set Pt (l/min)	13.67
Unit s/n	1405A207691003	Filter Load (%)	21.4%
Firmware Ver.	1.51	K _o Factor	15634.0
Parameter	PM 2.5 (with FDMS)	Temp (°C)	-17.0
		Press (ATM)	0.919

Conversion from mmHg or "Hg to ATM (Atmospheres)

ATM = (mmHg) X (1.316 X 10⁻³) or ATM = ("Hg) X (3.34207 X 10⁻²)

Note: Tolerances are noted as BOLD in Brackets

Audit

Status			
Noise <0.10ug	0.002	Warnings	None
Pump Vacuum <0.4atm	0.29	Pump Gauge (inHg)	19
Temperature/Pressure			
Measured Temp (± 2 °C)	-16.9	D °C	-0.1
Measured Press (± 0.01atm)	0.918	DATM	0.001
Flow Audit			
Indicated Main Flow (l/min)	3.00	Main Flow Drift (±10.0%)	1.80%
Measured Main Flow (l/min)	3.05	Flow Adjusted to Measured?	YES
Indicated Bypass Flow (l/min)	13.67	Bypass Flow Drift (±10.0%)	4.43%
Measured Bypass Flow (l/min)	13.90	Flow Adjusted to Measured?	YES
Leak Check		Instrument Setup	
Main (< 0.15 l/min)	Base=-0.01 Ref=-0.01	Flow Control = Active	
Aux (< 0.6 l/min)	Base=0.00 Ref= 0.00	Report Conditions = Actual	
K_o Factor			
Measured	NA		
K _o Difference (± 2.5%)	NA		

Start Time: 13:15 **Finish Time:** 14:00

Sample Inlet Cleaned: No **New Filters Installed:** No
New Filter Loading %: 21.4%

Comments: Teom installation. Removed the existing one due to keeping recording negative readings

Auditor/s: Limin Li / Theo McLaren

Lakeland Industry & Community Association

Cold Lake Monitoring Site

Ambient Air Monitoring

Data Report

For

January 2012

Prepared By:



January 12, 2012

Lakeland Industry & Community Association Cold Lake Monitoring Site Ambient Air Monitoring

Table of Contents	Page		Page
Introduction	3	Calibration Reports	111
Calibration Procedure	4	• Sulphur Dioxide	112
Monthly Continuous Summary	5	• Total Reduced Sulphur	115
Monthly Non-Continuous Summary	6	• Total Hydrocarbons	118
Volatile Organics Data Summary	7	• Particulate Matter 2.5	121
Polycyclic Aromatic Hydrocarbons Data Summary	8	• Nitrogen Dioxide	123
General Monthly Summary	9	• Ozone	129
Continuous Monitoring	13	Passive Bubble Maps	132
• Monthly Summaries, Graphs & Wind Roses	14	Passive Field Data	137
○ Air Quality Index	15	• Field Notes	138
○ Sulphur Dioxide	17	Passive Monitoring Laboratory Analysis	140
○ Total Reduced Sulphur	25	Volatile Organics Laboratory Analysis	148
○ Total Hydrocarbons	33	Polycyclic Aromatic Hydrocarbons Laboratory Analysis	208
○ Particulate Matter 2.5	41		
○ Nitrogen Dioxide	46		
○ Nitric Oxide	54		
○ Oxides of Nitrogen	61		
○ Ozone	69		
○ Ambient Temperature	77		
○ Relative Humidity	80		
○ Vector Wind Speed	83		
○ Vector Wind Direction	90		
○ Standard Deviation Wind Direction	93		
Non-Continuous Monitoring	96		
Volatile Organics	101		
Polycyclic Aromatic Hydrocarbons	104		

Introduction

The following Ambient Air Monitoring report was prepared for:

Mr. Mike Bisaga
Lakeland Industry & Community Association
Box 8237
5107W – 50 Street
Bonnyville, Alberta
T9N 2J5

Monitoring Location: Cold Lake
Data Period: January 2012

The monthly ambient data report:

- Prepared by Lily Lin
- Reviewed by Craig Snider

The monthly analytical report for passive monitoring:
Authorized by Levi Manchak

The 6-day analytical report for VOCs and PAHs:
Authorized by Petro Oh

Calibration Procedure

The following calibration procedure applies to all calibrations conducted at the Lakeland Industry & Community Association Air Monitoring Station.

Calibration gas concentrations are generated using a dynamic mass flow controlled calibrator. EPA Protocol one gases are diluted with zero air generated on site. The Mass Flow Controllers in the calibrator are referenced using an NIST traceable flow meter once per month. All listed flows are reported as corrected to Standard Temperature and Pressure (STP).

Generated zero gas is introduced to the analyzer first. Three concentrations of calibration gas are then generated in order to introduce points at approximately 50-80%, 25-40% & 10-20% of the analyzer's full-scale range. An auto zero and span are then performed to validate the daily zero and span values recorded to the next multi-point calibration.

All indicated concentrations are taken from the ESC data logger used to collect the data for monthly reporting.

Conformance of each calibration to Alberta Environment regulations is outlined in the individual calibration reports. The slope and correlation coefficient are derived from the calculated and indicated analyzer responses. The percent change is calculated using the previous calibration correction factor and the current correction factor before adjustment. The calibration conforms to the procedure outlined in the *Air Monitoring Directive, Appendix A-10, Section 1.6*.

MONTHLY CONTINUOUS DATA SUMMARY

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

Continuous Ambient Monitoring – January 2012

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION COLD LAKE SITE						MAXIMUM VALUES							OPERATIONAL TIME (PERCENT)	
						OBJECTIVES					EXCEEDENCES			MONTHLY AVERAGE
PARAMETER	1-HR	24-HR	1-HR	24-HR		READING	DAY	HOUR	WIND SPEED (KPH)	WIND DIRECTION (DEGREES)	READING	DAY		
SO ₂ (PPB)	172	48	0	0	0.22	5	16	2	10.4	345(NNW)	1.2	16	99.9	
TRS (PPB)	-	-	-	-	0.00	0	ALL	ALL	VAR	VAR	0.0	ALL	99.9	
NO ₂ (PPB)	159	-	0	-	7.02	37	20	19	0.9	65(ENE)	14.2	3	99.9	
NO (PPB)	-	-	-	-	2.25	100	9	9	1.7	74(ENE)	16.6	4	99.9	
NO _x (PPB)	-	-	-	-	9.29	134	9	9	1.7	74(ENE)	29.4	4	99.9	
O ₃ (PPB)	82	-	0	-	22.93	39	9	22	16.3	269(W)	33.7	27	99.9	
THC (PPM)	-	-	-	-	2.27	3.8	5	0, 1	0.8, 1	150(SSE), 76(ENE)	3.0	4	100.0	
PM 2.5 (UG/M ³)	-	30	-	0	5.36	22.9	4	20	1.3	111(ESE)	11.5	4	99.5	
TEMPERATURE (DEG C)	-	-	-	-	-9.89	8.7	8	14	13.3	263(W)	3.1	8	100.0	
RELATIVE HUMIDITY (%)	-	-	-	-	71.11	96	5	20	17.7	270(W)	87.5	30	100.0	
VECTOR WS (KPH)	-	-	-	-	6.14	21.6	10	10	-	317(NW)	15.5	10	100.0	
VECTOR WD (DEGREES)	-	-	-	-	251(WSW)	-	-	-	-	-	-	-	100.0	

VAR-VARIOUS NA: NOT AVAILABLE

Monthly Non-Continuous Data Summary

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

Passive Ambient Monitoring Network – January 2012

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION PASSIVE NETWORK			
NETWORK MAXIMUM			NETWORK AVERAGE
PARAMETER	STATION	READING (PPB)	READING (PPB)
SO ₂	#27	1.3	0.57
H ₂ S	#26	0.17	0.11
NO ₂	#28	7.0	2.8
O ₃	#4	33.5	26.7

Volatile Organics Data Summary

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION – COLD LAKE

Xontech Model 910A – January 4, 2012

Maximum reading (ug/m3)	Volatile Organic
<32.0	Hexachlorobutadiene

Xontech Model 910A – January 10, 2012

Maximum reading (ug/m3)	Volatile Organic
<32.0	Hexachlorobutadiene

Xontech Model 910A – January 16, 2012

Maximum reading (ug/m3)	Volatile Organic
<32.0	Hexachlorobutadiene

Xontech Model 910A – January 22, 2012

Maximum reading (ug/m3)	Volatile Organic
<32.0	Hexachlorobutadiene

Xontech Model 910A – January 28, 2012

Maximum reading (ug/m3)	Volatile Organic
<32.0	Hexachlorobutadiene

Polycyclic Aromatic Hydrocarbons (PAHs) Data Summary

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION – COLD LAKE

PUF cartridge – December 29, 2011

Maximum reading (ng/m3)	Semi-Volatile Organic
<6.055	3-Methylcholanthrene

PUF cartridge – January 4, 2012

Maximum reading (ng/m3)	Semi-Volatile Organic
23.036	2-Methylnaphthalene

PUF cartridge – January 10, 2012

Maximum reading (ng/m3)	Semi-Volatile Organic
<6.055	3-Methylcholanthrene

PUF cartridge – January 16, 2012

Maximum reading (ng/m3)	Semi-Volatile Organic
8.264	Naphthalene

PUF cartridge – January 22, 2012

Maximum reading (ng/m3)	Semi-Volatile Organic
9.263	Naphthalene

PUF cartridge – January 28, 2012

Maximum reading (ng/m3)	Semi-Volatile Organic
<6.055	3-Methylcholanthrene

General Monthly Summary - Cold Lake

Equipment Operation

The following summary outlines the analyzer performance. Any non-conformances, problems or maintenance performed are detailed at the end of each section.

AQM STATION – LICA – COLD LAKE

Sulphur Dioxide (PPB)

- Analyzer make / model – Thermo 43i, S/N: 806528242

No operational issues observed during the month. The inlet filter was changed before the monthly calibration was started. Data was corrected using daily zero information.

Total Reduced Sulphur (PPB)

- Analyzer make / model –TEI 450i, S/N: 812728560
- Converter - CD NOVA CDN 101, S/N: 250

No operational issues observed during the month. The inlet filter was changed before the monthly calibration was started. Data was corrected using daily zero information.

Ozone (PPB)

- Analyzer make / model –Thermo 49i, S/N: 700419951

No operational issue observed during the month. The inlet filter was changed before the monthly calibration was started. Data was corrected using daily zero information.

General Monthly Summary - Cold Lake

AQM STATION – LICA – COLD LAKE

Total Hydrocarbon (PPM)

- Analyzer make / model -TECO 51C-LT, S/N: 427408718

No operational issue observed during the month. The inlet filter was changed before the monthly calibration was started on January 5th. Data was corrected using daily zero information.

Nitrogen Dioxide (PPB)

- Analyzer make / model - TECO 42C, S/N: 427408716

No operational issue observed during the month. The inlet filter was changed before the monthly calibration was started on January 4th. The external zero/span oven flow rate was increased to lower the span value after the monthly calibration was completed. The analyzer spanned high on January 13th due to flow rate instability. The zero/span oven flow rate was adjusted following the as found points on January 18th. Data was corrected using daily zero information.

Particulate Matter 2.5 (UG/M3)

- Analyzer make / model –TEOM1405F, S/N: 1405A201620804

No operational issue was observed this month. A routine Teom audit and a leak check were performed on January 4th. Both the Teom filter and the FDMS filter were changed on January 4th. Data was corrected using Alberta air quality guideline. If the data was between 0 to –3, the data was corrected to 0. If the data was below –3, the data was invalidated. Four hours of data were invalidated as the data were below –3 ug/m3.

General Monthly Summary - Cold Lake

AQM STATION – LICA – COLD LAKE

Vector Wind Speed (KPH) & Vector Wind Direction (DEG)

- System make / model –Met One 50.5H

The wind system is reported as vector wind speed and vector wind direction.

No operational issue was observed during the month.

Relative Humidity (PERCENT)

- System make / model - Rotronic Hygroclip-S3

No operational issue was observed during the month.

Ambient Temperature (DEGC)

- System make / model - Rotronic Hygroclip-S3

No operational issues observed during the month.

Trailer Temperature (DEGC)

- System make / model - R&R 61

No operational issues observed during the month.

Datalogger

- System make / model - ESC 8832, S/N: 263

- Software make / version - ESC v 5.51a

The ESC 8832 is connected to a modem with DSL for continuous connection with the base computer.

Trailer

No issue was observed during this month.

The manifold was cleaned on January 5th.

General Monthly Summary - Cold Lake

AQM STATION – LICA – COLD LAKE

Air Quality Index (AQI)

The AQI data was adjusted to reflect regular monthly and daily calibrations, maintenance, and downtime. All AQI values were within the Good range. The highest hourly concentration of ozone was 39 ppb and an AQI value of 20 on January 9th, hour of 22. The highest hourly concentration of PM2.5 was 22.9 ug/m3 and an AQI value of 19 on January 4th, hour of 20.

Passive Network

The 10% duplicate sampling program was run this month.
The H2S sample at station #17 is missing.

Volatile Organics (VOCs)

The volatile organics were sampled from January 4th to January 28th. The sampler was programmed to run for 24 hours, and, every 6 days per sample cycle. The values for the VOCs in this report were reported as ug/m3 in 3 significant figures.

Polycyclic Aromatic Hydrocarbons (PAHs)

The PAHs scheduled to be sampled on January 4th to January 28th. The sampler was programmed to run for 24 hours, and, every 6 days per sample cycle. The values for the PAHs in this report were reported as ng/m3. Sample result for December 29th, 2011 is also included in this monthly report.

Continuous Monitoring

Monthly Summaries, Graphs & Wind Roses

Air Quality Index

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

JANUARY 2012

AIR QUALITY INDEX (AQI)

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	
DAY	PEAK	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX	
1		15	13	14	14	13	13	14	13	-	13	13	13	13	13	11	6	5	-	9	10	13	6	7	15		
2		13	14	14	14	15	15	15	15	15	15	15	13	14	13	12	10	-	8	9	7	6	6	6	15		
3		6	5	7	8	7	8	8	7	7	7	8	9	10	14	11	14	-	16	17	10	8	6	8	9	17	
4		8	6	8	9	5	9	11	7	8	10	8	12	12	12	-	-	-	-	-	-	19	18	12	15	19	
5		15	18	8	12	18	15	10	8	6	-	-	-	16	-	-	15	16	17	17	16	16	16	15	18		
6		15	15	16	16	15	14	14	15	13	14	14	14	15	-	16	14	14	15	14	14	14	13	11	10	16	
7		9	11	-	14	14	14	14	13	13	11	11	11	-	12	12	12	9	11	10	8	4	6	8	8	14	
8		9	10	11	11	11	12	13	14	14	14	15	-	17	17	18	18	18	18	18	17	16	15	14	13	18	
9		14	12	12	9	10	11	5	5	8	8	-	10	11	8	9	8	8	8	8	10	11	17	20	19	20	
10		19	18	13	14	18	18	17	17	-	-	18	-	18	18	17	16	15	15	15	15	15	15	16	15	19	
11		15	15	15	13	11	10	8	3	-	8	13	14	15	-	15	15	12	7	7	7	5	4	8	4	15	
12		4	3	4	5	5	10	13	-	13	14	15	16	16	17	16	15	16	16	16	16	16	16	15	14	17	
13		10	9	11	11	10	13	-	13	13	15	15	16	17	18	18	18	18	18	18	17	16	16	15	16	18	
14		16	14	13	11	9	-	12	11	-	-	10	14	15	15	15	14	14	14	14	14	14	14	14	13	16	
15		13	13	14	15	-	14	14	14	13	13	14	15	15	15	15	14	14	14	14	14	14	15	14	14	15	
16		14	14	13	-	14	14	13	13	13	13	14	14	14	15	14	13	13	12	9	9	11	11	11	11	15	
17		10	9	-	8	7	8	8	7	8	10	11	12	13	14	14	14	13	12	11	12	11	11	11	11	14	
18		11	-	11	12	13	13	12	12	12	-	-	15	16	15	15	15	15	14	14	14	14	14	14	14	16	
19		-	13	13	14	14	14	13	12	13	13	14	15	16	16	17	16	16	16	14	13	11	12	13	-	17	
20		NA	03	03	03	03	03	03	03	03	03	03	03	03	03	03	03	03	03	03	03	03	03	03	03	03	03
21		13	12	12	11	11	12	12	10	10	11	11	12	13	14	14	12	8	8	5	11	10	11	-	12	14	
22		12	12	13	13	14	15	15	15	16	16	15	16	16	16	16	15	15	15	16	16	-	16	15	16		
23		15	15	14	12	11	12	12	10	10	11	14	12	12	13	13	12	9	14	13	15	-	15	14	11	15	
24		11	11	12	13	14	14	14	13	7	9	14	15	15	15	14	12	11	6	-	7	10	7	7	15		
25		13	13	14	13	10	7	7	5	7	7	9	9	10	12	11	17	-	18	17	18	18	18	18	18	18	
26		18	17	17	17	17	16	17	16	14	15	16	17	17	18	16	16	-	14	12	14	16	15	14	14	18	
27		15	16	17	18	18	19	19	19	18	18	17	18	17	18	-	17	16	17	17	16	16	15	15	19		
28		14	15	16	17	17	15	15	15	14	13	13	14	-	14	13	8	8	10	10	12	14	14	17			
29		14	15	15	15	15	15	15	16	15	16	16	16	16	-	15	14	14	13	13	9	12	6	8	16		
30		9	6	6	6	7	10	10	12	8	10	9	12	-	11	14	11	9	10	14	8	9	11	11	12	14	
31		11	12	12	12	12	13	11	11	11	10	11	11	13	14	14	8	8	6	7	11	11	11	10	14		
PEAK		19	18	17	18	18	19	19	19	18	18	18	18	18	18	18	18	18	18	18	17	19	18	20	19		

STATUS FLAG CODES

NA - NOT APPLICABLE

V - VARIOUS

AQI CLASS	OZONE (O ₃)					PARTICULATE MATTER 2.5 (PM _{2.5})					NITROGEN DIOXIDE (NO ₂)					SULPHUR DIOXIDE (SO ₂)					FREQUENCY	
	HRS	%	MAX AQI	HR	DAY	HRS	%	MAX AQI	HR	DAY	HRS	%	MAX AQI	HR	DAY	HRS	%	MAX AQI	HR	DAY	HRS	%
VERY POOR (101-255)	0	0.0%	-	-	-	0	0.0%	-	-	-	0	0.0%	-	-	-	0	0.0%	-	-	-	0	0.0%
POOR (51-100)	0	0.0%	-	-	-	0	0.0%	-	-	-	0	0.0%	-	-	-	0	0.0%	-	-	-	0	0.0%
FAIR (26-50)	0	0.0%	-	-	-	0	0.0%	-	-	-	0	0.0%	-	-	-	0	0.0%	-	-	-	0	0.0%
GOOD (1-25)	577	77.6%	20	22	9	115	15.5%	19	20	4	0	0.0%	-	-	-	0	0.0%	-	-	-	692	93.0%
OVERALL	577	77.6%	-	-	-	115	15.5%	-	-	-	0	0.0%	-	-	-	0	0.0%	-	-	-	692	93.0%
UNAVAILABLE	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	52	7.0%

Sulphur Dioxide

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

JANUARY 2012

SULPHUR DIOXIDE (SO₂) hourly averages in ppb

MST

DAY	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	DAILY MAX.	24-HOUR AVG.	RDGS.
1	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	1	0	0	IZS	0	0	0	0	0	0	1	0.2	24
2	1	1	1	0	0	0	0	0	0	0	0	0	0	1	0	0	0	IZS	0	0	0	0	0	0	0	1	0.2	24
3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0.0	24
4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	1	0	0	0	1	0.0	24	
5	1	0	0	0	0	0	0	0	0	C	C	C	C	0	IZS	M	0	0	0	0	0	0	0	0	1	0.1	23	
6	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
7	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	1	1	0	0	0	0	0	0	0	0	0	1	0.1	24
8	0	0	0	0	0	0	1	1	1	1	1	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	1	0.2	24
9	0	0	0	0	0	0	0	0	1	1	IZS	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1	0.1	24
10	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1	1	0.1	24
11	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
12	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
13	0	0	0	1	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0.0	24
14	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
15	0	0	0	0	IZS	0	0	1	1	3	3	2	1	1	1	1	1	1	1	1	1	1	1	1	1	3	0.9	24
16	1	2	5	IZS	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	5	1.2	24
17	0	0	IZS	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	1	0.0	24
18	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
19	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0.0	24
20	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	2	IZS	1	2	0.2	24
21	1	1	1	1	1	0	0	0	0	1	3	1	0	0	0	0	0	0	0	0	0	0	IZS	0	0	3	0.4	24
22	0	0	0	0	0	0	0	0	0	0	1	2	3	3	3	2	1	0	0	1	IZS	1	1	1	3	0.8	24	
23	1	2	1	1	1	1	1	1	0	0	1	1	1	1	1	1	0	0	0	IZS	0	0	0	0	2	0.7	24	
24	0	1	1	0	0	0	0	0	0	0	0	0	0	0	1	1	0	0	IZS	1	1	1	1	1	1	1	0.4	24
25	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0.0	24
26	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0.0	24
27	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	1	0	0	0	0	1	0.0	24	
28	0	0	0	0	0	0	0	1	1	1	2	2	2	1	IZS	1	0	0	0	0	0	0	0	0	0	2	0.5	24
29	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0.0	24
30	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	1	1	1	0	0	0	0	1	0.1	24
31	0	0	0	0	0	0	0	0	0	0	0	0	IZS	1	2	2	1	1	0	0	1	1	1	1	0	2	0.5	24
HOURLY MAX	1	2	5	1	1	1	1	1	1	3	3	2	3	3	3	2	1	1	1	1	1	1	2	1	1			
HOURLY AVG	0.2	0.2	0.3	0.1	0.1	0.1	0.1	0.2	0.2	0.3	0.4	0.4	0.4	0.4	0.4	0.4	0.1	0.1	0.1	0.2	0.2	0.3	0.2	0.2				

STATUS FLAG CODES


S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

OBJECTIVE LIMIT:


ALBERTA ENVIRONMENT:	1-HR	172	PPB	24-HR	48	PPB
-----------------------------	------	-----	-----	-------	----	-----

MONTHLY SUMMARY

NUMBER OF 1-HR EXCEEDENCES:	0
NUMBER OF 24-HR EXCEEDENCES:	0
NUMBER OF NON-ZERO READINGS:	130
MAXIMUM 1-HR AVERAGE:	5 PPB @ HOUR(S) 2 ON DAY(S) 16
MAXIMUM 24-HR AVERAGE:	1.2 PPB ON DAY(S) 16
IZS CALIBRATION TIME:	32 HRS
MONTHLY CALIBRATION TIME:	4 HRS
STANDARD DEVIATION:	0.53
OPERATIONAL TIME:	743 HRS
AMD OPERATION UPTIME:	99.9 %
MONTHLY AVERAGE:	0.22 PPB




01 Hour Averages



— LICA SO2_ PPB

01 Hour Averages



— LICA SO2MAX PPB

LICA
 SO2_ / WDR Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 01
 Site Name : LICA
 Parameter : SO2_
 Units : PPB

Wind Parameter : WDR
 Instrument Height : 10 Meters

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 20	.56	1.13	1.55	1.83	4.95	5.94	9.33	4.10	1.83	2.40	23.33	23.47	7.77	3.11	5.23	3.39	100.00
< 60	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 110	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 170	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 340	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 340	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	.56	1.13	1.55	1.83	4.95	5.94	9.33	4.10	1.83	2.40	23.33	23.47	7.77	3.11	5.23	3.39	

Calm : .00 %

Total # Operational Hours : 707



Distribution By Samples

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 20	4	8	11	13	35	42	66	29	13	17	165	166	55	22	37	24	707
< 60																	
< 110																	
< 170																	
< 340																	
>= 340																	
Totals	4	8	11	13	35	42	66	29	13	17	165	166	55	22	37	24	


Calm : .00 %

Total # Operational Hours : 707

Class Limits (PPB)



Calibration Graph for Site: LICA Parameter: SO2_ Sequence: SO2 Phase: SPAN



Total Reduced Sulphur

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

JANUARY 2012


TOTAL REDUCED SULPHUR (TRS) hourly averages in ppb

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	23:00	DAILY	24-HOUR	
DAY	DAY	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0.0	24
2	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0.0	24
3	3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0.0	24
4	4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	C	C	C	C	0	0	0	0	0	0	0	0.0	24
5	5	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	M	0	0	0	0	0	0	0	0	0	0	0	0.0	23
6	6	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
7	7	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
8	8	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
9	9	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
10	10	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
11	11	0	0	0	0	0	0	0	IZS	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
12	12	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
13	13	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
14	14	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
15	15	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
16	16	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
17	17	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
18	18	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
19	19	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0.0	24
20	20	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0.0	24
21	21	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0.0	24	
22	22	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0.0	24	
23	23	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0.0	24	
24	24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0.0	24	
25	25	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0.0	24	
26	26	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0.0	24	
27	27	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0.0	24	
28	28	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
29	29	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
30	30	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
31	31	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
HOURLY MAX		0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
HOURLY AVG		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			

STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE


24 HOUR AVERAGES FOR JANUARY 2012



MONTHLY SUMMARY

NUMBER OF 1-HR EXCEEDENCES:	0
NUMBER OF 24-HR EXCEEDENCES:	0
NUMBER OF NON-ZERO READINGS:	0
MAXIMUM 1-HR AVERAGE:	0 PPB @ HOUR(S) ALL ON DAY(S) ALL
MAXIMUM 24-HR AVERAGE:	0.0 PPB ON DAY(S) ALL
	VAR-VARIOUS
IZS CALIBRATION TIME:	31 HRS
MONTHLY CALIBRATION TIME:	5 HRS
STANDARD DEVIATION:	0.00
OPERATIONAL TIME:	743 HRS
AMD OPERATION UPTIME:	99.9 %
MONTHLY AVERAGE:	0.00 PPB

01 Hour Averages



— LICA TRS PPB

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

JANUARY 2012

TOTAL REDUCED SULPHUR MAX instantaneous maximum in ppb

MST	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY 24-HOUR			
DAY	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	1	0	0	1	0.0	24	
2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0.0	24
3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	1	0	0	0	0	0	0	1	0.0	24	
4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	C	C	C	C	C	C	0	0	0	0	0	0.0	24	
5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	M	0	0	0	0	0	0	0	0	0	0.0	23	
6	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
7	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
8	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
9	0	0	0	0	0	0	0	0	0	1	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0.0	24	
10	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
11	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
12	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
13	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
14	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
15	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
16	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
17	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	1	0.0	24
18	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
19	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
20	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0.0	24
21	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0.0	24
22	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0.0	24
23	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0.0	24
24	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	1	0.0	24
25	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0.0	24
26	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0.0	24
27	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0.0	24
28	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0.0	24
29	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
30	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24
31	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	1	0	0	0	0	0	0	1	0.0	24	
HOURLY MAX	0	0	0	0	0	0	1	0	0	1	0	0	0	0	1	0	0	1	0	0	0	1	0	0	0	0		
HOURLY AVG	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	6					
MAXIMUM INSTANTANEOUS VALUE:	1	PPB	@ HOUR(S)	VAR	ON DAY(S)	VAR
IZS CALIBRATION TIME:	31	HRS	OPERATIONAL TIME:	743	HRS	
MONTHLY CALIBRATION TIME:	6	HRS				
STANDARD DEVIATION:	0.09					

01 Hour Averages



LICA
 TRS_ / WDR Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 01
 Site Name : LICA
 Parameter : TRS_
 Units : PPB

Wind Parameter : WDR
 Instrument Height : 10 Meters

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 3	.56	1.13	1.55	1.83	4.95	5.94	9.33	3.81	1.83	2.40	23.33	23.33	8.20	3.11	5.23	3.39	100.00
< 10	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 50	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 50	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	.56	1.13	1.55	1.83	4.95	5.94	9.33	3.81	1.83	2.40	23.33	23.33	8.20	3.11	5.23	3.39	

Calm : .00 %

Total # Operational Hours : 707



Distribution By Samples

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 3	4	8	11	13	35	42	66	27	13	17	165	165	58	22	37	24	707
< 10																	
< 50																	
>= 50																	
Totals	4	8	11	13	35	42	66	27	13	17	165	165	58	22	37	24	


Calm : .00 %

Total # Operational Hours : 707

Class Limits (PPB)



Calibration Graph for Site: LICA Parameter: TRS_ Sequence: TRS Phase: SPAN



Total Hydrocarbons

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE


JANUARY 2012

TOTAL HYDROCARBONS (THC) hourly averages in ppm

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY 24-HOUR			
DAY	HOURLY MAX	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
1		2.2	2.3	2.2	2.3	2.4	2.7	2.2	2.2	2.2	2.4	2.4	2.3	2.2	2.2	2.3	2.4	2.4	2.5	IZS	2.6	2.8	2.7	2.5	2.5	2.8	2.4	24	
2		2.3	2.3	2.4	2.3	2.2	2.1	2	2	2	2	1.9	2	2	2.1	2.2	2.3	2.3	IZS	2.3	2.3	2.3	2.3	2.3	2.5	2.5	2.2	24	
3		2.9	3.2	3	3	3	2.7	2.5	2.4	2.4	2.3	2.1	2.1	2.2	2.2	2.3	2.4	IZS	2.6	2.7	2.5	2.4	2.5	2.4	2.5	3.2	2.5	24	
4		2.7	2.6	2.8	2.8	3.2	3.1	2.9	2.9	2.9	2.9	2.7	2.5	2.5	2.6	2.6	IZS	2.9	3	3.1	3.1	3.7	3.5	3.6	3.7	3.7	3.0	24	
5		3.8	3.8	3.6	3.4	3.6	3.5	3.4	3.3	2.8	2.4	1.9	1.8	C	C	C	C	2	2	2	2	2	2	2.1	2.2	3.8	2.7	24	
6		2.1	2.2	2.1	2.1	2.2	2.2	2.2	2.2	2.2	2.1	2.1	2.2	2.2	IZS	2	2	2	2.1	2.2	2.2	2.1	2.3	2.1	2.1	2.3	2.1	24	
7		2.2	2.5	2.5	2.3	2.3	2.4	2.4	2.4	2.3	2.2	2.3	2.3	IZS	2.2	2.4	2.3	2.2	2.2	2.2	2.2	2.2	2.3	2.3	2.4	2.5	2.3	24	
8		2.5	2.5	2.4	2.3	2.3	2.2	2	2	2	2	2	IZS	2	2	2	2	2	2	2	2.1	2.1	2.2	2.1	2.1	2.5	2.1	24	
9		2.1	2.1	2.1	2.2	2.2	2.2	2.3	2.4	2.8	3.1	IZS	2.2	2.3	2.5	2.5	2.5	2.3	2.2	2.3	2.2	2.1	2	1.9	1.9	3.1	2.3	24	
10		1.9	2	2	1.9	1.9	1.9	1.9	1.9	1.9	IZS	1.9	2	1.9	2	2	2	2	2	2	2	2	2	2.1	2.1	2.1	2.0	24	
11		2.1	2.1	2.1	2.1	2.2	2.3	2.5	2.6	IZS	2.5	2.1	2.1	2.2	2.3	2.4	2.2	2.2	2.3	2.3	2.6	3.1	3.5	2.9	3.5	2.4	24		
12		2.6	2.7	2.6	2.6	2.7	2.7	2.4	IZS	2.2	2.2	2.2	2.1	2.1	2.1	2.1	2.1	2.3	2.2	2.2	2	2.1	2.2	2.2	2.2	2.7	2.3	24	
13		2.2	2.2	2.3	2.1	2.2	2.1	IZS	2.1	2.1	2.1	2	2	1.9	1.9	1.9	1.9	1.9	1.9	2	2	2	2	2.1	2	2.3	2.0	24	
14		2	2.1	2.2	2.3	2.3	IZS	2.2	2.2	2.3	2.3	2.4	2.1	2	2	2	2	1.9	1.9	1.9	1.9	2	2	2	2	2.4	2.1	24	
15		2	2	2	2	IZS	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2.0	2.0	24
16		2.1	2.1	2.1	IZS	2	2	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.2	2.2	2.3	2.2	2.1	2.1	2.2	2.3	2.1	24	
17		2.2	2.3	IZS	2.5	2.5	2.7	2.7	2.5	2.3	2.3	2.3	2.2	2.2	2.2	2.1	2.2	2.3	2.4	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.7	2.3	24
18		2.2	IZS	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2	2	2	2	2	2	2.1	2.1	2.1	2.1	2.2	2.1	24	
19		IZS	2.1	2.1	2.1	2	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2	2	2	2	2	2.1	2.2	2.1	2.1	2.2	IZS	2.2	2.1	24
20		2.2	2.1	2.2	2.2	2.2	2.2	2.3	2.4	2.5	2.7	2.5	2.3	2.3	2.3	2.3	2.2	2.2	2.2	2.2	2.3	2.5	2.5	2.6	IZS	2.7	2.7	2.3	24
21		2.7	2.6	2.5	2.4	2.3	2.2	2.1	2.1	2	2	2	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	2	IZS	2	2.1	2.7	2.1	24	
22		2.1	2.1	2.1	2.1	2.2	2.6	2.6	2.5	2.5	2.5	2.5	2.5	2.5	2.4	2.5	2.5	2.6	2.6	2.9	3.1	3.2	IZS	2.7	2.7	2.8	3.2	24	
23		2.7	2.5	2.4	2.3	2.2	2.2	2.1	2.1	2.2	2.2	2.1	2.1	2.1	2.2	2.2	2.3	2.4	2.7	2.8	IZS	3.1	3.2	2.9	2.9	3.2	2.4	24	
24		3	2.3	2.2	2.5	2.6	2.6	2.8	2.7	2.8	2.8	2.8	2.6	2.5	2.4	2.4	2.4	2.5	2.5	IZS	2.7	2.6	2.4	2.3	2.2	3.0	2.5	24	
25		2.2	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.2	2.3	2.3	3	3	2.8	2.9	2.6	2.3	2	IZS	2	2.2	2.1	2.1	2.1	3.0	2.3	24	
26		2.1	2.1	2.1	2.1	2.1	2.2	2.2	2.2	2.2	2.3	2.3	2.2	2.2	2.1	2.1	2.1	IZS	2.3	2.4	2.1	2.1	2.1	2.2	2.3	2.4	2.2	24	
27		2.1	2.1	2	2	2.1	1.9	1.9	1.9	2	2.1	2.1	2.1	2	2	2.1	IZS	2	2.1	2	2	2.1	2.1	2.1	2.1	2.1	2.0	24	
28		2.2	2.1	2	2	2	2	2	2	2	2.1	2.1	2.1	2.1	2.1	2.1	IZS	2.1	2.2	2.3	2.2	2.2	2.1	2.1	2.2	2.1	2.3	24	
29		2.1	2.2	2.2	2.1	2.1	2	2	2	2	2	2	1.9	2	IZS	2.1	2.2	2.2	2.2	2.2	2.2	2.3	2.3	2.4	2.4	2.4	2.1	24	
30		2.5	2.4	2.4	2.4	2.5	2.4	2.5	2.6	2.6	2.7	2.8	2.5	IZS	2.3	2.1	2.2	2.4	2.4	2.3	2.3	2.2	2.2	2.2	2.2	2.8	2.4	24	
31		2.2	2.1	2.1	2.1	2.1	2.1	2.1	2.3	2.5	2.6	2.6	IZS	2.3	2.2	2.1	2.2	2.4	2.4	2.4	2.4	2.5	2.5	2.5	2.4	2.4	2.6	2.3	24
HOURLY MAX		3.8	3.8	3.6	3.4	3.6	3.5	3.4	3.3	2.9	3.1	3.0	3.0	2.8	2.9	2.6	2.6	2.9	3.0	3.1	3.2	3.7	3.5	3.6	3.7				
HOURLY AVG		2.3	2.3	2.3	2.3	2.3	2.3	2.3	2.3	2.3	2.3	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.2	2.3	2.3	2.3	2.3	2.3	2.3			

STATUS FLAG CODES


S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE
BB	- BELOW BACKGROUND OF 1.5 PPM		



MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	709					
MAXIMUM 1-HR AVERAGE:	3.8	PPM	@ HOUR(S)	0, 1	ON DAY(S)	5
MAXIMUM 24-HR AVERAGE:	3.0	PPM			ON DAY(S)	4
IZS CALIBRATION TIME:	31	HRS	OPERATIONAL TIME:	744	HRS	
MONTHLY CALIBRATION TIME:	4	HRS	AMD OPERATION UPTIME:	100.0	%	
STANDARD DEVIATION:	0.32		MONTHLY AVERAGE:	2.27	PPM	

01 Hour Averages



— LICA — THC — PPM

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

JANUARY 2012

TOTAL HYDROCARBONS MAX instantaneous maximum in ppr

MST																										DAILY	24-HOUR	
HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00				
DAY																												
1	2.4	2.4	2.3	2.4	2.6	3.1	2.3	2.2	2.4	2.7	2.5	2.6	2.7	2.3	2.4	2.5	2.6	3.3	IZS	2.9	3.1	3	3	2.6	3.3	2.6	24	
2	2.5	2.4	2.4	2.3	2.4	2.2	2.1	2.1	2.1	2.1	2	2	2.3	2.7	2.3	2.8	2.5	IZS	2.4	2.4	2.4	2.4	2.4	2.4	2.8	2.8	2.3	24
3	3.5	3.5	3.1	3.1	6.1	3	2.6	2.5	3.1	2.5	2.4	2.2	2.3	2.5	2.6	2.5	IZS	3.3	2.9	2.9	2.6	2.6	2.6	2.6	2.9	6.1	2.9	24
4	2.8	2.7	3.1	3	3.5	3.4	3.1	3.1	3.6	3.1	3	2.7	2.7	2.6	2.7	IZS	3.1	3.2	3.6	3.7	3.9	3.9	3.9	3.9	4	4	3.2	24
5	4.1	3.9	3.8	3.5	4.6	3.7	3.6	3.5	3.1	2.8	2.1	C	C	C	C	C	2.1	2.1	2	2	2	2	2.2	2.3	4.6	2.9	24	
6	2.2	2.3	2.2	2.2	2.2	2.2	2.3	2.3	2.3	2.2	2.2	2.2	2.4	IZS	2.1	2.3	2.3	2.2	2.3	2.4	2.2	2.5	2.3	2.3	2.5	2.3	24	
7	2.4	2.8	2.8	2.5	2.4	2.5	2.5	2.4	2.4	2.3	2.4	IZS	2.4	2.8	2.4	2.3	2.2	2.2	2.3	2.5	2.5	2.5	2.5	2.5	2.8	2.5	24	
8	2.6	2.6	2.5	2.4	2.4	2.3	2.2	2	2	2.1	2.1	IZS	2	2	2.1	2.1	2	2	2.2	2.2	2.3	2.2	2.1	2.1	2.6	2.2	24	
9	2.1	2.2	2.2	2.2	2.2	2.2	2.6	2.8	3.4	3.2	IZS	2.4	2.5	2.7	2.7	2.8	2.5	2.3	2.4	2.3	2.2	2.2	1.9	1.9	3.4	2.4	24	
10	2	2	2	1.9	1.9	1.9	2	2	2	IZS	2	2	2	2	2	2	2	2.1	2.1	2.1	2.1	2.1	2.1	2.2	2.2	2.0	24	
11	2.2	2.1	2.1	2.2	2.3	2.5	2.6	3	IZS	3.1	2.2	2.2	2.2	2.5	2.6	2.5	2.4	2.8	2.4	2.7	2.9	3.7	4	3.2	4	2.6	24	
12	2.9	2.8	2.7	2.7	2.8	2.8	2.7	IZS	2.3	2.4	2.4	2.3	2.2	2.2	2.1	2.3	2.5	2.3	2.4	2.1	2.5	2.2	2.7	2.3	2.9	2.5	24	
13	2.4	2.4	2.4	2.3	2.2	2.1	IZS	2.1	2.2	2.2	2.1	2.1	2	2	2	1.9	2	1.9	2	2	2.1	2.1	2.1	2.1	2.4	2.1	24	
14	2.1	2.2	2.3	2.3	2.4	IZS	2.3	2.3	2.4	2.5	2.5	2.3	2.1	2.1	2	2	2	2	2	2	2	2	2	2	2	2.5	2.2	24
15	2	2	2	2	IZS	2	2	2	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	24
16	2.2	2.3	2.1	IZS	2.1	2.1	2.1	2.2	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.2	2.3	2.6	2.4	2.3	2.2	2.2	2.2	2.2	2.6	2.2	24
17	2.3	2.3	IZS	2.6	2.6	2.9	2.8	2.6	2.5	2.4	2.4	2.3	2.3	2.5	2.3	2.2	2.4	2.7	2.5	2.3	2.3	2.2	2.2	2.2	2.2	2.9	2.4	24
18	2.2	IZS	2.2	2.2	2.2	2.2	2.2	2.2	2.4	2.2	2.3	2.3	2.1	2.1	2.4	2.1	2.1	2.3	2.1	2.1	2.2	2.2	2.2	2.2	2.2	2.4	2.2	24
19	IZS	2.2	2.1	2.1	2.1	2.1	2.1	2.2	2.2	2.2	2.2	2.3	2.3	2.3	2.1	2.1	2.3	2.1	2.3	2.3	2.2	2.2	2.2	IZS	2.3	2.2	24	
20	2.3	2.2	2.2	2.2	2.2	2.4	2.4	2.5	2.7	2.8	2.6	2.5	2.4	2.4	2.5	2.4	2.3	2.3	2.7	2.6	2.7	2.7	IZS	2.8	2.8	2.5	24	
21	2.8	2.6	2.6	2.4	2.4	2.3	2.2	2.2	2.1	2	2	2	2.3	2.6	2	2	2	2.2	2	2	4.8	IZS	2.1	2.2	4.8	2.3	24	
22	2.2	2.1	2.1	2.2	2.5	2.7	2.7	2.9	2.6	2.6	2.6	2.6	2.5	2.8	2.5	2.7	2.8	3.1	3.2	3.6	IZS	2.9	2.8	2.9	3.6	2.7	24	
23	2.8	2.6	2.5	2.3	2.3	2.2	2.2	2.3	2.4	2.5	2.2	2.2	2.2	2.2	2.2	2.4	2.6	2.9	3.1	IZS	3.3	4.7	3.1	3.2	4.7	2.6	24	
24	3.3	2.9	2.5	2.9	2.9	2.9	3.5	2.9	3.8	3	3	2.8	2.6	2.5	2.4	2.5	3.1	2.8	IZS	2.8	2.7	2.5	2.4	2.3	3.8	2.8	24	
25	2.3	2.2	2.2	2.1	2.2	2.2	2.2	2.4	2.7	2.8	3.4	3.3	3	3	2.7	2.5	2.2	IZS	2.1	2.2	2.2	2.2	2.2	2.1	3.4	2.5	24	
26	2.2	2.1	2.1	2.2	2.2	2.4	2.2	2.3	2.5	2.4	2.3	2.2	2.4	2.2	2.3	IZS	2.4	2.5	2.3	2.2	2.2	2.3	2.4	2.5	2.3	2.4	24	
27	2.2	2.1	2.1	2.1	2.1	2	2	2	2.1	2.2	2.1	2.2	2.5	2.2	2.3	IZS	2	2.2	2.2	2.1	2.2	2.1	2.2	2.4	2.5	2.2	24	
28	2.3	2.2	2.1	2	2	2.1	2.1	2.1	2.1	2.1	2.2	2.2	2.2	2.2	IZS	2.2	2.6	2.6	2.6	2.3	3	2.3	7.9	2.3	2.1	7.9	2.5	24
29	2.2	2.8	2.2	2.2	2.2	2.1	2	2	2	2	2	2	2.3	IZS	2.7	2.6	2.3	2.3	2.3	2.4	2.5	2.4	2.5	2.6	2.8	2.3	24	
30	2.6	2.5	2.4	2.5	2.6	2.7	2.9	2.7	2.7	3.6	3.3	2.6	IZS	2.4	2.3	2.5	2.5	2.7	2.3	2.9	2.3	2.3	2.2	2.2	3.6	2.6	24	
31	2.3	2.2	2.2	2.2	2.2	2.2	2.2	2.4	3.7	2.8	2.7	IZS	2.7	2.3	2.2	2.6	3.1	2.6	2.5	2.7	2.7	2.6	2.6	2.5	3.7	2.5	24	
HOURLY MAX	4	4	4	4	6	4	4	4	4	4	3	3	3	3	3	3	3	3	3	4	4	5	8	4	4			
HOURLY AVG	2.5	2.5	2.4	2.4	2.6	2.4	2.4	2.4	2.5	2.5	2.4	2.3	2.3	2.4	2.3	2.3	2.4	2.5	2.4	2.5	2.4	2.5	2.7	2.4	2.5			


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE
BB	- BELOW BACKGROUND OF 1.5 PPM		

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	708					
MAXIMUM INSTANTANEOUS VALUE:	7.9	PPM	@ HOUR(S)	21	ON DAY(S)	28
IZS CALIBRATION TIME:	31	HRS	OPERATIONAL TIME:	744	HRS	
MONTHLY CALIBRATION TIME:	5	HRS				
STANDARD DEVIATION:	0.48					

01 Hour Averages



— LICA THCMAX PPM

LICA
 THC / WD Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 01
 Site Name : LICA
 Parameter : THC
 Units : PPM

Wind Parameter : WD
 Instrument Height : 10 Meters

		Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq	
< 3.0	.56	1.12	1.55	1.26	4.79	5.21	9.02	3.66	1.69	2.39	22.70	22.14	7.75	3.10	5.21	3.38	95.62	
< 10.0	.00	.00	.00	.56	.14	.70	.28	.42	.14	.00	.56	1.26	.28	.00	.00	.00	4.37	
< 50.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
>= 50.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
Totals	.56	1.12	1.55	1.83	4.93	5.92	9.30	4.09	1.83	2.39	23.27	23.41	8.03	3.10	5.21	3.38		

Calm : .00 %

Total # Operational Hours : 709

Distribution By Samples

		Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq	
< 3.0	4	8	11	9	34	37	64	26	12	17	161	157	55	22	37	24	678	
< 10.0				4	1	5	2	3	1		4	9	2				31	
< 50.0																		
>= 50.0																		
Totals	4	8	11	13	35	42	66	29	13	17	165	166	57	22	37	24		


Calm : .00 %

Total # Operational Hours : 709


Class Limits (PPM)

Period : 01/01/12-01/31/12

Level : 10



Calibration Graph for Site: LICA Parameter: THC Sequence: THC Phase: SPAN



Particulate Matter 2.5

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

JANUARY 2012

PARTICULATE MATTER 2.5 (PM2.5) hourly averages in ug/m³

MST

DAY	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	DAILY MAX.	24-HOUR AVG.	RDGS.
1	0	3.8	2.5	1.1	6	3.5	0	1.3	N	1.7	1	6.5	10.5	9.3	9	7.9	3.4	6.1	8.1	10.9	11.9	15.5	6.9	8.8	15.5	5.9	23	
2	0.1	3.4	1.4	3.5	0	3.4	0	0	0	5.4	0	0.4	2.6	1.4	5.6	3.4	4.4	2.9	1.4	10.6	4.4	7.4	1.4	1.4	10.6	2.7	24	
3	0.9	5	7.9	9.9	8.3	2.9	0	6	8.4	7.9	7	3.4	9	17	13.5	17	16.5	19	19.9	12	9	7.5	9.4	10.9	19.9	9.5	24	
4	4.4	3.4	9	11	6.5	10.9	13	7.9	9.4	11.5	9.4	14.9	13.9	13.9	12.5	13.5	C	7.5	11	5	22.9	22	14.5	17.5	22.9	11.5	24	
5	18	22	9.9	14.4	21	18.5	12.4	9	7.5	3.4	1	1.9	0	1.9	4	2.9	0	0	1.4	1	3.4	2.5	0	3.4	22.0	6.6	24	
6	0	0	0	1.9	1	1	0	1.4	1.9	0	1.4	0	1.4	4.4	1	0	1.9	4.4	0	1	0	2.5	4.4	5	5.0	1.4	24	
7	0	0.5	N	1	5.5	2.9	7.9	2.5	4	5.5	7	11.5	12	11.5	5	8.4	5	7.9	1	2.5	4.4	6	9	5.5	12.0	5.5	23	
8	4.4	3.4	5	10.9	2.5	0.4	1.9	1.4	6.9	1.9	2.9	0.5	1.9	1	2.9	1.4	2.9	0.4	0.4	1	5	0	2.5	0	10.9	2.6	24	
9	0	5.5	1.9	1.4	3.4	1.9	0	5.5	9.9	9	9.4	6	3.4	0	7.9	5	5	1.9	1.9	2.5	6.5	0	0	0.4	9.9	3.7	24	
10	0	1	1	2.5	0	0	1.4	6	6.5	5	6	N	0.5	3.4	1	3.4	0.5	1.9	2.5	0.4	2.9	0.5	2.5	2.9	6.5	2.3	23	
11	2.9	1	0.5	1.4	8.4	1.9	0	3.4	7.5	5.9	1.4	4.4	4.4	N	7.5	5	1	8.4	8.4	2.9	3.4	5	9	4.4	9.0	4.3	23	
12	1.9	1.9	2.9	5.5	6.5	6	6	6.5	2.5	5.5	7.9	4.4	5	5	0.5	5.5	10.5	4	7.5	4	2.5	5.5	9.9	7.5	10.5	5.2	24	
13	4	6.5	7.5	6.5	3.4	5.5	5	7.5	6	4	0	4.4	1	2.9	2.9	0	0	0.9	0	1.9	1	0.5	3.4	4	7.5	3.3	24	
14	3.4	1.9	4.4	4	1	6	2.9	0	5.5	0.5	4	2.5	0	5	3.4	6	1.9	0	5.5	0	2.5	5	2.9	5.5	6.0	3.1	24	
15	3.4	5	2.9	3.4	4.4	5	9.9	4.4	2.9	0	0.5	0	0.4	6	3.4	6.5	1	0	5	0	1.4	1	2.5	3.4	9.9	3.0	24	
16	1	4	7.5	7.9	3.4	6.5	10.5	6.5	5.5	9.4	5.5	4.4	7	9.9	2.9	4.4	9.4	9.9	6.5	7	9.4	2.5	7.9	2.9	10.5	6.3	24	
17	5.5	7.9	9	1.4	4.4	9.4	5.5	7	4	1	3.4	5.5	9	5.5	1.4	3.4	7.9	3.4	4	6	6.5	5	2.5	10.5	10.5	5.4	24	
18	7	7.5	5	2.5	2.9	5	5.5	9	5.5	2.9	3.4	0.5	2.9	1.4	0	2.9	2.9	5	7.9	1.9	2.5	0	3.4	4	9.0	3.8	24	
19	5.5	1.9	4.4	4.4	2.5	4	7	5	6	5	5	2.9	6.5	2.5	5.5	5	0	2.9	4.4	4	3.4	4	6	6.5	7.0	4.3	24	
20	2.5	4	3.4	6.5	4.4	6	6.5	10.9	9.9	9.4	11.5	13.9	15.5	10.9	11.5	11.5	9.9	9.4	6	13	6.5	7.5	7.9	9.4	15.5	8.7	24	
21	4.4	4.4	7.5	9.4	7	6.9	9	6	5.5	7.5	5	5.5	1.9	3.4	5	1.9	4	1.9	1	0	3.4	6.5	4.4	6	9.4	4.9	24	
22	4.4	4	4	5	3.4	2.9	4.4	9.9	5.5	6	16.5	13.9	14.9	16	16	14.9	10.5	17	15.5	17.5	15.5	18.5	17	13	18.5	11.1	24	
23	13.4	9.4	9	10.9	4	6.5	7.5	5	6.5	7.5	6.5	10.5	6	5.5	4.4	5	7.5	11.5	7.5	9.4	8.4	12.5	6.5	7.9	13.4	7.9	24	
24	10.5	8.4	6.9	6.9	5.5	9.9	12.5	10.5	11.5	7	9	9.9	7.9	6	1	0	3.4	4.4	2.9	6.5	1.9	2.9	1.9	1	12.5	6.2	24	
25	3.4	4.4	1.9	1	2.9	3.4	2.9	1	7.9	7.9	8.4	9.9	9.4	14.4	7	5	2.5	4	5.5	3.4	1.9	1.4	0.5	0.5	14.4	4.6	24	
26	5	5	5	2.9	1	2.5	4.4	4	5	4.4	0	4.4	1	0	4.4	2.5	6	1	5.5	6.5	4.4	2.5	6	5.5	6.5	3.7	24	
27	5.5	3.4	6	1.9	0	2.9	1.9	6	2.5	1.4	2.9	0	1	5.5	4.4	5	2.9	7.5	7.5	4.4	2.5	5.5	5	7.9	7.9	3.9	24	
28	6.5	7.9	6	5.5	1.9	1.9	6.5	2.5	0	6.5	5.5	6	7.5	6.5	7	5	3.4	7.9	9	4.4	6	5	6.5	6	9.0	5.5	24	
29	4	6	5	6	0	1.4	5	1.9	3.4	2.5	2.9	1.4	1.9	6.5	5.5	7	1.4	0	2.5	6	10.9	13.9	6.5	9	13.9	4.6	24	
30	10.5	7.5	7	7	8.4	12.5	11.5	14.9	9	12	10.5	13.9	15	9.9	6.5	4	7.5	12.4	16.5	9.4	2.9	7.5	6	7.9	16.5	9.6	24	
31	7	4.4	2.5	6	0	1.4	7	4	0	4	4	5	6.5	7.9	7.9	5	7	9	7	5.5	3.4	6	7.5	9.9	9.9	5.3	24	
HOURLY MAX	18	22	10	14	21	19	13	15	12	12	17	15	16	17	16	17	17	19	20	18	23	22	17	18				
HOURLY AVG	4.5	5.0	4.9	5.3	4.2	4.9	5.4	5.4	5.6	5.2	5.1	5.6	5.8	6.5	5.5	5.4	4.7	5.6	5.9	5.2	5.5	5.9	5.6	6.1				

STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE


OBJECTIVE LIMIT:

ALBERTA ENVIRONMENT:


1-HR	-	ug/m ³	24-HR	30	ug/m ³
------	---	-------------------	-------	----	-------------------

MONTHLY SUMMARY

NUMBER OF 1-HR EXCEEDENCES:	-		
NUMBER OF 24-HR EXCEEDENCES:	0 PROPOSED CANADA WIDE GUIDELINE		
NUMBER OF NON-ZERO READINGS:	680		
MAXIMUM 1-HR AVERAGE:	22.9 UG/M ³ @ HOUR(S) 20 ON DAY(S) 4		
MAXIMUM 24-HR AVERAGE:	11.5 UG/M ³ ON DAY(S) 4		
IZS CALIBRATION TIME:	0 HRS	OPERATIONAL TIME:	740 HRS
MONTHLY CALIBRATION TIME:	1 HRS	AMD OPERATION UPTIME:	99.5 %
STANDARD DEVIATION:	4.13	MONTHLY AVERAGE:	5.36 UG/M ³



01 Hour Averages



— LICA PM2 UG/M3

LICA
 PM2 / WD Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 01
 Site Name : LICA
 Parameter : PM2
 Units : UG/M3

Wind Parameter : WD
 Instrument Height : 10 Meters

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 30.0	.54	1.08	1.48	1.89	4.73	5.95	9.74	3.92	1.75	2.30	23.54	22.86	8.52	3.11	4.87	3.65	100.00
< 60.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 80.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 120.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 240.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 240.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	.54	1.08	1.48	1.89	4.73	5.95	9.74	3.92	1.75	2.30	23.54	22.86	8.52	3.11	4.87	3.65	

Calm : .00 %



Total # Operational Hours : 739

Distribution By Samples

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 30.0	4	8	11	14	35	44	72	29	13	17	174	169	63	23	36	27	739
< 60.0																	
< 80.0																	
< 120.0																	
< 240.0																	
>= 240.0																	
Totals	4	8	11	14	35	44	72	29	13	17	174	169	63	23	36	27	

Calm : .00 %

Total # Operational Hours : 739



Nitrogen Dioxide

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

JANUARY 2012

NITROGEN DIOXIDE hourly averages in ppb

MST	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY MAX.	24-HOUR AVG.	RDGS.
DAY																											
1	5	7	4	4	5	4	3	5	5	5	5	5	6	7	7	10	16	15	IZS	20	21	22	20	19	22	9.6	24
2	5	4	4	3	2	3	4	3	2	2	3	5	4	4	4	5	6	IZS	9	10	9	13	11	10	13	5.4	24
3	9	11	9	11	11	8	8	10	14	12	13	10	10	9	12	21	IZS	31	30	19	20	18	18	13	31	14.2	24
4	7	6	6	10	14	21	19	16	17	17	12	6	7	9	C	C	C	C	C	C	16	16	17	15	21	12.8	24
5	13	14	12	12	14	15	16	16	12	C	2	1	2	2	IZS	M	C	3	1	1	1	1	2	4	16	6.9	23
6	3	4	3	3	3	4	4	4	6	4	4	4	4	IZS	6	10	6	5	6	6	5	5	6	7	10	4.9	24
7	8	6	3	3	3	3	4	4	5	7	10	8	IZS	8	8	8	11	8	9	10	14	11	8	7	14	7.2	24
8	7	6	5	5	5	5	5	4	4	4	3	IZS	2	2	2	2	2	1	2	4	4	3	4	7	3.7	24	
9	3	4	4	5	4	4	10	15	30	34	IZS	7	5	11	5	7	9	8	9	7	6	2	1	1	34	8.3	24
10	1	1	1	1	1	1	1	2	C	IZS	2	2	1	1	1	1	1	1	1	2	2	2	2	3	3	1.4	24
11	3	2	2	2	2	3	9	19	IZS	10	4	3	4	3	4	4	8	16	13	10	13	16	14	11	19	7.6	24
12	11	13	12	15	14	10	6	IZS	7	6	5	5	4	4	4	5	6	4	3	3	3	3	4	4	15	6.6	24
13	5	4	4	7	9	6	IZS	7	6	6	5	3	1	1	1	1	1	1	2	2	3	3	4	3	9	3.7	24
14	3	3	5	6	9	IZS	4	4	C	C	11	5	3	3	3	4	4	3	3	1	1	1	1	1	11	3.7	24
15	1	1	0	0	IZS	1	2	3	4	4	3	2	2	2	2	2	2	2	2	2	2	1	1	2	4	1.9	24
16	2	3	4	IZS	1	2	2	3	3	4	3	2	2	2	2	3	5	5	6	9	10	7	6	6	10	4.0	24
17	6	6	IZS	8	7	8	9	12	11	8	5	4	3	3	2	3	5	6	7	6	7	7	6	6	12	6.3	24
18	6	IZS	6	5	4	4	5	5	5	C	C	C	3	2	2	3	4	4	4	6	5	5	4	5	6	4.4	24
19	IZS	5	5	4	4	4	5	7	7	6	5	4	3	3	2	3	5	5	8	8	10	10	6	IZS	10	5.4	24
20	7	8	8	9	10	9	7	11	11	10	10	10	8	8	10	12	23	21	24	37	16	12	IZS	8	37	12.6	24
21	8	8	7	6	6	5	5	5	4	4	5	3	3	3	4	4	5	5	4	3	3	IZS	2	2	8	4.5	24
22	2	2	2	3	3	4	5	5	6	4	6	6	6	7	7	8	15	23	24	24	IZS	23	23	12	24	9.6	24
23	9	7	5	5	4	4	4	7	19	15	5	3	3	3	4	5	10	11	17	IZS	16	22	13	16	22	9.0	24
24	21	11	13	16	18	19	22	19	20	18	10	6	6	6	6	8	16	20	IZS	8	7	6	5	5	22	12.4	24
25	6	6	5	7	10	13	10	14	23	17	12	13	10	10	9	10	4	IZS	4	4	4	4	3	3	23	8.7	24
26	3	4	4	3	4	4	3	6	9	7	7	6	4	4	9	8	IZS	10	11	8	6	7	7	7	11	6.1	24
27	6	5	4	3	2	1	1	2	3	4	4	3	4	4	4	IZS	5	6	5	4	5	5	5	6	6	4.0	24
28	6	5	2	2	3	4	4	4	3	4	6	6	5	5	IZS	4	6	15	16	10	11	7	5	4	16	6.0	24
29	4	4	3	3	3	3	2	2	3	3	2	2	2	IZS	3	3	4	4	4	4	10	11	14	19	19	4.9	24
30	16	13	11	10	13	10	15	16	14	10	6	6	IZS	6	5	10	10	11	13	13	10	9	8	6	16	10.5	24
31	9	7	7	7	7	6	6	9	9	8	11	IZS	13	10	10	10	20	30	28	19	12	10	11	11	30	11.7	24
HOURLY MAX	21	14	13	16	18	21	22	19	30	34	13	13	13	11	12	21	23	31	30	37	21	23	23	19			
HOURLY AVG	6.5	6.0	5.3	5.9	6.5	6.3	6.7	8.0	9.4	8.6	6.2	5.0	4.5	4.9	4.9	6.2	7.6	9.7	9.5	9.0	8.4	8.8	7.7	7.3			

STATUS FLAG CODES


S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

OBJECTIVE LIMIT:


ALBERTA ENVIRONMENT: 1-HR 159 PPB

MONTHLY SUMMARY

NUMBER OF 1-HR EXCEEDENCES:	0					
NUMBER OF NON-ZERO READINGS:	697					
MAXIMUM 1-HR AVERAGE:	37	PPB	@ HOUR(S)	19	ON DAY(S)	20
MAXIMUM 24-HR AVERAGE:	14.2	PPB			ON DAY(S)	3
IZS CALIBRATION TIME:	31	HRS	OPERATIONAL TIME:	743	HRS	
MONTHLY CALIBRATION TIME:	13	HRS	AMD OPERATION UPTIME:	99.9	%	
STANDARD DEVIATION:	5.51		MONTHLY AVERAGE:	7.02	PPB	



01 Hour Averages



— LICA NO2_ PPB

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

JANUARY 2012

NITROGEN DIOXIDE MAX instantaneous maximum in ppb

MST

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR		
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
DAY																												
1	10	10	5	6	6	5	4	7	7	8	7	6	8	8	9	16	28	27	IZS	24	24	27	24	22	28	13.0	24	
2	8	5	5	5	4	21	15	4	12	4	10	7	7	15	5	11	14	IZS	28	20	15	16	12	11	28	11.0	24	
3	12	13	11	16	18	13	17	15	22	20	30	17	12	12	21	30	IZS	35	39	28	24	22	22	19	39	20.3	24	
4	11	9	11	15	19	99	92	19	36	25	21	8	10	12	C	C	C	C	C	C	C	C	22	19	20	99	26.4	24
5	16	17	14	17	18	18	19	18	16	C	C	2	3	3	IZS	M	4	3	2	2	2	2	3	7	19	9.3	23	
6	5	5	5	6	5	5	7	6	29	5	5	6	5	IZS	35	76	14	6	10	9	7	7	11	12	76	12.2	24	
7	11	9	6	5	5	5	5	7	7	9	36	8	IZS	9	8	13	14	10	13	20	23	17	11	10	36	11.3	24	
8	9	7	6	10	6	6	10	5	5	5	4	IZS	2	3	3	3	2	2	6	6	6	6	4	5	10	5.3	24	
9	5	6	5	8	6	8	19	23	42	40	IZS	12	8	16	14	10	11	9	18	10	8	5	1	1	42	12.4	24	
10	2	2	2	1	2	1	2	2	C	IZS	3	4	1	2	2	7	2	2	2	2	2	3	3	4	7	2.4	24	
11	4	5	4	4	3	4	25	24	IZS	15	6	8	36	4	8	5	15	21	24	14	16	18	23	16	36	13.1	24	
12	16	16	16	18	16	12	9	IZS	10	7	7	7	4	6	11	11	8	5	5	4	4	4	4	5	18	8.9	24	
13	7	12	7	11	10	9	IZS	12	17	10	8	5	3	1	3	3	2	3	3	3	6	5	5	4	17	6.5	24	
14	5	6	7	12	14	IZS	6	7	C	C	22	17	9	7	5	9	8	5	4	2	5	1	2	2	22	7.4	24	
15	1	1	1	1	IZS	2	2	4	4	4	4	3	2	2	3	3	3	3	3	3	3	2	2	2	4	2.5	24	
16	3	4	5	IZS	2	2	3	4	5	5	4	3	3	3	3	4	6	7	8	12	13	12	9	7	13	5.5	24	
17	8	6	IZS	10	8	10	12	14	13	9	7	5	5	4	3	5	36	8	9	7	8	8	7	7	36	9.1	24	
18	7	IZS	7	6	5	6	6	7	6	C	C	C	3	3	4	4	5	5	5	7	8	6	5	6	8	5.6	24	
19	IZS	6	6	5	6	5	7	10	M	M	6	5	4	4	3	5	6	6	11	10	11	12	9	IZS	12	6.9	22	
20	9	13	12	10	12	10	9	14	52	14	15	14	9	9	18	19	29	27	37	45	34	14	IZS	9	52	18.9	24	
21	10	11	8	8	7	11	7	6	6	8	6	5	5	4	5	6	7	7	6	5	5	IZS	4	3	11	6.5	24	
22	2	4	4	6	3	5	7	9	14	5	7	7	7	8	9	10	22	29	29	30	IZS	30	29	24	30	13.0	24	
23	11	8	6	5	5	5	6	25	27	26	11	5	4	7	7	8	12	16	28	IZS	24	28	20	21	28	13.7	24	
24	26	14	19	22	22	23	25	23	26	24	18	8	6	6	8	19	26	32	IZS	9	8	7	7	6	32	16.7	24	
25	10	9	10	11	18	24	13	24	38	25	15	17	12	11	11	13	11	IZS	11	6	6	6	5	4	38	13.5	24	
26	5	5	5	5	8	8	7	9	11	10	10	8	6	5	54	39	IZS	14	23	13	7	8	9	9	54	12.1	24	
27	7	7	5	4	4	2	2	5	5	5	5	6	5	6	7	6	IZS	11	7	6	5	6	7	7	11	5.7	24	
28	7	6	4	2	4	5	5	5	4	8	8	6	7	IZS	6	10	24	20	15	17	9	9	5	24	8.3	24		
29	6	6	4	4	5	8	3	4	5	4	3	2	4	IZS	9	4	7	5	6	5	18	13	19	27	27	7.4	24	
30	19	15	14	14	14	17	27	21	19	15	14	7	IZS	7	5	14	14	12	15	14	13	10	10	8	27	13.8	24	
31	13	11	11	9	8	9	9	13	15	13	13	IZS	15	13	26	21	31	37	31	28	15	11	12	14	37	16.4	24	
HOURLY MAX	26	17	19	22	22	99	92	25	52	40	36	17	36	16	54	76	36	37	39	45	34	30	29	27				
HOURLY AVG	8.8	8.3	7.5	8.5	8.8	11.9	12.7	11.5	16.8	12.3	10.9	7.5	7.1	6.8	10.6	13.4	12.8	13.1	14.4	12.3	11.7	11.3	10.2	9.9				


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	695					
MAXIMUM INSTANTANEOUS VALUE:	99	PPB	@ HOUR(S)	5	ON DAY(S)	4
IZS CALIBRATION TIME:	31	HRS	OPERATIONAL TIME:	741	HRS	
MONTHLY CALIBRATION TIME:	15	HRS				
STANDARD DEVIATION	9.71					

01 Hour Averages



— LICA NO2MAX PPB

LICA
 NO2_ / WD Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 01
 Site Name : LICA
 Parameter : NO2_
 Units : PPB

Wind Parameter : WD
 Instrument Height : 10 Meters

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	.57	1.14	1.43	1.85	5.00	5.86	9.44	3.86	1.71	2.43	23.46	23.31	8.15	3.14	5.15	3.43	100.00
< 110	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	.57	1.14	1.43	1.85	5.00	5.86	9.44	3.86	1.71	2.43	23.46	23.31	8.15	3.14	5.15	3.43	

Calm : .00 %

Total # Operational Hours : 699



Distribution By Samples

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	4	8	10	13	35	41	66	27	12	17	164	163	57	22	36	24	699
< 110																	
< 210																	
>= 210																	
Totals	4	8	10	13	35	41	66	27	12	17	164	163	57	22	36	24	


Calm : .00 %

Total # Operational Hours : 699

Class Limits (PPB)



Calibration Graph for Site: LICA Parameter: H02_ Sequence: H02 Phase: SPAN



Nitric Oxide

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

JANUARY 2012

NITRIC OXIDE hourly averages in ppb

MST

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY MAX.	24-HOUR AVG.	RDGS.	
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00				
DAY																												
1	0	0	0	0	0	0	0	0	0	1	2	2	3	3	2	1	1	1	IZS	5	10	20	8	2	20	2.7	24	
2	1	0	0	0	0	1	1	0	1	0	1	2	1	2	1	1	0	IZS	2	1	0	0	0	0	2	0.7	24	
3	0	0	0	1	2	1	1	1	2	4	5	5	3	2	3	4	IZS	36	45	10	2	3	5	2	45	6.0	24	
4	0	0	0	1	3	16	22	11	30	38	14	2	3	6	C	C	C	C	C	C	28	36	43	46	46	16.6	24	
5	37	41	35	23	28	8	2	1	0	C	0	0	0	0	IZS	M	0	0	0	0	0	0	0	0	41	8.3	23	
6	0	0	0	0	0	0	0	0	1	0	1	1	1	IZS	6	8	0	0	0	0	0	0	0	0	8	0.8	24	
7	0	0	0	0	0	0	0	0	0	1	5	3	IZS	3	2	1	1	0	0	0	3	1	0	0	5	0.9	24	
8	0	0	0	0	0	0	0	0	0	0	1	IZS	0	1	0	0	0	0	0	0	0	0	0	0	1	0.1	24	
9	0	0	0	0	0	0	1	10	67	100	IZS	2	1	3	1	2	1	0	0	0	0	0	0	0	100	8.2	24	
10	0	0	0	0	0	0	0	0	C	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
11	0	0	0	0	0	0	1	4	IZS	2	1	1	2	1	1	1	1	1	1	1	0	1	1	1	0	4	0.9	24
12	1	1	0	1	1	0	0	IZS	0	1	1	1	1	1	1	0	0	0	0	0	0	0	0	0	0	1	0.4	24
13	0	0	0	0	0	0	IZS	0	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	1	0.2	24	
14	0	0	0	0	0	IZS	0	0	C	C	3	2	1	1	1	1	0	1	0	0	0	0	0	0	3	0.5	24	
15	0	0	0	0	IZS	0	0	0	0	0	1	1	1	1	0	0	0	0	0	0	0	0	0	0	1	0.2	24	
16	0	0	0	IZS	0	0	0	0	0	1	1	1	1	1	1	1	0	0	0	0	1	1	1	1	0	1	0.5	24
17	0	0	IZS	0	0	0	1	1	1	3	3	3	3	2	1	1	1	0	1	1	0	0	0	0	3	1.0	24	
18	0	IZS	0	0	0	0	0	0	1	C	C	C	2	1	1	1	0	0	0	0	0	0	0	0	2	0.3	24	
19	IZS	0	0	0	0	0	0	0	1	2	2	2	2	2	1	1	0	0	0	0	0	0	0	0	IZS	2	0.6	24
20	0	0	0	1	1	0	1	0	4	3	5	6	5	4	4	3	3	2	5	19	4	1	IZS	0	19	3.1	24	
21	1	1	1	1	1	0	1	1	1	1	1	1	1	1	1	1	1	0	0	0	0	IZS	0	0	1	0.7	24	
22	0	0	0	0	0	0	0	0	1	1	2	4	5	4	4	2	3	8	13	21	IZS	6	7	1	21	3.6	24	
23	0	0	0	0	0	0	0	1	4	5	2	1	1	1	1	1	0	1	IZS	1	3	0	1	5	1	1.0	24	
24	3	0	0	1	3	6	23	18	23	28	7	3	3	3	2	1	1	3	IZS	0	0	0	0	0	28	5.6	24	
25	0	0	0	0	0	2	0	4	34	21	7	8	4	4	3	2	0	IZS	0	0	0	0	0	0	34	3.9	24	
26	0	0	0	0	0	0	1	0	1	1	2	2	2	1	9	6	IZS	0	0	0	0	0	0	0	9	1.1	24	
27	0	0	0	0	0	0	0	0	1	1	2	1	1	1	1	IZS	1	0	0	0	0	0	0	0	2	0.4	24	
28	0	0	0	0	0	0	0	0	0	1	2	2	3	2	IZS	1	0	1	0	0	1	1	1	0	3	0.7	24	
29	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	1	1	0	0	0	0	1	0	0	1	1	0.2	24	
30	0	0	0	0	1	2	4	13	16	8	3	2	IZS	2	1	2	1	0	0	0	0	0	0	0	16	2.4	24	
31	0	0	0	0	0	0	0	0	1	2	5	IZS	7	4	3	4	2	6	3	1	0	0	0	0	7	1.7	24	
HOURLY MAX	37	41	35	23	28	16	23	18	67	100	14	8	7	6	9	8	3	36	45	21	28	36	43	46				
HOURLY AVG	1.4	1.4	1.2	1.0	1.3	1.2	2.0	2.2	6.8	8.4	2.8	2.1	2.0	2.0	1.9	1.7	0.6	2.1	2.5	2.0	1.7	2.4	2.2	1.8				


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE


MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	316					
MAXIMUM 1-HR AVERAGE:	100	PPB	@ HOUR(S)	9	ON DAY(S)	9
MAXIMUM 24-HR AVERAGE:	16.6	PPB			ON DAY(S)	4
IZS CALIBRATION TIME:	31	HRS	OPERATIONAL TIME:	743	HRS	
MONTHLY CALIBRATION TIME:	13	HRS	AMD OPERATION UPTIME:	99.9	%	
STANDARD DEVIATION:	7.30		MONTHLY AVERAGE:	2.25	PPB	

24 HOUR AVERAGES FOR JANUARY 2012



01 Hour Averages



LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

JANUARY 2012

NITRIC OXIDE MAX instantaneous maximum in ppb

MST

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	23:00	DAILY	24-HOUR	
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX	AVG.	RDGS.	
DAY																												
1	1	1	1	1	1	1	1	2	1	3	4	12	4	4	6	4	9	6	IZS	14	17	33	28	5	33	6.9	24	
2	5	1	1	1	1	14	14	3	8	2	12	4	6	14	7	7	1	IZS	43	12	1	4	1	1	43	7.1	24	
3	1	3	4	4	16	4	4	3	7	16	11	12	6	3	12	21	IZS	55	63	34	5	8	12	5	63	13.4	24	
4	1	1	1	4	9	146	146	27	73	69	42	4	6	10	C	C	C	C	C	C	C	C	62	55	60	146	42.1	24
5	46	46	44	31	33	23	6	4	3	C	C	1	1	1	IZS	M	1	1	1	1	1	1	1	3	46	12.5	23	
6	1	1	1	1	1	1	1	1	44	2	2	2	1	IZS	35	124	2	1	1	2	4	3	4	2	124	10.3	24	
7	1	2	2	2	1	1	1	1	1	2	33	4	IZS	4	3	2	4	3	1	8	22	3	4	3	33	4.7	24	
8	1	1	1	2	0	2	1	1	1	1	2	IZS	1	1	1	1	1	1	1	2	1	1	1	1	2	1.1	24	
9	2	1	1	1	2	1	8	42	113	126	IZS	5	3	7	7	18	4	2	5	1	5	1	1	1	126	15.5	24	
10	1	1	1	0	0	0	0	0	C	IZS	1	1	0	4	1	7	0	0	0	0	0	0	0	0	7	0.8	24	
11	1	1	1	1	0	1	17	13	IZS	4	2	3	14	1	6	1	4	11	6	1	1	3	5	2	17	4.3	24	
12	3	3	1	3	1	1	1	IZS	2	1	3	3	2	2	2	2	1	1	1	0	1	1	0	1	3	1.6	24	
13	1	2	1	2	2	2	IZS	1	38	1	6	2	1	2	1	1	0	1	1	1	1	1	1	1	38	3.0	24	
14	1	1	0	1	1	IZS	1	1	C	C	9	13	12	8	4	2	2	2	2	1	6	1	2	1	13	3.4	24	
15	1	1	0	1	IZS	1	1	0	1	1	1	1	1	1	0	0	0	0	0	1	1	1	1	0	1	0.7	24	
16	0	0	1	IZS	0	0	0	1	0	1	1	1	1	3	1	1	0	0	1	1	2	5	3	3	5	1.3	24	
17	3	1	IZS	5	1	1	3	4	3	6	4	3	4	3	4	2	7	1	3	2	1	1	2	1	7	2.8	24	
18	2	IZS	1	2	2	2	1	1	2	C	C	C	2	2	3	1	2	1	2	1	1	1	2	0	3	1.5	24	
19	IZS	2	1	1	1	0	0	1	M	M	4	3	3	3	1	2	1	2	3	1	1	1	1	1	IZS	4	1.6	22
20	1	1	1	2	1	2	1	2	71	6	6	8	6	5	9	6	7	15	46	30	19	3	IZS	2	71	10.9	24	
21	1	1	2	1	1	1	1	1	1	3	2	2	2	1	2	1	1	4	1	1	1	IZS	1	0	4	1.4	24	
22	0	1	0	0	1	0	1	2	14	1	4	5	5	6	5	4	7	17	27	43	IZS	15	14	8	43	7.8	24	
23	1	1	1	1	1	1	1	16	10	9	6	2	3	4	3	2	3	1	6	IZS	6	9	3	4	16	4.1	24	
24	7	1	1	6	10	16	41	31	47	44	25	5	4	6	5	5	4	11	IZS	1	1	1	1	1	47	11.9	24	
25	1	2	2	2	1	17	1	16	108	42	12	12	6	6	5	3	2	IZS	1	1	1	1	1	1	108	10.6	24	
26	1	1	1	1	1	2	3	1	2	3	7	3	3	2	48	42	IZS	1	1	1	1	1	1	1	48	5.6	24	
27	1	0	1	1	1	1	1	1	10	1	10	2	4	3	13	IZS	12	1	0	0	1	1	1	1	13	2.9	24	
28	1	1	1	0	1	1	1	1	1	1	3	4	5	3	IZS	1	1	10	2	1	4	3	3	1	10	2.2	24	
29	1	1	1	1	1	5	1	1	1	1	1	1	2	IZS	5	1	1	1	3	1	4	1	2	6	6	1.9	24	
30	1	1	3	1	3	17	18	30	32	18	8	5	IZS	4	2	4	8	3	2	1	2	2	1	1	32	7.3	24	
31	1	1	1	1	2	1	1	1	3	5	9	IZS	10	6	17	50	8	17	6	4	0	3	2	2	50	6.6	24	
HOURLY MAX	46	46	44	31	33	146	146	42	113	126	42	13	14	14	48	124	12	55	63	43	22	62	55	60				
HOURLY AVG	3.0	2.7	2.6	2.7	3.2	8.8	9.2	7.0	22.1	14.2	8.2	4.4	4.1	4.1	7.5	11.3	3.3	6.1	8.1	5.8	3.9	5.6	5.1	3.9				


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	648					
MAXIMUM INSTANTANEOUS VALUE:	146	PPB	@ HOUR(S)	5, 6	ON DAY(S)	4
IZS CALIBRATION TIME:	31	HRS	OPERATIONAL TIME:	741	HRS	
MONTHLY CALIBRATION TIME:	15	HRS				
STANDARD DEVIATION	15.38					

01 Hour Averages



LICA
 NO_ / WD Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 01
 Site Name : LICA
 Parameter : NO
 Units : PPB

Wind Parameter : WD
 Instrument Height : 10 Meters

		Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq	
< 50	.57	1.14	1.43	1.71	4.86	5.86	9.44	3.86	1.71	2.43	23.46	23.31	8.15	3.14	5.15	3.43	99.71	
< 110	.00	.00	.00	.14	.14	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.28	
< 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
Totals	.57	1.14	1.43	1.85	5.00	5.86	9.44	3.86	1.71	2.43	23.46	23.31	8.15	3.14	5.15	3.43		

Calm : .00 %



Total # Operational Hours : 699

Distribution By Samples

		Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq	
< 50	4	8	10	12	34	41	66	27	12	17	164	163	57	22	36	24	697	
< 110				1	1												2	
< 210																		
>= 210																		
Totals	4	8	10	13	35	41	66	27	12	17	164	163	57	22	36	24		

Calm : .00 %

Total # Operational Hours : 699



Oxides of Nitrogen

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

JANUARY 2012


OXIDES OF NITROGEN hourly averages in ppb

MST

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY MAX.	24-HOUR AVG.	RDGS.
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00			
DAY 1	5	8	4	4	5	4	3	5	5	6	6	7	9	9	9	11	17	17	IZS	25	31	42	28	21	42	12.2	24
2	6	4	4	4	3	4	5	3	3	2	3	7	5	5	4	5	6	IZS	11	10	9	14	11	10	14	6.0	24
3	9	11	10	12	13	9	9	11	17	16	18	15	13	11	15	25	IZS	67	75	28	22	21	23	15	75	20.2	24
4	7	6	7	11	17	37	41	27	47	54	26	8	10	15	C	C	C	C	C	C	44	52	60	61	61	29.4	24
5	50	54	46	35	42	24	18	17	12	C	2	1	2	2	IZS	M	3	1	1	1	1	1	2	4	54	15.2	23
6	4	4	4	4	3	4	4	4	7	5	5	6	5	IZS	12	18	6	5	6	6	5	6	6	7	18	5.9	24
7	8	6	3	3	4	3	4	4	5	8	14	11	IZS	11	10	9	11	8	9	10	17	11	9	7	17	8.0	24
8	7	6	5	5	5	5	5	4	4	4	4	IZS	2	2	2	2	2	1	2	4	4	3	4	7	3.7	24	
9	3	4	4	5	4	5	12	25	97	134	IZS	9	6	14	6	8	9	8	10	8	6	3	1	1	134	16.6	24
10	1	1	1	1	1	1	1	1	C	IZS	2	2	1	1	1	2	1	1	1	2	2	2	2	3	3	1.4	24
11	3	2	2	2	2	3	10	23	IZS	12	5	4	6	4	5	4	8	17	13	10	14	17	14	12	23	8.3	24
12	11	14	12	16	15	11	6	IZS	7	6	7	6	5	5	5	6	6	4	3	3	3	3	4	4	16	7.0	24
13	5	4	5	8	9	6	IZS	7	8	6	5	4	2	1	1	1	1	1	2	2	3	4	4	3	9	4.0	24
14	3	3	5	6	9	IZS	4	4	C	C	14	7	4	4	4	5	5	3	3	1	1	1	1	1	14	4.2	24
15	1	1	0	1	IZS	1	2	3	4	4	3	3	3	2	2	3	2	2	2	2	2	1	2	2	4	2.1	24
16	2	3	4	IZS	1	2	2	3	4	5	3	3	3	3	2	3	5	5	6	10	11	7	7	6	11	4.3	24
17	6	6	IZS	8	7	9	10	14	12	11	8	6	6	5	4	4	6	6	8	6	8	7	6	6	14	7.3	24
18	6	IZS	6	5	4	5	5	6	6	C	C	C	4	3	3	4	4	4	5	6	6	5	4	5	6	4.8	24
19	IZS	5	6	4	4	4	5	7	8	8	7	5	5	4	3	4	5	5	8	8	10	10	7	IZS	10	6.0	24
20	8	9	9	9	10	9	7	11	15	13	15	16	13	11	14	15	26	23	28	56	20	13	IZS	8	56	15.6	24
21	9	9	8	7	6	6	6	5	4	5	6	4	4	4	5	5	6	5	4	3	3	IZS	2	2	9	5.1	24
22	2	2	2	3	3	4	5	6	8	5	8	10	11	11	10	17	31	36	45	IZS	29	30	13	45	13.1	24	
23	9	7	5	5	4	4	4	8	23	20	7	5	4	5	5	6	11	11	18	IZS	17	25	14	17	25	10.2	24
24	24	11	13	17	21	24	45	37	43	46	16	9	8	8	8	9	18	23	IZS	8	7	6	6	5	46	17.9	24
25	6	6	6	7	10	15	10	17	57	39	19	21	14	14	12	12	5	IZS	4	4	4	4	3	3	57	12.7	24
26	3	4	4	3	4	4	4	6	9	8	9	8	5	19	14	IZS	10	11	8	6	7	8	7	19	7.2	24	
27	6	5	4	3	3	1	1	2	4	4	6	4	5	5	5	IZS	6	6	5	4	5	5	6	6	6	4.4	24
28	6	5	3	2	3	4	4	4	3	5	8	8	8	7	IZS	5	6	16	16	10	12	7	6	4	16	6.6	24
29	5	4	3	3	4	4	2	2	3	3	2	2	2	IZS	3	4	4	4	4	4	11	11	14	20	20	5.1	24
30	16	13	12	10	14	12	19	30	30	18	9	8	IZS	8	6	11	11	11	14	13	10	9	8	6	30	13.0	24
31	9	7	7	7	7	6	6	9	10	11	16	IZS	20	14	14	14	22	37	31	20	12	11	11	11	37	13.6	24
HOURLY MAX	50	54	46	35	42	37	45	37	97	134	26	21	20	15	19	25	26	67	75	56	44	52	60	61			
HOURLY AVG	8.0	7.5	6.8	7.0	7.9	7.7	8.6	10.2	16.3	17.0	8.7	7.1	6.4	6.7	6.8	7.8	8.2	11.9	12.0	10.9	10.2	11.3	10.1	9.1			

STATUS FLAG CODES


S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE



MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	698					
MAXIMUM 1-HR AVERAGE:	134	PPB	@ HOUR(S)	9	ON DAY(S)	9
MAXIMUM 24-HR AVERAGE:	29.4	PPB			ON DAY(S)	4
IZS CALIBRATION TIME:	31	HRS	OPERATIONAL TIME:	743	HRS	
MONTHLY CALIBRATION TIME:	13	HRS	AMD OPERATION UPTIME:	99.9	%	
STANDARD DEVIATION:	11.34		MONTHLY AVERAGE:	9.29	PPB	

01 Hour Averages



— LICA NOX_ PPB

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

JANUARY 2012

OXIDES OF NITROGEN MAX instantaneous maximum in ppb

MST

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR		
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
DAY																												
1	10	11	6	6	7	6	4	7	8	11	9	12	12	11	14	20	33	31	IZS	37	41	60	41	26	60	18.4	24	
2	10	5	5	6	4	31	27	7	17	4	21	10	10	28	9	14	15	IZS	69	31	16	17	14	11	69	16.6	24	
3	12	14	13	19	33	16	20	17	27	34	38	29	18	14	29	43	IZS	89	100	60	27	30	31	23	100	32.0	24	
4	12	10	12	17	28	238	238	45	92	93	61	11	15	22	C	C	C	C	C	C	C	79	74	78	238	66.2	24	
5	61	62	56	46	49	34	24	21	18	C	C	3	4	4	IZS	M	5	3	2	2	2	2	3	8	62	20.5	23	
6	6	6	6	6	5	6	8	6	59	7	6	7	7	IZS	53	185	15	7	10	11	8	9	14	14	185	20.0	24	
7	11	9	8	5	5	6	5	8	7	11	52	12	IZS	12	11	14	15	12	13	27	33	20	12	12	52	13.9	24	
8	10	8	6	12	6	6	10	5	5	5	5	IZS	3	3	3	3	3	3	6	7	7	7	4	5	12	5.7	24	
9	5	6	6	8	7	8	27	63	154	165	IZS	16	10	22	20	21	13	10	23	11	10	6	1	1	165	26.7	24	
10	2	3	3	1	2	2	2	2	C	IZS	4	5	1	4	2	12	2	2	2	2	2	3	3	4	12	3.0	24	
11	5	6	5	5	3	4	39	35	IZS	19	7	11	44	5	11	5	18	25	30	14	17	20	28	17	44	16.2	24	
12	17	19	16	19	17	12	10	IZS	11	8	9	9	6	8	13	13	9	5	5	4	5	5	5	5	19	10.0	24	
13	7	13	7	11	11	9	IZS	13	47	11	13	6	3	2	4	3	3	3	3	4	7	6	6	4	47	8.5	24	
14	7	6	7	12	14	IZS	6	8	C	C	30	29	19	11	7	10	9	7	6	2	10	2	3	2	30	9.9	24	
15	1	2	1	1	IZS	2	3	4	5	5	4	4	3	3	3	3	3	3	3	3	3	2	2	2	5	2.9	24	
16	3	4	6	IZS	2	2	3	4	6	6	5	4	4	4	4	5	6	7	8	14	17	14	11	9	17	6.4	24	
17	9	7	IZS	15	8	11	15	17	16	14	11	8	8	6	6	6	41	9	10	8	9	9	8	8	41	11.3	24	
18	8	IZS	8	7	6	6	7	7	7	C	C	C	5	4	6	6	5	6	6	8	9	6	6	6	9	6.5	24	
19	IZS	7	7	5	6	5	7	10	M	M	8	8	7	6	4	6	7	7	11	10	12	13	9	IZS	13	7.8	22	
20	9	13	12	12	13	11	10	16	123	19	21	21	15	13	26	23	36	37	77	73	53	16	IZS	10	123	28.7	24	
21	11	12	9	8	7	12	8	8	7	10	7	7	6	6	7	7	8	10	7	5	6	IZS	5	3	12	7.7	24	
22	2	5	4	6	4	5	8	12	24	6	11	12	13	13	14	13	29	43	54	73	IZS	45	43	31	73	20.4	24	
23	11	9	7	6	5	5	6	40	38	35	17	7	7	10	10	9	15	16	32	IZS	29	36	22	24	40	17.2	24	
24	32	15	19	28	31	39	65	51	69	67	43	12	10	10	12	24	29	43	IZS	9	9	8	8	7	69	27.8	24	
25	10	10	12	12	20	38	13	39	143	66	26	28	17	16	16	15	12	IZS	11	6	7	7	5	5	143	23.2	24	
26	5	5	6	6	9	9	9	10	12	12	14	11	8	7	75	61	IZS	15	24	13	8	8	10	9	75	15.0	24	
27	7	7	5	4	4	2	3	5	11	6	11	6	8	10	17	IZS	21	8	6	5	6	7	7	8	21	7.6	24	
28	8	7	4	2	5	5	6	5	5	10	12	10	10	IZS	7	10	33	21	16	18	10	9	6	33	9.7	24		
29	7	6	4	5	5	13	4	5	6	5	4	3	5	IZS	12	5	8	5	6	6	19	14	21	34	34	8.8	24	
30	19	16	17	15	16	33	45	51	49	33	22	12	IZS	11	7	17	16	14	16	15	13	10	10	8	51	20.2	24	
31	14	11	11	9	9	10	10	14	17	16	20	IZS	25	19	39	71	38	53	37	31	15	13	13	14	71	22.1	24	
HOURLY MAX	61	62	56	46	49	238	238	63	154	165	61	29	44	28	75	185	41	89	100	73	53	79	74	78				
HOURLY AVG	11.0	10.5	9.6	10.5	11.4	19.5	21.4	17.9	36.4	25.9	17.5	11.3	10.5	10.1	15.5	22.2	15.1	18.1	21.4	17.5	14.4	16.1	14.3	13.1				


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	695					
MAXIMUM INSTANTANEOUS VALUE:	238	PPB	@ HOUR(S)	5, 6	ON DAY(S)	4
IZS CALIBRATION TIME:	31	HRS	OPERATIONAL TIME:	741	HRS	
MONTHLY CALIBRATION TIME:	15	HRS				
STANDARD DEVIATION	22.77					

01 Hour Averages



LICA
 NOX_ / WD Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 01
 Site Name : LICA
 Parameter : NOX_
 Units : PPB

Wind Parameter : WD
 Instrument Height : 10 Meters

		Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq	
< 50	.57	1.14	1.43	1.00	4.72	5.86	9.29	3.57	1.57	2.43	23.46	23.31	8.15	3.14	5.15	3.43	98.28	
< 110	.00	.00	.00	.71	.28	.00	.14	.28	.14	.00	.00	.00	.00	.00	.00	.00	1.57	
< 210	.00	.00	.00	.14	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.14	
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
Totals	.57	1.14	1.43	1.85	5.00	5.86	9.44	3.86	1.71	2.43	23.46	23.31	8.15	3.14	5.15	3.43		

Calm : .00 %

Total # Operational Hours : 699

Distribution By Samples

		Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq	
< 50	4	8	10	7	33	41	65	25	11	17	164	163	57	22	36	24	687	
< 110				5	2		1	2	1								11	
< 210				1													1	
>= 210																		
Totals	4	8	10	13	35	41	66	27	12	17	164	163	57	22	36	24		



Calm : .00 %

Total # Operational Hours : 699


Class Limits (PPB)

Period : 01/01/12-01/31/12

Level : 10



Calibration Graph for Site: LICA Parameter: NOX_ Sequence: NO2 Phase: SPAN



Ozone

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

JANUARY 2012

OZONE (O₃) hourly averages in ppb

MST


HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR	RDGS.
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	MAX.	AVG.		
DAY																											
1	29	26	28	27	25	26	28	25	22	25	26	26	25	25	25	22	12	10	IZS	2	1	2	2	4	29	19.3	24
2	26	27	27	27	29	29	29	30	30	30	30	26	27	26	25	23	20	IZS	16	15	13	11	12	12	30	23.5	24
3	11	9	10	6	7	15	14	10	11	16	18	19	21	18	10	IZS	1	1	7	4	2	1	5	21	10.0	24	
4	15	12	10	5	2	1	2	0	0	1	9	16	16	14	14	IZS	8	5	3	2	2	1	2	1	16	6.1	24
5	1	1	1	1	1	2	2	5	9	C	C	C	C	31	IZS	M	29	32	33	33	32	32	32	29	33	17.0	23
6	30	30	31	31	30	28	28	29	26	27	28	28	30	IZS	31	28	28	30	27	27	27	26	22	19	31	27.9	24
7	17	21	27	28	28	28	27	26	25	21	21	22	IZS	23	23	24	17	22	19	15	7	12	14	15	28	21.0	24
8	18	20	21	21	22	23	25	28	27	28	29	IZS	33	34	35	35	36	35	34	31	29	27	28	26	36	28.0	24
9	27	24	23	17	20	21	9	5	2	2	IZS	20	21	15	18	16	15	16	15	19	22	34	39	38	39	19.0	24
10	37	36	26	27	36	35	33	33	33	IZS	35	34	35	35	34	32	30	29	30	30	30	30	31	30	37	32.2	24
11	30	30	29	26	22	20	15	6	IZS	16	26	28	30	30	29	29	24	12	13	14	9	5	8	6	30	19.9	24
12	8	5	7	7	10	19	25	IZS	25	27	29	31	32	32	33	31	30	31	32	32	32	31	30	28	33	24.7	24
13	20	17	21	22	20	25	IZS	25	26	29	30	32	34	36	36	36	35	35	33	32	31	30	30	31	36	29.0	24
14	31	28	25	21	18	IZS	23	22	16	17	19	27	30	29	29	28	28	28	28	27	27	27	27	26	31	25.3	24
15	26	26	28	29	IZS	28	28	27	26	26	28	29	29	29	29	28	28	28	28	28	27	29	28	28	29	27.8	24
16	27	27	26	IZS	28	27	26	26	25	25	27	27	28	28	29	28	26	25	23	18	17	21	21	21	29	25.0	24
17	20	18	IZS	16	13	11	15	13	16	19	22	24	26	27	28	28	26	24	22	23	22	22	22	22	28	20.8	24
18	22	IZS	22	24	25	25	24	24	24	27	28	28	29	31	30	30	29	29	28	27	27	27	28	27	31	26.7	24
19	IZS	26	26	27	28	27	26	24	25	25	27	30	31	32	33	32	31	31	27	25	22	23	26	IZS	33	27.5	24
20	25	24	23	22	21	23	24	19	20	21	22	24	26	27	27	24	12	12	9	2	19	21	IZS	24	27	20.5	24
21	24	24	25	26	27	29	29	29	31	32	30	32	32	32	31	31	29	30	30	31	31	IZS	31	30	32	29.4	24
22	30	30	27	23	22	23	23	20	19	22	21	20	20	20	20	11	3	3	4	IZS	4	3	14	30	17.5	24	
23	18	22	24	25	27	27	27	25	14	18	27	29	29	29	29	28	23	21	12	IZS	12	5	13	9	29	21.4	24
24	5	19	17	9	4	2	1	1	2	4	20	26	27	28	29	28	19	14	IZS	26	25	26	27	27	29	16.8	24
25	26	26	27	25	20	13	13	9	3	7	18	17	19	19	21	22	33	IZS	36	34	36	36	36	36	36	23.1	24
26	35	34	34	34	33	32	33	31	27	30	32	33	34	35	32	32	IZS	27	24	27	31	29	27	27	35	31.0	24
27	29	31	33	36	36	38	38	37	36	35	34	35	34	34	35	IZS	33	32	33	33	32	32	30	29	38	33.7	24
28	28	29	31	33	33	30	29	29	29	28	26	26	26	27	IZS	28	26	15	11	20	20	24	27	28	33	26.2	24
29	28	29	30	30	29	29	30	31	30	31	32	32	31	IZS	29	28	27	26	25	25	17	13	11	7	32	26.1	24
30	8	9	7	7	5	6	2	1	2	6	12	15	IZS	22	28	21	18	16	13	14	18	21	22	23	28	12.9	24
31	21	23	23	23	24	23	25	22	22	21	20	IZS	22	26	28	27	16	4	3	14	21	22	22	19	28	20.5	24
HOURLY MAX	37	36	34	36	36	38	38	37	36	35	35	35	35	36	36	36	36	36	35	36	34	36	36	39	38		
HOURLY AVG	22.4	22.8	23.0	21.8	21.5	22.2	21.8	20.5	20.1	21.1	25.0	26.3	27.7	27.5	27.9	26.8	24.1	21.5	21.1	21.2	21.4	20.8	21.7	21.4			

STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

OBJECTIVE LIMIT:


ALBERTA ENVIRONMENT: 1-HR 82 PPB



MONTHLY SUMMARY

NUMBER OF 1-HR EXCEEDENCES:	0					
NUMBER OF NON-ZERO READINGS:	705					
MAXIMUM 1-HR AVERAGE:	39	PPB	@ HOUR(S)	22	ON DAY(S)	9
MAXIMUM 24-HR AVERAGE:	33.7	PPB			ON DAY(S)	27
					VAR-VARIOUS	
IZS CALIBRATION TIME:	32	HRS	OPERATIONAL TIME:	743	HRS	
MONTHLY CALIBRATION TIME:	4	HRS	AMD OPERATION UPTIME	99.9	%	
STANDARD DEVIATION	9.14		MONTHLY AVERAGE	22.93	PPB	

01 Hour Averages



— LICA 03_ PPB

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

JANUARY 2012

OZONE MAX instantaneous maximum in ppb

MST

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	DAILY MAX	24-HOUR AVG.	RDGS.
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00				
DAY																												
1	32	29	28	29	26	28	28	28	26	26	27	27	26	26	26	24	17	16	IZS	5	1	12	7	20	32	22.3	24	
2	28	28	27	29	29	31	31	31	31	31	30	29	28	27	27	25	22	IZS	20	18	16	12	14	13	31	25.1	24	
3	12	10	11	8	15	17	17	18	17	19	19	20	21	23	21	13	IZS	2	2	17	10	4	3	18	23	13.8	24	
4	18	15	13	9	4	6	9	2	2	3	16	17	17	15	17	IZS	13	9	7	3	3	2	2	2	18	8.9	24	
5	2	2	1	1	2	4	5	9	C	C	C	C	C	C	IZS	M	30	33	34	33	33	33	32	31	34	17.8	23	
6	31	32	32	32	31	29	29	30	28	28	29	29	32	IZS	33	31	30	31	29	29	29	27	25	22	33	29.5	24	
7	21	26	28	29	29	28	28	26	22	23	24	IZS	24	24	25	24	24	24	20	15	19	19	19	19	29	23.9	24	
8	21	21	22	22	23	25	28	29	28	29	30	IZS	34	35	36	37	37	36	35	33	32	29	29	28	37	29.5	24	
9	28	26	24	22	23	22	19	14	3	3	IZS	22	22	21	20	18	16	17	17	20	27	40	40	39	40	21.9	24	
10	38	37	36	36	36	35	35	33	35	IZS	35	35	35	35	35	35	31	30	30	30	31	30	31	31	38	33.7	24	
11	31	31	31	28	24	22	19	15	IZS	23	28	29	31	31	30	30	28	20	22	19	13	6	12	8	31	23.1	24	
12	13	8	10	10	17	22	27	IZS	27	29	30	33	33	33	35	32	32	32	33	33	33	32	31	30	35	26.7	24	
13	25	25	25	24	22	29	IZS	27	29	31	32	34	36	37	37	37	36	36	33	33	32	32	31	31	37	31.0	24	
14	31	30	28	24	22	IZS	27	27	19	21	25	30	31	31	30	30	29	29	29	28	29	28	28	26	31	27.5	24	
15	27	27	29	29	IZS	28	28	28	26	26	28	29	30	29	30	28	29	29	28	28	29	30	29	28	30	28.3	24	
16	28	27	27	IZS	29	28	27	26	26	26	27	28	28	29	29	29	27	26	25	21	20	23	22	22	29	26.1	24	
17	22	20	IZS	17	15	15	17	16	18	21	23	25	27	27	29	29	28	25	24	24	23	22	22	22	29	22.2	24	
18	23	IZS	24	25	27	26	25	25	26	28	29	29	30	32	31	30	30	30	29	28	28	28	28	27	32	27.7	24	
19	IZS	27	27	29	29	28	28	25	26	26	29	30	32	33	33	32	32	32	30	28	24	24	27	IZS	33	28.7	24	
20	26	26	25	23	23	25	26	21	22	22	23	25	27	28	29	27	17	17	14	3	26	25	IZS	25	29	22.8	24	
21	24	26	25	27	28	30	30	31	33	33	31	33	33	33	32	32	31	31	32	31	34	IZS	31	31	34	30.5	24	
22	31	30	29	26	25	26	25	22	23	23	22	20	20	21	22	20	19	11	8	15	IZS	8	6	17	31	20.4	24	
23	20	23	25	26	27	28	28	27	23	24	29	30	30	29	29	25	23	18	IZS	16	9	19	17	30	24.1	24		
24	15	22	21	14	7	6	2	1	4	11	26	27	28	29	31	30	27	25	IZS	26	26	27	28	27	31	20.0	24	
25	27	27	29	29	25	19	16	15	10	18	20	18	20	20	23	25	37	IZS	40	36	37	37	37	37	40	26.2	24	
26	36	35	35	35	35	34	34	33	29	32	33	35	35	36	35	34	IZS	31	29	33	33	30	28	28	36	33.0	24	
27	30	32	34	36	38	38	38	38	37	36	36	35	35	36	IZS	35	33	34	34	33	32	31	30	38	34.7	24		
28	29	30	32	34	34	32	30	30	30	28	27	28	27	28	IZS	28	28	22	16	23	24	28	29	34	28.1	24		
29	29	30	31	30	30	31	31	31	30	32	32	32	32	IZS	30	29	28	27	26	26	24	17	14	11	32	27.5	24	
30	10	10	10	9	7	8	5	2	4	11	15	18	IZS	25	30	28	20	18	14	16	19	22	23	24	30	15.1	24	
31	23	24	24	25	25	26	26	25	23	25	IZS	25	28	31	31	24	10	12	20	23	24	23	22	31	23.7	24		
HOURLY MAX	38	37	36	36	38	38	38	38	37	36	36	36	37	37	37	37	37	36	40	36	37	40	40	39				
HOURLY AVG	24.4	24.5	24.8	23.9	23.6	24.2	23.9	22.9	22.9	23.6	26.9	27.6	28.8	28.6	29.3	28.5	27.0	24.3	23.9	23.8	24.1	23.1	23.4	23.8				


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	705					
MAXIMUM INSTANTANEOUS VALUE:	40	PPB	@ HOUR(S)	VAR	ON DAY(S)	9, 25
IZS CALIBRATION TIME:	32	HRS	OPERATIONAL TIME:	743	HRS	
MONTHLY CALIBRATION TIME:	6	HRS				
STANDARD DEVIATION	8.27					

01 Hour Averages



— LICA O3MAX PPB

LICA
 O3_ / WD Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 01
 Site Name : LICA
 Parameter : O3
 Units : PPB

Wind Parameter : WD
 Instrument Height : 10 Meters

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	.56	1.13	1.55	1.83	4.95	5.94	9.33	4.10	1.83	2.40	23.33	23.47	7.77	3.11	5.23	3.39	100.00
< 110	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	.56	1.13	1.55	1.83	4.95	5.94	9.33	4.10	1.83	2.40	23.33	23.47	7.77	3.11	5.23	3.39	

Calm : .00 %



Total # Operational Hours : 707

Distribution By Samples


	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	4	8	11	13	35	42	66	29	13	17	165	166	55	22	37	24	707
< 110																	
< 210																	
>= 210																	
Totals	4	8	11	13	35	42	66	29	13	17	165	166	55	22	37	24	

Calm : .00 %

Total # Operational Hours : 707



Calibration Graph for Site: LICA Parameter: 03_ Sequence: 03 Phase: SPAll



Ambient Temperature

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

JANUARY 2012


AMBIENT TEMPERATURE hourly averages (Degrees C)

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR	
DAY	HOURLY MAX	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	MAX.	AVG.	RDGS.	
1	3.2	-10.5	-11.9	-12.9	-13.4	-14.9	-15.3	-15.2	-16.3	-18.2	-15.7	-13.7	-12.1	-10.6	-9.5	-8.8	-9.9	-13.5	-16.2	-17.8	-19.1	-20	-19.7	-20.3	-20.2	-8.8	-14.8	24
2	1.7	-13.2	-12.1	-12.1	-12.3	-11.4	-10.4	-9.4	-8.9	-8.8	-8.5	-7.3	-6.2	-4.7	-4.2	-4.2	-4.5	-5.1	-5.5	-5.7	-6.4	-6.6	-6.2	-6.2	-6.4	-4.2	-7.8	24
3	0.9	-7.1	-7.2	-7.1	-8.9	-9.4	-6.5	-6.8	-7.1	-7.7	-8.3	-4.5	-2.3	-1.3	-0.8	-0.8	-0.7	-1.2	-1.7	-2.6	-2.3	-2.3	-3	-3	-2.5	-0.7	-4.4	24
4	1.3	-1.9	-3.8	-4.2	-5.6	-7	-7.3	-7.1	-8.2	-8.6	-7	-3.3	-2.1	-1.3	-1.4	-0.3	-1	-1.9	-3.1	-4	-4.9	-5.5	-6	-6.7	-7.4	-0.3	-4.6	24
5	0.8	-8.6	-8.7	-8.4	-6.7	-6.1	-5.2	-4.6	-1.6	-0.5	0.9	1.6	2.2	2.4	3	3.8	3.5	2.7	3	2.6	1	0.2	0.2	0	-0.6	3.8	-1.0	24
6	0.8	-0.3	-0.3	-0.8	-1.7	-2.3	-2.9	-2.9	-2.2	-2.7	-2.8	-2.2	-1	0.3	1.9	1.6	0.7	-0.4	-1.2	-2.2	-2.9	-4.1	-5.3	-7.7	-8.8	1.9	-2.1	24
7	0.8	-9.1	-7.7	-6.9	-8.1	-7.6	-6.8	-6.4	-6.7	-7.6	-7.6	-6.4	-4.9	-3.2	-2.2	-1.4	-1.6	-4.3	-5.3	-7	-8.9	-10.2	-9.4	-9.1	-6.2	-1.4	-6.4	24
8	3.0	-4.7	-3.5	-2.7	-2	-1.1	-0.6	1.3	3	2.4	3	4.4	6.4	7.8	8.2	8.7	8.3	7.5	7.1	6.4	5.1	3.5	2.3	1.9	1.2	8.7	3.1	24
9	4.4	1.1	0.8	0.3	-2.1	-1.3	-1.1	-3.7	-4.3	-3.2	-2.2	0.3	2.1	3.1	2.7	3.3	4	3.2	3.1	2.7	3.3	2.7	5.2	5.5	4.7	5.5	1.3	24
10	4.4	3.2	1.7	0.9	1.3	0.8	0.8	0.8	0.6	-0.2	-1	-2.1	-2.7	-3.7	-4.5	-5.4	-6.7	-9.4	-13	-15.7	-16	-16.1	-16.4	-16.6	-17.4	3.2	-5.7	24
11	4.4	-18.2	-18.8	-19.5	-21.8	-22.9	-23.5	-23.5	-23.5	-23.4	-20.6	-17.4	-15.5	-13.6	-12.6	-12.1	-11.2	-12.3	-14.5	-16	-17.2	-17.8	-17.9	-17.5	-17.3	-11.2	-17.9	24
12	4.4	-15.9	-14.1	-12.9	-11	-9	-7.8	-7.4	-7.6	-7.8	-7	-5.5	-4	-3	-2.5	-1.9	-2.4	-3.1	-3	-2.8	-2.5	-2.2	-2.1	-2.3	-2.6	-1.9	-5.9	24
13	4.4	-3.1	-3.4	-3	-2.1	-2.9	-3	-3	-3.4	-3.2	-2.8	-2.4	-0.8	0	0.1	0.6	0.7	0	0.1	-0.3	-0.4	-1	-1.4	-1.6	-1.6	0.7	-1.6	24
14	4.4	-2	-2.7	-3.8	-4.3	-4.5	-4.7	-5.8	-7.6	-7.9	-7	-5.6	-4.4	-3.4	-3.2	-3.2	-3.3	-3.7	-3.9	-3.9	-5.3	-7.5	-9.5	-10.7	-11.6	-2.0	-5.4	24
15	4.4	-12.9	-13.4	-14.2	-14.9	-15.3	-15.8	-16.5	-17.3	-18.3	-18.5	-19.2	-18.7	-18.5	-18.7	-19	-19.1	-19.9	-20.4	-20.6	-20.9	-21	-21.6	-22.7	-23.4	-12.9	-18.4	24
16	4.4	-24.1	-24.8	-25.4	-26.5	-27.4	-27.4	-27.6	-27.7	-27.3	-27.3	-27.2	-26.9	-26.6	-26.3	-26.1	-26.4	-27.2	-28.2	-28.4	-28.7	-28.6	-28.8	-29.3	-30.3	-24.1	-27.3	24
17	4.4	-31.2	-32.9	-34.2	-34.3	-35.4	-35.9	-34.8	-34.8	-34.9	-33.6	-32.2	-30.1	-28.7	-27.7	-27.3	-27.5	-29.3	-30.4	-31.2	-31.6	-32.1	-32.5	-32.7	-32.9	-27.3	-32.0	24
18	4.4	-33.1	-33.3	-33.4	-33	-32.4	-32.3	-32.2	-32.1	-31.8	-30.6	-29.3	-28	-26.2	-24.4	-23.9	-24.5	-25.2	-25.6	-25.9	-26.3	-26.5	-26.4	-26.2	-26.8	-23.9	-28.7	24
19	4.4	-27	-27.1	-26.9	-26.5	-26	-26.2	-26.5	-26.8	-26.6	-25.6	-23.8	-21.5	-19.7	-18.5	-17.7	-17.5	-18.5	-19.7	-20.8	-22.1	-22.8	-23.3	-23.3	-23.6	-17.5	-23.3	24
20	4.4	-23.8	-24.3	-24.6	-24.8	-25.6	-24.8	-25.1	-25.8	-24.8	-23.8	-22.1	-20.1	-18.1	-17	-16.8	-16.8	-18.6	-20.4	-21.2	-21	-19.9	-19.4	-18.9	-19.4	-16.8	-21.5	24
21	4.4	-19.8	-19.4	-19.3	-19.3	-18.9	-18.3	-18	-18.1	-17.8	-17.5	-17.1	-16.7	-16.3	-15.7	-15.3	-15	-14.8	-14.7	-14.6	-14.5	-14.5	-14.5	-14.4	-14.4	-14.4	-16.8	24
22	4.4	-14.4	-14.4	-15	-16.1	-16	-15.7	-15.6	-16.6	-16.5	-15	-13.4	-11.4	-10	-8.5	-6.9	-6.8	-9.3	-13	-14.1	-13.6	-11.7	-12.2	-12.7	-10.8	-6.8	-12.9	24
23	4.4	-10.1	-9.1	-9.5	-8.9	-8.2	-7.8	-8.2	-8.6	-9.7	-9.5	-7.7	-6.6	-5.1	-4.3	-3.8	-3.1	-4.1	-6.6	-8.4	-8.6	-10	-10.7	-8.6	-8.1	-3.1	-7.7	24
24	4.4	-8.3	-7.4	-8.6	-12.4	-13.9	-14.9	-15.8	-16.4	-16.4	-13	-7	-5.6	-3.3	-1.5	-0.7	-0.9	-2.4	-3.7	-3.9	-5.1	-5.9	-6.2	-6.3	-6.7	-0.7	-7.8	24
25	4.4	-6.9	-6.9	-6.4	-6.9	-8.6	-10.2	-11.8	-13.1	-13.9	-11.9	-8.9	-7.1	-5.7	-4.9	-2.7	-0.5	2	2.9	1.8	-0.3	-0.3	-1.5	-2.8	-3.6	2.9	-5.3	24
26	4.4	-5	-5.4	-5.7	-6.5	-7.1	-8.5	-8.5	-8.3	-9.4	-8.1	-6.4	-4.2	-2.8	-1.8	-1.7	-2.6	-4.3	-6.3	-8.1	-8.6	-7.8	-7.6	-8.5	-9.1	-1.7	-6.3	24
27	4.4	-8.2	-8.2	-8.8	-7.6	-6.8	-5.5	-5.3	-6	-7.2	-7.3	-6.8	-6.2	-6.1	-6	-5.5	-4.8	-4.6	-4.4	-4.1	-4.3	-4.9	-5.4	-5.2	-5.4	-4.1	-6.0	24
28	4.4	-5.1	-5.3	-5.9	-6.4	-7.6	-9.1	-10.5	-10.4	-11.2	-10.9	-10.9	-10.7	-10	-9.5	-9.9	-10.5	-11.1	-12.5	-13.9	-13.5	-12.7	-12.7	-11.9	-11.5	-5.1	-10.2	24
29	4.4	-11.3	-10.9	-10.6	-10.4	-10.4	-10.5	-10.5	-10.2	-10.2	-9.5	-8.7	-8	-6.9	-6.4	-5.8	-5.3	-5.1	-5	-5.1	-5.3	-6.3	-6.2	-5	-3.9	-3.9	-7.8	24
30	4.4	-3.1	-3.1	-3.2	-3.1	-2.9	-2.6	-2.5	-2.7	-2.5	-1.6	-0.2	0.7	1.2	2.8	4.4	3.9	2.9	1.7	1.1	1.4	1.9	1.9	2.1	1.2	4.4	0.0	24
31	4.4	0.2	-0.7	-1.5	-2.5	-3.2	-3.8	-4	-4.3	-5.2	-5.9	-2.6	-1.6	-0.1	0.9	1.5	1.6	0.9	-0.2	-0.7	0	0.3	-0.8	-1.9	-3.4	1.6	-1.5	24
HOURLY MAX	3.2	1.7	0.9	1.3	0.8	0.8	1.3	3.0	2.4	3.0	4.4	6.4	7.8	8.2	8.7	8.3	7.5	7.1	6.4	5.1	3.5	5.2	5.5	4.7				
HOURLY AVG	-10.8	-10.9	-11.2	-11.6	-11.8	-11.7	-11.8	-12.0	-12.3	-11.5	-9.9	-8.7	-7.6	-6.9	-6.4	-6.5	-7.4	-8.4	-9.2	-9.7	-10.0	-10.2	-10.4	-10.6				

STATUS FLAG CODES

S	- OUT OF SERVICE	OD	- OUTSIDE DETECTION LIMITS
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

24 HOUR AVERAGES FOR JANUARY 2012




MONTHLY SUMMARY

MINIMUM 1-HR AVERAGE:	-35.9 °C	@ HOUR(S)	5	ON DAY(S)	17
MAXIMUM 1-HR AVERAGE:	8.7 °C	@ HOUR(S)	14	ON DAY(S)	8
MAXIMUM 24-HR AVERAGE:	3.1 °C			ON DAY(S)	8
				VAR-VARIOUS	
CALIBRATION TIME:	0 HRS	OPERATIONAL TIME:	744 HRS		
		AMD OPERATION UPTIME:	100.0 %		
STANDARD DEVIATION:	9.60	MONTHLY AVERAGE:	-9.89 °C		

* Outside detection limits of sensor.

01 Hour Averages



Relative Humidity

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

JANUARY 2012


RELATIVE HUMIDITY hourly averages (%)

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR		
HOUR START	HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX	AVG	RDGS	
DAY																													
1		72	74	75	75	77	77	73	74	78	71	64	58	53	50	48	54	70	77	79	78	77	77	73	75	79	70.0	24	
2		57	56	58	58	54	53	53	54	57	60	60	61	61	63	66	69	72	74	76	80	81	80	81	82	82	65.3	24	
3		84	85	86	88	88	85	86	88	87	86	79	71	69	70	70	72	77	80	84	82	82	85	85	84	88	81.4	24	
4		82	89	88	90	91	92	91	89	89	88	87	85	81	79	74	78	82	85	87	88	89	89	90	89	92	86.3	24	
5		89	89	88	88	90	92	92	94	94	94	93	90	87	80	71	68	68	64	64	86	96	92	86	84	96	85.0	24	
6		76	73	73	73	73	74	74	73	75	76	76	71	67	60	59	61	65	67	70	70	74	77	83	87	87	72.0	24	
7		86	82	77	77	73	72	72	73	76	75	69	64	59	57	56	58	68	70	76	82	84	83	81	75	86	72.7	24	
8		71	66	62	60	57	60	67	66	67	66	62	55	51	49	46	47	49	51	54	59	64	68	70	73	73	60.0	24	
9		74	75	76	83	82	80	87	88	86	85	79	72	69	72	68	67	69	70	70	67	65	42	32	32	88	70.4	24	
10		36	44	51	58	66	71	74	68	67	66	65	63	56	59	55	60	61	59	58	60	62	63	63	64	74	60.4	24	
11		67	68	71	76	76	76	76	75	75	73	68	62	53	48	51	51	57	67	72	75	78	78	78	77	78	68.7	24	
12		78	79	79	78	75	82	87	89	90	82	74	68	63	61	60	62	66	65	64	63	67	69	73	77	90	73.0	24	
13		79	81	79	69	69	67	67	68	67	67	64	61	65	70	68	67	69	67	60	59	61	63	63	64	81	67.3	24	
14		66	69	72	75	77	76	78	81	83	80	75	73	72	71	71	73	77	80	79	85	87	85	82	81	87	77.0	24	
15		76	76	74	71	70	68	67	68	66	65	62	60	59	59	59	61	59	60	62	63	65	64	66	64	76	65.2	24	
16		65	66	63	63	64	64	65	67	66	65	61	58	57	58	56	57	59	62	65	67	68	69	70	69	70	63.5	24	
17		68	68	68	68	67	67	68	68	68	67	66	65	62	59	58	59	65	67	67	66	67	68	68	68	68	68	65.9	24
18		68	68	67	67	67	67	67	66	66	63	60	57	54	51	50	53	57	60	61	63	65	67	70	71	71	62.7	24	
19		72	72	72	72	72	72	72	73	73	71	69	66	62	59	58	57	59	64	67	71	73	73	74	74	74	68.6	24	
20		74	74	74	74	74	74	73	73	72	70	68	65	60	56	57	57	66	70	73	74	69	68	66	68	74	68.7	24	
21		69	68	69	69	68	65	65	64	64	69	75	74	73	74	76	77	78	77	76	74	72	70	70	71	78	71.1	24	
22		72	73	78	80	79	80	80	81	80	77	72	64	60	58	54	53	69	79	80	80	77	80	82	78	82	73.6	24	
23		75	71	70	69	70	71	75	77	80	75	70	66	61	58	58	56	60	68	75	76	80	82	80	81	82	71.0	24	
24		81	74	75	83	83	83	82	80	78	69	57	53	46	42	41	43	50	55	53	57	61	65	68	71	83	64.6	24	
25		74	76	76	78	83	85	86	85	83	77	78	74	73	83	82	72	47	34	38	47	40	43	45	47	86	66.9	24	
26		50	53	54	57	61	67	70	71	75	71	64	57	52	49	48	52	56	62	68	69	73	75	78	78	78	62.9	24	
27		70	64	63	61	65	70	67	68	69	61	57	54	55	55	56	63	70	76	78	83	88	89	88	87	89	69.0	24	
28		84	83	84	79	76	79	83	79	79	77	75	74	69	67	70	71	74	79	82	84	81	82	81	79	84	78.0	24	
29		78	75	73	73	74	77	80	82	85	85	84	84	86	91	92	92	91	91	91	91	91	91	91	91	92	85.0	24	
30		92	93	93	93	93	93	93	94	93	91	92	91	91	89	82	86	86	82	84	83	80	77	74	75	94	87.5	24	
31		77	77	77	77	78	80	79	80	80	82	69	66	61	57	53	55	62	69	72	68	67	70	72	76	82	71.0	24	
HOURLY MAX		92	93	93	93	93	93	93	94	94	93	91	91	91	92	92	91	91	91	91	91	96	92	91	92				
HOURLY AVG		73.0	72.9	73.1	73.6	73.9	74.8	75.8	76.0	76.4	74.3	70.8	67.2	64.1	63.0	61.7	62.9	66.4	68.7	70.5	72.6	73.7	73.7	73.6	74.0				

STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE


24 HOUR AVERAGES FOR JANUARY 2012



MONTHLY SUMMARY

MAXIMUM 1-HR AVERAGE:	96	%	@ HOUR(S)	20	ON DAY(S)	5
MAXIMUM 24-HR AVERAGE:	87.5	%			ON DAY(S)	30
CALIBRATION TIME:	0	HRS	OPERATIONAL TIME:	744	HRS	
			AMD OPERATION UPTIME:	100.0	%	
STANDARD DEVIATION:	11.34		MONTHLY AVERAGE:	71.11	%	

01 Hour Averages



Vector Wind Speed

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

JANUARY 2012

VECTOR WIND SPEED (WS) hourly averages (km/hr)

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	23:00	DAILY	24-HOUR	
HOURLY MAX	HOURLY AVG	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
DAY																													
1		7.2	7	6.7	6.2	5.1	5.8	5.8	4.1	4.2	7.3	7.2	9.7	8.1	6.7	5.8	4.1	0.9	0.8	0.8	0.8	0.7	2.7	0.4	1.9	9.7	4	24	
2		8.7	9.1	10	9.2	13.3	11.3	6.8	9	12.2	9.8	5.9	2.9	3.8	5.5	4.3	2.9	2.7	1.8	2	0.4	1.2	0.2	1.2	1.5	13.3	5.3	24	
3		2.1	3.1	3.4	1.8	4	6.6	5.2	6.7	3	3.8	5.3	4.3	1.3	2.1	0.5	0.3	1.1	1.6	1.1	2.4	0.8	0.3	1	1.6	6.7	2	24	
4		0.6	0.8	0.6	0.5	2	2.4	1.9	0.7	0.2	1.1	3.3	4.9	3.7	4.6	4.1	5.5	1.9	1.1	0.5	0.2	1.3	1.2	0.6	0.4	5.5	1.5	24	
5		0.8	1	0.7	0.2	1.3	3.1	3.4	3	3.8	14.1	12.2	11.8	12.6	13.5	15.1	14.6	12.5	15.4	14.2	16.6	17.7	13	7.9	5.8	17.7	8.9	24	
6		7.8	8	7.6	8.3	5.9	5.2	6.2	6.8	5.8	7.4	7.1	6.8	8.1	9.9	7.7	6	7.7	7.1	5.5	6.2	5.7	6	3.7	4.9	9.9	6.7	24	
7		3.9	5.1	5.1	5.2	5.3	3.4	4.5	4.8	4.6	5.5	5.9	6.3	6.5	7	5.8	4.7	3.1	5.1	1.7	0.8	0.5	1	1	1.6	7.0	4.1	24	
8		2.1	2.6	4	3.7	5.7	3.4	6.8	12.5	12.2	12.7	11.7	13.1	15.8	13.8	13.3	14.4	12.5	11.7	9	6.8	6	6.4	7.2	7.3	15.8	8.9	24	
9		8.5	6.5	4.1	2.8	5.4	4.6	1.3	0.3	1	1.7	2.8	2.9	1.2	2.3	7.8	5.9	6.1	5.6	5.8	8.4	9.5	15	16.3	17.5	17.5	6.0	24	
10		15.3	12.9	11.6	12.7	10.8	10.2	12.4	16.3	16.3	20.1	21.6	20.6	20.6	20.4	17.8	17.2	19.7	20	20.2	12.3	12.6	11	12.1	7.2	21.6	15.5	24	
11		6.3	6.1	1.9	2	1.7	1	1.1	1.1	0.9	1.7	2.5	3.9	4.3	4.6	5.1	2.8	1.2	0.6	1.2	0.8	0.4	0.7	1	1.1	6.3	2.3	24	
12		1.3	0.2	2.9	2.8	3	7	7.9	6.2	6.5	6.1	4.9	9.4	8.9	8.4	8.6	7	6	6.4	7.1	7	5.7	4.9	4.7	2.2	9.4	5.6	24	
13		1.2	1.1	4	6.6	6	6.8	5	6	7.8	7.8	7.5	9.2	11.1	14.3	14.6	13.5	12.5	9.1	9.2	6	8.9	8.6	7	6	14.6	7.9	24	
14		4.5	2.3	3.1	0.5	1.1	1.9	2.7	1.1	0.6	0.9	0.9	4.9	3.7	4	4.8	4	5.8	8.9	8	10.6	12.8	13.8	13	12	13.8	5.2	24	
15		15.3	13.8	13.9	14.4	12.7	14.2	14.3	13.4	14.5	12.3	15	14	13.9	13.6	11.4	10.5	12.9	10.9	10.4	9.4	8.6	8.7	7.2	9.3	15.3	12.3	24	
16		7.3	8.1	10.4	9.9	6.6	7	6.6	5.7	7.3	8.1	10.7	9.9	9.9	9	8.5	6.7	6.3	4.5	3.8	3.7	3.1	4.3	3.7	4.5	10.7	6.9	24	
17		4.3	3.5	3.4	3	0.5	4.2	5	5.3	5.5	4.4	5.5	5.9	6.8	7.9	9.2	7.2	7.4	5.6	6.1	7.1	6.8	7.3	7.3	7.1	9.2	5.7	24	
18		6.8	7.9	8.9	8.5	8.1	7.2	8.1	8.9	9.2	10.9	11	12.3	12.1	14	12.2	12.7	10.3	10.1	8.1	6.6	7.6	9.7	7.2	6.5	14.0	9.4	24	
19		6.7	7.7	6.7	6.3	6.3	5.2	5.7	6.6	6.8	6.8	7	8.7	10	10.4	10.9	8.3	7.8	7	5.4	5.4	5.8	6.6	7.2	6.2	10.9	7.1	24	
20		6.4	6.7	6	5.5	6.5	6.5	6	3.6	4.9	5.8	6.9	5.8	5.5	5.6	4.5	3.3	1.3	0.9	0.7	0.9	4.9	4.5	6.8	6.2	6.9	4.8	24	
21		4.8	5.1	6.6	8.3	10	8.7	8.2	8.9	9.8	10.1	10.5	11.7	12	11.3	9.3	8.4	5.7	6.5	6.5	6.2	6.7	5.5	4	1.9	12.0	7.8	24	
22		1.2	0.9	1.5	1.5	2	2.2	1.1	1.4	1.5	1.8	4.8	5.8	6.6	5.3	3.1	1.5	0.3	1.9	1.2	2.5	2	2.9	2.6	6.3	6.6	2.6	24	
23		8	9.8	10.7	11	12	10.3	7.8	5.1	3.2	2.8	7	7.6	5	4.8	4.3	3.1	4.6	4.4	3	5.4	1.9	1.2	3.9	0.4	12.0	5.7	24	
24		1	5.9	3	0.2	0.7	0.7	0.6	1	0.5	1.4	2	5.2	4.4	3.8	2.4	2.9	1.6	3.5	11.1	11.6	11.3	8.7	9	5.4	11.6	4.1	24	
25		5.4	3.7	4.2	3.1	1.6	0.6	1.7	0.6	0.5	3	5.1	5.2	6.4	6.5	6.3	8.2	9.9	16.4	11	9.6	9.1	8.9	7.8	7	16.4	5.9	24	
26		6.9	8.7	7.3	6.3	6.7	4.2	6.3	6.1	6	6.6	7.7	6.9	8.4	7.2	7.3	7.4	5.7	4.9	3.4	5.9	7.2	8.1	5.8	7.9	8.7	6.6	24	
27		7.8	9.1	9.4	10.6	11.4	11.3	11.2	7.8	9	8.9	10.1	9.4	7.2	6.6	4.6	4.4	4.4	4	4.1	4.6	5.9	4.2	2.7	3.4	11.4	7.2	24	
28		7	7.7	7.7	10.7	9.1	5.5	4.7	8.3	7.8	5.1	5.7	3	3	3.1	4.5	3.1	1.2	0.7	1.2	3.6	4.3	4.6	7.2	6.5	10.7	5.2	24	
29		5.8	5.2	8.7	8.3	7.3	7	9.4	8.1	7	6	8.2	7.5	6.7	6.5	5.6	4.9	4.6	5	4.1	3.7	1.2	0.9	0.6	0.8	9.4	5.5	24	
30		0.6	1.6	1.1	0.5	0.9	0.4	0.8	0.9	0.8	1.7	1.4	3.1	3.8	3.4	4.4	2.5	5.1	6.4	5.5	5.7	5.3	7	6.6	6.7	7.0	3.2	24	
31		7.1	6.5	5.8	5.7	6	6.7	6.2	5.6	4.9	0.7	1.5	2.4	3.1	3.8	4.8	2.4	0.6	0.8	0.8	4	5.9	6.3	5.7	5.4	7.1	4.3	24	
HOURLY MAX		15.3	13.8	13.9	14.4	13.3	14.2	14.3	16.3	16.3	20.1	21.6	20.6	20.6	20.4	17.8	17.2	19.7	20.0	20.2	16.6	17.7	15.0	16.3	17.5				
HOURLY AVG		5.6	5.7	5.8	5.7	5.8	5.6	5.6	5.7	5.8	6.3	7.1	7.6	7.6	7.7	7.4	6.5	5.9	6.1	5.6	5.7	5.9	5.9	5.6	5.2				

STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE


LAST CALIBRATION:

December 16, 2010


MONTHLY SUMMARY

MAXIMUM 1-HR AVERAGE:	21.6	KPH	@ HOUR(S)	10	ON DAY(S)	10
MAXIMUM 24-HR AVERAGE:	15.5	KPH			ON DAY(S)	10
CALMS (≤ 0 KPH)	1.34	%			OPERATIONAL TIME:	744 HRS
MONTHLY CALIBRATION TIME:	0	HRS			AMD OPERATION UPTIME:	100.0 %
STANDARD DEVIATION:	4.08				MONTHLY AVERAGE:	6.14 KPH

24 HOUR AVERAGES FOR JANUARY 2012



01 Hour Averages



LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

JANUARY 2012

VECTOR WIND SPEED MAX instantaneous maximum in km/hr

MST		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	
HOUR START		0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	MAX.	
HOUR END		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00		
DAY																											
1		10.2	9.8	9.7	9.5	7.1	7.7	7.9	9.2	8	9.6	9.7	16.5	12.8	9.4	8.3	7.1	3	2.7	3.2	2.4	4.3	6.3	5.2	9.3	16.5	
2		12.5	14.1	14.6	16.2	18.4	16.8	12.8	17.8	17.9	17.3	11.4	6.4	6.8	8.7	7.3	5.9	5.5	6	4.5	5	4.4	7.4	8.6	4.8	18.4	
3		10.9	6.5	6.3	5.1	9.4	9	7.3	9.3	7	8.6	9.5	8.6	3.7	4.1	2.9	2.3	2.7	4	3.4	5.7	2.9	5.9	5.8	6	10.9	
4		3.3	3.8	3.9	2.8	3.9	4.7	6.1	3.1	2.9	3.7	6.8	7.8	8.3	9.1	9	9.1	6.6	6.3	2.4	2.9	3.5	2.8	2.2	2.9	9.1	
5		2.2	5.6	3.1	4.9	7.1	6.7	9.4	7.9	8.4	19.4	18.1	17.3	20.2	19.4	25.6	20.2	17.3	24.7	20.5	27	29.7	19.4	13	8.9	29.7	
6		10.1	10.1	11	11	8.5	7.1	9.5	10.3	9.2	12.1	10.4	10.9	12.5	14.2	10.7	8.2	10.3	10.6	7.9	7.9	7.5	8.5	5.9	6.2	14.2	
7		5.1	7.7	7.5	8.2	8.1	5.4	6.7	7.1	7.4	7.3	9.4	10.2	9.9	11.1	9.3	9.1	6.3	8.1	4.3	2.3	2.6	2.7	2.9	3.5	11.1	
8		7.7	5.9	9.8	7.4	10.1	7.3	13.7	16.7	17.5	18	16.5	20.2	20.4	19.5	19.5	22.3	18.7	17.5	14	9	7.8	11.2	10	9.2	22.3	
9		11.5	9.5	8	6.2	7	6.5	3.8	3.7	3.4	4.4	5.6	7.1	7.4	12.2	16.2	9.9	8.9	8	8.6	12.7	16.2	22	27	25.6	27	
10		23.6	17.7	17.9	21.8	16.1	15.8	18.1	26.2	28.7	29	33	32.8	34.4	31.9	29.8	29.1	31.3	28.3	30.7	18.3	17.5	16.5	17	10.4	34.4	
11		8.6	8.7	5.6	4.1	3.2	3	2.8	2.5	3.5	4	6	8.1	8.7	10.4	10.4	5.7	4.1	2.1	3.2	3.1	2.3	2.6	3.3	3.4	10.4	
12		5.2	2.7	4.7	4.5	7.4	13.5	13.6	12.5	9.2	9.3	8.7	15.2	12.1	13.3	13	9.6	8.9	10.5	12.9	12.6	8.9	8	8	5.9	15.2	
13		2.9	3.2	6.9	9.9	9.3	9.4	9.4	10.8	11.5	11.8	11.6	13.1	20.2	28.2	24.3	22.4	18.6	15.9	13.2	9.7	11.3	11.8	11.8	9.1	28.2	
14		6.7	4.2	5.2	3.5	3.7	5	5.6	3.8	2.6	4.7	3.9	9.6	7.8	7.5	8.2	6.8	9.6	12	13.4	16.1	18.7	20.7	19.1	18.8	20.7	
15		22	23.6	20	22.4	18.6	19.6	22.9	20.2	22.8	19.1	22.7	18.9	21.3	18.5	16.5	16.2	18.8	16.4	18	14.6	13.6	16	12.2	12.5	23.6	
16		10.1	15	15.8	14.3	11.1	10	10	8.5	12.1	14.9	16.9	16.3	14.4	13.1	13	11.3	10.4	7	5.7	5.8	5	6.1	6.1	7.4	16.9	
17		6	5.7	5.9	5.4	29.2	6.7	6.4	7.8	8.6	6.7	9.2	9.3	12	12.6	15.1	14.7	10.6	8.5	9.7	12.1	10.8	11.3	10.1	11.5	29.2	
18		11.2	11.6	13.2	12	12	12.2	12.5	13.5	14	15	15.1	17.1	18.9	21.1	17.3	18.3	16.8	13.8	11.7	9.4	11.7	13.7	13.1	9.2	21.1	
19		9.1	10.2	10.7	8.5	9.4	7.4	7.4	11.6	9.3	9.8	10.6	12.9	17.3	15.7	16.5	12.1	10.9	8.8	7.6	7.9	8.2	8.8	9.4	7.6	17.3	
20		9	9.3	7.7	8.2	8.8	9.5	9.7	6.9	6.7	9.7	12.1	8.8	8.6	8.9	8.5	6.4	4.4	3	2.3	2.1	8.4	8.1	10.2	10.8	12.1	
21		8.9	9.4	10.9	12.8	15.9	13.3	12.8	16.2	15.8	15.9	16.4	19.2	18.1	17.8	14.9	13.9	11.6	10.9	10.8	10.3	11.6	8.4	5.8	3.8	19.2	
22		2.8	2.3	3.2	2.8	3.5	4.8	2.9	2.8	3.3	3.8	9.7	9.8	11.1	9.2	5.9	4.9	1.2	4.8	5.6	4.5	5.7	5.7	4.4	10	11.1	
23		11.8	15	15.8	18.3	16.4	16.1	13.9	8.5	6.4	5	13	12.3	11.8	7.1	7.5	7.8	7	6.7	6.3	7.1	6.2	4.6	5.6	4.2	18.3	
24		5.1	8.2	7.8	4.4	5.1	4.5	3.7	3.7	2.3	4	5.4	8.8	7.1	6.4	5.2	6.2	4	7.6	16.5	15.4	14.6	12.4	13.1	10	16.5	
25		8.4	8.6	10.2	6.7	5.4	3.6	4.5	4	3.2	6.9	9.2	9.8	11	10.9	10.9	12.7	15.4	26.6	24.5	16.2	11.9	11.5	11.8	9.8	26.6	
26		9.8	13.1	11.9	10	9.5	6.1	8.5	8.9	8.4	9.1	12.1	12.8	12.2	13.4	10.4	10.9	8.6	8.4	6.9	11.9	11.4	12	8.1	12.6	13.4	
27		10.7	14.2	13.6	16.6	18	18.8	19.8	12	11.9	13	15.3	13	10.5	13.1	7.4	9.2	8.7	6.8	7.3	9	9.4	6.9	5.3	5.9	19.8	
28		12.8	11.3	12.5	19.6	15.5	9	8.7	14.5	12.4	9.5	10.2	6.8	8.1	8.9	8.4	7.9	2.5	2.7	3.7	5.6	7.4	9.5	12.3	12.5	19.6	
29		8.4	9.7	16.3	12.3	11.9	14.4	15.4	13.9	10.1	8.9	14.2	12	11.3	9.8	8.8	8.5	7.5	8.4	9	7.3	5.6	3.1	4.8	3.6	16.3	
30		2.5	4.3	3.8	3	2.6	1.7	2.7	2.3	2.2	3.7	3.9	6.3	7.3	7.1	8.3	5	10.6	10.7	8.4	8.1	8.9	10.6	9.1	10.1	10.7	
31		11.1	11	8.4	8.1	9.7	10.3	8.8	7.4	7.8	3.1	4.7	4.7	5.3	5.7	10.3	6	7	3.3	5.5	6.6	8.2	8.1	9	7.5	11.1	
PEAK		23.6	23.6	20.0	22.4	29.2	19.6	22.9	26.2	28.7	29.0	33.0	32.8	34.4	31.9	29.8	29.1	31.3	28.3	30.7	27.0	29.7	22.0	27.0	25.6		


STATUS FLAG CODES

S - OUT OF SERVICE	IZS - IZS - DAILY ZERO/SPAN CHECK
N - INVALID DATA	M - MISSING DATA
D - INSTRUMENT DRIFT	P - POWER FAILURE
C - CALIBRATION	NA - NOT APPLICABLE

MONTHLY SUMMARY

MAXIMUM INSTANTANEOUS READING	34.4	KPH		@ HOUR(S)	12
				ON DAY(S)	10

01 Hour Averages



LICA
WSP / WD Joint Frequency Distribution (Percent)

January 2012

Distribution By % Of Samples

Logger Id : 01
Site Name : LICA
Parameter : WSP
Units : KPH

Wind Parameter : WD
Instrument Height : 10 Meters

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 6.0	.13	.26	1.07	1.88	2.01	3.76	6.04	3.76	1.88	2.15	13.84	8.87	2.15	1.20	.80	.26	50.13
< 12.0	.00	.13	.26	.00	2.28	2.01	3.09	.00	.00	.00	9.13	12.76	3.62	1.07	1.61	2.28	38.30
< 20.0	.40	.67	.00	.00	.13	.00	.40	.00	.00	.00	.53	.94	2.68	.80	1.74	.94	9.27
< 29.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.80	.13	.94
< 39.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 39.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	.53	1.07	1.34	1.88	4.43	5.77	9.54	3.76	1.88	2.15	23.52	22.58	8.46	3.09	4.97	3.62	

Calm : 1.34 %

Total # Operational Hours : 744

Distribution By Samples

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 6.0	1	2	8	14	15	28	45	28	14	16	103	66	16	9	6	2	373
< 12.0		1	2		17	15	23				68	95	27	8	12	17	285
< 20.0	3	5			1		3				4	7	20	6	13	7	69
< 29.0															6	1	7
< 39.0																	
>= 39.0																	
Totals	4	8	10	14	33	43	71	28	14	16	175	168	63	23	37	27	



Calm : 1.34 %

Total # Operational Hours : 744

Class Limits (KPH)

Period : 01/01/12-01/31/12

Level : 10



Vector Wind Direction

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

JANUARY 2012

VECTOR WIND DIRECTION (WD) hourly averages in degrees

MST

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24-HOUR	24-HOUR AVG	
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	AVG.	QUADRANT	RDGS.
DAY																											
1	255	248	238	234	229	233	231	243	231	239	243	233	229	228	231	239	151	115	113	58	217	94	162	128	232	SW	24
2	124	123	124	122	126	127	111	120	128	131	124	96	131	129	136	135	139	149	123	273	346	192	251	238	126	SE	24
3	275	247	249	241	258	247	240	241	248	225	239	239	262	248	294	129	107	87	161	112	23	253	160	164	238	SW	24
4	155	197	164	66	113	104	118	219	117	73	116	126	107	62	115	134	166	272	154	251	111	130	70	64	117	ESE	24
5	150	76	235	84	167	237	267	224	256	270	276	275	265	270	273	268	261	269	274	272	270	273	263	258	268	W	24
6	260	256	258	253	245	232	241	240	228	240	238	249	259	264	262	251	247	255	249	249	244	240	244	242	249	WSW	24
7	244	232	239	234	228	231	225	227	233	227	231	231	233	226	228	220	214	221	217	235	164	157	217	205	227	SW	24
8	146	163	216	216	214	228	243	236	234	245	241	246	252	254	263	266	267	267	263	254	236	240	238	245	247	WSW	24
9	244	242	241	231	237	232	201	149	94	74	127	121	212	171	221	243	232	237	228	238	255	267	269	273	245	WSW	24
10	268	269	279	296	289	283	306	314	315	328	317	310	326	318	314	327	331	319	319	315	317	314	312	304	311	NW	24
11	290	293	267	227	204	196	135	154	181	222	213	156	172	170	158	196	162	229	142	177	125	119	191	258	203	SSW	24
12	282	52	246	252	262	242	258	247	228	226	240	250	250	248	247	229	225	228	225	226	232	219	219	223	238	SW	24
13	183	167	242	245	235	243	232	234	240	237	237	259	274	287	290	283	280	273	273	254	257	266	269	263	280	W	24
14	264	269	249	245	138	234	235	236	181	54	191	130	103	77	66	72	55	54	52	25	21	22	28	21	38	NE	24
15	14	9	360	357	346	336	344	335	335	325	320	319	318	316	318	308	314	319	315	315	320	330	314	315	332	NNW	24
16	318	331	345	343	333	335	327	321	331	335	331	332	331	330	334	332	325	316	302	293	287	289	280	287	326	NW	24
17	250	238	238	250	249	226	230	227	229	235	233	234	242	240	257	238	220	235	239	237	231	227	228	226	235	SW	24
18	231	231	228	231	231	231	232	229	236	240	237	235	251	253	237	231	237	243	237	235	235	245	236	228	237	SW	24
19	230	231	234	234	229	229	224	230	240	233	234	249	254	256	266	260	260	258	245	226	232	240	242	238	242	WSW	24
20	235	236	237	240	239	238	241	235	232	232	237	234	231	229	234	247	144	115	50	65	123	114	129	125	220	SW	24
21	115	102	93	86	87	91	87	81	82	85	84	79	89	84	84	86	82	83	88	106	122	129	132	160	91	E	24
22	195	167	212	198	227	202	167	159	162	188	216	227	239	247	267	136	95	126	131	112	78	83	61	122	191	S	24
23	124	128	125	125	124	128	125	118	93	91	127	130	127	129	131	193	233	238	242	236	235	240	242	270	138	SE	24
24	244	229	224	168	143	189	128	175	237	110	146	130	139	129	156	141	127	112	131	130	127	124	125	115	136	SE	24
25	89	88	117	80	41	228	240	215	189	251	241	222	243	248	247	254	278	292	273	252	257	250	237	230	253	WSW	24
26	235	235	233	229	237	236	246	232	229	235	230	252	253	255	240	232	230	232	217	227	239	245	228	234	237	SW	24
27	231	235	236	255	263	285	289	275	258	260	252	245	227	222	231	214	225	222	216	228	237	272	250	257	249	WSW	24
28	272	269	277	294	303	300	297	331	329	329	318	325	248	239	233	230	131	89	130	125	95	102	121	121	292	WNW	24
29	95	99	118	117	98	106	119	118	94	108	128	124	133	134	133	133	129	133	125	133	36	135	46	40	117	ESE	24
30	307	12	208	271	49	1	110	158	150	129	199	223	219	211	229	256	226	227	238	236	237	244	248	247	233	SW	24
31	243	241	236	228	234	232	234	236	243	306	237	269	269	252	219	247	237	174	217	240	223	236	231	235	237	SW	24
HOURLY AVG	318	331	360	357	346	336	344	335	335	335	331	332	331	330	334	332	331	319	319	315	346	330	314	315			


STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MISSING DATA
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

LAST CALIBRATION:	December 16, 2010
DECLINATION :	NA

MONTHLY CALIBRATION TIME:	0	HRS	OPERATIONAL TIME:	744	HRS
STANDARD DEVIATION	72.81		AMD OPERATION UPTIME	100.0	%
			MONTHLY AVERAGE	251	DEG

01 Hour Averages



— LICA WDR DEG

Standard Deviation Wind Direction

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

JANUARY 2012

STANDARD DEVIATION WIND DIRECTION (STDWDIR) hourly averages in degrees

MST

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00
DAY																								
1	13	13	13	14	11	12	14	17	14	13	14	17	16	17	17	21	45	36	63	42	46	35	31	52
2	13	18	18	19	15	15	26	19	14	19	22	27	28	17	23	23	42	33	66	51	51	77	49	
3	59	31	28	55	33	9	9	9	35	17	14	19	52	25	36	77	33	33	32	34	45	68	50	32
4	37	37	42	51	22	26	38	69	47	45	20	20	26	21	23	17	30	54	56	57	34	44	55	45
5	46	49	68	53	44	35	42	29	23	18	20	19	17	19	19	18	16	19	20	19	18	19	17	16
6	15	15	16	14	15	17	16	18	18	17	18	18	18	19	19	16	14	15	12	12	11	12	8	9
7	11	15	15	13	15	16	14	15	13	14	15	17	20	19	18	19	19	14	39	53	56	58	59	45
8	45	49	36	24	21	21	23	19	18	18	17	18	16	17	19	18	18	18	18	16	15	20	18	15
9	16	15	24	28	10	12	43	35	38	38	52	28	67	55	34	24	16	16	20	17	15	19	20	20
10	17	18	18	16	16	18	15	15	14	14	15	15	15	16	16	18	14	15	15	15	15	13	12	13
11	14	12	33	26	28	52	34	41	43	39	32	31	34	36	31	38	50	51	28	35	76	56	34	30
12	48	63	14	23	27	15	17	16	15	15	19	16	17	16	15	16	17	19	17	20	20	18	17	28
13	34	47	28	13	16	13	26	21	18	18	19	19	20	20	19	19	18	18	18	18	15	16	17	17
14	20	32	25	36	41	39	38	57	69	61	54	23	28	21	18	19	16	14	16	19	21	20	19	18
15	16	17	21	17	17	14	17	17	14	15	15	16	16	15	16	14	13	14	15	14	15	13	13	13
16	12	14	15	16	14	15	15	14	14	16	14	17	18	19	17	18	12	14	25	39	43	36	43	34
17	39	34	34	41	52	23	22	23	25	29	33	27	27	27	25	25	15	23	27	29	27	25	26	23
18	26	24	22	24	26	27	27	24	25	23	21	21	22	20	20	20	20	18	18	18	18	17	17	16
19	18	17	18	15	18	16	14	16	17	17	20	19	17	19	20	19	17	14	13	12	15	14	13	12
20	16	17	18	18	17	17	19	27	18	18	19	21	18	20	23	21	47	40	43	30	20	20	15	18
21	22	24	20	19	17	21	18	19	17	20	18	19	21	19	18	19	21	20	23	25	20	17	17	26
22	35	36	18	23	19	28	42	34	43	34	26	23	19	22	25	35	63	49	62	26	35	21	20	18
23	15	20	15	18	16	15	18	20	20	28	21	18	28	21	19	24	15	14	14	12	47	48	13	39
24	32	14	23	55	47	78	69	37	70	39	47	18	24	23	37	37	46	19	12	11	12	15	16	23
25	21	30	22	22	29	61	35	56	62	18	20	23	20	21	18	17	21	18	17	14	17	14	16	17
26	17	17	19	16	15	18	11	14	15	15	17	20	19	20	18	19	16	14	16	17	16	14	15	18
27	18	19	17	16	18	19	18	18	16	16	18	17	19	19	19	27	20	17	25	18	19	21	22	21
28	19	18	18	16	16	19	18	14	15	18	18	30	58	41	28	26	34	41	29	16	19	22	17	20
29	19	26	20	21	22	21	20	20	21	24	17	18	16	14	14	16	18	18	25	34	44	45	49	41
30	55	27	50	41	42	54	50	49	39	51	52	26	21	35	24	24	21	18	17	16	20	18	16	17
31	14	14	13	14	14	14	11	11	15	54	36	20	22	17	21	41	60	64	45	15	14	13	13	12


STATUS FLAG CODES

S - OUT OF SERVICE	IZS - IZS - DAILY ZERO/SPAN CHECK
N - INVALID DATA	M - MISSING DATA
D - INSTRUMENT DRIFT	P - POWER FAILURE
C - CALIBRATION	NA - NOT APPLICABLE

LAST CALIBRATION: December 16, 2010

CALIBRATION TIME: 0 HRS OPERATIONAL TIME: 744 HRS

01 Hour Averages




— LICA STDWDIR DEG

Non-Continuous Monitoring

Passive Summary Results for January 2012


Lakeland Industry & Community Association

	Sulphur Dioxide ppb																												Reading	Site
	2	3	4	5	6	8	9	10	11	12	13	14	15	16	17	18	19	22	23	24	25	26	27	28	29	32	34			
Mean	0.2	0.4	0.5	0.5	0.5	0.5	0.4	0.4	0.3	0.5	0.6	1.0	0.4	0.4	0.5	0.3	0.4	0.4	0.3	0.5	0.5	0.6	1.0	0.5	0.4	0.5	0.4	0.6	-	
Minimum	0.1	0.1	0.1	0.2	0.1	0.2	0.1	0.1	0.1	0.1	0.1	0.4	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.3	0.1	0.2	0.1	0.2	#2	
Maximum	0.6	1.3	1.3	1.1	1.0	1.0	1.0	1.0	0.6	1.5	1.9	2.2	1.1	0.9	1.3	0.8	1.0	1.3	0.5	1.4	1.4	1.1	1.7	1.1	0.9	1.4	0.9	1.3	#27	



Passive Summary Results for January 2012 Lakeland Industry & Community Association


	Hydrogen Sulphide ppb																January 2012			
	3	5	10	11	12	13	14	16	17	18	22	24	25	26	27	29	32	34	Reading	Site
Mean	0.15	0.20	0.14	0.09	0.11	0.15	0.17	0.15	0.29	0.12	0.14	0.16	0.09	0.17	0.48	0.15	0.15	0.18	0.11	-
Minimum	0.03	0.10	0.10	0.04	0.06	0.04	0.12	0.06	0.08	0.05	0.08	0.09	0.04	0.12	0.13	0.09	0.09	0.09	0.07	#11
Maximum	0.29	0.38	0.21	0.13	0.17	0.80	0.21	0.21	0.67	0.18	0.23	0.21	0.18	0.25	1.12	0.25	0.22	0.29	0.17	#26



Passive Summary Results for January 2012


Lakeland Industry & Community Association

	Nitrogen Dioxide ppb																								January 2012	
	2	3	4	5	6	8	9	10	11	12	13	14	15	16	17	18	19	22	23	24	28	29	32	34	Reading	Site
Mean	0.8	1.1	1.0	1.0	1.6	0.9	1.3	2.3	0.5	0.9	0.9	1.3	1.1	1.4	1.8	0.9	0.8	1.5	0.4	1.9	4.1	1.8	0.8	2.0	2.8	-
Minimum	0.1	0.4	0.1	0.2	0.6	0.2	0.4	0.7	0.1	0.2	0.1	0.1	0.2	0.4	0.9	0.2	0.2	0.3	0.1	0.8	1.6	0.3	0.2	0.5	0.8	#23
Maximum	2.5	2.6	2.2	2.2	3.5	2.4	3.0	5.6	1.2	2.3	2.1	3.0	2.4	3.0	3.5	2.2	2.3	3.7	1.0	3.7	11.3	4.7	2.3	6.9	7.0	#28




Passive Summary Results for January 2012 Lakeland Industry & Community Association

	Ozone ppb																												January 2012	
	2	3	4	5	6	8	9	10	11	12	2011 13	14	15	16	17	18	19	22	23	24	28	29	32	34	Reading	Site				
Mean	21.4	27.5	29.6	28.0	26.6	29.1	26.9	23.5	21.2	25.1	27.5	27.6	25.7	26.1	27.5	23.8	27.7	25.6	23.7	26.7	24.3	26.3	32.2	28.3	26.7	-				
Minimum	11.9	17.6	20.0	18.5	16.8	19.1	18.0	13.9	11.5	14.0	18.4	19.1	16.1	16.6	17.8	13.3	18.6	15.1	12.8	17.1	15.8	17.3	25.0	17.6	22.3	#2				
Maximum	33.2	39.2	39.6	44.1	40.8	42.4	38.2	33.9	30.9	34.9	38.1	39.1	40.3	37.0	40.3	35.4	40.1	37.0	32.5	35.9	34.8	36.4	42.0	42.5	33.5	#4				



Volatile Organics

Volatile Organics in ug/m3 Site: LICA - Cold Lake South



1	2,2,4-Trimethylpentane	33	1,1,2,2-Tetrachloroethane
2	Carbon Disulfide	34	cis-1,3-Dichloropropene
3	Propene	35	trans-1,3-Dichloropropene
4	Vinyl Acetate	36	1,2-Dichloropropane
5	Vinyl Bromide	37	Bromomethane
6	Dichlorodifluoromethane (FREON 12)	38	Bromoform
7	1,2-Dichlorotetrafluoroethane	39	Bromodichloromethane
8	Chloromethane	40	Dibromochloromethane
9	Vinyl Chloride	41	Heptane
10	Chloroethane	42	Trichloroethylene
11	1,3-Butadiene	43	Tetrachloroethylene
12	Trichlorofluoromethane (FREON 11)	44	Benzene
13	Trichlorotrifluoroethane	45	Toluene
14	Ethanol	46	Ethylbenzene
15	2-Propanol	47	p+m-Xylene
16	2-Propanone	48	o-Xylene
17	Methyl Ethyl Ketone (2-Butanone)	49	Styrene
18	Methyl Isobutyl Ketone	50	1,3,5-Trimethylbenzene
19	Methyl Butyl Ketone (2-Hexanone)	51	1,2,4-Trimethylbenzene
20	Methyl t-butyl ether (MTBE)	52	4-ethyltoluene
21	Ethyl Acetate	53	Chlorobenzene
22	1,1-Dichloroethylene	54	Benzyl chloride
23	cis-1,2-Dichloroethylene	55	1,3-Dichlorobenzene
24	trans-1,2-Dichloroethylene	56	1,4-Dichlorobenzene
25	Methylene Chloride (Dichloromethane)	57	1,2-Dichlorobenzene
26	Chloroform	58	1,2,4-Trichlorobenzene
27	Carbon Tetrachloride	59	Hexachlorobutadiene
28	1,1-Dichloroethane	60	Hexane
29	1,2-Dichloroethane	61	Cyclohexane
30	Ethylene Dibromide	62	Tetrahydrofuran
31	1,1,1-Trichloroethane	63	1,4-Dioxane
32	1,1,2-Trichloroethane	64	Xylene (Total)


Polycyclic Aromatic Hydrocarbons

Polycyclic Aromatic Hydrocarbons (PAHs) Results for December 2011
LICA- Cold Lake South Site
Unit: ng/m3

PAHs	12/05/2011	12/12/2011	12/17/2011	12/23/2011	12/29/2011
Sample Volume (unit: m3)	330.37	330.34	330.32	330.36	330.38
1 1-Methylnaphthalene	0.424	0.333	0.908	0.363	0.757
2 1-Methylphenanthrene	0.303	0.303	0.303	0.303	0.303
3 2-Chloronaphthalene	0.303	0.303	0.303	0.303	0.303
4 2-Methylantracene	0.303	0.303	0.303	0.303	0.303
5 2-Methylnaphthalene	0.636	0.605	2.180	0.969	1.302
6 3-Methylcholanthrene	6.055	6.055	6.055	6.055	6.055
7 7,12-Dimethylbenzo(a)anthracene	0.303	0.303	0.303	0.303	0.303
8 9,10-Dimethylanthracene	1.211	1.211	1.211	1.211	1.211
9 Acenaphthene	0.206	0.151	0.279	0.182	0.218
10 Acenaphthylene	0.151	0.151	0.248	0.206	0.309
11 Anthracene	0.151	0.151	0.151	0.151	0.151
12 Benzo(a)anthracene	0.151	0.151	0.151	0.151	0.151
13 Benzo(a)fluorene	0.303	0.303	0.303	0.303	0.303
14 Benzo(a)pyrene	0.151	0.151	0.151	0.151	0.151
15 Benzo(b)fluoranthene	0.151	0.151	0.151	0.151	0.151
16 Benzo(b)fluorene	0.303	0.303	0.303	0.303	0.303
17 Benzo(e)pyrene	0.303	0.303	0.303	0.303	0.303
18 Benzo(g,h,i)perylene	0.151	0.151	0.151	0.151	0.151
19 Benzo(k)fluoranthene	0.151	0.151	0.151	0.151	0.151
20 Biphenyl	0.938	0.848	2.180	0.938	1.514
21 Chrysene	0.151	0.151	0.151	0.151	0.151
22 Coronene	0.303	0.303	0.303	0.303	0.303
23 Dibenz(a,h)anthracene	0.151	0.151	0.151	0.151	0.151
24 Dibenzo(a,e)pyrene	0.605	0.605	0.605	0.605	0.605
25 Fluoranthene	0.266	0.151	0.327	0.309	0.291
26 Fluorene	0.684	0.357	1.011	0.745	0.708
27 Indeno(1,2,3-cd)pyrene	0.151	0.151	0.151	0.151	0.151
28 m-Terphenyl	0.303	0.303	0.303	0.303	0.303
29 Naphthalene	0.775	0.842	2.125	0.866	1.387
30 o-Terphenyl	0.303	0.303	0.303	0.303	0.303
31 Perylene	0.303	0.303	0.303	0.303	0.303
32 Phenanthrene	1.144	0.503	1.435	1.108	1.320
33 p-Terphenyl	0.303	0.303	0.303	0.303	0.303
34 Pyrene	0.151	0.151	0.212	0.272	0.212
35 Quinoline	1.211	1.211	1.211	1.211	1.211
36 Tetralin	0.303	0.303	0.303	0.303	0.303

Note: - values were calculated by the formula of [reading (ug) x 1000 / sample volume (m3)].
- Where the analytical results are less than the minimum detection limit (MDL), the MDL has been used in calculations.
- No sample result for Dec 29 is included in this report because it is not available when the monthly report was preparing.

PAHs in ng/m3 Site: LICA - Cold Lake South




1	1-Methylnaphthalene
2	1-Methylphenanthrene
3	2-Chloronaphthalene
4	2-Methlyanthracene
5	2-Methylnaphthalene
6	3-Methylcholanthrene
7	7,12-Dimethylbenzo(a)anthracene
8	9,10-Dimethylanthracene
9	Acenaphthene
10	Acenaphthylene
11	Anthracene
12	Benzo(a)anthracene
13	Benzo(a)fluorene
14	Benzo(a)pyrene
15	Benzo(b)fluoranthene
16	Benzo(b)fluorene
17	Benzo(e)pyrene
18	Benzo(g,h,l)perylene
19	Benzo(k)fluoranthene
20	Biphenyl
21	Chrysene
22	Coronene
23	Dibenz(a,h)anthracene
24	Dibenzo(a,e)pyrene
25	Fluoranthene
26	Fluorene
27	Indeno(1,2,3-cd)pyrene
28	m-Terphenyl
29	Naphthalene
30	o-Terphenyl
31	Perylene
32	Phenanthrene
33	p-Terphenyl
34	Pyrene
35	Quinoline
36	Tetralin

Polycyclic Aromatic Hydrocarbons (PAHs) Results for January 2012
LICA- Cold Lake South Site
Unit: ng/m3

PAHs	01/04/2012	01/10/2012	01/16/2012	01/22/2012	01/28/2012
Sample Volume (unit: m3)	330.35	330.36	330.35	330.34	330.36
1 1-Methylnaphthalene	11.140	0.575	2.058	5.873	3.390
2 1-Methylphenanthrene	0.303	0.303	0.303	0.303	0.303
3 2-Chloronaphthalene	0.303	0.303	0.303	0.303	0.303
4 2-Methylantracene	0.303	0.303	0.303	0.303	0.303
5 2-Methylnaphthalene	23.036	1.029	2.785	11.563	6.781
6 3-Methylcholanthrene	6.054	6.054	6.054	6.054	6.054
7 7,12-Dimethylbenzo(a)anthracene	0.303	0.303	0.303	0.303	0.303
8 9,10-Dimethylanthracene	1.211	1.211	1.211	1.211	1.211
9 Acenaphthene	0.981	0.151	0.151	0.678	0.315
10 Acenaphthylene	3.360	0.151	0.151	3.300	0.642
11 Anthracene	0.230	0.151	0.151	0.363	0.151
12 Benzo(a)anthracene	0.157	0.151	0.151	0.151	0.151
13 Benzo(a)fluorene	0.303	0.303	0.303	0.303	0.303
14 Benzo(a)pyrene	0.151	0.151	0.151	0.151	0.151
15 Benzo(b)fluoranthene	0.351	0.151	0.266	0.418	0.151
16 Benzo(b)fluorene	0.303	0.303	0.303	0.303	0.303
17 Benzo(e)pyrene	0.303	0.303	0.303	0.303	0.303
18 Benzo(g,h,l)perylene	0.303	0.151	0.151	0.170	0.151
19 Benzo(k)fluoranthene	0.151	0.151	0.151	0.151	0.151
20 Biphenyl	3.148	0.848	1.786	3.269	1.514
21 Chrysene	0.309	0.151	0.224	0.327	0.151
22 Coronene	0.303	0.303	0.303	0.303	0.303
23 Dibenz(a,h)anthracene	0.151	0.151	0.151	0.151	0.151
24 Dibenzo(a,e)pyrene	0.605	0.605	0.605	0.605	0.605
25 Fluoranthene	0.521	0.151	0.581	1.253	0.363
26 Fluorene	2.186	0.381	0.545	1.683	0.708
27 Indeno(1,2,3-cd)pyrene	0.182	0.151	0.151	0.157	0.151
28 m-Terphenyl	0.303	0.303	0.303	0.303	0.303
29 Naphthalene	17.466	1.411	8.264	9.263	4.117
30 o-Terphenyl	0.303	0.303	0.303	0.303	0.303
31 Perylene	0.303	0.303	0.303	0.303	0.303
32 Phenanthrene	2.343	0.442	1.017	3.511	1.411
33 p-Terphenyl	0.303	0.303	0.303	0.303	0.303
34 Pyrene	0.484	0.151	0.375	0.739	0.254
35 Quinoline	1.211	1.211	1.211	1.211	1.211
36 Tetralin	0.303	0.303	0.303	0.303	0.303

Note: - values were calculated by the formula of [reading (ug) x 1000 / sample volume (m3)].
- Where the analytical results are less than the minimum detection limit (MDL), the MDL has been used in calculations.

PAHs in ng/m3 Site: LICA - Cold Lake South



1	1-Methylnaphthalene
2	1-Methylphenanthrene
3	2-Chloronaphthalene
4	2-Methlyanthracene
5	2-Methylnaphthalene
6	3-Methylcholanthrene
7	7,12-Dimethylbenzo(a)anthracene
8	9,10-Dimethylanthracene
9	Acenaphthene
10	Acenaphthylene
11	Anthracene
12	Benzo(a)anthracene
13	Benzo(a)fluorene
14	Benzo(a)pyrene
15	Benzo(b)fluoranthene
16	Benzo(b)fluorene
17	Benzo(e)pyrene
18	Benzo(g,h,l)perylene
19	Benzo(k)fluoranthene
20	Biphenyl
21	Chrysene
22	Coronene
23	Dibenz(a,h)anthracene
24	Dibenzo(a,e)pyrene
25	Fluoranthene
26	Fluorene
27	Indeno(1,2,3-cd)pyrene
28	m-Terphenyl
29	Naphthalene
30	o-Terphenyl
31	Perylene
32	Phenanthrene
33	p-Terphenyl
34	Pyrene
35	Quinoline
36	Tetralin

Calibration Reports

Sulphur Dioxide

SO2 Calibration Report Station Information

Calibration Date	January 5, 2012	Previous Calibration	December 8, 2011
Company	Lakeland Community and Industry Association		
Plant / Location	LICA 1 - Cold Lake South		
Start Time (MST)	8:59	End Time (MST)	12:40
Reason:	Monthly Calibration		
Barometric Pressure	0.913 atm	Station Temperature	22 Deg C
Cal Gas	48.3 ppm	Gas Cyl. #	LL103831
DAS Output Voltage	0 - 10 Volts	Cal Gas Expiry date	February 28, 2013
		Chart Rec. Output	NA Volts

Equipment Information

Analyzer Make / Model:	Thermo 43i	S/N :	806528242	Method:	Fluorescent
Converter Make / Model:	NA	S/N :	NA		
Calibrator Make / Model:	API 700	S/N :	831	Method:	Dilution
DAS Make / Model:	ESC 8832	S/N :	3485		
Chart Recorder Make / Model:	NA	S/N:	NA		
Flow Meter:	API 700	S/N :	831		

Analyzer Settings

Before Calibration			After Calibration		
Concentration Range	0 - 1000		ppb		
Sample Flow / Box Temp	440 ccm	30.2 Deg C	441 ccm	31.5	Deg C
HVPS / Lamp Setting	-632	746	-652	745	
PMT / RxCell Temp	OK Deg C	45.1 Deg C	OK Deg C	45.2	Deg C
Converter / IZS Temp	NA Deg C	45 Deg C	NA Deg C	45.0	Deg C
Offset / Slope	6.1	1.023	6	1.009	

Calibration Data

Dilution Flow Rate	Source Gas Flow Rate	Calculated Concentration	Indicated Conc. (DAS)	Correction Factor
4995	0	0	0	N/A
No Zero Adj				
4953	41.4	400	403	0.9935
4953	41.4	400	400	1.0000
4976	23.3	225	227	0.9917
4987	12.9	125	127	0.9812
4995	0	0	0	N/A
Sum of Least Squares				0.9975
New Correction Factor				1.0000

Before Calibration

Auto Zero	-0.1	After Calibration	-0.1
Auto Span	381.0		379.0
Sample Lines Connected			YES

Percent Change

Previous Month's Calibration Correction Factor:	0.9985
Current Correction Factor Before Span Adjust:	1.0000
Percent Change:	-0.1%


Notes: **N/A : Not applicable**

Calibration Performed by: Ting Xu

SO2 Calibration Curve


Calibration Date	January 5, 2012
Company	Lakeland Community and Industry Association
Plant / Location	LICA 1 - Cold Lake South
Start Time (MST)	8:59
End Time (MST)	12:40

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient Slope Intercept (± 3% F.S.)	(≥ 0.995)
0	0	n/a	0.999938	0.999938
125	127	0.9812	0.998158	0.998158
225	227	0.9917	1.320901	1.320901
400	400	1.0009		



Notes:

01 Minute Averages



Total Reduced Sulphur

TRS Calibration Report
Station Information

Calibration Date	January 4, 2012	Previous Calibration	December 7, 2011
Company	Lakeland Industry & Community Association		
Plant / Location	LICA 1 - Cold Lake South		
Start Time (MST)	14:48	End Time (MST)	19:20
Reason:	Monthly Calibration		
Barometric Pressure	0.921 atm	Station Temperature	22 Deg C
Cal Gas	10.2 ppm	Gas Cyl. #	BLM000804
DAS Output Voltage	0 - 10 Volts	Cal Gas Expiry date	February 2, 2012
		Chart Rec. Output	NA Volts

Equipment Information

Analyzer Make / Model:	Thermo 450i	S/N :	812728560	Method:	Fluorescent
Converter Make / Model:	CDN 101	S/N :	250		
Calibrator Make / Model:	API 700	S/N :	831	Method:	Dilution
DAS Make / Model:	ESC 8832	S/N :	3485		
Chart Recorder Make / Model:	NA	S/N:	NA		
Flow Meter:	API 700	S/N :	831		

Analyzer Settings

Before Calibration		After Calibration	
Concentration Range	0 - 100		
Sample Flow / Box Temp	350 ccm, 32.4 Deg C	352 ccm, 33.2 Deg C	
HVPS / Lamp Setting	-623.1, 751	-622.7, 752	
PMT / RxCell Temp	OK Deg C, 45.2 Deg C	OK Deg C, 45 Deg C	
Converter / IZS Temp	810 Deg C, 45 Deg C	810 Deg C, 45.0 Deg C	
Offset / Slope	13.1, 1.261	13.5, 1.308	

Calibration Data

Dilution Flow Rate	Source Gas Flow Rate	Calculated Concentration	Indicated Conc. (DAS)	Correction Factor
4996	0	0	0	N/A
	No Zero Adj			
4959	39.2	80	77	1.0389
4959	39.2	80	80	1.0000
4980	19.6	40	41	0.9753
4986	11.2	23	23	1.0000
4996	0.0	0	0	N/A
Sum of Least Squares				0.9949
New Correction Factor				1.0000

Before Calibration

Auto Zero	-0.4	After Calibration	-0.2
Auto Span	60.1		63.8
Sample Lines Connected			YES

Percent Change

Previous Month's Calibration Correction Factor:	1.0000
Current Correction Factor Before Span Adjust:	1.0389
Percent Change:	-3.7%


Notes: **N/A : Not applicable**

Calibration Performed by: Ting Xu

TRS Calibration Curve


Calibration Date	January 4, 2012
Company	Lakeland Industry & Community Association
Plant / Location	LICA 1 - Cold Lake South
Start Time (MST)	14:48
End Time (MST)	19:20

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient Slope Intercept	(≥ 0.995) (0.85 to 1.15) (± 3% F.S.)
0	0	n/a		0.999793
23	23	0.0000		1.000785
40	41	0.5576		0.260776
80	80	0.4998		



Notes:

01 Minute Averages



Total Hydrocarbons

THC Calibration Report

Station Information			
Calibration Date:	January 5, 2012	Previous Calibration	December 8, 2011
Company:	Lakeland Industry and Community Association		
Plant / Location:	LICA1/Cold Lake		
Start Time (MST)	11:55	End Time (MST)	15:34
Reason:	Monthly Calibration		
Barometric Pressure:	0.924 atm	Station Temperature:	21 Deg C
Calibrator:	API 700	S/N:	831
Cal Gas Concentration:	CH4 980 PPM	C3H8 304 PPM	
	TOTAL CH4 1816.0 PPM	Gas Cyl. # LL84144	Cal Gas Expiry Date: December 3, 2013
DAS make & Model:	ESC 8832	S/N :	3485
Chart Recorder:	NA	S/N:	NA
Output Voltage Range:	0 - 10 VDC	Chart Speed:	NA mm/hr

Analyzer Information			
Make / Model	TEI 51C-LT	S/N :	427408718
Method	Flame Ionization		

Analyzer Settings				
	Before Calibration		After Calibration	
Concentration Range	0 - 50	ppm	0 - 50	ppm
Sample Pressure	6.5	psi	6.5	psi
Hydrogen Pressure	8	psi	8	psi
Air Pressure	20	psi	20	psi

Calibration Data				
Dilution Flow	Source Gas Flow	Calculated Concentration	Indicated Concentration	Correction Factor
3000	0.0	0.0	-0.1	NA
3000	0.0	0.0	0.0	NA
3000	70.0	41.4	41.1	1.0075
3000	70.0	41.4	41.7	0.9930
3000	35.0	20.9	20.7	1.0117
3000	20.0	12.0	11.9	1.0106
3000	0.0	0.0	0.0	NA
New Correction Factor:				0.9930

Percent Change	
Previous Calibration Correction Factor:	0.9930
Current Correction Factor Before Span Adjust:	1.0075
Percent Change:	-1.4%

IZS Calibration Data		
	Before Calibration	After Calibration
Auto Zero	0.0	0.0
Auto Span	34.6	35.1
Sample Lines Connected	YES	

Cylinder Pressures			
Span	1700 psi	Hydrogen	1500 psi
Zero Air	32 psi		


Notes: **NA : Not Applicable**

Calibration Performed by: Ting Xu

THC Calibration Curve


Calibration Date	January 5, 2012		
Company	Lakeland Industry and Community Association		
Plant / Location	LICA1/Cold Lake		
Start Time (MST)	11:55	End Time (MST)	15:34

Calculated Conc. ppm	Indicated Response ppm	Correction Factor	Correlation Coefficient Slope (0.85 to 1.15)	Correlation Coefficient Intercept (±3% F.S.)
0.0	0.0	NA	0.999885	1.007588
12.0	11.9	1.0106		-0.16010
20.9	20.7	1.0117		
41.4	41.7	0.9930		



Notes:

01 Minute Averages



Particulate Matter 2.5

TEOM 1405F Audit

	<u>Station</u>		<u>Audit Transfer Standard</u>
Date:	January 4, 2012	Make/Model:	Streamline FTS
Station Name:	LICA 1	Serial Number:	Hi 091001
Location:	Cold Lake South	Cell s/n:	Lo 091099
Operator:	LICA	Thermometer s/n:	Station Temp Sensor

	<u>Sampler</u>		<u>Set-up and current Sampler readings</u>
Make/Model	Thermo Scientific Series 1405F	F-Main Set Pt (l/min)	3.00
Unit #	AMU 1775	F-Aux Set Pt (l/min)	13.67
Unit s/n	1405A201620804	Filter Load (%)	36.2%
Firmware Ver.	1.52	K _o Factor	14578.0
Parameter	PM 2.5 (with FDMS)	Temp (°C)	-1.8
		Press (ATM)	0.920

Conversion from mmHg or "Hg to ATM (Atmospheres)

ATM = (mmHg) X (1.316 X 10⁻³) or ATM = ("Hg) X (3.34207 X 10⁻²)

Note: Tolerances are noted as BOLD in Brackets

Audit

Status			
Noise <0.10ug	0.009	Warnings	None
0.36	0.33		
Temperature/Pressure			
Measured Temp (± 2 °C)	-1.6	Δ °C	-0.2
Measured Press (± 0.01atm)	0.916	DATM	0.004
Flow Audit			
Indicated Main Flow (l/min)	3.00	Main Flow Drift (±10.0%)	0.50%
Measured Main Flow (l/min)	3.00	Flow Adjusted to Measured?	Yes
Indicated Bypass Flow (l/min)	13.67	Bypass Flow Drift (±10.0%)	0.37%
Measured Bypass Flow (l/min)	13.53	Flow Adjusted to Measured?	Yes
Leak Check		Instrument Setup	
Main (< 0.15 l/min)	NA	Flow Control = Active	
Aux (< 0.6 l/min)	NA	Report Conditions = Actual	
K_o Factor			
Measured	NA		
K _o Difference (± 2.5%)	NA		

Start Time: 16:27 **Finish Time:** 17:58

Sample Inlet Cleaned: Yes **New Filters Installed:** YES
New Filter Loading %: 26.3%

Comments:

Auditor/s: Ting Xu

Nitrogen Dioxide

NOx - NO- NO2 Calibration Report
Station Information

Calibration Date	January 4, 2012	Previous Calibration	December 7, 2011	
Company	LICA	Plant/Location	Cold Lake South	
Start Time (MST)	14:37	End Time (MST)	20:07	
Reason:	Monthly Calibration			
Barometric Pressure	0.921 atm	Station Temperature	22 Deg C	
Cal Gas Concentration	NOx 49.7 ppm	NO 49.4 ppm	Cal Gas Expiry date	February 28, 2013
Cal Gas Cylinder #	LL103831	MFCF	0	
DAS Output Voltage	0 - 10 Volts	Chart Rec. Output	NA Volts	

Equipment Information

Analyzer Make / Model:	Thermo 42C	S/N :	427408716	Method:	Chemiluminescent
Calibrator Make / Model:	Envionics 6100	S/N:	4760		
DAS Make / Model:	ESC 8832	S/N :	3485		
Chart Recorder Make / Model:	NA	S/N:	NA		
Flow Meter:	Envionics 6100	S/N :	4760		

Analyzer Settings

Before Calibration				After Calibration			
Concentration Range	0 - 500			ppb			
Sample Flow/Conv. Temp	727 ccm	316 Deg C		720 ccm	317 Deg C		
Ozone Flow / Vacuum	OK ccm	173.6 Hg-A		OK ccm	171.6 Hg-A		
HVPS / A ZERO	-821 Volts	NA MV		-821 Volts	NA MV		
Rx/ Temp / PMT Temp	49.9 Deg C	-2.4 Deg C		49.9 Deg C	-2.5 Deg C		
Box Temp / IZS Temp	26.7 Deg C	OK Deg C		28.6 Deg C	OK Deg C		
Offset	3.7 NOx	4.3 NO		3.8 NOx	3.5 NO		
Slope	1.007 NOx	0.878 NO		1.007 NOx	0.893 NO		
NO2 COEF / Conv Efficiency	0.998 NO2	NA		0.998 NO2	NA		

Dilution Calibration Data

Dilution Air Flow Rate	Source Flow Rate	O3 Set Point	Calculated Concentration			Indicated Concentration			Correction Factor	
			NOx	NO	NO2	NOx	NO	NO2	NOx	NO
4995	0.0	NA	0	0	NA	0	0	0	NA	NA
	No Zero Adj									
4954	40.4	NA	402	400	NA	396	394	3	1.0152	1.0142
4954	40.4	NA	402	400	NA	403	400	3	0.9976	1.0000
4974	20.2	NA	201	200	NA	202	200	1	0.9952	1.0000
4985	10.1	NA	100	100	NA	101	100	1	0.9950	1.0000
4996	0.0	NA	0	0	NA	0	0	0	NA	NA

Gas Phase Titration Calibration Data

Dilution Air Flow Rate	Source Flow Rate	O3 Set Point	Calculated Concentration			Indicated Concentration			NO2 Correction Factor	NO2 Conv Efficiency
			NOx	NO	NO2	NOx	NO	NO2		
4954	40.4	NA	402	400	NA	402	400	2	NA	NA
	No Adj. Required									
4954	40.4	350	402	NA	322	402	80	322	1.0000	100.00%
4954	40.4	150	402	NA	141	402	261	141	1.0000	100.00%
4954	40.4	75	402	NA	72	401	330	72	1.0000	100.00%

Linearity	Sum of Least Squares		NOx= 0.997	NO= 0.999	NO2= 1.000
OK?	Yes	No	Correction Factors: NOx= 0.9976	NO= 1.0000	NO2= 1.0000
			Average Converter Efficiency= 100.00%		

Before Calibration				After Calibration			
Auto Zero	0.1 NOx	0.2 NO2		0.1 NOx	0.2 NO2		
Auto Span	459 NOx	448 NO2		331 NOx	319 NO2		
	Sample Lines Connected YES						
Percent Change from Previous Calibration	NOx	-1.2%	NO	-1.3%	NO2	-0.3%	


Notes: **NA : Not Applicable**

Calibration Performed by: Ting Xu

NO2 Calibration Curve

Calibration Date	January 4, 2012
Company	LICA
Plant / Location	Cold Lake South
Start Time (MST)	14:37
End Time (MST)	20:07

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient Slope	(≥ 0.995) (0.85 to 1.15)	0.99929
3	2	N/A	Intercept	(± 3% F.S.)	0.32166
70	72	0.9722			
139	141	0.9858			
320	322	0.9938			




Notes:

NOx Calibration Curve

Calibration Date January 4, 2012
 Company LICA
 Plant / Location Cold Lake South
 Start Time (MST) 14:37 End Time (MST) 20:07

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient Slope	(≥ 0.995)	0.999998
0	0	N/A	Intercept	($\pm 3\%$ F.S.)	0.20403
100	101	0.9950			
201	202	0.9952			
402	403	0.9976			




Notes:

NO Calibration Curve


Calibration Date January 4, 2012
 Company LICA
 Plant / Location Cold Lake South
 Start Time (MST) 14:37 End Time (MST) 20:07

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient Slope	(≥ 0.995)	1.000000
0	0	N/A	Intercept	($\pm 3\%$ F.S.)	-0.0160
100	100	0.9989			
200	200	0.9990			
400	400	0.9990			



Notes:

01 Minute Averages



— LICA

NOX_

PPB

— LICA

NO_

PPB

— LICA

NO2_

PPB

NOx - NO- NO2 Calibration Report
Station Information

Calibration Date	January 18, 2012	Previous Calibration	January 4, 2012
Company	LICA	Plant/Location	Cold Lake South
Start Time (MST)	9:10	End Time (MST)	11:30
Reason:	As Found		
Barometric Pressure	0.938 atm	Station Temperature	22 Deg C
Cal Gas Concentration	NOx 49.7 ppm	NO	49.4 ppm
Cal Gas Cylinder #	LL103831	Cal Gas Expiry date	February 28, 2013
DAS Output Voltage	0 - 10 Volts	Chart Rec. Output	NA Volts

Equipment Information

Analyzer Make / Model:	Thermo 42C	S/N :	427408716	Method:	Chemiluminescent
Calibrator Make / Model:	Enviro-nics 6100	S/N :	4760		
DAS Make / Model:	ESC 8832	S/N :	3485		
Chart Recorder Make / Model:	NA	S/N :	NA		
Flow Meter:	Enviro-nics 6100	S/N :	4760		

Analyzer Settings

Before Calibration				After Calibration			
Concentration Range	0 - 500			ppb			
Sample Flow/Conv. Temp	734 ccm	317 Deg C		720 ccm	317 Deg C		
Ozone Flow / Vacuum	OK ccm	176.9 "Hg-A		OK ccm	176.9 "Hg-A		
HVPS / A ZERO	-821 Volts	NA MV		-821 Volts	NA MV		
Rx/ Temp / PMT Temp	49.5 Deg C	-2.5 Deg C		49.5 Deg C	-2.5 Deg C		
Box Temp / IZS Temp	26.2 Deg C	OK Deg C		26.2 Deg C	OK Deg C		
Offset	3.7 NOx	3.5 NO		3.7 NOx	3.5 NO		
Slope	1.007 NOx	0.893 NO		1.007 NOx	0.893 NO		
NO2 COEF / Conv Efficiency	0.998 NO2	NA		0.998 NO2	NA		

Dilution Calibration Data

Dilution Air Flow Rate	Source Flow Rate	O3 Set Point	Calculated Concentration			Indicated Concentration			Correction Factor	
			NOx	NO	NO2	NOx	NO	NO2	NOx	NO
5000	0.0	NA	0	0	NA	0	0	0	NA	NA
	No Zero Adj									
4960	40.5	NA	403	400	NA	398	396	2	1.0114	1.0104

Gas Phase Titration Calibration Data

Dilution Air Flow Rate	Source Flow Rate	O3 Set Point	Calculated Concentration			Indicated Concentration			NO2 Correction Factor	NO2 Conv Efficiency
			NOx	NO	NO2	NOx	NO	NO2		

Linearity OK?	Yes	No	Sum of Least Squares Correction Factors:	NOx= #VALUE!	NO= #VALUE!	NO2=
				NOx= 1.0114	NO= 1.0104	NO2=
Average Converter Efficiency=						

Before Calibration				After Calibration			
Auto Zero	0.1 NOx	0.2 NO2		0.1 NOx	0.2 NO2		
Auto Span	300 NOx	298 NO2		300 NOx	298 NO2		
Sample Lines Connected YES							

Percent Change from Previous Calibration	NOx	-1.4%	NO	-1.0%	NO2	NA
--	-----	-------	----	-------	-----	----


Notes: **NA : Not Applicable**
Following the A/F point, the Z/S oven dilution flow rate was adjusted.

Calibration Performed by: Ting Xu

NO2 Calibration Curve


Calibration Date	January 18, 2012
Company	LICA
Plant / Location	Cold Lake South
Start Time (MST)	9:10
End Time (MST)	11:30

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient Slope	(≥ 0.995) (0.85 to 1.15)	#DIV/0!
0	0	N/A	Intercept	(± 3% F.S.)	#DIV/0!
0	0	#DIV/0!			#DIV/0!
0	0	#DIV/0!			#DIV/0!
0	0	#DIV/0!			#DIV/0!



Notes:

01 Minute Averages



Ozone

O₃ Calibration Report

Station Information

Calibration Date	January 5, 2012	Previous Calibration	December 8, 2011
Company	Lakeland Industry & Community Association		
Plant / Location	LICA 1 - Cold Lake South		
Start Time (MST)	8:59	End Time (MST)	13:03
Reason:	Monthly Calibration		
Barometric Pressure	0.913 atm	Station Temperature	22 Deg C
DAS Output Voltage	0 - 10 Volts		

Equipment Information

Analyzer Make / Model:	Thermo 49i	S/N :	700419951	Method:	Photometric
Calibrator Make / Model:	EnviroNics 6100	S/N :	4760	Method:	GPT
DAS Make / Model:	ESC 8832	S/N :	3485		

Analyzer Settings

Before Calibration				After Calibration			
Concentration Range	0 - 500 ppb						
Cell A Flow / Cell B Flow	696 LPM	735 LPM	703 LPM	743 LPM			
O ₃ Set Level	691 mmHg		691 mmHg				
Bench Lamp	53.5 Deg C		53.5 Deg C				
O ₃ Lamp / Box Temp	67.6 Deg	28.5 Deg C	67.6 Deg C	29.4 Deg C			
Offset / Slope	-0.5	0.994	-0.1	1.004			

Calibration Data

Dilution Flow Rate	Ozone Set Point	Calculated Concentration	Indicated Conc. (DAS)	Correction Factor
4495	0	0	0	NA
	No Zero Adj			
4994	350	320	315	1.0159
4994	350	320	321	0.9969
4994	150	139	139	1.0000
4994	75	70	69	1.0145
4994	0	0	0	NA
Sum of Least Squares				0.9980
New Correction Factor				0.9969

Before Calibration		After Calibration	
Auto Zero	0.4	0.2	
Auto Span	274.0	275.0	
Sample Lines Connected		YES	
Previous Calibration Correction Factor:		0.9848	
Current Correctio Factor Before Span Adjust:		0.9969	
Percent Change:		-1.2%	


Note: NA : Not Applicable

Calibration Performed by: Ting Xu

O₃ Calibration Curve


Calibration Date	January 5, 2012
Company	Lakeland Industry & Community Association
Plant / Location	LICA 1 - Cold Lake South
Start Time (MST)	8:59
End Time (MST)	13:03

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient Slope Intercept	(≥ 0.995) (0.85 to 1.15) (± 3% F.S.)
0	0	n/a		0.999984
70	69	1.0145		1.004412
139	139	1.0000		-0.583517
320	321	0.9969		



Notes:

01 Minute Averages




Passive Bubble Maps

Lakeland Industry & Community Association H₂S Passive Bubble Map

JANUARY 2012


PASSIVE STATIONS

		DUPLICATE
3 – Therien	0.09 PPB	NA
5 – Lake Eliza	0.09 PPB	NA
10 – La Corey	0.10 PPB	NA
11 – Wolf Lake	0.07 PPB	NA
12 – Foster Creek	0.10 PPB	NA
13 – Primrose	0.10 PPB	NA
14 – Maskwa	0.15 PPB	0.13 PPB
16 – Frog Lake	0.12 PPB	0.14 PPB
17 – Clear Range	MISSING	NA
18 – Fishing Lake	0.10 PPB	NA
22 – Cold Lake South	0.10 PPB	NA
24 – Fort George	0.13 PPB	NA
25 – Burnt Lake	0.09 PPB	NA
26 – Mahihkan	0.17 PPB	NA
27 – Mahkeses	0.13 PPB	NA
29 – Cold Lake South 2	0.12 PPB	NA
32 – St. Lina	0.10 PPB	NA
34 – Portable	0.13 PPB	NA



Summary

Minimum : 0.07 PPB – Wolf Lake
 Maximum: 0.17 PPB – Mahihkan
 Average: 0.11 PPB *Includes Duplicates



Lakeland Industry & Community Association NO₂ Passive Bubble Map

JANUARY 2012


PASSIVE STATIONS

		DUPLICATE
2 – Sand River	1.5 PPB	NA
3 – Therien	3.0 PPB	NA
4 – Flat Lake	1.7 PPB	NA
5 – Lake Eliza	2.2 PPB	NA
6 – Telegraph Creek	2.7 PPB	NA
8 – Muriel-Kehewin	2.0 PPB	NA
9 – Dupre	2.7 PPB	2.3 PPB
10 – La Corey	4.9 PPB	3.9 PPB
11 – Wolf Lake	0.9 PPB	NA
12 – Foster Creek	1.8 PPB	NA
13 – Primrose	2.5 PPB	NA
14 – Maskwa	3.2 PPB	NA
15 – Ardmore	2.6 PPB	NA
16 – Frog Lake	3.8PPB	NA
17 – Clear Range	3.5 PPB	NA
18 – Fishing Lake	2.5 PPB	NA
19 – Beaverdam	1.6 PPB	NA
22 – Cold Lake South	3.0 PPB	NA
23 – Medley-Martineau	0.8 PPB	NA
24 – Fort George	3.6 PPB	NA
28 – Town of Bonnyville	7.0 PPB	NA
29 – Cold Lake South 2	4.3 PPB	NA
32 – St. Lina	1.7 PPB	NA
34 – Portable	4.5 PPB	NA



Summary

Minimum : 0.8 PPB – Medley-Martineau
Maximum: 7.0 PPB – Town of Bonnyville
Average: 2.8 PPB *Includes Duplicates




Lakeland Industry & Community Association O₃ Passive Bubble Map

JANUARY 2012


PASSIVE STATIONS

		DUPLICATE
2 – Sand River	22.3 PPB	NA
3 – Therien	27.6 PPB	NA
4 – Flat Lake	33.5 PPB	NA
5 – Lake Eliza	25.6 PPB	NA
6 – Telegraph Creek	25.7 PPB	NA
8 – Muriel-Kehewin	32.6 PPB	NA
9 – Dupre	29.9 PPB	28.8 PPB
10 – La Corey	24.6 PPB	24.9 PPB
11 – Wolf Lake	23.9 PPB	NA
12 – Foster Creek	27.0 PPB	NA
13 – Primrose	29.4 PPB	NA
14 – Maskwa	27.3 PPB	NA
15 – Ardmore	27.0 PPB	NA
16 – Frog Lake	24.3 PPB	NA
17 – Clear Range	27.9 PPB	NA
18 – Fishing Lake	25.2 PPB	NA
19 – Beaverdam	30.3 PPB	NA
22 – Cold Lake South	24.8 PPB	NA
23 – Medley-Martineau	22.7 PPB	NA
24 – Fort George	26.1 PPB	NA
28 – Town of Bonnyville	22.7 PPB	NA
29 – Cold Lake South 2	25.5 PPB	NA
32 – St. Lina	30.1 PPB	NA
34 – Portable	25.6 PPB	NA



Summary

Minimum : 22.3 PPB – Sand River
 Maximum: 33.5 PPB – Flat Lake
 Average: 26.7 PPB *Includes Duplicates



Lakeland Industry & Community Association SO₂ Passive Bubble Map

JANUARY 2012


PASSIVE STATIONS

Station Number	SO ₂ Concentration (PPB)	Duplicate
2 – Sand River	0.2 PPB	NA
3 – Therien	0.5 PPB	NA
4 – Flat Lake	0.7 PPB	NA
5 – Lake Eliza	0.7 PPB	NA
6 – Telegraph Creek	0.5 PPB	NA
8 – Muriel-Kehewin	MISSING	NA
9 – Dupre	0.6 PPB	NA
10 – La Corey	0.3 PPB	NA
11 – Wolf Lake	0.3 PPB	NA
12 – Foster Creek	0.5 PPB	0.5 PPB
13 – Primrose	1.0 PPB	1.1 PPB
14 – Maskwa	1.2 PPB	1.2 PPB
15 – Ardmore	0.5 PPB	NA
16 – Frog Lake	0.6 PPB	NA
17 – Clear Range	0.7 PPB	NA
18 – Fishing Lake	0.4 PPB	NA
19 – Beaverdam	0.5 PPB	NA
22 – Cold Lake South	0.4 PPB	NA
23 – Medley-Martineau	0.3 PPB	NA
24 – Fort George	0.4 PPB	NA
25 – Burnt Lake	0.5 PPB	NA
26 – Mahikan	0.7 PPB	NA
27 – Mahkeses	1.3 PPB	NA
28 – Town of Bonnyville	0.5 PPB	NA
29 – Cold Lake South 2	0.4 PPB	NA
32 – St. Lina	0.6 PPB	NA
34 – Portable	0.4 PPB	NA



Summary

Minimum : 0.2 PPB –Sand River
 Maximum: 1.3 PPB –Mahkeses
 Average: 0.57 PPB *Includes Duplicates



Passive Field Data

Field Notes

ID	SAMPLER	START		END		NOTES
		DATE	TIME	DATE	TIME	
2	SO ₂ /NO ₂ /O ₃	12/29/2011	16:43	02/01/2012	11:35	
3	H ₂ S/SO ₂ /NO ₂ /O ₃	12/29/2011	16:05	02/01/2012	11:00	
4	SO ₂ /NO ₂ /O ₃	12/28/2011	16:00	02/02/2012	14:00	
5	H ₂ S/SO ₂ /NO ₂ /O ₃	12/28/2011	15:20	02/02/2012	13:20	
6	SO ₂ /NO ₂ /O ₃	12/28/2011	13:55	02/02/2012	11:30	
8	SO ₂ /NO ₂ /O ₃	12/28/2011	17:01	02/02/2012	15:18	
9	SO ₂ /NO ₂ /O ₃	12/28/2011	17:52	02/01/2012	09:55	
10	H ₂ S/SO ₂ /NO ₂ /O ₃	12/29/2011	09:45	01/31/2012	13:00	
11	H ₂ S/SO ₂ /NO ₂ /O ₃	12/29/2011	10:21	01/31/2012	13:45	
12	H ₂ S/SO ₂ /NO ₂ /O ₃	12/29/2011	12:14	01/31/2012	15:15	
13	H ₂ S/SO ₂ /NO ₂ /O ₃	12/29/2011	08:35	02/01/2012	1406	
14	H ₂ S/SO ₂ /NO ₂ /O ₃	12/29/2011	07:48	02/01/2012	15:00	
15	SO ₂ /NO ₂ /O ₃	12/28/2011	18:44	02/01/1201	09:02	
16	H ₂ S/SO ₂ /NO ₂ /O ₃	12/28/2011	12:22	02/02/2012	10:00	
17	H ₂ S/SO ₂ /NO ₂ /O ₃	12/28/2011	13:05	02/02/2012	10:05	
18	H ₂ S/SO ₂ /NO ₂ /O ₃	12/28/2011	11:32	02/02/2012	09:15	
19	SO ₂ /NO ₂ /O ₃	12/28/2011	10:28	02/02/2012	08:15	
22	H ₂ S/SO ₂ /NO ₂ /O ₃	12/28/2011	09:05	02/01/2012	16:45	
23	SO ₂ /NO ₂ /O ₃	12/29/2011	18:10	02/02/2012	-	
24	H ₂ S/SO ₂ /NO ₂ /O ₃	12/28/2011	14:31	02/02/2012	12:35	
25	H ₂ S/SO ₂	12/29/2011	11:07	01/31/2012	16:20	
26	H ₂ S/SO ₂	12/29/2011	08:07	02/01/2012	14:38	
27	H ₂ S/SO ₂	12/29/2011	07:22	02/01/2012	15:22	
28	SO ₂ /NO ₂ /O ₃	12/28/2011	17:33	02/01/2012	10:08	
29	H ₂ S/SO ₂ /NO ₂ /O ₃	12/28/2011	09:20	02/01/2012	16:45	
32	H ₂ S/SO ₂ /NO ₂ /O ₃	12/29/2011	15:02	01/31/2012	11:36	
34	H ₂ S/SO ₂ /NO ₂ /O ₃	12/28/2011	18:15	02/01/2012	9:32	

ID	SAMPLER	START		END		NOTES
		DATE	TIME	DATE	TIME	
Duplicate # 12	SO ₂	12/29/2011	12:14	01/31/2012	15:15	
Duplicate # 13	SO ₂	12/29/2011	08:35	02/01/2012	14:06	
Duplicate # 14	SO ₂	12/29/2011	07:48	20/01/2012	15:00	
Duplicate # 14	H ₂ S	12/29/2011	07:48	20/01/2012	15:00	
Duplicate # 16	H ₂ S	12/28/2011	12:22	02/02/2012	18:00	
Duplicate # 9	NO ₂	12/28/2011	17:52	02/01/2012	09:55	
Duplicate # 10	NO ₂	12/29/2011	09:45	01/31/2012	13:00	
Duplicate # 9	O ₃	12/28/2011	17:52	02/01/2012	09:55	
Duplicate # 10	O ₃	12/29/2011	09:45	01/31/2012	13:00	

Passive Network Laboratory Analysis



Your Project #: 2011/12/29 - 2012/01/31
Site Location: LICA

Attention: MICHAEL BISAGA
LAKELAND INDUSTRY AND COMMUNITY ASSOCIATION
PO BOX 8237
5107W- 50TH STREET
BONNYVILLE, AB
CANADA T9N 2J5

Report Date: 2012/02/13

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: B210194
Received: 2012/02/07, 13:58

Sample Matrix: Air
Samples Received: 33

Analyses	Quantity	Date		Laboratory Method	Analytical Method
		Extracted	Analyzed		
H2S Passive Analysis (1)	19	2012/02/11	2012/02/13	EINDSOP-00150	Tang.Passive H2S in
NO2 Passive Analysis (1)	26	2012/02/13	2012/02/13	EINDSOP-00148	Tang Passive NO2 in
O3 Passive Analysis (1)	26	2012/02/10	2012/02/13	EINDSOP-00197	EPA 300 R2.1
SO2 Passive Analysis (1)	30	2012/02/13	2012/02/13	EINDSOP-00149	Tang Passive SO2 in

* RPDs calculated using raw data. The rounding of final results may result in the apparent difference.

(1) The detection limit is based on a 30 day sampling period.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

Levi Manchak, Customer Service
Email: LManchak@maxxam.ca
Phone# (780) 378-8500

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Total cover pages: 1



Maxxam Job #: B210194
 Report Date: 2012/02/13

LAKELAND INDUSTRY AND COMMUNITY ASSOCIATION
 Client Project #: 2011/12/29 - 2012/01/31
 Site Location: LICA
 Sampler Initials: SB

RESULTS OF CHEMICAL ANALYSES OF AIR

Maxxam ID		CR0460	CR0461	CR0462	CR0463	CR0464		
Sampling Date		2011/12/29 16:43	2011/12/29 16:05	2011/12/28 16:00	2011/12/28 15:20	2011/12/28 13:55		
	Units	2	3	4	5	6	RDL	QC Batch

Passive Monitoring								
Calculated H2S	ppb		0.09		0.09		0.02	5588574
Calculated NO2	ppb	1.5	3.0	1.7	2.2	2.7	0.1	5589329
Calculated O3	ppb	22.3	27.6	33.5	25.6	25.7	0.1	5585264
Calculated SO2	ppb	0.2	0.5	0.7	0.7	0.5	0.1	5589311
RDL = Reportable Detection Limit								

Maxxam ID		CR0465	CR0466	CR0467	CR0468	CR0469		
Sampling Date		2011/12/28 17:01	2011/12/28 17:52	2011/12/29 09:45	2011/12/29 10:21	2011/12/29 12:14		
	Units	8	9	10	11	12	RDL	QC Batch

Passive Monitoring								
Calculated H2S	ppb			0.10	0.07	0.10	0.02	5588574
Calculated NO2	ppb	2.0	2.7	4.9	0.9	1.8	0.1	5589329
Calculated O3	ppb	32.6	29.9	24.6	23.9	27.0	0.1	5585264
Calculated SO2	ppb	MISSING	0.6	0.3	0.3	0.5	0.1	5589311
RDL = Reportable Detection Limit								

Maxxam ID		CR0470	CR0471	CR0472	CR0473		
Sampling Date		2011/12/29 08:35	2011/12/29 07:48	2011/12/28 18:44	2011/12/28 12:22		
	Units	13	14	15	16	RDL	QC Batch

Passive Monitoring								
Calculated H2S	ppb	0.10	0.15		0.12	0.02	5588574	
Calculated NO2	ppb	2.5	3.2	2.6	3.8	0.1	5589329	
Calculated O3	ppb	29.4	27.3	27.0	24.3	0.1	5585264	
Calculated SO2	ppb	1.0	1.2	0.5	0.6	0.1	5589311	
RDL = Reportable Detection Limit								



Maxxam Job #: B210194
 Report Date: 2012/02/13

LAKELAND INDUSTRY AND COMMUNITY ASSOCIATION
 Client Project #: 2011/12/29 - 2012/01/31
 Site Location: LICA
 Sampler Initials: SB

RESULTS OF CHEMICAL ANALYSES OF AIR

Maxxam ID		CR0474	CR0475		CR0476	CR0477		
Sampling Date		2011/12/28 13:05	2011/12/28 11:32		2011/12/28 10:28	2011/12/28 09:05		
	Units	17	18	QC Batch	19	22	RDL	QC Batch

Passive Monitoring								
Calculated H2S	ppb		0.10	5588574		0.10	0.02	5588574
Calculated NO2	ppb	3.5	2.5	5589329	1.6	3.0	0.1	5589334
Calculated O3	ppb	27.9	25.2	5585271	30.3	24.8	0.1	5585271
Calculated SO2	ppb	0.7	0.4	5589311	0.5	0.4	0.1	5589311
RDL = Reportable Detection Limit								

Maxxam ID		CR0478		CR0479	CR0480	CR0481		
Sampling Date		2011/12/29 18:10		2011/12/28 14:31	2011/12/29 11:07	2011/12/29 08:07		
	Units	23	QC Batch	24	25	26	RDL	QC Batch

Passive Monitoring								
Calculated H2S	ppb		5588574	0.13	0.09	0.17	0.02	5588574
Calculated NO2	ppb	0.8	5589334	3.6			0.1	5589334
Calculated O3	ppb	22.7	5585271	26.1			0.1	5585271
Calculated SO2	ppb	0.3	5589311	0.4	0.5	0.7	0.1	5589318
RDL = Reportable Detection Limit								

Maxxam ID		CR0482	CR0483	CR0484	CR0485	CR0486		
Sampling Date		2011/12/29 07:22	2011/12/28 17:33	2011/12/28 09:20	2011/12/29 15:02	2011/12/28 18:16		
	Units	27	28	29	32	34	RDL	QC Batch

Passive Monitoring								
Calculated H2S	ppb	0.13		0.12	0.10	0.13	0.02	5588574
Calculated NO2	ppb		7.0	4.3	1.7	4.5	0.1	5589334
Calculated O3	ppb		22.7	25.5	30.1	25.6	0.1	5585271
Calculated SO2	ppb	1.3	0.5	0.4	0.6	0.4	0.1	5589318
RDL = Reportable Detection Limit								



Maxxam Job #: B210194
 Report Date: 2012/02/13

LAKELAND INDUSTRY AND COMMUNITY ASSOCIATION
 Client Project #: 2011/12/29 - 2012/01/31
 Site Location: LICA
 Sampler Initials: SB

RESULTS OF CHEMICAL ANALYSES OF AIR

Maxxam ID		CR0489	CR0490	CR0491	CR0492	CR0493		
Sampling Date		2011/12/28 17:52	2011/12/29 09:45	2011/12/29 12:14	2011/12/29 08:35	2011/12/29 07:48		
	Units	9 DUP	10 DUP	12 DUP	13 DUP	14 DUP	RDL	QC Batch

Passive Monitoring								
Calculated H2S	ppb					0.13	0.02	5588574
Calculated NO2	ppb	2.3	3.9				0.1	5589334
Calculated O3	ppb	28.8	24.9				0.1	5585271
Calculated SO2	ppb			0.5	1.1	1.2	0.1	5589318

RDL = Reportable Detection Limit

Maxxam ID		CR0494		
Sampling Date		2011/12/28 12:22		
	Units	16 DUP	RDL	QC Batch

Passive Monitoring				
Calculated H2S	ppb	0.14	0.02	5588574

RDL = Reportable Detection Limit



Maxxam Job #: B210194
Report Date: 2012/02/13

LAKELAND INDUSTRY AND COMMUNITY ASSOCIATION
Client Project #: 2011/12/29 - 2012/01/31
Site Location: LICA
Sampler Initials: SB

General Comments

H2S sample from station #11 and #26 received to the Lab with body, bag and filter wet. SS
Sample: CR0465 for SO2 parameter was not returned to the lab. - DF

Results relate only to the items tested.



LAKELAND INDUSTRY AND COMMUNITY ASSOCIATION
 Attention: MICHAEL BISAGA
 Client Project #: 2011/12/29 - 2012/01/31
 P.O. #:
 Site Location: LICA

Quality Assurance Report
 Maxxam Job Number: PB210194


QA/QC Batch Num Init	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
5585264 OZ	Calibration Check	Calculated O3	2012/02/10		98	%	91 - 107
	Spiked Blank	Calculated O3	2012/02/10		100	%	N/A
	Method Blank	Calculated O3	2012/02/10	<0.1		ppb	
5585271 OZ	Calibration Check	Calculated O3	2012/02/10		99	%	91 - 107
	Spiked Blank	Calculated O3	2012/02/10		100	%	N/A
	Method Blank	Calculated O3	2012/02/10	<0.1		ppb	
5588574 SS6	Calibration Check	Calculated H2S	2012/02/11		103	%	80 - 120
	Spiked Blank	Calculated H2S	2012/02/11		99	%	N/A
5589311 DF4	Calibration Check	Calculated SO2	2012/02/13		99	%	95 - 105
	Spiked Blank	Calculated SO2	2012/02/13		100	%	N/A
	Method Blank	Calculated SO2	2012/02/13	<0.1		ppb	
5589318 DF4	Calibration Check	Calculated SO2	2012/02/13		102	%	95 - 105
	Spiked Blank	Calculated SO2	2012/02/13		100	%	N/A
	Method Blank	Calculated SO2	2012/02/13	<0.1		ppb	
5589329 DF4	Calibration Check	Calculated NO2	2012/02/13		101	%	76 - 118
	Spiked Blank	Calculated NO2	2012/02/13		102	%	N/A
	Method Blank	Calculated NO2	2012/02/13	<0.1		ppb	
5589334 DF4	Calibration Check	Calculated NO2	2012/02/13		100	%	76 - 118
	Spiked Blank	Calculated NO2	2012/02/13		101	%	N/A
	Method Blank	Calculated NO2	2012/02/13	<0.1		ppb	

Calibration Check: A calibration standard analyzed at different times to evaluate on-going calibration accuracy.
 Spiked Blank: A blank matrix to which a known amount of the analyte has been added. Used to evaluate analyte recovery.
 Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

Validation Signature Page

Maxxam Job #: B210194

The analytical data and all QC contained in this report were reviewed and validated by the following individual(s).

A handwritten signature in black ink, appearing to be "Linda Lin", written over a horizontal line.

Linda Lin, Supervisor, Centre for Passive Sampling Technology

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Volatile Organics Laboratory Analysis

MAXXAM

Xontech Model 910A VOC Sample Collection Data Sheet

Client: LICA Sampler s/n: 6167
Location: Cold Lake South Canister ID: 258
Station ID: Lica 1 Canister Installation Date/Time: Jan 03, 2011 @ 08:35 mst
Field Sample ID: LICA VOC/ CLS /Jan 04, 2012 Canister Removal Date/Time: Jan 05, 2011 @ 11:38 mst

Date and Time Information			
Sample Date	Start Time (MST)	End Time (MST)	Elapsed Time (Hours)
04-Jan-12	01/04/2012 0:00	01/05/2012 0:00	24.00

Flow Settings		
Meter Reading (sccm)	Pot Set Pt.	Pump Pressure Setting (psig)
10.0	646	25

Canister Information	
Initial Canister Vacuum (inHg)	Final Canister Pressure (psig)
-28	24

Canister valve open prior to sampling?: YES / NO
Timer set to 0.00 minutes prior to sampling? YES / NO
Canister valve closed prior to disconnection?: YES / NO

Comments: System leak check prior to sampling. COC # 08576

Technician Signiture: Ting Xu



Your C.O.C. #: 08576

Attention: Michael Bisaga

Maxxam Analytics
2608 6A Ave.
Cold Lake, AB
CANADA T9M 2C7

Report Date: 2012/01/13

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: B202401

Received: 2012/01/07, 10:10

Sample Matrix: AIR
Samples Received: 1

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Canister Pressure (TO-15)	1	N/A	2012/01/09	BRL SOP-00304	EPA TO-15
Volatile Organics in Air (TO-15) ¶	1	N/A	2012/01/09	BRL SOP-00304	EPA TO-15

(1) Air sampling canisters have been cleaned in accordance with U.S. EPA Method TO14A. At the end of the cleaning, evacuation, and pressurization cycles, one canister was selected and was pressurized with Zero Air. This canister was then analyzed via TO14A on a GC/MS. The canister must have been found to contain <0.2 ppbv concentration of all target analytes in order for the batch to have been considered clean. Each canister also underwent a leak check prior to shipment.

Please Note: SUMMA® canister samples will be retained by Maxxam for a period of 5 calendar days from the date of this report, after which time they will be cleaned for reuse. If you require a longer sample storage period, please contact your service representative.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

THERESA STEPHENSON, Project Manager
Email: TStephenson@maxxam.ca
Phone# (905) 817-5763

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Maxxam Analytics Inc. is a NELAC accredited laboratory. Certificate # CANA001. Use of the NELAC logo however does not insure that Maxxam is accredited for all of the methods indicated. This certificate shall not be reproduced except in full, without the written approval of Maxxam Analytics Inc. Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section.

Total cover pages: 1

Maxxam Job #: B202401
 Report Date: 2012/01/13

RESULTS OF ANALYSES OF AIR

Maxxam ID		ME0742	
Sampling Date		2012/01/04	
COC Number		08576	
	Units	LICA VOC/CLS/JAN 04, 2012 - 258	QC Batch

Volatile Organics			
Pressure on Receipt	psig	23	2732465

QC Batch = Quality Control Batch

Maxxam Job #: B202401
 Report Date: 2012/01/13

VOLATILE ORGANICS BY GC/MS (AIR)

Maxxam ID		ME0742				
Sampling Date		2012/01/04				
COC Number		08576				
	Units	LICA VOC/CLS/JAN 04, 2012 - 258	RDL	ug/m3	DL (ug/m3)	QC Batch

Volatile Organics						
2,2,4-Trimethylpentane	ppbv	0.65	0.20	3.05	0.934	2732446
Carbon Disulfide	ppbv	<0.50	0.50	<1.56	1.56	2732446
Propene	ppbv	<3.6	3.6	<6.20	6.20	2732446
Vinyl Acetate	ppbv	<0.20	0.20	<0.704	0.704	2732446
Vinyl Bromide	ppbv	<0.20	0.20	<0.875	0.875	2732446
Dichlorodifluoromethane (FREON 12)	ppbv	0.59	0.20	2.93	0.989	2732446
1,2-Dichlorotetrafluoroethane	ppbv	<0.17	0.17	<1.19	1.19	2732446
Chloromethane	ppbv	0.51	0.30	1.04	0.620	2732446
Vinyl Chloride	ppbv	<0.18	0.18	<0.460	0.460	2732446
Chloroethane	ppbv	<0.30	0.30	<0.792	0.792	2732446
1,3-Butadiene	ppbv	<0.50	0.50	<1.11	1.11	2732446
Trichlorofluoromethane (FREON 11)	ppbv	0.26	0.20	1.48	1.12	2732446
Trichlorotrifluoroethane	ppbv	<0.15	0.15	<1.15	1.15	2732446
Ethanol	ppbv	14.0	2.3	26.3	4.33	2732446
2-propanol	ppbv	<3.0	3.0	<7.37	7.37	2732446
2-Propanone	ppbv	0.90	0.80	2.13	1.90	2732446
Methyl Ethyl Ketone (2-Butanone)	ppbv	<3.0	3.0	<8.85	8.85	2732446
Methyl Isobutyl Ketone	ppbv	<3.2	3.2	<13.1	13.1	2732446
Methyl Butyl Ketone (2-Hexanone)	ppbv	<2.0	2.0	<8.19	8.19	2732446
Methyl t-butyl ether (MTBE)	ppbv	<0.20	0.20	<0.721	0.721	2732446
Ethyl Acetate	ppbv	<2.2	2.2	<7.93	7.93	2732446
1,1-Dichloroethylene	ppbv	<0.25	0.25	<0.991	0.991	2732446
cis-1,2-Dichloroethylene	ppbv	<0.19	0.19	<0.753	0.753	2732446
trans-1,2-Dichloroethylene	ppbv	<0.20	0.20	<0.793	0.793	2732446
Methylene Chloride(Dichloromethane)	ppbv	<0.80	0.80	<2.78	2.78	2732446
Chloroform	ppbv	<0.15	0.15	<0.732	0.732	2732446
Carbon Tetrachloride	ppbv	<0.30	0.30	<1.89	1.89	2732446
1,1-Dichloroethane	ppbv	<0.20	0.20	<0.809	0.809	2732446
1,2-Dichloroethane	ppbv	<0.20	0.20	<0.809	0.809	2732446
Ethylene Dibromide	ppbv	<0.17	0.17	<1.31	1.31	2732446
1,1,1-Trichloroethane	ppbv	<0.30	0.30	<1.64	1.64	2732446
RDL = Reportable Detection Limit QC Batch = Quality Control Batch						

Maxxam Job #: B202401
 Report Date: 2012/01/13

VOLATILE ORGANICS BY GC/MS (AIR)

Maxxam ID		ME0742				
Sampling Date		2012/01/04				
COC Number		08576				
	Units	LICA VOC/CLS/JAN 04, 2012 - 258	RDL	ug/m3	DL (ug/m3)	QC Batch
1,1,2-Trichloroethane	ppbv	<0.15	0.15	<0.818	0.818	2732446
1,1,2,2-Tetrachloroethane	ppbv	<0.20	0.20	<1.37	1.37	2732446
cis-1,3-Dichloropropene	ppbv	<0.18	0.18	<0.817	0.817	2732446
trans-1,3-Dichloropropene	ppbv	<0.17	0.17	<0.772	0.772	2732446
1,2-Dichloropropane	ppbv	<0.40	0.40	<1.85	1.85	2732446
Bromomethane	ppbv	<0.18	0.18	<0.699	0.699	2732446
Bromoform	ppbv	<0.20	0.20	<2.07	2.07	2732446
Bromodichloromethane	ppbv	<0.20	0.20	<1.34	1.34	2732446
Dibromochloromethane	ppbv	<0.20	0.20	<1.70	1.70	2732446
Heptane	ppbv	0.47	0.30	1.91	1.23	2732446
Trichloroethylene	ppbv	<0.30	0.30	<1.61	1.61	2732446
Tetrachloroethylene	ppbv	<0.20	0.20	<1.36	1.36	2732446
Benzene	ppbv	0.63	0.18	2.00	0.575	2732446
Toluene	ppbv	1.63	0.20	6.12	0.753	2732446
Ethylbenzene	ppbv	0.29	0.20	1.28	0.868	2732446
p+m-Xylene	ppbv	1.06	0.37	4.61	1.61	2732446
o-Xylene	ppbv	0.40	0.20	1.73	0.868	2732446
Styrene	ppbv	<0.20	0.20	<0.852	0.852	2732446
1,3,5-Trimethylbenzene	ppbv	<0.50	0.50	<2.46	2.46	2732446
1,2,4-Trimethylbenzene	ppbv	<0.50	0.50	<2.46	2.46	2732446
4-ethyltoluene	ppbv	<2.2	2.2	<10.8	10.8	2732446
Chlorobenzene	ppbv	<0.20	0.20	<0.921	0.921	2732446
Benzyl chloride	ppbv	<1.0	1.0	<5.18	5.18	2732446
1,3-Dichlorobenzene	ppbv	<0.40	0.40	<2.40	2.40	2732446
1,4-Dichlorobenzene	ppbv	<0.40	0.40	<2.40	2.40	2732446
1,2-Dichlorobenzene	ppbv	<0.40	0.40	<2.40	2.40	2732446
1,2,4-Trichlorobenzene	ppbv	<2.0	2.0	<14.8	14.8	2732446
Hexachlorobutadiene	ppbv	<3.0	3.0	<32.0	32.0	2732446
Hexane	ppbv	0.78	0.30	2.74	1.06	2732446
Cyclohexane	ppbv	0.36	0.20	1.23	0.688	2732446
Tetrahydrofuran	ppbv	<0.40	0.40	<1.18	1.18	2732446
1,4-Dioxane	ppbv	<2.0	2.0	<7.21	7.21	2732446
Xylene (Total)	ppbv	1.46	0.60	6.34	2.61	2732446
QC Batch = Quality Control Batch						

Maxxam Job #: B202401
 Report Date: 2012/01/13

VOLATILE ORGANICS BY GC/MS (AIR)

Maxxam ID		ME0742				
Sampling Date		2012/01/04				
COC Number		08576				
	Units	LICA VOC/CLS/JAN 04, 2012 - 258	RDL	ug/m3	DL (ug/m3)	QC Batch

Surrogate Recovery (%)						
Bromochloromethane	%	95		N/A	N/A	2732446
D5-Chlorobenzene	%	93		N/A	N/A	2732446
Difluorobenzene	%	94		N/A	N/A	2732446
N/A = Not Applicable QC Batch = Quality Control Batch						

Maxxam Job #: B202401
Report Date: 2012/01/13

Test Summary

Maxxam ID ME0742
Sample ID LICA VOC/CLS/JAN 04, 2012 - 258
Matrix AIR

Collected 2012/01/04
Shipped
Received 2012/01/07

Test Description	Instrumentation	Batch	Extracted	Analyzed	Analyst
Canister Pressure (TO-15)	PRES	2732465	N/A	2012/01/09	DIANE TEMNIUK
Volatile Organics in Air (TO-15)	GC/MS	2732446	N/A	2012/01/09	DIANE TEMNIUK

Maxxam Job #: B202401
Report Date: 2012/01/13

GENERAL COMMENTS

WS#2732446

Benzyl Chloride exceeds 40%RSD in Continuing Calibration. No positives were found, therefore data was accepted.

Sample ME0742-01: DL raised for propene due to matrix interference.

Results relate only to the items tested.

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report

Maxxam Job Number: GB202401

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2732446	DVO	Spiked Blank					
		Bromochloromethane	2012/01/09		99	%	60 - 140
		D5-Chlorobenzene	2012/01/09		101	%	60 - 140
		Difluorobenzene	2012/01/09		103	%	60 - 140
		2,2,4-Trimethylpentane	2012/01/09		100	%	70 - 130
		Carbon Disulfide	2012/01/09		103	%	70 - 130
		Propene	2012/01/09		91	%	70 - 130
		Vinyl Acetate	2012/01/09		116	%	70 - 130
		Vinyl Bromide	2012/01/09		107	%	70 - 130
		Dichlorodifluoromethane (FREON 12)	2012/01/09		100	%	70 - 130
		1,2-Dichlorotetrafluoroethane	2012/01/09		113	%	70 - 130
		Chloromethane	2012/01/09		96	%	70 - 130
		Vinyl Chloride	2012/01/09		101	%	70 - 130
		Chloroethane	2012/01/09		101	%	70 - 130
		1,3-Butadiene	2012/01/09		100	%	70 - 130
		Trichlorofluoromethane (FREON 11)	2012/01/09		105	%	70 - 130
		Trichlorotrifluoroethane	2012/01/09		101	%	70 - 130
		Ethanol	2012/01/09		99	%	70 - 130
		2-propanol	2012/01/09		120	%	70 - 130
		2-Propanone	2012/01/09		109	%	70 - 130
		Methyl Ethyl Ketone (2-Butanone)	2012/01/09		113	%	70 - 130
		Methyl Isobutyl Ketone	2012/01/09		98	%	70 - 130
		Methyl Butyl Ketone (2-Hexanone)	2012/01/09		102	%	70 - 130
		Methyl t-butyl ether (MTBE)	2012/01/09		109	%	70 - 130
		Ethyl Acetate	2012/01/09		104	%	70 - 130
		1,1-Dichloroethylene	2012/01/09		110	%	70 - 130
		cis-1,2-Dichloroethylene	2012/01/09		107	%	70 - 130
		trans-1,2-Dichloroethylene	2012/01/09		102	%	70 - 130
		Methylene Chloride(Dichloromethane)	2012/01/09		91	%	70 - 130
		Chloroform	2012/01/09		101	%	70 - 130
		Carbon Tetrachloride	2012/01/09		101	%	70 - 130
		1,1-Dichloroethane	2012/01/09		98	%	70 - 130
		1,2-Dichloroethane	2012/01/09		106	%	70 - 130
		Ethylene Dibromide	2012/01/09		107	%	70 - 130
		1,1,1-Trichloroethane	2012/01/09		103	%	70 - 130
		1,1,2-Trichloroethane	2012/01/09		100	%	70 - 130
		1,1,2,2-Tetrachloroethane	2012/01/09		103	%	70 - 130
		cis-1,3-Dichloropropene	2012/01/09		112	%	70 - 130
		trans-1,3-Dichloropropene	2012/01/09		133 (1)	%	70 - 130
		1,2-Dichloropropane	2012/01/09		97	%	70 - 130
		Bromomethane	2012/01/09		103	%	70 - 130
		Bromoform	2012/01/09		109	%	70 - 130
		Bromodichloromethane	2012/01/09		102	%	70 - 130
		Dibromochloromethane	2012/01/09		104	%	70 - 130
		Heptane	2012/01/09		94	%	70 - 130
		Trichloroethylene	2012/01/09		99	%	70 - 130
		Tetrachloroethylene	2012/01/09		99	%	70 - 130
		Benzene	2012/01/09		99	%	70 - 130
		Toluene	2012/01/09		103	%	70 - 130
		Ethylbenzene	2012/01/09		104	%	70 - 130
		p+m-Xylene	2012/01/09		102	%	70 - 130
		o-Xylene	2012/01/09		100	%	70 - 130
		Styrene	2012/01/09		97	%	70 - 130
		1,3,5-Trimethylbenzene	2012/01/09		108	%	70 - 130
		1,2,4-Trimethylbenzene	2012/01/09		112	%	70 - 130
		4-ethyltoluene	2012/01/09		104	%	70 - 130

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report (Continued)

Maxxam Job Number: GB202401

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2732446 DVO	Spiked Blank	Chlorobenzene	2012/01/09		102	%	70 - 130
		Benzyl chloride	2012/01/09		147 (1)	%	70 - 130
1,3-Dichlorobenzene		2012/01/09		119	%	70 - 130	
1,4-Dichlorobenzene		2012/01/09		124	%	70 - 130	
1,2-Dichlorobenzene		2012/01/09		117	%	70 - 130	
1,2,4-Trichlorobenzene		2012/01/09		128	%	70 - 130	
Hexachlorobutadiene		2012/01/09		101	%	70 - 130	
Hexane		2012/01/09		97	%	70 - 130	
Cyclohexane		2012/01/09		99	%	70 - 130	
Tetrahydrofuran		2012/01/09		103	%	70 - 130	
1,4-Dioxane		2012/01/09		94	%	70 - 130	
Xylene (Total)		2012/01/09		101	%	70 - 130	
Method Blank		Bromochloromethane	2012/01/09		92	%	60 - 140
		D5-Chlorobenzene	2012/01/09		92	%	60 - 140
		Difluorobenzene	2012/01/09		96	%	60 - 140
	2,2,4-Trimethylpentane	2012/01/09	<0.20			ppbv	
	Carbon Disulfide	2012/01/09	<0.50			ppbv	
	Propene	2012/01/09	<0.30			ppbv	
	Vinyl Acetate	2012/01/09	<0.20			ppbv	
	Vinyl Bromide	2012/01/09	<0.20			ppbv	
	Dichlorodifluoromethane (FREON 12)	2012/01/09	<0.20			ppbv	
	1,2-Dichlorotetrafluoroethane	2012/01/09	<0.17			ppbv	
	Chloromethane	2012/01/09	<0.30			ppbv	
	Vinyl Chloride	2012/01/09	<0.18			ppbv	
	Chloroethane	2012/01/09	<0.30			ppbv	
	1,3-Butadiene	2012/01/09	<0.50			ppbv	
	Trichlorofluoromethane (FREON 11)	2012/01/09	<0.20			ppbv	
	Trichlorotrifluoroethane	2012/01/09	<0.15			ppbv	
	Ethanol	2012/01/09	<2.3			ppbv	
	2-propanol	2012/01/09	<3.0			ppbv	
	2-Propanone	2012/01/09	<0.80			ppbv	
	Methyl Ethyl Ketone (2-Butanone)	2012/01/09	<3.0			ppbv	
	Methyl Isobutyl Ketone	2012/01/09	<3.2			ppbv	
	Methyl Butyl Ketone (2-Hexanone)	2012/01/09	<2.0			ppbv	
	Methyl t-butyl ether (MTBE)	2012/01/09	<0.20			ppbv	
	Ethyl Acetate	2012/01/09	<2.2			ppbv	
	1,1-Dichloroethylene	2012/01/09	<0.25			ppbv	
	cis-1,2-Dichloroethylene	2012/01/09	<0.19			ppbv	
	trans-1,2-Dichloroethylene	2012/01/09	<0.20			ppbv	
	Methylene Chloride(Dichloromethane)	2012/01/09	<0.80			ppbv	
	Chloroform	2012/01/09	<0.15			ppbv	
	Carbon Tetrachloride	2012/01/09	<0.30			ppbv	
	1,1-Dichloroethane	2012/01/09	<0.20			ppbv	
	1,2-Dichloroethane	2012/01/09	<0.20			ppbv	
	Ethylene Dibromide	2012/01/09	<0.17			ppbv	
	1,1,1-Trichloroethane	2012/01/09	<0.30			ppbv	
	1,1,2-Trichloroethane	2012/01/09	<0.15			ppbv	
	1,1,2,2-Tetrachloroethane	2012/01/09	<0.20			ppbv	
	cis-1,3-Dichloropropene	2012/01/09	<0.18			ppbv	
	trans-1,3-Dichloropropene	2012/01/09	<0.17			ppbv	
1,2-Dichloropropane	2012/01/09	<0.40			ppbv		
Bromomethane	2012/01/09	<0.18			ppbv		
Bromoform	2012/01/09	<0.20			ppbv		
Bromodichloromethane	2012/01/09	<0.20			ppbv		
Dibromochloromethane	2012/01/09	<0.20			ppbv		

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report (Continued)

Maxxam Job Number: GB202401

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2732446	DVO	Method Blank					
		Heptane	2012/01/09	<0.30		ppbv	
		Trichloroethylene	2012/01/09	<0.30		ppbv	
		Tetrachloroethylene	2012/01/09	<0.20		ppbv	
		Benzene	2012/01/09	<0.18		ppbv	
		Toluene	2012/01/09	<0.20		ppbv	
		Ethylbenzene	2012/01/09	<0.20		ppbv	
		p+m-Xylene	2012/01/09	<0.37		ppbv	
		o-Xylene	2012/01/09	<0.20		ppbv	
		Styrene	2012/01/09	<0.20		ppbv	
		1,3,5-Trimethylbenzene	2012/01/09	<0.50		ppbv	
		1,2,4-Trimethylbenzene	2012/01/09	<0.50		ppbv	
		4-ethyltoluene	2012/01/09	<2.2		ppbv	
		Chlorobenzene	2012/01/09	<0.20		ppbv	
		Benzyl chloride	2012/01/09	<1.0		ppbv	
		1,3-Dichlorobenzene	2012/01/09	<0.40		ppbv	
		1,4-Dichlorobenzene	2012/01/09	<0.40		ppbv	
		1,2-Dichlorobenzene	2012/01/09	<0.40		ppbv	
		1,2,4-Trichlorobenzene	2012/01/09	<2.0		ppbv	
		Hexachlorobutadiene	2012/01/09	<3.0		ppbv	
		Hexane	2012/01/09	<0.30		ppbv	
		Cyclohexane	2012/01/09	<0.20		ppbv	
		Tetrahydrofuran	2012/01/09	<0.40		ppbv	
		1,4-Dioxane	2012/01/09	<2.0		ppbv	
		Xylene (Total)	2012/01/09	<0.60		ppbv	
	RPD - Sample/Sample Dup	2,2,4-Trimethylpentane	2012/01/09	NC		%	25
		Carbon Disulfide	2012/01/09	NC		%	25
		Propene	2012/01/09	NC		%	25
		Vinyl Acetate	2012/01/09	NC		%	25
		Vinyl Bromide	2012/01/09	NC		%	25
		Dichlorodifluoromethane (FREON 12)	2012/01/09	NC		%	25
		1,2-Dichlorotetrafluoroethane	2012/01/09	NC		%	25
		Chloromethane	2012/01/09	NC		%	25
		Vinyl Chloride	2012/01/09	NC		%	25
		Chloroethane	2012/01/09	NC		%	25
		1,3-Butadiene	2012/01/09	NC		%	25
		Trichlorofluoromethane (FREON 11)	2012/01/09	NC		%	25
		Trichlorotrifluoroethane	2012/01/09	NC		%	25
		Ethanol	2012/01/09	14.2		%	25
		2-propanol	2012/01/09	NC		%	25
		2-Propanone	2012/01/09	19.4		%	25
		Methyl Ethyl Ketone (2-Butanone)	2012/01/09	NC		%	25
		Methyl Isobutyl Ketone	2012/01/09	NC		%	25
		Methyl Butyl Ketone (2-Hexanone)	2012/01/09	NC		%	25
		Methyl t-butyl ether (MTBE)	2012/01/09	NC		%	25
		Ethyl Acetate	2012/01/09	NC		%	25
		1,1-Dichloroethylene	2012/01/09	NC		%	25
		cis-1,2-Dichloroethylene	2012/01/09	NC		%	25
		trans-1,2-Dichloroethylene	2012/01/09	NC		%	25
		Methylene Chloride(Dichloromethane)	2012/01/09	NC		%	25
		Chloroform	2012/01/09	NC		%	25
		Carbon Tetrachloride	2012/01/09	NC		%	25
		1,1-Dichloroethane	2012/01/09	NC		%	25
		1,2-Dichloroethane	2012/01/09	NC		%	25

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report (Continued)

Maxxam Job Number: GB202401

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2732446 DVO	RPD - Sample/Sample Dup	Ethylene Dibromide	2012/01/09	NC		%	25
		1,1,1-Trichloroethane	2012/01/09	NC		%	25
		1,1,2-Trichloroethane	2012/01/09	NC		%	25
		1,1,2,2-Tetrachloroethane	2012/01/09	NC		%	25
		cis-1,3-Dichloropropene	2012/01/09	NC		%	25
		trans-1,3-Dichloropropene	2012/01/09	NC		%	25
		1,2-Dichloropropane	2012/01/09	NC		%	25
		Bromomethane	2012/01/09	NC		%	25
		Bromoform	2012/01/09	NC		%	25
		Bromodichloromethane	2012/01/09	NC		%	25
		Dibromochloromethane	2012/01/09	NC		%	25
		Heptane	2012/01/09	NC		%	25
		Trichloroethylene	2012/01/09	NC		%	25
		Tetrachloroethylene	2012/01/09	7.4		%	25
		Benzene	2012/01/09	NC		%	25
		Toluene	2012/01/09	7.7		%	25
		Ethylbenzene	2012/01/09	NC		%	25
		p+m-Xylene	2012/01/09	NC		%	25
		o-Xylene	2012/01/09	12.7		%	25
		Styrene	2012/01/09	11.9		%	25
		1,3,5-Trimethylbenzene	2012/01/09	NC		%	25
		1,2,4-Trimethylbenzene	2012/01/09	NC		%	25
		4-ethyltoluene	2012/01/09	NC		%	25
		Chlorobenzene	2012/01/09	NC		%	25
		Benzyl chloride	2012/01/09	NC		%	25
		1,3-Dichlorobenzene	2012/01/09	NC		%	25
		1,4-Dichlorobenzene	2012/01/09	NC		%	25
		1,2-Dichlorobenzene	2012/01/09	NC		%	25
		1,2,4-Trichlorobenzene	2012/01/09	NC		%	25
		Hexachlorobutadiene	2012/01/09	NC		%	25
		Hexane	2012/01/09	NC		%	25
		Cyclohexane	2012/01/09	NC		%	25
		Tetrahydrofuran	2012/01/09	1.0		%	25
		1,4-Dioxane	2012/01/09	NC		%	25
		Xylene (Total)	2012/01/09	NC		%	25

Spiked Blank: A blank matrix to which a known amount of the analyte has been added. Used to evaluate analyte recovery.

Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

Surrogate: A pure or isotopically labeled compound whose behavior mirrors the analytes of interest. Used to evaluate extraction efficiency.

NC (RPD): The RPD was not calculated. The level of analyte detected in the parent sample and its duplicate was not sufficiently significant to permit a reliable calculation.

(1) Recovery or RPD for this parameter is outside control limits. The overall quality control for this analysis meets acceptability criteria.

MAXXAM

Xontech Model 910A VOC Sample Collection Data Sheet

Client: LICA Sampler s/n: 6167
Location: Cold Lake South Canister ID: 7909
Station ID: Lica 1 Canister Installation Date/Time: Jan 09, 2011 @ 13:32 mst
Field Sample ID: LICA VOC/ CLS /Jan 10, 2012 Canister Removal Date/Time: Jan 11, 2011 @ 12:05 mst

Date and Time Information			
Sample Date	Start Time (MST)	End Time (MST)	Elapsed Time (Hours)
10-Jan-12	01/10/2012 0:00	01/11/2012 0:00	24.00

Flow Settings		
Meter Reading (sccm)	Pot Set Pt.	Pump Pressure Setting (psig)
10.0	649	25

Canister Information	
Initial Canister Vacuum (inHg)	Final Canister Pressure (psig)
-28	24

Canister valve open prior to sampling?: YES / NO
Timer set to 0.00 minutes prior to sampling? YES / NO
Canister valve closed prior to disconnection?: YES / NO

Comments: System leak check prior to sampling. COC # 08542

Technician Signiture: Ting Xu



Your C.O.C. #: 08542

Attention: Michael Bisaga

Maxxam Analytics
 2608 6A Ave.
 Cold Lake, AB
 CANADA T9M 2C7

Report Date: 2012/01/19

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: B205432

Received: 2012/01/13, 10:20

Sample Matrix: AIR
 # Samples Received: 1

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Canister Pressure (TO-15)	1	N/A	2012/01/16	BRL SOP-00304	EPA TO-15
Volatile Organics in Air (TO-15) ¶	1	N/A	2012/01/16	BRL SOP-00304	EPA TO-15

(1) Air sampling canisters have been cleaned in accordance with U.S. EPA Method TO14A. At the end of the cleaning, evacuation, and pressurization cycles, one canister was selected and was pressurized with Zero Air. This canister was then analyzed via TO14A on a GC/MS. The canister must have been found to contain <0.2 ppbv concentration of all target analytes in order for the batch to have been considered clean. Each canister also underwent a leak check prior to shipment.

Please Note: SUMMA® canister samples will be retained by Maxxam for a period of 5 calendar days from the date of this report, after which time they will be cleaned for reuse. If you require a longer sample storage period, please contact your service representative.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

THERESA STEPHENSON, Project Manager
 Email: TStephenson@maxxam.ca
 Phone# (905) 817-5763

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Maxxam Analytics Inc. is a NELAC accredited laboratory. Certificate # CANA001. Use of the NELAC logo however does not insure that Maxxam is accredited for all of the methods indicated. This certificate shall not be reproduced except in full, without the written approval of Maxxam Analytics Inc. Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section.

Total cover pages: 1

Maxxam Job #: B205432
 Report Date: 2012/01/19

RESULTS OF ANALYSES OF AIR

Maxxam ID		MF4254	
Sampling Date		2012/01/10	
COC Number		08542	
	Units	LICA VOC/CLS/JAN 10/12 - 7909	QC Batch

Volatile Organics			
Pressure on Receipt	psig	23	2738276

QC Batch = Quality Control Batch

Maxxam Job #: B205432
 Report Date: 2012/01/19

VOLATILE ORGANICS BY GC/MS (AIR)

Maxxam ID		MF4254				
Sampling Date		2012/01/10				
COC Number		08542				
	Units	LICA VOC/CLS/JAN 10/12 - 7909	RDL	ug/m3	DL (ug/m3)	QC Batch

Volatile Organics						
2,2,4-Trimethylpentane	ppbv	<0.20	0.20	<0.934	0.934	2738246
Carbon Disulfide	ppbv	<0.50	0.50	<1.56	1.56	2738246
Propene	ppbv	<0.30	0.30	<0.516	0.516	2738246
Vinyl Acetate	ppbv	<0.20	0.20	<0.704	0.704	2738246
Vinyl Bromide	ppbv	<0.20	0.20	<0.875	0.875	2738246
Dichlorodifluoromethane (FREON 12)	ppbv	0.66	0.20	3.27	0.989	2738246
1,2-Dichlorotetrafluoroethane	ppbv	<0.17	0.17	<1.19	1.19	2738246
Chloromethane	ppbv	0.60	0.30	1.24	0.620	2738246
Vinyl Chloride	ppbv	<0.18	0.18	<0.460	0.460	2738246
Chloroethane	ppbv	<0.30	0.30	<0.792	0.792	2738246
1,3-Butadiene	ppbv	<0.50	0.50	<1.11	1.11	2738246
Trichlorofluoromethane (FREON 11)	ppbv	0.32	0.20	1.80	1.12	2738246
Trichlorotrifluoroethane	ppbv	<0.15	0.15	<1.15	1.15	2738246
Ethanol	ppbv	<2.3	2.3	<4.33	4.33	2738246
2-propanol	ppbv	<3.0	3.0	<7.37	7.37	2738246
2-Propanone	ppbv	0.82	0.80	1.95	1.90	2738246
Methyl Ethyl Ketone (2-Butanone)	ppbv	<3.0	3.0	<8.85	8.85	2738246
Methyl Isobutyl Ketone	ppbv	<3.2	3.2	<13.1	13.1	2738246
Methyl Butyl Ketone (2-Hexanone)	ppbv	<2.0	2.0	<8.19	8.19	2738246
Methyl t-butyl ether (MTBE)	ppbv	<0.20	0.20	<0.721	0.721	2738246
Ethyl Acetate	ppbv	<2.2	2.2	<7.93	7.93	2738246
1,1-Dichloroethylene	ppbv	<0.25	0.25	<0.991	0.991	2738246
cis-1,2-Dichloroethylene	ppbv	<0.19	0.19	<0.753	0.753	2738246
trans-1,2-Dichloroethylene	ppbv	<0.20	0.20	<0.793	0.793	2738246
Methylene Chloride(Dichloromethane)	ppbv	<0.80	0.80	<2.78	2.78	2738246
Chloroform	ppbv	<0.15	0.15	<0.732	0.732	2738246
Carbon Tetrachloride	ppbv	<0.30	0.30	<1.89	1.89	2738246
1,1-Dichloroethane	ppbv	<0.20	0.20	<0.809	0.809	2738246
1,2-Dichloroethane	ppbv	<0.20	0.20	<0.809	0.809	2738246
Ethylene Dibromide	ppbv	<0.17	0.17	<1.31	1.31	2738246
1,1,1-Trichloroethane	ppbv	<0.30	0.30	<1.64	1.64	2738246

 RDL = Reportable Detection Limit
 QC Batch = Quality Control Batch

Maxxam Job #: B205432
 Report Date: 2012/01/19

VOLATILE ORGANICS BY GC/MS (AIR)

Maxxam ID		MF4254				
Sampling Date		2012/01/10				
COC Number		08542				
	Units	LICA VOC/CLS/JAN 10/12 - 7909	RDL	ug/m3	DL (ug/m3)	QC Batch
1,1,2-Trichloroethane	ppbv	<0.15	0.15	<0.818	0.818	2738246
1,1,2,2-Tetrachloroethane	ppbv	<0.20	0.20	<1.37	1.37	2738246
cis-1,3-Dichloropropene	ppbv	<0.18	0.18	<0.817	0.817	2738246
trans-1,3-Dichloropropene	ppbv	<0.17	0.17	<0.772	0.772	2738246
1,2-Dichloropropane	ppbv	<0.40	0.40	<1.85	1.85	2738246
Bromomethane	ppbv	<0.18	0.18	<0.699	0.699	2738246
Bromoform	ppbv	<0.20	0.20	<2.07	2.07	2738246
Bromodichloromethane	ppbv	<0.20	0.20	<1.34	1.34	2738246
Dibromochloromethane	ppbv	<0.20	0.20	<1.70	1.70	2738246
Heptane	ppbv	<0.30	0.30	<1.23	1.23	2738246
Trichloroethylene	ppbv	<0.30	0.30	<1.61	1.61	2738246
Tetrachloroethylene	ppbv	<0.20	0.20	<1.36	1.36	2738246
Benzene	ppbv	<0.18	0.18	<0.575	0.575	2738246
Toluene	ppbv	<0.20	0.20	<0.753	0.753	2738246
Ethylbenzene	ppbv	<0.20	0.20	<0.868	0.868	2738246
p+m-Xylene	ppbv	<0.37	0.37	<1.61	1.61	2738246
o-Xylene	ppbv	<0.20	0.20	<0.868	0.868	2738246
Styrene	ppbv	<0.20	0.20	<0.852	0.852	2738246
1,3,5-Trimethylbenzene	ppbv	<0.50	0.50	<2.46	2.46	2738246
1,2,4-Trimethylbenzene	ppbv	<0.50	0.50	<2.46	2.46	2738246
4-ethyltoluene	ppbv	<2.2	2.2	<10.8	10.8	2738246
Chlorobenzene	ppbv	<0.20	0.20	<0.921	0.921	2738246
Benzyl chloride	ppbv	<1.0	1.0	<5.18	5.18	2738246
1,3-Dichlorobenzene	ppbv	<0.40	0.40	<2.40	2.40	2738246
1,4-Dichlorobenzene	ppbv	<0.40	0.40	<2.40	2.40	2738246
1,2-Dichlorobenzene	ppbv	<0.40	0.40	<2.40	2.40	2738246
1,2,4-Trichlorobenzene	ppbv	<2.0	2.0	<14.8	14.8	2738246
Hexachlorobutadiene	ppbv	<3.0	3.0	<32.0	32.0	2738246
Hexane	ppbv	<0.30	0.30	<1.06	1.06	2738246
Cyclohexane	ppbv	<0.20	0.20	<0.688	0.688	2738246
Tetrahydrofuran	ppbv	<0.40	0.40	<1.18	1.18	2738246
1,4-Dioxane	ppbv	<2.0	2.0	<7.21	7.21	2738246
Xylene (Total)	ppbv	<0.60	0.60	<2.61	2.61	2738246
QC Batch = Quality Control Batch						

Maxxam Job #: B205432
 Report Date: 2012/01/19

VOLATILE ORGANICS BY GC/MS (AIR)

Maxxam ID		MF4254				
Sampling Date		2012/01/10				
COC Number		08542				
	Units	LICA VOC/CLS/JAN 10/12 - 7909	RDL	ug/m3	DL (ug/m3)	QC Batch

Surrogate Recovery (%)						
Bromochloromethane	%	79		N/A	N/A	2738246
D5-Chlorobenzene	%	76		N/A	N/A	2738246
Difluorobenzene	%	79		N/A	N/A	2738246
N/A = Not Applicable QC Batch = Quality Control Batch						

Maxxam Job #: B205432
Report Date: 2012/01/19

Test Summary

Maxxam ID MF4254
Sample ID LICA VOC/CLS/JAN 10/12 - 7909
Matrix AIR

Collected 2012/01/10
Shipped
Received 2012/01/13

Test Description	Instrumentation	Batch	Extracted	Analyzed	Analyst
Canister Pressure (TO-15)	PRES	2738276	N/A	2012/01/16	DIANE TEMNIUK
Volatile Organics in Air (TO-15)	GC/MS	2738246	N/A	2012/01/16	DIANE TEMNIUK

Maxxam Job #: B205432
Report Date: 2012/01/19

GENERAL COMMENTS

WS #2738246

3 parameters; Vinyl Acetate, 2-Butanone, and Benzyl Chloride, exceed 30% RSD in the continuing calibration. Benzyl Chloride exceeds 40%. No positives were found for these parameters, therefore data was accepted.

Results relate only to the items tested.

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report
 Maxxam Job Number: GB205432

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2738246	DVO	Spiked Blank					
		Bromochloromethane	2012/01/16		106	%	60 - 140
		D5-Chlorobenzene	2012/01/16		107	%	60 - 140
		Difluorobenzene	2012/01/16		108	%	60 - 140
		2,2,4-Trimethylpentane	2012/01/16		102	%	70 - 130
		Carbon Disulfide	2012/01/16		99	%	70 - 130
		Propene	2012/01/16		101	%	70 - 130
		Vinyl Acetate	2012/01/16		126	%	70 - 130
		Vinyl Bromide	2012/01/16		108	%	70 - 130
		Dichlorodifluoromethane (FREON 12)	2012/01/16		111	%	70 - 130
		1,2-Dichlorotetrafluoroethane	2012/01/16		124	%	70 - 130
		Chloromethane	2012/01/16		108	%	70 - 130
		Vinyl Chloride	2012/01/16		105	%	70 - 130
		Chloroethane	2012/01/16		102	%	70 - 130
		1,3-Butadiene	2012/01/16		106	%	70 - 130
		Trichlorofluoromethane (FREON 11)	2012/01/16		106	%	70 - 130
		Trichlorotrifluoroethane	2012/01/16		99	%	70 - 130
		Ethanol	2012/01/16		95	%	70 - 130
		2-propanol	2012/01/16		97	%	70 - 130
		2-Propanone	2012/01/16		89	%	70 - 130
		Methyl Ethyl Ketone (2-Butanone)	2012/01/16		116	%	70 - 130
		Methyl Isobutyl Ketone	2012/01/16		110	%	70 - 130
		Methyl Butyl Ketone (2-Hexanone)	2012/01/16		113	%	70 - 130
		Methyl t-butyl ether (MTBE)	2012/01/16		106	%	70 - 130
		Ethyl Acetate	2012/01/16		109	%	70 - 130
		1,1-Dichloroethylene	2012/01/16		114	%	70 - 130
		cis-1,2-Dichloroethylene	2012/01/16		103	%	70 - 130
		trans-1,2-Dichloroethylene	2012/01/16		101	%	70 - 130
		Methylene Chloride(Dichloromethane)	2012/01/16		96	%	70 - 130
		Chloroform	2012/01/16		100	%	70 - 130
		Carbon Tetrachloride	2012/01/16		109	%	70 - 130
		1,1-Dichloroethane	2012/01/16		96	%	70 - 130
		1,2-Dichloroethane	2012/01/16		108	%	70 - 130
		Ethylene Dibromide	2012/01/16		100	%	70 - 130
		1,1,1-Trichloroethane	2012/01/16		107	%	70 - 130
		1,1,2-Trichloroethane	2012/01/16		97	%	70 - 130
		1,1,2,2-Tetrachloroethane	2012/01/16		90	%	70 - 130
		cis-1,3-Dichloropropene	2012/01/16		108	%	70 - 130
		trans-1,3-Dichloropropene	2012/01/16		117	%	70 - 130
		1,2-Dichloropropane	2012/01/16		97	%	70 - 130
		Bromomethane	2012/01/16		106	%	70 - 130
		Bromoform	2012/01/16		110	%	70 - 130
		Bromodichloromethane	2012/01/16		109	%	70 - 130
		Dibromochloromethane	2012/01/16		106	%	70 - 130
		Heptane	2012/01/16		103	%	70 - 130
		Trichloroethylene	2012/01/16		92	%	70 - 130
		Tetrachloroethylene	2012/01/16		96	%	70 - 130
		Benzene	2012/01/16		95	%	70 - 130
		Toluene	2012/01/16		99	%	70 - 130
		Ethylbenzene	2012/01/16		101	%	70 - 130
		p+m-Xylene	2012/01/16		100	%	70 - 130
		o-Xylene	2012/01/16		101	%	70 - 130
		Styrene	2012/01/16		94	%	70 - 130
		1,3,5-Trimethylbenzene	2012/01/16		92	%	70 - 130
		1,2,4-Trimethylbenzene	2012/01/16		91	%	70 - 130
		4-ethyltoluene	2012/01/16		93	%	70 - 130

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report (Continued)

Maxxam Job Number: GB205432

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2738246	DVO	Spiked Blank	2012/01/16		93	%	70 - 130
		Chlorobenzene	2012/01/16		114	%	70 - 130
		Benzyl chloride	2012/01/16		89	%	70 - 130
		1,3-Dichlorobenzene	2012/01/16		88	%	70 - 130
		1,4-Dichlorobenzene	2012/01/16		82	%	70 - 130
		1,2-Dichlorobenzene	2012/01/16		122	%	70 - 130
		1,2,4-Trichlorobenzene	2012/01/16		107	%	70 - 130
		Hexachlorobutadiene	2012/01/16		94	%	70 - 130
		Hexane	2012/01/16		101	%	70 - 130
		Cyclohexane	2012/01/16		109	%	70 - 130
		Tetrahydrofuran	2012/01/16		106	%	70 - 130
		1,4-Dioxane	2012/01/16		100	%	70 - 130
	Method Blank	Xylene (Total)	2012/01/16		89	%	60 - 140
		Bromochloromethane	2012/01/16		89	%	60 - 140
		D5-Chlorobenzene	2012/01/16		91	%	60 - 140
		Difluorobenzene	2012/01/16				
		2,2,4-Trimethylpentane	2012/01/16	<0.20		ppbv	
		Carbon Disulfide	2012/01/16	<0.50		ppbv	
		Propene	2012/01/16	<0.30		ppbv	
		Vinyl Acetate	2012/01/16	<0.20		ppbv	
		Vinyl Bromide	2012/01/16	<0.20		ppbv	
		Dichlorodifluoromethane (FREON 12)	2012/01/16	<0.20		ppbv	
		1,2-Dichlorotetrafluoroethane	2012/01/16	<0.17		ppbv	
		Chloromethane	2012/01/16	<0.30		ppbv	
		Vinyl Chloride	2012/01/16	<0.18		ppbv	
		Chloroethane	2012/01/16	<0.30		ppbv	
		1,3-Butadiene	2012/01/16	<0.50		ppbv	
		Trichlorofluoromethane (FREON 11)	2012/01/16	<0.20		ppbv	
		Trichlorotrifluoroethane	2012/01/16	<0.15		ppbv	
		Ethanol	2012/01/16	<2.3		ppbv	
		2-propanol	2012/01/16	<3.0		ppbv	
		2-Propanone	2012/01/16	<0.80		ppbv	
		Methyl Ethyl Ketone (2-Butanone)	2012/01/16	<3.0		ppbv	
		Methyl Isobutyl Ketone	2012/01/16	<3.2		ppbv	
		Methyl Butyl Ketone (2-Hexanone)	2012/01/16	<2.0		ppbv	
		Methyl t-butyl ether (MTBE)	2012/01/16	<0.20		ppbv	
		Ethyl Acetate	2012/01/16	<2.2		ppbv	
		1,1-Dichloroethylene	2012/01/16	<0.25		ppbv	
		cis-1,2-Dichloroethylene	2012/01/16	<0.19		ppbv	
		trans-1,2-Dichloroethylene	2012/01/16	<0.20		ppbv	
		Methylene Chloride(Dichloromethane)	2012/01/16	<0.80		ppbv	
		Chloroform	2012/01/16	<0.15		ppbv	
		Carbon Tetrachloride	2012/01/16	<0.30		ppbv	
		1,1-Dichloroethane	2012/01/16	<0.20		ppbv	
		1,2-Dichloroethane	2012/01/16	<0.20		ppbv	
		Ethylene Dibromide	2012/01/16	<0.17		ppbv	
		1,1,1-Trichloroethane	2012/01/16	<0.30		ppbv	
		1,1,2-Trichloroethane	2012/01/16	<0.15		ppbv	
		1,1,2,2-Tetrachloroethane	2012/01/16	<0.20		ppbv	
		cis-1,3-Dichloropropene	2012/01/16	<0.18		ppbv	
		trans-1,3-Dichloropropene	2012/01/16	<0.17		ppbv	
		1,2-Dichloropropane	2012/01/16	<0.40		ppbv	
		Bromomethane	2012/01/16	<0.18		ppbv	
		Bromoform	2012/01/16	<0.20		ppbv	
		Bromodichloromethane	2012/01/16	<0.20		ppbv	
		Dibromochloromethane	2012/01/16	<0.20		ppbv	

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report (Continued)

Maxxam Job Number: GB205432

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2738246	DVO	Method Blank					
		Heptane	2012/01/16	<0.30		ppbv	
		Trichloroethylene	2012/01/16	<0.30		ppbv	
		Tetrachloroethylene	2012/01/16	<0.20		ppbv	
		Benzene	2012/01/16	<0.18		ppbv	
		Toluene	2012/01/16	<0.20		ppbv	
		Ethylbenzene	2012/01/16	<0.20		ppbv	
		p+m-Xylene	2012/01/16	<0.37		ppbv	
		o-Xylene	2012/01/16	<0.20		ppbv	
		Styrene	2012/01/16	<0.20		ppbv	
		1,3,5-Trimethylbenzene	2012/01/16	<0.50		ppbv	
		1,2,4-Trimethylbenzene	2012/01/16	<0.50		ppbv	
		4-ethyltoluene	2012/01/16	<2.2		ppbv	
		Chlorobenzene	2012/01/16	<0.20		ppbv	
		Benzyl chloride	2012/01/16	<1.0		ppbv	
		1,3-Dichlorobenzene	2012/01/16	<0.40		ppbv	
		1,4-Dichlorobenzene	2012/01/16	<0.40		ppbv	
		1,2-Dichlorobenzene	2012/01/16	<0.40		ppbv	
		1,2,4-Trichlorobenzene	2012/01/16	<2.0		ppbv	
		Hexachlorobutadiene	2012/01/16	<3.0		ppbv	
		Hexane	2012/01/16	<0.30		ppbv	
		Cyclohexane	2012/01/16	<0.20		ppbv	
		Tetrahydrofuran	2012/01/16	<0.40		ppbv	
		1,4-Dioxane	2012/01/16	<2.0		ppbv	
		Xylene (Total)	2012/01/16	<0.60		ppbv	
	RPD - Sample/Sample Dup	2,2,4-Trimethylpentane	2012/01/16	NC		%	25
		Carbon Disulfide	2012/01/16	NC		%	25
		Propene	2012/01/16	NC		%	25
		Vinyl Acetate	2012/01/16	NC		%	25
		Vinyl Bromide	2012/01/16	NC		%	25
		Dichlorodifluoromethane (FREON 12)	2012/01/16	NC		%	25
		1,2-Dichlorotetrafluoroethane	2012/01/16	NC		%	25
		Chloromethane	2012/01/16	NC		%	25
		Vinyl Chloride	2012/01/16	NC		%	25
		Chloroethane	2012/01/16	NC		%	25
		1,3-Butadiene	2012/01/16	NC		%	25
		Trichlorofluoromethane (FREON 11)	2012/01/16	NC		%	25
		Trichlorotrifluoroethane	2012/01/16	NC		%	25
		Ethanol	2012/01/16	NC		%	25
		2-propanol	2012/01/16	NC		%	25
		2-Propanone	2012/01/16	NC		%	25
		Methyl Ethyl Ketone (2-Butanone)	2012/01/16	NC		%	25
		Methyl Isobutyl Ketone	2012/01/16	NC		%	25
		Methyl Butyl Ketone (2-Hexanone)	2012/01/16	NC		%	25
		Methyl t-butyl ether (MTBE)	2012/01/16	NC		%	25
		Ethyl Acetate	2012/01/16	NC		%	25
		1,1-Dichloroethylene	2012/01/16	NC		%	25
		cis-1,2-Dichloroethylene	2012/01/16	NC		%	25
		trans-1,2-Dichloroethylene	2012/01/16	NC		%	25
		Methylene Chloride(Dichloromethane)	2012/01/16	NC		%	25
		Chloroform	2012/01/16	NC		%	25
		Carbon Tetrachloride	2012/01/16	NC		%	25
		1,1-Dichloroethane	2012/01/16	NC		%	25
		1,2-Dichloroethane	2012/01/16	NC		%	25

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report (Continued)

Maxxam Job Number: GB205432

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2738246 DVO	RPD - Sample/Sample Dup	Ethylene Dibromide	2012/01/16	NC		%	25
		1,1,1-Trichloroethane	2012/01/16	NC		%	25
		1,1,2-Trichloroethane	2012/01/16	NC		%	25
		1,1,2,2-Tetrachloroethane	2012/01/16	NC		%	25
		cis-1,3-Dichloropropene	2012/01/16	NC		%	25
		trans-1,3-Dichloropropene	2012/01/16	NC		%	25
		1,2-Dichloropropane	2012/01/16	NC		%	25
		Bromomethane	2012/01/16	NC		%	25
		Bromoform	2012/01/16	NC		%	25
		Bromodichloromethane	2012/01/16	NC		%	25
		Dibromochloromethane	2012/01/16	NC		%	25
		Heptane	2012/01/16	NC		%	25
		Trichloroethylene	2012/01/16	NC		%	25
		Tetrachloroethylene	2012/01/16	NC		%	25
		Benzene	2012/01/16	NC		%	25
		Toluene	2012/01/16	0.09		%	25
		Ethylbenzene	2012/01/16	NC		%	25
		p+m-Xylene	2012/01/16	NC		%	25
		o-Xylene	2012/01/16	NC		%	25
		Styrene	2012/01/16	NC		%	25
		1,3,5-Trimethylbenzene	2012/01/16	NC		%	25
		1,2,4-Trimethylbenzene	2012/01/16	NC		%	25
		4-ethyltoluene	2012/01/16	NC		%	25
		Chlorobenzene	2012/01/16	NC		%	25
		Benzyl chloride	2012/01/16	NC		%	25
		1,3-Dichlorobenzene	2012/01/16	NC		%	25
		1,4-Dichlorobenzene	2012/01/16	NC		%	25
		1,2-Dichlorobenzene	2012/01/16	NC		%	25
		1,2,4-Trichlorobenzene	2012/01/16	NC		%	25
		Hexachlorobutadiene	2012/01/16	NC		%	25
		Hexane	2012/01/16	NC		%	25
		Cyclohexane	2012/01/16	NC		%	25
		Tetrahydrofuran	2012/01/16	NC		%	25
		1,4-Dioxane	2012/01/16	NC		%	25
		Xylene (Total)	2012/01/16	NC		%	25

Spiked Blank: A blank matrix to which a known amount of the analyte has been added. Used to evaluate analyte recovery.

Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

Surrogate: A pure or isotopically labeled compound whose behavior mirrors the analytes of interest. Used to evaluate extraction efficiency.

NC (RPD): The RPD was not calculated. The level of analyte detected in the parent sample and its duplicate was not sufficiently significant to permit a reliable calculation.

MAXXAM

Xontech Model 910A VOC Sample Collection Data Sheet

Client: LICA Sampler s/n: 6167
Location: Cold Lake South Canister ID: 7914
Station ID: Lica 1 Canister Installation Date/Time: Jan 11, 2012 @ 13:20 mst
Field Sample ID: LICA VOC/ CLS /Jan 16, 2012 Canister Removal Date/Time: Jan 19, 2012 @ 8:30 mst

Date and Time Information			
Sample Date	Start Time (MST)	End Time (MST)	Elapsed Time (Hours)
16-Jan-12	01/16/2012 0:00	01/17/2012 0:00	24.00

Flow Settings		
Meter Reading (sccm)	Pot Set Pt.	Pump Pressure Setting (psig)
10.0	646	25

Canister Information	
Initial Canister Vacuum (inHg)	Final Canister Pressure (psig)
-28	23

Canister valve open prior to sampling?: YES / NO
Timer set to 0.00 minutes prior to sampling? YES / NO
Canister valve closed prior to disconnection?: YES / NO

Comments: System leak check prior to sampling. COC # 08652

Technician Signiture: Theo McLaren



Your C.O.C. #: 08652

Attention: Michael Bisaga

Maxxam Analytics
2608 6A Ave.
Cold Lake, AB
CANADA T9M 2C7

Report Date: 2012/02/05

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: B210494

Received: 2012/01/24, 09:50

Sample Matrix: AIR
Samples Received: 1

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Canister Pressure (TO-15)	1	N/A	2012/02/01	BRL SOP-00304	EPA TO-15
Volatile Organics in Air (TO-15) (1)	1	N/A	2012/02/01	BRL SOP-00304	EPA TO-15

(1) Air sampling canisters have been cleaned in accordance with U.S. EPA Method TO14A. At the end of the cleaning, evacuation, and pressurization cycles, one canister was selected and was pressurized with Zero Air. This canister was then analyzed via TO14A on a GC/MS. The canister must have been found to contain <0.2 ppbv concentration of all target analytes in order for the batch to have been considered clean. Each canister also underwent a leak check prior to shipment.

Please Note: SUMMA® canister samples will be retained by Maxxam for a period of 5 calendar days from the date of this report, after which time they will be cleaned for reuse. If you require a longer sample storage period, please contact your service representative.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

THERESA STEPHENSON, Project Manager
Email: TStephenson@maxxam.ca
Phone# (905) 817-5763

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Maxxam Analytics Inc. is a NELAC accredited laboratory. Certificate # CANA001. Use of the NELAC logo however does not insure that Maxxam is accredited for all of the methods indicated. This certificate shall not be reproduced except in full, without the written approval of Maxxam Analytics Inc. Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section.

Total cover pages: 1

Maxxam Job #: B210494
Report Date: 2012/02/05

RESULTS OF ANALYSES OF AIR

Maxxam ID		MI0838	
Sampling Date		2012/01/16	
COC Number		08652	
	Units	LICA VOC/CLS /JAN16, 2012/7914	QC Batch

Volatile Organics			
Pressure on Receipt	psig	22	2753444
QC Batch = Quality Control Batch			

Maxxam Job #: B210494
 Report Date: 2012/02/05

VOLATILE ORGANICS BY GC/MS (AIR)

Maxxam ID		MI0838				
Sampling Date		2012/01/16				
COC Number		08652				
	Units	LICA VOC/CLS /JAN16, 2012/7914	RDL	ug/m3	DL (ug/m3)	QC Batch

Volatile Organics						
2,2,4-Trimethylpentane	ppbv	<0.20	0.20	<0.934	0.934	2753443
Carbon Disulfide	ppbv	<0.50	0.50	<1.56	1.56	2753443
Propene	ppbv	<0.30	0.30	<0.516	0.516	2753443
Vinyl Acetate	ppbv	<0.20	0.20	<0.704	0.704	2753443
Vinyl Bromide	ppbv	<0.20	0.20	<0.875	0.875	2753443
Dichlorodifluoromethane (FREON 12)	ppbv	0.77	0.20	3.81	0.989	2753443
1,2-Dichlorotetrafluoroethane	ppbv	<0.17	0.17	<1.19	1.19	2753443
Chloromethane	ppbv	0.61	0.30	1.26	0.620	2753443
Vinyl Chloride	ppbv	<0.18	0.18	<0.460	0.460	2753443
Chloroethane	ppbv	<0.30	0.30	<0.792	0.792	2753443
1,3-Butadiene	ppbv	<0.50	0.50	<1.11	1.11	2753443
Trichlorofluoromethane (FREON 11)	ppbv	0.35	0.20	1.95	1.12	2753443
Trichlorotrifluoroethane	ppbv	<0.15	0.15	<1.15	1.15	2753443
Ethanol (ethyl alcohol)	ppbv	<2.3	2.3	<4.33	4.33	2753443
2-propanol	ppbv	<3.0	3.0	<7.37	7.37	2753443
2-Propanone	ppbv	<0.80	0.80	<1.90	1.90	2753443
Methyl Ethyl Ketone (2-Butanone)	ppbv	<3.0	3.0	<8.85	8.85	2753443
Methyl Isobutyl Ketone	ppbv	<3.2	3.2	<13.1	13.1	2753443
Methyl Butyl Ketone (2-Hexanone)	ppbv	<2.0	2.0	<8.19	8.19	2753443
Methyl t-butyl ether (MTBE)	ppbv	<0.20	0.20	<0.721	0.721	2753443
Ethyl Acetate	ppbv	<2.2	2.2	<7.93	7.93	2753443
1,1-Dichloroethylene	ppbv	<0.25	0.25	<0.991	0.991	2753443
cis-1,2-Dichloroethylene	ppbv	<0.19	0.19	<0.753	0.753	2753443
trans-1,2-Dichloroethylene	ppbv	<0.20	0.20	<0.793	0.793	2753443
Methylene Chloride(Dichloromethane)	ppbv	<0.80	0.80	<2.78	2.78	2753443
Chloroform	ppbv	<0.15	0.15	<0.732	0.732	2753443
Carbon Tetrachloride	ppbv	<0.30	0.30	<1.89	1.89	2753443
1,1-Dichloroethane	ppbv	<0.20	0.20	<0.809	0.809	2753443
1,2-Dichloroethane	ppbv	<0.20	0.20	<0.809	0.809	2753443
Ethylene Dibromide	ppbv	<0.17	0.17	<1.31	1.31	2753443

 RDL = Reportable Detection Limit
 QC Batch = Quality Control Batch

Maxxam Job #: B210494
 Report Date: 2012/02/05

VOLATILE ORGANICS BY GC/MS (AIR)

Maxxam ID		MI0838				
Sampling Date		2012/01/16				
COC Number		08652				
	Units	LICA VOC/CLS /JAN16, 2012/7914	RDL	ug/m3	DL (ug/m3)	QC Batch

1,1,1-Trichloroethane	ppbv	<0.30	0.30	<1.64	1.64	2753443
1,1,2-Trichloroethane	ppbv	<0.15	0.15	<0.818	0.818	2753443
1,1,2,2-Tetrachloroethane	ppbv	<0.20	0.20	<1.37	1.37	2753443
cis-1,3-Dichloropropene	ppbv	<0.18	0.18	<0.817	0.817	2753443
trans-1,3-Dichloropropene	ppbv	<0.17	0.17	<0.772	0.772	2753443
1,2-Dichloropropane	ppbv	<0.40	0.40	<1.85	1.85	2753443
Bromomethane	ppbv	<0.18	0.18	<0.699	0.699	2753443
Bromoform	ppbv	<0.20	0.20	<2.07	2.07	2753443
Bromodichloromethane	ppbv	<0.20	0.20	<1.34	1.34	2753443
Dibromochloromethane	ppbv	<0.20	0.20	<1.70	1.70	2753443
Heptane	ppbv	<0.30	0.30	<1.23	1.23	2753443
Trichloroethylene	ppbv	<0.30	0.30	<1.61	1.61	2753443
Tetrachloroethylene	ppbv	<0.20	0.20	<1.36	1.36	2753443
Benzene	ppbv	0.27	0.18	0.857	0.575	2753443
Toluene	ppbv	<0.20	0.20	<0.753	0.753	2753443
Ethylbenzene	ppbv	<0.20	0.20	<0.868	0.868	2753443
p+m-Xylene	ppbv	<0.37	0.37	<1.61	1.61	2753443
o-Xylene	ppbv	<0.20	0.20	<0.868	0.868	2753443
Styrene	ppbv	<0.20	0.20	<0.852	0.852	2753443
1,3,5-Trimethylbenzene	ppbv	<0.50	0.50	<2.46	2.46	2753443
1,2,4-Trimethylbenzene	ppbv	<0.50	0.50	<2.46	2.46	2753443
4-ethyltoluene	ppbv	<2.2	2.2	<10.8	10.8	2753443
Chlorobenzene	ppbv	<0.20	0.20	<0.921	0.921	2753443
Benzyl chloride	ppbv	<1.0	1.0	<5.18	5.18	2753443
1,3-Dichlorobenzene	ppbv	<0.40	0.40	<2.40	2.40	2753443
1,4-Dichlorobenzene	ppbv	<0.40	0.40	<2.40	2.40	2753443
1,2-Dichlorobenzene	ppbv	<0.40	0.40	<2.40	2.40	2753443
1,2,4-Trichlorobenzene	ppbv	<2.0	2.0	<14.8	14.8	2753443
Hexachlorobutadiene	ppbv	<3.0	3.0	<32.0	32.0	2753443
Hexane	ppbv	<0.30	0.30	<1.06	1.06	2753443
Cyclohexane	ppbv	<0.20	0.20	<0.688	0.688	2753443
Tetrahydrofuran	ppbv	<0.40	0.40	<1.18	1.18	2753443

QC Batch = Quality Control Batch

Maxxam Job #: B210494
 Report Date: 2012/02/05

VOLATILE ORGANICS BY GC/MS (AIR)

Maxxam ID		MI0838				
Sampling Date		2012/01/16				
COC Number		08652				
	Units	LICA VOC/CLS /JAN16, 2012/7914	RDL	ug/m3	DL (ug/m3)	QC Batch
1,4-Dioxane	ppbv	<2.0	2.0	<7.21	7.21	2753443
Xylene (Total)	ppbv	<0.60	0.60	<2.61	2.61	2753443
Surrogate Recovery (%)						
Bromochloromethane	%	79		N/A	N/A	2753443
D5-Chlorobenzene	%	75		N/A	N/A	2753443
Difluorobenzene	%	80		N/A	N/A	2753443
N/A = Not Applicable QC Batch = Quality Control Batch						

Maxxam Job #: B210494
Report Date: 2012/02/05

Test Summary

Maxxam ID MI0838
Sample ID LICA VOC/CLS /JAN16, 2012/7914
Matrix AIR

Collected 2012/01/16
Shipped
Received 2012/01/24

Test Description	Instrumentation	Batch	Extracted	Analyzed	Analyst
Canister Pressure (TO-15)	PRES	2753444	N/A	2012/02/01	MELANIE MABINI
Volatile Organics in Air (TO-15)	GC/MS	2753443	N/A	2012/02/01	MELANIE MABINI

Maxxam Job #: B210494
Report Date: 2012/02/05

GENERAL COMMENTS

Results relate only to the items tested.

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report
 Maxxam Job Number: GB210494

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2753443 MM2	Spiked Blank	Bromochloromethane	2012/02/01		95	%	60 - 140
		D5-Chlorobenzene	2012/02/01		99	%	60 - 140
		Difluorobenzene	2012/02/01		98	%	60 - 140
		2,2,4-Trimethylpentane	2012/02/01		107	%	70 - 130
		Carbon Disulfide	2012/02/01		93	%	70 - 130
		Propene	2012/02/01		101	%	70 - 130
		Vinyl Acetate	2012/02/01		116	%	70 - 130
		Vinyl Bromide	2012/02/01		102	%	70 - 130
		Dichlorodifluoromethane (FREON 12)	2012/02/01		110	%	70 - 130
		1,2-Dichlorotetrafluoroethane	2012/02/01		119	%	70 - 130
		Chloromethane	2012/02/01		109	%	70 - 130
		Vinyl Chloride	2012/02/01		104	%	70 - 130
		Chloroethane	2012/02/01		105	%	70 - 130
		1,3-Butadiene	2012/02/01		104	%	70 - 130
		Trichlorofluoromethane (FREON 11)	2012/02/01		106	%	70 - 130
		Trichlorotrifluoroethane	2012/02/01		106	%	70 - 130
		Ethanol (ethyl alcohol)	2012/02/01		90	%	70 - 130
		2-propanol	2012/02/01		102	%	70 - 130
		2-Propanone	2012/02/01		104	%	70 - 130
		Methyl Ethyl Ketone (2-Butanone)	2012/02/01		96	%	70 - 130
		Methyl Isobutyl Ketone	2012/02/01		107	%	70 - 130
		Methyl Butyl Ketone (2-Hexanone)	2012/02/01		109	%	70 - 130
		Methyl t-butyl ether (MTBE)	2012/02/01		108	%	70 - 130
		Ethyl Acetate	2012/02/01		114	%	70 - 130
		1,1-Dichloroethylene	2012/02/01		109	%	70 - 130
		cis-1,2-Dichloroethylene	2012/02/01		111	%	70 - 130
		trans-1,2-Dichloroethylene	2012/02/01		109	%	70 - 130
		Methylene Chloride(Dichloromethane)	2012/02/01		102	%	70 - 130
		Chloroform	2012/02/01		107	%	70 - 130
		Carbon Tetrachloride	2012/02/01		113	%	70 - 130
		1,1-Dichloroethane	2012/02/01		109	%	70 - 130
		1,2-Dichloroethane	2012/02/01		111	%	70 - 130
		Ethylene Dibromide	2012/02/01		108	%	70 - 130
		1,1,1-Trichloroethane	2012/02/01		109	%	70 - 130
		1,1,2-Trichloroethane	2012/02/01		109	%	70 - 130
		1,1,2,2-Tetrachloroethane	2012/02/01		106	%	70 - 130
		cis-1,3-Dichloropropene	2012/02/01		113	%	70 - 130
		trans-1,3-Dichloropropene	2012/02/01		118	%	70 - 130
		1,2-Dichloropropane	2012/02/01		110	%	70 - 130
		Bromomethane	2012/02/01		102	%	70 - 130
		Bromoform	2012/02/01		114	%	70 - 130
		Bromodichloromethane	2012/02/01		111	%	70 - 130
		Dibromochloromethane	2012/02/01		113	%	70 - 130
		Heptane	2012/02/01		115	%	70 - 130
		Trichloroethylene	2012/02/01		104	%	70 - 130
		Tetrachloroethylene	2012/02/01		105	%	70 - 130
		Benzene	2012/02/01		107	%	70 - 130
		Toluene	2012/02/01		109	%	70 - 130
		Ethylbenzene	2012/02/01		107	%	70 - 130
		p+m-Xylene	2012/02/01		104	%	70 - 130
		o-Xylene	2012/02/01		107	%	70 - 130
		Styrene	2012/02/01		99	%	70 - 130
		1,3,5-Trimethylbenzene	2012/02/01		105	%	70 - 130
		1,2,4-Trimethylbenzene	2012/02/01		104	%	70 - 130
		4-ethyltoluene	2012/02/01		112	%	70 - 130

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report (Continued)

Maxxam Job Number: GB210494

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2753443 MM2	Spiked Blank	Chlorobenzene	2012/02/01		102	%	70 - 130
		Benzyl chloride	2012/02/01		114	%	70 - 130
		1,3-Dichlorobenzene	2012/02/01		101	%	70 - 130
		1,4-Dichlorobenzene	2012/02/01		101	%	70 - 130
		1,2-Dichlorobenzene	2012/02/01		99	%	70 - 130
		1,2,4-Trichlorobenzene	2012/02/01		70	%	70 - 130
		Hexachlorobutadiene	2012/02/01		87	%	70 - 130
		Hexane	2012/02/01		107	%	70 - 130
		Cyclohexane	2012/02/01		110	%	70 - 130
		Tetrahydrofuran	2012/02/01		112	%	70 - 130
		1,4-Dioxane	2012/02/01		99	%	70 - 130
	Method Blank	Bromochloromethane	2012/02/01		81	%	60 - 140
		D5-Chlorobenzene	2012/02/01		80	%	60 - 140
		Difluorobenzene	2012/02/01		84	%	60 - 140
		2,2,4-Trimethylpentane	2012/02/01	<0.20		ppbv	
		Carbon Disulfide	2012/02/01	<0.50		ppbv	
		Propene	2012/02/01	<0.30		ppbv	
		Vinyl Acetate	2012/02/01	<0.20		ppbv	
		Vinyl Bromide	2012/02/01	<0.20		ppbv	
		Dichlorodifluoromethane (FREON 12)	2012/02/01	<0.20		ppbv	
		1,2-Dichlorotetrafluoroethane	2012/02/01	<0.17		ppbv	
		Chloromethane	2012/02/01	<0.30		ppbv	
		Vinyl Chloride	2012/02/01	<0.18		ppbv	
		Chloroethane	2012/02/01	<0.30		ppbv	
		1,3-Butadiene	2012/02/01	<0.50		ppbv	
		Trichlorofluoromethane (FREON 11)	2012/02/01	<0.20		ppbv	
		Trichlorotrifluoroethane	2012/02/01	<0.15		ppbv	
		Ethanol (ethyl alcohol)	2012/02/01	<2.3		ppbv	
		2-propanol	2012/02/01	<3.0		ppbv	
		2-Propanone	2012/02/01	<0.80		ppbv	
		Methyl Ethyl Ketone (2-Butanone)	2012/02/01	<3.0		ppbv	
		Methyl Isobutyl Ketone	2012/02/01	<3.2		ppbv	
		Methyl Butyl Ketone (2-Hexanone)	2012/02/01	<2.0		ppbv	
		Methyl t-butyl ether (MTBE)	2012/02/01	<0.20		ppbv	
		Ethyl Acetate	2012/02/01	<2.2		ppbv	
		1,1-Dichloroethylene	2012/02/01	<0.25		ppbv	
		cis-1,2-Dichloroethylene	2012/02/01	<0.19		ppbv	
		trans-1,2-Dichloroethylene	2012/02/01	<0.20		ppbv	
		Methylene Chloride(Dichloromethane)	2012/02/01	<0.80		ppbv	
		Chloroform	2012/02/01	<0.15		ppbv	
		Carbon Tetrachloride	2012/02/01	<0.30		ppbv	
		1,1-Dichloroethane	2012/02/01	<0.20		ppbv	
		1,2-Dichloroethane	2012/02/01	<0.20		ppbv	
		Ethylene Dibromide	2012/02/01	<0.17		ppbv	
		1,1,1-Trichloroethane	2012/02/01	<0.30		ppbv	
		1,1,2-Trichloroethane	2012/02/01	<0.15		ppbv	
		1,1,2,2-Tetrachloroethane	2012/02/01	<0.20		ppbv	
		cis-1,3-Dichloropropene	2012/02/01	<0.18		ppbv	
		trans-1,3-Dichloropropene	2012/02/01	<0.17		ppbv	
		1,2-Dichloropropane	2012/02/01	<0.40		ppbv	
		Bromomethane	2012/02/01	<0.18		ppbv	
		Bromoform	2012/02/01	<0.20		ppbv	
		Bromodichloromethane	2012/02/01	<0.20		ppbv	
		Dibromochloromethane	2012/02/01	<0.20		ppbv	
		Heptane	2012/02/01	<0.30		ppbv	

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report (Continued)

Maxxam Job Number: GB210494

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2753443	MM2	Method Blank					
		Trichloroethylene	2012/02/01	<0.30		ppbv	
		Tetrachloroethylene	2012/02/01	<0.20		ppbv	
		Benzene	2012/02/01	<0.18		ppbv	
		Toluene	2012/02/01	<0.20		ppbv	
		Ethylbenzene	2012/02/01	<0.20		ppbv	
		p+m-Xylene	2012/02/01	<0.37		ppbv	
		o-Xylene	2012/02/01	<0.20		ppbv	
		Styrene	2012/02/01	<0.20		ppbv	
		1,3,5-Trimethylbenzene	2012/02/01	<0.50		ppbv	
		1,2,4-Trimethylbenzene	2012/02/01	<0.50		ppbv	
		4-ethyltoluene	2012/02/01	<2.2		ppbv	
		Chlorobenzene	2012/02/01	<0.20		ppbv	
		Benzyl chloride	2012/02/01	<1.0		ppbv	
		1,3-Dichlorobenzene	2012/02/01	<0.40		ppbv	
		1,4-Dichlorobenzene	2012/02/01	<0.40		ppbv	
		1,2-Dichlorobenzene	2012/02/01	<0.40		ppbv	
		1,2,4-Trichlorobenzene	2012/02/01	<2.0		ppbv	
		Hexachlorobutadiene	2012/02/01	<3.0		ppbv	
		Hexane	2012/02/01	<0.30		ppbv	
		Cyclohexane	2012/02/01	<0.20		ppbv	
		Tetrahydrofuran	2012/02/01	<0.40		ppbv	
		1,4-Dioxane	2012/02/01	<2.0		ppbv	
		Xylene (Total)	2012/02/01	<0.60		ppbv	
	RPD - Sample/Sample Dup	2,2,4-Trimethylpentane	2012/02/01	1.3		%	25
		Carbon Disulfide	2012/02/01	1		%	25
		Propene	2012/02/01	NC		%	25
		Vinyl Acetate	2012/02/01	NC		%	25
		Vinyl Bromide	2012/02/01	NC		%	25
		Dichlorodifluoromethane (FREON 12)	2012/02/01	NC		%	25
		1,2-Dichlorotetrafluoroethane	2012/02/01	NC		%	25
		Chloromethane	2012/02/01	4.5		%	25
		Vinyl Chloride	2012/02/01	NC		%	25
		Chloroethane	2012/02/01	NC		%	25
		1,3-Butadiene	2012/02/01	NC		%	25
		Trichlorofluoromethane (FREON 11)	2012/02/01	NC		%	25
		Trichlorotrifluoroethane	2012/02/01	NC		%	25
		Ethanol (ethyl alcohol)	2012/02/01	NC		%	25
		2-propanol	2012/02/01	NC		%	25
		2-Propanone	2012/02/01	3.4		%	25
		Methyl Ethyl Ketone (2-Butanone)	2012/02/01	NC		%	25
		Methyl Isobutyl Ketone	2012/02/01	NC		%	25
		Methyl Butyl Ketone (2-Hexanone)	2012/02/01	NC		%	25
		Methyl t-butyl ether (MTBE)	2012/02/01	NC		%	25
		Ethyl Acetate	2012/02/01	NC		%	25
		1,1-Dichloroethylene	2012/02/01	NC		%	25
		cis-1,2-Dichloroethylene	2012/02/01	NC		%	25
		trans-1,2-Dichloroethylene	2012/02/01	NC		%	25
		Methylene Chloride(Dichloromethane)	2012/02/01	NC		%	25
		Chloroform	2012/02/01	NC		%	25
		Carbon Tetrachloride	2012/02/01	NC		%	25
		1,1-Dichloroethane	2012/02/01	NC		%	25
		1,2-Dichloroethane	2012/02/01	NC		%	25
		Ethylene Dibromide	2012/02/01	NC		%	25

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report (Continued)

Maxxam Job Number: GB210494

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2753443 MM2	RPD - Sample/Sample Dup	1,1,1-Trichloroethane	2012/02/01	NC		%	25
		1,1,2-Trichloroethane	2012/02/01	NC		%	25
		1,1,2,2-Tetrachloroethane	2012/02/01	NC		%	25
		cis-1,3-Dichloropropene	2012/02/01	NC		%	25
		trans-1,3-Dichloropropene	2012/02/01	NC		%	25
		1,2-Dichloropropane	2012/02/01	NC		%	25
		Bromomethane	2012/02/01	NC		%	25
		Bromoform	2012/02/01	NC		%	25
		Bromodichloromethane	2012/02/01	NC		%	25
		Dibromochloromethane	2012/02/01	NC		%	25
		Heptane	2012/02/01	1.4		%	25
		Trichloroethylene	2012/02/01	NC		%	25
		Tetrachloroethylene	2012/02/01	NC		%	25
		Benzene	2012/02/01	0.06		%	25
		Toluene	2012/02/01	2.2		%	25
		Ethylbenzene	2012/02/01	NC		%	25
		p+m-Xylene	2012/02/01	2.4		%	25
		o-Xylene	2012/02/01	NC		%	25
		Styrene	2012/02/01	NC		%	25
		1,3,5-Trimethylbenzene	2012/02/01	NC		%	25
		1,2,4-Trimethylbenzene	2012/02/01	NC		%	25
		4-ethyltoluene	2012/02/01	NC		%	25
		Chlorobenzene	2012/02/01	NC		%	25
		Benzyl chloride	2012/02/01	NC		%	25
		1,3-Dichlorobenzene	2012/02/01	NC		%	25
		1,4-Dichlorobenzene	2012/02/01	NC		%	25
		1,2-Dichlorobenzene	2012/02/01	NC		%	25
		1,2,4-Trichlorobenzene	2012/02/01	NC		%	25
		Hexachlorobutadiene	2012/02/01	NC		%	25
		Hexane	2012/02/01	3.0		%	25
		Cyclohexane	2012/02/01	NC		%	25
		Tetrahydrofuran	2012/02/01	NC		%	25
		1,4-Dioxane	2012/02/01	NC		%	25
		Xylene (Total)	2012/02/01	3.4		%	25

Spiked Blank: A blank matrix to which a known amount of the analyte has been added. Used to evaluate analyte recovery.

Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

Surrogate: A pure or isotopically labeled compound whose behavior mirrors the analytes of interest. Used to evaluate extraction efficiency.

NC (RPD): The RPD was not calculated. The level of analyte detected in the parent sample and its duplicate was not sufficiently significant to permit a reliable calculation.

MAXXAM

Xontech Model 910A VOC Sample Collection Data Sheet

Client: LICA Sampler s/n: 6167
Location: Cold Lake South Canister ID: 7842
Station ID: Lica 1 Canister Installation Date/Time: Jan 18, 2012 @ 11:20 mst
Field Sample ID: LICA VOC/ CLS /Jan 22, 2012 Canister Removal Date/Time: Jan 25, 2012 @ 16:15

Date and Time Information			
Sample Date	Start Time (MST)	End Time (MST)	Elapsed Time (Hours)
22-Jan-12	01/22/2012 0:00	01/23/2012 0:00	24.00

Flow Settings		
Meter Reading (sccm)	Pot Set Pt.	Pump Pressure Setting (psig)
10.0	646	25

Canister Information	
Initial Canister Vacuum (inHg)	Final Canister Pressure (psig)
-28	23

Canister valve open prior to sampling?: YES / NO
Timer set to 0.00 minutes prior to sampling? YES / NO
Canister valve closed prior to disconnection?: YES / NO

Comments: System leak check prior to sampling. COC # 08701

Technician Signiture: Ting Xu



Your C.O.C. #: 08701

Attention: Michael Bisaga

Maxxam Analytics
2608 6A Ave.
Cold Lake, AB
CANADA T9M 2C7

Report Date: 2012/02/05

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: B213399

Received: 2012/01/28, 10:43

Sample Matrix: AIR
Samples Received: 1

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Canister Pressure (TO-15)	1	N/A	2012/02/01	BRL SOP-00304	EPA TO-15
Volatile Organics in Air (TO-15) (1)	1	N/A	2012/02/01	BRL SOP-00304	EPA TO-15

(1) Air sampling canisters have been cleaned in accordance with U.S. EPA Method TO14A. At the end of the cleaning, evacuation, and pressurization cycles, one canister was selected and was pressurized with Zero Air. This canister was then analyzed via TO14A on a GC/MS. The canister must have been found to contain <0.2 ppbv concentration of all target analytes in order for the batch to have been considered clean. Each canister also underwent a leak check prior to shipment.

Please Note: SUMMA® canister samples will be retained by Maxxam for a period of 5 calendar days from the date of this report, after which time they will be cleaned for reuse. If you require a longer sample storage period, please contact your service representative.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

THERESA STEPHENSON, Project Manager
Email: TStephenson@maxxam.ca
Phone# (905) 817-5763

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Maxxam Analytics Inc. is a NELAC accredited laboratory. Certificate # CANA001. Use of the NELAC logo however does not insure that Maxxam is accredited for all of the methods indicated. This certificate shall not be reproduced except in full, without the written approval of Maxxam Analytics Inc. Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section.

Total cover pages: 1

Maxxam Job #: B213399
Report Date: 2012/02/05

RESULTS OF ANALYSES OF AIR

Maxxam ID		MJ4701	
Sampling Date		2012/01/22	
COC Number		08701	
	Units	LICA VOC/CLS/JAN22/12 - 7842	QC Batch

Volatile Organics			
Pressure on Receipt	psig	22	2753444

QC Batch = Quality Control Batch

Maxxam Job #: B213399
 Report Date: 2012/02/05

VOLATILE ORGANICS BY GC/MS (AIR)

Maxxam ID		MJ4701				
Sampling Date		2012/01/22				
COC Number		08701				
	Units	LICA VOC/CLS/JAN22/12 - 7842	RDL	ug/m3	DL (ug/m3)	QC Batch

Volatile Organics						
2,2,4-Trimethylpentane	ppbv	0.36	0.20	1.68	0.934	2753443
Carbon Disulfide	ppbv	<0.50	0.50	<1.56	1.56	2753443
Propene	ppbv	<0.30	0.30	<0.516	0.516	2753443
Vinyl Acetate	ppbv	<0.20	0.20	<0.704	0.704	2753443
Vinyl Bromide	ppbv	<0.20	0.20	<0.875	0.875	2753443
Dichlorodifluoromethane (FREON 12)	ppbv	0.84	0.20	4.18	0.989	2753443
1,2-Dichlorotetrafluoroethane	ppbv	<0.17	0.17	<1.19	1.19	2753443
Chloromethane	ppbv	0.61	0.30	1.25	0.620	2753443
Vinyl Chloride	ppbv	<0.18	0.18	<0.460	0.460	2753443
Chloroethane	ppbv	<0.30	0.30	<0.792	0.792	2753443
1,3-Butadiene	ppbv	<0.50	0.50	<1.11	1.11	2753443
Trichlorofluoromethane (FREON 11)	ppbv	0.36	0.20	2.01	1.12	2753443
Trichlorotrifluoroethane	ppbv	<0.15	0.15	<1.15	1.15	2753443
Ethanol (ethyl alcohol)	ppbv	2.4	2.3	4.45	4.33	2753443
2-propanol	ppbv	<3.0	3.0	<7.37	7.37	2753443
2-Propanone	ppbv	<0.80	0.80	<1.90	1.90	2753443
Methyl Ethyl Ketone (2-Butanone)	ppbv	<3.0	3.0	<8.85	8.85	2753443
Methyl Isobutyl Ketone	ppbv	<3.2	3.2	<13.1	13.1	2753443
Methyl Butyl Ketone (2-Hexanone)	ppbv	<2.0	2.0	<8.19	8.19	2753443
Methyl t-butyl ether (MTBE)	ppbv	<0.20	0.20	<0.721	0.721	2753443
Ethyl Acetate	ppbv	<2.2	2.2	<7.93	7.93	2753443
1,1-Dichloroethylene	ppbv	<0.25	0.25	<0.991	0.991	2753443
cis-1,2-Dichloroethylene	ppbv	<0.19	0.19	<0.753	0.753	2753443
trans-1,2-Dichloroethylene	ppbv	<0.20	0.20	<0.793	0.793	2753443
Methylene Chloride(Dichloromethane)	ppbv	<0.80	0.80	<2.78	2.78	2753443
Chloroform	ppbv	<0.15	0.15	<0.732	0.732	2753443
Carbon Tetrachloride	ppbv	<0.30	0.30	<1.89	1.89	2753443
1,1-Dichloroethane	ppbv	<0.20	0.20	<0.809	0.809	2753443
1,2-Dichloroethane	ppbv	<0.20	0.20	<0.809	0.809	2753443
Ethylene Dibromide	ppbv	<0.17	0.17	<1.31	1.31	2753443
1,1,1-Trichloroethane	ppbv	<0.30	0.30	<1.64	1.64	2753443

 RDL = Reportable Detection Limit
 QC Batch = Quality Control Batch

Maxxam Job #: B213399
 Report Date: 2012/02/05

VOLATILE ORGANICS BY GC/MS (AIR)

Maxxam ID		MJ4701				
Sampling Date		2012/01/22				
COC Number		08701				
	Units	LICA VOC/CLS/JAN22/12 - 7842	RDL	ug/m3	DL (ug/m3)	QC Batch
1,1,2-Trichloroethane	ppbv	<0.15	0.15	<0.818	0.818	2753443
1,1,2,2-Tetrachloroethane	ppbv	<0.20	0.20	<1.37	1.37	2753443
cis-1,3-Dichloropropene	ppbv	<0.18	0.18	<0.817	0.817	2753443
trans-1,3-Dichloropropene	ppbv	<0.17	0.17	<0.772	0.772	2753443
1,2-Dichloropropane	ppbv	<0.40	0.40	<1.85	1.85	2753443
Bromomethane	ppbv	<0.18	0.18	<0.699	0.699	2753443
Bromoform	ppbv	<0.20	0.20	<2.07	2.07	2753443
Bromodichloromethane	ppbv	<0.20	0.20	<1.34	1.34	2753443
Dibromochloromethane	ppbv	<0.20	0.20	<1.70	1.70	2753443
Heptane	ppbv	<0.30	0.30	<1.23	1.23	2753443
Trichloroethylene	ppbv	<0.30	0.30	<1.61	1.61	2753443
Tetrachloroethylene	ppbv	<0.20	0.20	<1.36	1.36	2753443
Benzene	ppbv	0.44	0.18	1.39	0.575	2753443
Toluene	ppbv	0.66	0.20	2.47	0.753	2753443
Ethylbenzene	ppbv	<0.20	0.20	<0.868	0.868	2753443
p+m-Xylene	ppbv	0.41	0.37	1.77	1.61	2753443
o-Xylene	ppbv	<0.20	0.20	<0.868	0.868	2753443
Styrene	ppbv	<0.20	0.20	<0.852	0.852	2753443
1,3,5-Trimethylbenzene	ppbv	<0.50	0.50	<2.46	2.46	2753443
1,2,4-Trimethylbenzene	ppbv	<0.50	0.50	<2.46	2.46	2753443
4-ethyltoluene	ppbv	<2.2	2.2	<10.8	10.8	2753443
Chlorobenzene	ppbv	<0.20	0.20	<0.921	0.921	2753443
Benzyl chloride	ppbv	<1.0	1.0	<5.18	5.18	2753443
1,3-Dichlorobenzene	ppbv	<0.40	0.40	<2.40	2.40	2753443
1,4-Dichlorobenzene	ppbv	<0.40	0.40	<2.40	2.40	2753443
1,2-Dichlorobenzene	ppbv	<0.40	0.40	<2.40	2.40	2753443
1,2,4-Trichlorobenzene	ppbv	<2.0	2.0	<14.8	14.8	2753443
Hexachlorobutadiene	ppbv	<3.0	3.0	<32.0	32.0	2753443
Hexane	ppbv	0.46	0.30	1.64	1.06	2753443
Cyclohexane	ppbv	0.24	0.20	0.841	0.688	2753443
Tetrahydrofuran	ppbv	<0.40	0.40	<1.18	1.18	2753443
1,4-Dioxane	ppbv	<2.0	2.0	<7.21	7.21	2753443
Xylene (Total)	ppbv	<0.60	0.60	<2.61	2.61	2753443
QC Batch = Quality Control Batch						

Maxxam Job #: B213399
 Report Date: 2012/02/05

VOLATILE ORGANICS BY GC/MS (AIR)

Maxxam ID		MJ4701				
Sampling Date		2012/01/22				
COC Number		08701				
	Units	LICA	RDL	ug/m3	DL (ug/m3)	QC Batch
		VOC/CLS/JAN22/12				
		- 7842				

Surrogate Recovery (%)						
Bromochloromethane	%	73		N/A	N/A	2753443
D5-Chlorobenzene	%	73		N/A	N/A	2753443
Difluorobenzene	%	77		N/A	N/A	2753443

N/A = Not Applicable
 QC Batch = Quality Control Batch

Maxxam Job #: B213399
Report Date: 2012/02/05

Test Summary

Maxxam ID MJ4701
Sample ID LICA VOC/CLS/JAN22/12 - 7842
Matrix AIR

Collected 2012/01/22
Shipped
Received 2012/01/28

Test Description	Instrumentation	Batch	Extracted	Analyzed	Analyst
Canister Pressure (TO-15)	PRES	2753444	N/A	2012/02/01	MELANIE MABINI
Volatile Organics in Air (TO-15)	GC/MS	2753443	N/A	2012/02/01	MELANIE MABINI

Maxxam Job #: B213399
Report Date: 2012/02/05

GENERAL COMMENTS

Results relate only to the items tested.

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report
 Maxxam Job Number: GB213399

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2753443 MM2	Spiked Blank	Bromochloromethane	2012/02/01		95	%	60 - 140
		D5-Chlorobenzene	2012/02/01		99	%	60 - 140
		Difluorobenzene	2012/02/01		98	%	60 - 140
		2,2,4-Trimethylpentane	2012/02/01		107	%	70 - 130
		Carbon Disulfide	2012/02/01		93	%	70 - 130
		Propene	2012/02/01		101	%	70 - 130
		Vinyl Acetate	2012/02/01		116	%	70 - 130
		Vinyl Bromide	2012/02/01		102	%	70 - 130
		Dichlorodifluoromethane (FREON 12)	2012/02/01		110	%	70 - 130
		1,2-Dichlorotetrafluoroethane	2012/02/01		119	%	70 - 130
		Chloromethane	2012/02/01		109	%	70 - 130
		Vinyl Chloride	2012/02/01		104	%	70 - 130
		Chloroethane	2012/02/01		105	%	70 - 130
		1,3-Butadiene	2012/02/01		104	%	70 - 130
		Trichlorofluoromethane (FREON 11)	2012/02/01		106	%	70 - 130
		Trichlorotrifluoroethane	2012/02/01		106	%	70 - 130
		Ethanol (ethyl alcohol)	2012/02/01		90	%	70 - 130
		2-propanol	2012/02/01		102	%	70 - 130
		2-Propanone	2012/02/01		104	%	70 - 130
		Methyl Ethyl Ketone (2-Butanone)	2012/02/01		96	%	70 - 130
		Methyl Isobutyl Ketone	2012/02/01		107	%	70 - 130
		Methyl Butyl Ketone (2-Hexanone)	2012/02/01		109	%	70 - 130
		Methyl t-butyl ether (MTBE)	2012/02/01		108	%	70 - 130
		Ethyl Acetate	2012/02/01		114	%	70 - 130
		1,1-Dichloroethylene	2012/02/01		109	%	70 - 130
		cis-1,2-Dichloroethylene	2012/02/01		111	%	70 - 130
		trans-1,2-Dichloroethylene	2012/02/01		109	%	70 - 130
		Methylene Chloride(Dichloromethane)	2012/02/01		102	%	70 - 130
		Chloroform	2012/02/01		107	%	70 - 130
		Carbon Tetrachloride	2012/02/01		113	%	70 - 130
		1,1-Dichloroethane	2012/02/01		109	%	70 - 130
		1,2-Dichloroethane	2012/02/01		111	%	70 - 130
		Ethylene Dibromide	2012/02/01		108	%	70 - 130
		1,1,1-Trichloroethane	2012/02/01		109	%	70 - 130
		1,1,2-Trichloroethane	2012/02/01		109	%	70 - 130
		1,1,2,2-Tetrachloroethane	2012/02/01		106	%	70 - 130
		cis-1,3-Dichloropropene	2012/02/01		113	%	70 - 130
		trans-1,3-Dichloropropene	2012/02/01		118	%	70 - 130
		1,2-Dichloropropane	2012/02/01		110	%	70 - 130
		Bromomethane	2012/02/01		102	%	70 - 130
		Bromoform	2012/02/01		114	%	70 - 130
		Bromodichloromethane	2012/02/01		111	%	70 - 130
		Dibromochloromethane	2012/02/01		113	%	70 - 130
		Heptane	2012/02/01		115	%	70 - 130
		Trichloroethylene	2012/02/01		104	%	70 - 130
		Tetrachloroethylene	2012/02/01		105	%	70 - 130
		Benzene	2012/02/01		107	%	70 - 130
		Toluene	2012/02/01		109	%	70 - 130
		Ethylbenzene	2012/02/01		107	%	70 - 130
		p+m-Xylene	2012/02/01		104	%	70 - 130
		o-Xylene	2012/02/01		107	%	70 - 130
		Styrene	2012/02/01		99	%	70 - 130
		1,3,5-Trimethylbenzene	2012/02/01		105	%	70 - 130
		1,2,4-Trimethylbenzene	2012/02/01		104	%	70 - 130
		4-ethyltoluene	2012/02/01		112	%	70 - 130

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report (Continued)

Maxxam Job Number: GB213399

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2753443 MM2	Spiked Blank	Chlorobenzene	2012/02/01		102	%	70 - 130
		Benzyl chloride	2012/02/01		114	%	70 - 130
		1,3-Dichlorobenzene	2012/02/01		101	%	70 - 130
		1,4-Dichlorobenzene	2012/02/01		101	%	70 - 130
		1,2-Dichlorobenzene	2012/02/01		99	%	70 - 130
		1,2,4-Trichlorobenzene	2012/02/01		70	%	70 - 130
		Hexachlorobutadiene	2012/02/01		87	%	70 - 130
		Hexane	2012/02/01		107	%	70 - 130
		Cyclohexane	2012/02/01		110	%	70 - 130
		Tetrahydrofuran	2012/02/01		112	%	70 - 130
		1,4-Dioxane	2012/02/01		99	%	70 - 130
	Method Blank	Bromochloromethane	2012/02/01		81	%	60 - 140
		D5-Chlorobenzene	2012/02/01		80	%	60 - 140
		Difluorobenzene	2012/02/01		84	%	60 - 140
		2,2,4-Trimethylpentane	2012/02/01	<0.20		ppbv	
		Carbon Disulfide	2012/02/01	<0.50		ppbv	
		Propene	2012/02/01	<0.30		ppbv	
		Vinyl Acetate	2012/02/01	<0.20		ppbv	
		Vinyl Bromide	2012/02/01	<0.20		ppbv	
		Dichlorodifluoromethane (FREON 12)	2012/02/01	<0.20		ppbv	
		1,2-Dichlorotetrafluoroethane	2012/02/01	<0.17		ppbv	
		Chloromethane	2012/02/01	<0.30		ppbv	
		Vinyl Chloride	2012/02/01	<0.18		ppbv	
		Chloroethane	2012/02/01	<0.30		ppbv	
		1,3-Butadiene	2012/02/01	<0.50		ppbv	
		Trichlorofluoromethane (FREON 11)	2012/02/01	<0.20		ppbv	
		Trichlorotrifluoroethane	2012/02/01	<0.15		ppbv	
		Ethanol (ethyl alcohol)	2012/02/01	<2.3		ppbv	
		2-propanol	2012/02/01	<3.0		ppbv	
		2-Propanone	2012/02/01	<0.80		ppbv	
		Methyl Ethyl Ketone (2-Butanone)	2012/02/01	<3.0		ppbv	
		Methyl Isobutyl Ketone	2012/02/01	<3.2		ppbv	
		Methyl Butyl Ketone (2-Hexanone)	2012/02/01	<2.0		ppbv	
		Methyl t-butyl ether (MTBE)	2012/02/01	<0.20		ppbv	
		Ethyl Acetate	2012/02/01	<2.2		ppbv	
		1,1-Dichloroethylene	2012/02/01	<0.25		ppbv	
		cis-1,2-Dichloroethylene	2012/02/01	<0.19		ppbv	
		trans-1,2-Dichloroethylene	2012/02/01	<0.20		ppbv	
		Methylene Chloride(Dichloromethane)	2012/02/01	<0.80		ppbv	
		Chloroform	2012/02/01	<0.15		ppbv	
		Carbon Tetrachloride	2012/02/01	<0.30		ppbv	
		1,1-Dichloroethane	2012/02/01	<0.20		ppbv	
		1,2-Dichloroethane	2012/02/01	<0.20		ppbv	
		Ethylene Dibromide	2012/02/01	<0.17		ppbv	
		1,1,1-Trichloroethane	2012/02/01	<0.30		ppbv	
		1,1,2-Trichloroethane	2012/02/01	<0.15		ppbv	
		1,1,2,2-Tetrachloroethane	2012/02/01	<0.20		ppbv	
		cis-1,3-Dichloropropene	2012/02/01	<0.18		ppbv	
		trans-1,3-Dichloropropene	2012/02/01	<0.17		ppbv	
		1,2-Dichloropropane	2012/02/01	<0.40		ppbv	
		Bromomethane	2012/02/01	<0.18		ppbv	
		Bromoform	2012/02/01	<0.20		ppbv	
		Bromodichloromethane	2012/02/01	<0.20		ppbv	
		Dibromochloromethane	2012/02/01	<0.20		ppbv	
		Heptane	2012/02/01	<0.30		ppbv	

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report (Continued)

Maxxam Job Number: GB213399

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2753443	MM2	Method Blank					
		Trichloroethylene	2012/02/01	<0.30		ppbv	
		Tetrachloroethylene	2012/02/01	<0.20		ppbv	
		Benzene	2012/02/01	<0.18		ppbv	
		Toluene	2012/02/01	<0.20		ppbv	
		Ethylbenzene	2012/02/01	<0.20		ppbv	
		p+m-Xylene	2012/02/01	<0.37		ppbv	
		o-Xylene	2012/02/01	<0.20		ppbv	
		Styrene	2012/02/01	<0.20		ppbv	
		1,3,5-Trimethylbenzene	2012/02/01	<0.50		ppbv	
		1,2,4-Trimethylbenzene	2012/02/01	<0.50		ppbv	
		4-ethyltoluene	2012/02/01	<2.2		ppbv	
		Chlorobenzene	2012/02/01	<0.20		ppbv	
		Benzyl chloride	2012/02/01	<1.0		ppbv	
		1,3-Dichlorobenzene	2012/02/01	<0.40		ppbv	
		1,4-Dichlorobenzene	2012/02/01	<0.40		ppbv	
		1,2-Dichlorobenzene	2012/02/01	<0.40		ppbv	
		1,2,4-Trichlorobenzene	2012/02/01	<2.0		ppbv	
		Hexachlorobutadiene	2012/02/01	<3.0		ppbv	
		Hexane	2012/02/01	<0.30		ppbv	
		Cyclohexane	2012/02/01	<0.20		ppbv	
		Tetrahydrofuran	2012/02/01	<0.40		ppbv	
		1,4-Dioxane	2012/02/01	<2.0		ppbv	
		Xylene (Total)	2012/02/01	<0.60		ppbv	
	RPD - Sample/Sample Dup	2,2,4-Trimethylpentane	2012/02/01	1.3		%	25
		Carbon Disulfide	2012/02/01	1		%	25
		Propene	2012/02/01	NC		%	25
		Vinyl Acetate	2012/02/01	NC		%	25
		Vinyl Bromide	2012/02/01	NC		%	25
		Dichlorodifluoromethane (FREON 12)	2012/02/01	NC		%	25
		1,2-Dichlorotetrafluoroethane	2012/02/01	NC		%	25
		Chloromethane	2012/02/01	4.5		%	25
		Vinyl Chloride	2012/02/01	NC		%	25
		Chloroethane	2012/02/01	NC		%	25
		1,3-Butadiene	2012/02/01	NC		%	25
		Trichlorofluoromethane (FREON 11)	2012/02/01	NC		%	25
		Trichlorotrifluoroethane	2012/02/01	NC		%	25
		Ethanol (ethyl alcohol)	2012/02/01	NC		%	25
		2-propanol	2012/02/01	NC		%	25
		2-Propanone	2012/02/01	3.4		%	25
		Methyl Ethyl Ketone (2-Butanone)	2012/02/01	NC		%	25
		Methyl Isobutyl Ketone	2012/02/01	NC		%	25
		Methyl Butyl Ketone (2-Hexanone)	2012/02/01	NC		%	25
		Methyl t-butyl ether (MTBE)	2012/02/01	NC		%	25
		Ethyl Acetate	2012/02/01	NC		%	25
		1,1-Dichloroethylene	2012/02/01	NC		%	25
		cis-1,2-Dichloroethylene	2012/02/01	NC		%	25
		trans-1,2-Dichloroethylene	2012/02/01	NC		%	25
		Methylene Chloride(Dichloromethane)	2012/02/01	NC		%	25
		Chloroform	2012/02/01	NC		%	25
		Carbon Tetrachloride	2012/02/01	NC		%	25
		1,1-Dichloroethane	2012/02/01	NC		%	25
		1,2-Dichloroethane	2012/02/01	NC		%	25
		Ethylene Dibromide	2012/02/01	NC		%	25

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report (Continued)

Maxxam Job Number: GB213399

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2753443 MM2	RPD - Sample/Sample Dup	1,1,1-Trichloroethane	2012/02/01	NC		%	25
		1,1,2-Trichloroethane	2012/02/01	NC		%	25
		1,1,2,2-Tetrachloroethane	2012/02/01	NC		%	25
		cis-1,3-Dichloropropene	2012/02/01	NC		%	25
		trans-1,3-Dichloropropene	2012/02/01	NC		%	25
		1,2-Dichloropropane	2012/02/01	NC		%	25
		Bromomethane	2012/02/01	NC		%	25
		Bromoform	2012/02/01	NC		%	25
		Bromodichloromethane	2012/02/01	NC		%	25
		Dibromochloromethane	2012/02/01	NC		%	25
		Heptane	2012/02/01	1.4		%	25
		Trichloroethylene	2012/02/01	NC		%	25
		Tetrachloroethylene	2012/02/01	NC		%	25
		Benzene	2012/02/01	0.06		%	25
		Toluene	2012/02/01	2.2		%	25
		Ethylbenzene	2012/02/01	NC		%	25
		p+m-Xylene	2012/02/01	2.4		%	25
		o-Xylene	2012/02/01	NC		%	25
		Styrene	2012/02/01	NC		%	25
		1,3,5-Trimethylbenzene	2012/02/01	NC		%	25
		1,2,4-Trimethylbenzene	2012/02/01	NC		%	25
		4-ethyltoluene	2012/02/01	NC		%	25
		Chlorobenzene	2012/02/01	NC		%	25
		Benzyl chloride	2012/02/01	NC		%	25
		1,3-Dichlorobenzene	2012/02/01	NC		%	25
		1,4-Dichlorobenzene	2012/02/01	NC		%	25
		1,2-Dichlorobenzene	2012/02/01	NC		%	25
		1,2,4-Trichlorobenzene	2012/02/01	NC		%	25
		Hexachlorobutadiene	2012/02/01	NC		%	25
		Hexane	2012/02/01	3.0		%	25
		Cyclohexane	2012/02/01	NC		%	25
		Tetrahydrofuran	2012/02/01	NC		%	25
		1,4-Dioxane	2012/02/01	NC		%	25
		Xylene (Total)	2012/02/01	3.4		%	25

Spiked Blank: A blank matrix to which a known amount of the analyte has been added. Used to evaluate analyte recovery.

Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

Surrogate: A pure or isotopically labeled compound whose behavior mirrors the analytes of interest. Used to evaluate extraction efficiency.

NC (RPD): The RPD was not calculated. The level of analyte detected in the parent sample and its duplicate was not sufficiently significant to permit a reliable calculation.

MAXXAM

Xontech Model 910A VOC Sample Collection Data Sheet

Client: LICA Sampler s/n: 6167
Location: Cold Lake South Canister ID: S2213
Station ID: Lica 1 Canister Installation Date/Time: Jan 25, 2012 @ 15:10 mst
Field Sample ID: LICA VOC/ CLS /Jan 28, 2012 Canister Removal Date/Time: Feb 1, 2012 @ 14:30 mst

Date and Time Information			
Sample Date	Start Time (MST)	End Time (MST)	Elapsed Time (Hours)
28-Jan-12	01/28/2012 0:00	01/29/2012 0:00	24.00

Flow Settings		
Meter Reading (sccm)	Pot Set Pt.	Pump Pressure Setting (psig)
10.0	646	25

Canister Information	
Initial Canister Vacuum (inHg)	Final Canister Pressure (psig)
-28	23

Canister valve open prior to sampling?: YES / NO
Timer set to 0.00 minutes prior to sampling? YES / NO
Canister valve closed prior to disconnection?: YES / NO

Comments: System leak check prior to sampling. COC # 08762

Technician Signiture: Theo McLaren

Your C.O.C. #: 08762

Attention: Michael BisagaMaxxam Analytics
2608 6A Ave.
Cold Lake, AB
CANADA T9M 2C7

Report Date: 2012/02/10

CERTIFICATE OF ANALYSIS**MAXXAM JOB #: B217077****Received: 2012/02/04, 09:35**Sample Matrix: AIR
Samples Received: 1

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
Canister Pressure (TO-15)	1	N/A	2012/02/07	BRL SOP-00304	EPA TO-15
Volatile Organics in Air (TO-15) (1)	1	N/A	2012/02/07	BRL SOP-00304	EPA TO-15

(1) Air sampling canisters have been cleaned in accordance with U.S. EPA Method TO14A. At the end of the cleaning, evacuation, and pressurization cycles, one canister was selected and was pressurized with Zero Air. This canister was then analyzed via TO14A on a GC/MS. The canister must have been found to contain <0.2 ppbv concentration of all target analytes in order for the batch to have been considered clean. Each canister also underwent a leak check prior to shipment.

Please Note: SUMMA® canister samples will be retained by Maxxam for a period of 5 calendar days from the date of this report, after which time they will be cleaned for reuse. If you require a longer sample storage period, please contact your service representative.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

THERESA STEPHENSON, Project Manager
Email: TStephenson@maxxam.ca
Phone# (905) 817-5763

=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Maxxam Analytics Inc. is a NELAC accredited laboratory. Certificate # CANA001. Use of the NELAC logo however does not insure that Maxxam is accredited for all of the methods indicated. This certificate shall not be reproduced except in full, without the written approval of Maxxam Analytics Inc. Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section.

Total cover pages: 1

Page 1 of 10

Maxxam Job #: B217077
 Report Date: 2012/02/10

RESULTS OF ANALYSES OF AIR

Maxxam ID		ML2911	
Sampling Date		2012/01/28	
COC Number		08762	
	Units	LICA VOC/CLS/JAN 28,12 - S2213	QC Batch

Volatile Organics			
Pressure on Receipt	psig	23	2758537

QC Batch = Quality Control Batch

Maxxam Job #: B217077
 Report Date: 2012/02/10

VOLATILE ORGANICS BY GC/MS (AIR)

Maxxam ID		ML2911				
Sampling Date		2012/01/28				
COC Number		08762				
	Units	LICA VOC/CLS/JAN 28,12 - S2213	RDL	ug/m3	DL (ug/m3)	QC Batch

Volatile Organics						
2,2,4-Trimethylpentane	ppbv	<0.20	0.20	<0.934	0.934	2758596
Carbon Disulfide	ppbv	<0.50	0.50	<1.56	1.56	2758596
Propene	ppbv	<0.30	0.30	<0.516	0.516	2758596
Vinyl Acetate	ppbv	<0.20	0.20	<0.704	0.704	2758596
Vinyl Bromide	ppbv	<0.20	0.20	<0.875	0.875	2758596
Dichlorodifluoromethane (FREON 12)	ppbv	0.81	0.20	3.98	0.989	2758596
1,2-Dichlorotetrafluoroethane	ppbv	<0.17	0.17	<1.19	1.19	2758596
Chloromethane	ppbv	0.67	0.30	1.38	0.620	2758596
Vinyl Chloride	ppbv	<0.18	0.18	<0.460	0.460	2758596
Chloroethane	ppbv	<0.30	0.30	<0.792	0.792	2758596
1,3-Butadiene	ppbv	<0.50	0.50	<1.11	1.11	2758596
Trichlorofluoromethane (FREON 11)	ppbv	0.35	0.20	1.96	1.12	2758596
Trichlorotrifluoroethane	ppbv	<0.15	0.15	<1.15	1.15	2758596
Ethanol (ethyl alcohol)	ppbv	<2.3	2.3	<4.33	4.33	2758596
2-propanol	ppbv	<3.0	3.0	<7.37	7.37	2758596
2-Propanone	ppbv	1.37	0.80	3.25	1.90	2758596
Methyl Ethyl Ketone (2-Butanone)	ppbv	<3.0	3.0	<8.85	8.85	2758596
Methyl Isobutyl Ketone	ppbv	<3.2	3.2	<13.1	13.1	2758596
Methyl Butyl Ketone (2-Hexanone)	ppbv	<2.0	2.0	<8.19	8.19	2758596
Methyl t-butyl ether (MTBE)	ppbv	<0.20	0.20	<0.721	0.721	2758596
Ethyl Acetate	ppbv	<2.2	2.2	<7.93	7.93	2758596
1,1-Dichloroethylene	ppbv	<0.25	0.25	<0.991	0.991	2758596
cis-1,2-Dichloroethylene	ppbv	<0.19	0.19	<0.753	0.753	2758596
trans-1,2-Dichloroethylene	ppbv	<0.20	0.20	<0.793	0.793	2758596
Methylene Chloride(Dichloromethane)	ppbv	<0.80	0.80	<2.78	2.78	2758596
Chloroform	ppbv	<0.15	0.15	<0.732	0.732	2758596
Carbon Tetrachloride	ppbv	<0.30	0.30	<1.89	1.89	2758596
1,1-Dichloroethane	ppbv	<0.20	0.20	<0.809	0.809	2758596
1,2-Dichloroethane	ppbv	<0.20	0.20	<0.809	0.809	2758596
Ethylene Dibromide	ppbv	<0.17	0.17	<1.31	1.31	2758596
1,1,1-Trichloroethane	ppbv	<0.30	0.30	<1.64	1.64	2758596
RDL = Reportable Detection Limit QC Batch = Quality Control Batch						

Maxxam Job #: B217077
 Report Date: 2012/02/10

VOLATILE ORGANICS BY GC/MS (AIR)

Maxxam ID		ML2911				
Sampling Date		2012/01/28				
COC Number		08762				
	Units	LICA VOC/CLS/JAN 28,12 - S2213	RDL	ug/m3	DL (ug/m3)	QC Batch
1,1,2-Trichloroethane	ppbv	<0.15	0.15	<0.818	0.818	2758596
1,1,2,2-Tetrachloroethane	ppbv	<0.20	0.20	<1.37	1.37	2758596
cis-1,3-Dichloropropene	ppbv	<0.18	0.18	<0.817	0.817	2758596
trans-1,3-Dichloropropene	ppbv	<0.17	0.17	<0.772	0.772	2758596
1,2-Dichloropropane	ppbv	<0.40	0.40	<1.85	1.85	2758596
Bromomethane	ppbv	<0.18	0.18	<0.699	0.699	2758596
Bromoform	ppbv	<0.20	0.20	<2.07	2.07	2758596
Bromodichloromethane	ppbv	<0.20	0.20	<1.34	1.34	2758596
Dibromochloromethane	ppbv	<0.20	0.20	<1.70	1.70	2758596
Heptane	ppbv	<0.30	0.30	<1.23	1.23	2758596
Trichloroethylene	ppbv	<0.30	0.30	<1.61	1.61	2758596
Tetrachloroethylene	ppbv	<0.20	0.20	<1.36	1.36	2758596
Benzene	ppbv	0.28	0.18	0.900	0.575	2758596
Toluene	ppbv	0.42	0.20	1.56	0.753	2758596
Ethylbenzene	ppbv	<0.20	0.20	<0.868	0.868	2758596
p+m-Xylene	ppbv	<0.37	0.37	<1.61	1.61	2758596
o-Xylene	ppbv	<0.20	0.20	<0.868	0.868	2758596
Styrene	ppbv	<0.20	0.20	<0.852	0.852	2758596
1,3,5-Trimethylbenzene	ppbv	<0.50	0.50	<2.46	2.46	2758596
1,2,4-Trimethylbenzene	ppbv	<0.50	0.50	<2.46	2.46	2758596
4-ethyltoluene	ppbv	<2.2	2.2	<10.8	10.8	2758596
Chlorobenzene	ppbv	<0.20	0.20	<0.921	0.921	2758596
Benzyl chloride	ppbv	<1.0	1.0	<5.18	5.18	2758596
1,3-Dichlorobenzene	ppbv	<0.40	0.40	<2.40	2.40	2758596
1,4-Dichlorobenzene	ppbv	<0.40	0.40	<2.40	2.40	2758596
1,2-Dichlorobenzene	ppbv	<0.40	0.40	<2.40	2.40	2758596
1,2,4-Trichlorobenzene	ppbv	<2.0	2.0	<14.8	14.8	2758596
Hexachlorobutadiene	ppbv	<3.0	3.0	<32.0	32.0	2758596
Hexane	ppbv	<0.30	0.30	<1.06	1.06	2758596
Cyclohexane	ppbv	<0.20	0.20	<0.688	0.688	2758596
Tetrahydrofuran	ppbv	<0.40	0.40	<1.18	1.18	2758596
1,4-Dioxane	ppbv	<2.0	2.0	<7.21	7.21	2758596
Xylene (Total)	ppbv	<0.60	0.60	<2.61	2.61	2758596
QC Batch = Quality Control Batch						

Maxxam Job #: B217077
 Report Date: 2012/02/10

VOLATILE ORGANICS BY GC/MS (AIR)

Maxxam ID		ML2911				
Sampling Date		2012/01/28				
COC Number		08762				
	Units	LICA VOC/CLS/JAN 28,12 - S2213	RDL	ug/m3	DL (ug/m3)	QC Batch

Surrogate Recovery (%)						
Bromochloromethane	%	88		N/A	N/A	2758596
D5-Chlorobenzene	%	99		N/A	N/A	2758596
Difluorobenzene	%	91		N/A	N/A	2758596

N/A = Not Applicable
 QC Batch = Quality Control Batch

Maxxam Job #: B217077
Report Date: 2012/02/10

Test Summary

Maxxam ID ML2911
Sample ID LICA VOC/CLS/JAN 28,12 - S2213
Matrix AIR

Collected 2012/01/28
Shipped
Received 2012/02/04

Test Description	Instrumentation	Batch	Extracted	Analyzed	Analyst
Canister Pressure (TO-15)	PRES	2758537	N/A	2012/02/07	YAO LIANG SUN
Volatile Organics in Air (TO-15)	GC/MS	2758596	N/A	2012/02/07	YAO LIANG SUN

Maxxam Job #: B217077
Report Date: 2012/02/10

GENERAL COMMENTS

Results relate only to the items tested.

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report
 Maxxam Job Number: GB217077

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2758596 LSY	Spiked Blank	Bromochloromethane	2012/02/07		107	%	60 - 140
		D5-Chlorobenzene	2012/02/07		108	%	60 - 140
		Difluorobenzene	2012/02/07		109	%	60 - 140
		2,2,4-Trimethylpentane	2012/02/07		102	%	70 - 130
		Carbon Disulfide	2012/02/07		99	%	70 - 130
		Propene	2012/02/07		91	%	70 - 130
		Vinyl Acetate	2012/02/07		108	%	70 - 130
		Vinyl Bromide	2012/02/07		101	%	70 - 130
		Dichlorodifluoromethane (FREON 12)	2012/02/07		107	%	70 - 130
		1,2-Dichlorotetrafluoroethane	2012/02/07		120	%	70 - 130
		Chloromethane	2012/02/07		108	%	70 - 130
		Vinyl Chloride	2012/02/07		99	%	70 - 130
		Chloroethane	2012/02/07		99	%	70 - 130
		1,3-Butadiene	2012/02/07		84	%	70 - 130
		Trichlorofluoromethane (FREON 11)	2012/02/07		104	%	70 - 130
		Trichlorotrifluoroethane	2012/02/07		103	%	70 - 130
		Ethanol (ethyl alcohol)	2012/02/07		85	%	70 - 130
		2-propanol	2012/02/07		97	%	70 - 130
		2-Propanone	2012/02/07		106	%	70 - 130
		Methyl Ethyl Ketone (2-Butanone)	2012/02/07		100	%	70 - 130
		Methyl Isobutyl Ketone	2012/02/07		107	%	70 - 130
		Methyl Butyl Ketone (2-Hexanone)	2012/02/07		113	%	70 - 130
		Methyl t-butyl ether (MTBE)	2012/02/07		103	%	70 - 130
		Ethyl Acetate	2012/02/07		107	%	70 - 130
		1,1-Dichloroethylene	2012/02/07		103	%	70 - 130
		cis-1,2-Dichloroethylene	2012/02/07		102	%	70 - 130
		trans-1,2-Dichloroethylene	2012/02/07		101	%	70 - 130
		Methylene Chloride(Dichloromethane)	2012/02/07		96	%	70 - 130
		Chloroform	2012/02/07		103	%	70 - 130
		Carbon Tetrachloride	2012/02/07		111	%	70 - 130
		1,1-Dichloroethane	2012/02/07		105	%	70 - 130
		1,2-Dichloroethane	2012/02/07		107	%	70 - 130
		Ethylene Dibromide	2012/02/07		102	%	70 - 130
		1,1,1-Trichloroethane	2012/02/07		107	%	70 - 130
		1,1,2-Trichloroethane	2012/02/07		102	%	70 - 130
		1,1,2,2-Tetrachloroethane	2012/02/07		100	%	70 - 130
		cis-1,3-Dichloropropene	2012/02/07		106	%	70 - 130
		trans-1,3-Dichloropropene	2012/02/07		107	%	70 - 130
		1,2-Dichloropropane	2012/02/07		99	%	70 - 130
		Bromomethane	2012/02/07		100	%	70 - 130
		Bromoform	2012/02/07		121	%	70 - 130
		Bromodichloromethane	2012/02/07		114	%	70 - 130
		Dibromochloromethane	2012/02/07		115	%	70 - 130
		Heptane	2012/02/07		105	%	70 - 130
		Trichloroethylene	2012/02/07		99	%	70 - 130
		Tetrachloroethylene	2012/02/07		100	%	70 - 130
		Benzene	2012/02/07		102	%	70 - 130
		Toluene	2012/02/07		102	%	70 - 130
		Ethylbenzene	2012/02/07		106	%	70 - 130
		p+m-Xylene	2012/02/07		105	%	70 - 130
		o-Xylene	2012/02/07		106	%	70 - 130
		Styrene	2012/02/07		88	%	70 - 130
		1,3,5-Trimethylbenzene	2012/02/07		91	%	70 - 130
		1,2,4-Trimethylbenzene	2012/02/07		84	%	70 - 130
		4-ethyltoluene	2012/02/07		95	%	70 - 130

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report (Continued)

Maxxam Job Number: GB217077

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2758596 LSY	Spiked Blank	Chlorobenzene	2012/02/07		105	%	70 - 130
		Benzyl chloride	2012/02/07		89	%	70 - 130
		1,3-Dichlorobenzene	2012/02/07		86	%	70 - 130
		1,4-Dichlorobenzene	2012/02/07		87	%	70 - 130
		1,2-Dichlorobenzene	2012/02/07		82	%	70 - 130
		1,2,4-Trichlorobenzene	2012/02/07		100	%	70 - 130
		Hexachlorobutadiene	2012/02/07		108	%	70 - 130
		Hexane	2012/02/07		105	%	70 - 130
		Cyclohexane	2012/02/07		99	%	70 - 130
		Tetrahydrofuran	2012/02/07		100	%	70 - 130
		1,4-Dioxane	2012/02/07		97	%	70 - 130
		Xylene (Total)	2012/02/07		105	%	70 - 130
	Method Blank	Bromochloromethane	2012/02/07		100	%	60 - 140
		D5-Chlorobenzene	2012/02/07		113	%	60 - 140
		Difluorobenzene	2012/02/07		104	%	60 - 140
		2,2,4-Trimethylpentane	2012/02/07	<0.20		ppbv	
		Carbon Disulfide	2012/02/07	<0.50		ppbv	
		Propene	2012/02/07	<0.30		ppbv	
		Vinyl Acetate	2012/02/07	<0.20		ppbv	
		Vinyl Bromide	2012/02/07	<0.20		ppbv	
		Dichlorodifluoromethane (FREON 12)	2012/02/07	<0.20		ppbv	
		1,2-Dichlorotetrafluoroethane	2012/02/07	<0.17		ppbv	
		Chloromethane	2012/02/07	<0.30		ppbv	
		Vinyl Chloride	2012/02/07	<0.18		ppbv	
		Chloroethane	2012/02/07	<0.30		ppbv	
		1,3-Butadiene	2012/02/07	<0.50		ppbv	
		Trichlorofluoromethane (FREON 11)	2012/02/07	<0.20		ppbv	
		Trichlorotrifluoroethane	2012/02/07	<0.15		ppbv	
		Ethanol (ethyl alcohol)	2012/02/07	<2.3		ppbv	
		2-propanol	2012/02/07	<3.0		ppbv	
		2-Propanone	2012/02/07	<0.80		ppbv	
		Methyl Ethyl Ketone (2-Butanone)	2012/02/07	<3.0		ppbv	
		Methyl Isobutyl Ketone	2012/02/07	<3.2		ppbv	
		Methyl Butyl Ketone (2-Hexanone)	2012/02/07	<2.0		ppbv	
		Methyl t-butyl ether (MTBE)	2012/02/07	<0.20		ppbv	
		Ethyl Acetate	2012/02/07	<2.2		ppbv	
		1,1-Dichloroethylene	2012/02/07	<0.25		ppbv	
		cis-1,2-Dichloroethylene	2012/02/07	<0.19		ppbv	
		trans-1,2-Dichloroethylene	2012/02/07	<0.20		ppbv	
		Methylene Chloride(Dichloromethane)	2012/02/07	1.37, RDL=0.80		ppbv	
		Chloroform	2012/02/07	<0.15		ppbv	
		Carbon Tetrachloride	2012/02/07	<0.30		ppbv	
		1,1-Dichloroethane	2012/02/07	<0.20		ppbv	
		1,2-Dichloroethane	2012/02/07	<0.20		ppbv	
		Ethylene Dibromide	2012/02/07	<0.17		ppbv	
		1,1,1-Trichloroethane	2012/02/07	<0.30		ppbv	
		1,1,2-Trichloroethane	2012/02/07	<0.15		ppbv	
		1,1,2,2-Tetrachloroethane	2012/02/07	<0.20		ppbv	
		cis-1,3-Dichloropropene	2012/02/07	<0.18		ppbv	
		trans-1,3-Dichloropropene	2012/02/07	<0.17		ppbv	
		1,2-Dichloropropane	2012/02/07	<0.40		ppbv	
		Bromomethane	2012/02/07	<0.18		ppbv	
		Bromoform	2012/02/07	<0.20		ppbv	
		Bromodichloromethane	2012/02/07	<0.20		ppbv	
		Dibromochloromethane	2012/02/07	<0.20		ppbv	

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report (Continued)

Maxxam Job Number: GB217077

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2758596 LSY	Method Blank	Heptane	2012/02/07	<0.30		ppbv	
		Trichloroethylene	2012/02/07	<0.30		ppbv	
		Tetrachloroethylene	2012/02/07	<0.20		ppbv	
		Benzene	2012/02/07	<0.18		ppbv	
		Toluene	2012/02/07	<0.20		ppbv	
		Ethylbenzene	2012/02/07	<0.20		ppbv	
		p+m-Xylene	2012/02/07	<0.37		ppbv	
		o-Xylene	2012/02/07	<0.20		ppbv	
		Styrene	2012/02/07	<0.20		ppbv	
		1,3,5-Trimethylbenzene	2012/02/07	<0.50		ppbv	
		1,2,4-Trimethylbenzene	2012/02/07	<0.50		ppbv	
		4-ethyltoluene	2012/02/07	<2.2		ppbv	
		Chlorobenzene	2012/02/07	<0.20		ppbv	
		Benzyl chloride	2012/02/07	<1.0		ppbv	
		1,3-Dichlorobenzene	2012/02/07	<0.40		ppbv	
		1,4-Dichlorobenzene	2012/02/07	<0.40		ppbv	
		1,2-Dichlorobenzene	2012/02/07	<0.40		ppbv	
		1,2,4-Trichlorobenzene	2012/02/07	<2.0		ppbv	
		Hexachlorobutadiene	2012/02/07	<3.0		ppbv	
		Hexane	2012/02/07	<0.30		ppbv	
		Cyclohexane	2012/02/07	<0.20		ppbv	
		Tetrahydrofuran	2012/02/07	<0.40		ppbv	
		1,4-Dioxane	2012/02/07	<2.0		ppbv	
		Xylene (Total)	2012/02/07	<0.60		ppbv	

Spiked Blank: A blank matrix to which a known amount of the analyte has been added. Used to evaluate analyte recovery.

Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

Surrogate: A pure or isotopically labeled compound whose behavior mirrors the analytes of interest. Used to evaluate extraction efficiency.

Polycyclic Aromatic Hydrocarbons Laboratory Analysis

MAXXAM

Tisch Hi-Vol PUF+ Sample Collection Data Sheet

Client: Lica
Location: Cold Lake South
Station ID: Lica1
Field Sample ID: LICA PUF/CLS/Dec 29,11

Puf+ s/n: 100-1020
Motor s/n: 1138
Installation Date/Time: Dec 28, 2011 @ 08:54 mst
Removal Date/Time: Dec 30, 2011 @ 08:52 mst

Date and Time Information			
Sample Date	Start Time (MST)	Finish Time (MST)	Elapsed Time (Hours)
29-Dec-11	12/29/2011 0:00	12/30/2011 0:00	24.000

PUF and QFF Information			
Date Received	Date Shipped	Puf Expiration Date	QFF Prep Date
23-Dec-11	03-Jan-12	03-Jan-12	????

Set Flow Rate (slpm): 230

Date of Last Calibration: 22-Sep-11

Sampling Data			
Average Pressure(mmHg)	AverageFlow (Qstd slpm)	Average Temperature (C)	Volume (Vstd m ³)
700	229	-4.1	330.38

Time set correctly prior to sampling? YES
Timer set correctly prior to sampling? YES
Sampling data saved to memory card after sampling? YES

Comments: COC# 09168

GB1J2721 PUFF # 1

Ran with a 102mm Quartz Fiber Filter - Sample ID - LICA QFF/CLS/Dec 29, 11

Technician Signiture: Ting Xu

Your C.O.C. #: 09168

Attention: Michael BisagaLakeland Industry & Community Assoc.
P.O. Box 8237
Bonnyville, AB
CANADA T9N 2J5

Report Date: 2012/01/13

CERTIFICATE OF ANALYSIS**MAXXAM JOB #: B201227****Received: 2012/01/05, 09:08**

Sample Matrix: PUF AND FILTER

Samples Received: 1

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
PAH's in Air (CARB429mod)	1	2012/01/08	2012/01/12	BRL SOP-00201	CARB429(ARBM1,M2)mod

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

THERESA STEPHENSON, Project Manager
Email: TStephenson@maxxam.ca
Phone# (905) 817-5763=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Maxxam Analytics Inc. is a NELAC accredited laboratory. Certificate # CANA001. Use of the NELAC logo however does not insure that Maxxam is accredited for all of the methods indicated. This certificate shall not be reproduced except in full, without the written approval of Maxxam Analytics Inc. Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section.

Total cover pages: 1

Page 1 of 7

Maxxam Job #: B201227
 Report Date: 2012/01/13

SEMI-VOLATILE ORGANICS BY GC-MS (PUF AND FILTER)

Maxxam ID		MD5385		
Sampling Date		2011/12/29		
COC Number		09168		
	Units	LICAPUFF+QFF/CLS/DEC29,11	RDL	QC Batch

Semivolatile Organics				
1-Methylnaphthalene	ug	0.25	0.10	2731188
1-Methylphenanthrene	ug	<0.10	0.10	2731188
2-Chloronaphthalene	ug	<0.10	0.10	2731188
2-Methylantracene	ug	<0.10	0.10	2731188
2-Methylnaphthalene	ug	0.43	0.10	2731188
3-Methylcholanthrene	ug	<2.0	2.0	2731188
7,12-Dimethylbenzo(a)anthracene	ug	<0.10	0.10	2731188
9,10-Dimethylantracene	ug	<0.40	0.40	2731188
Acenaphthene	ug	0.072	0.050	2731188
Acenaphthylene	ug	0.102	0.050	2731188
Anthracene	ug	<0.050	0.050	2731188
Benzo(a)anthracene	ug	<0.050	0.050	2731188
Benzo(a)fluorene	ug	<0.10	0.10	2731188
Benzo(a)pyrene	ug	<0.050	0.050	2731188
Benzo(b)fluoranthene	ug	<0.050	0.050	2731188
Benzo(b)fluorene	ug	<0.10	0.10	2731188
Benzo(e)pyrene	ug	<0.10	0.10	2731188
Benzo(g,h,i)perylene	ug	<0.050	0.050	2731188
Benzo(k)fluoranthene	ug	<0.050	0.050	2731188
Biphenyl	ug	0.50	0.10	2731188
Chrysene	ug	<0.050	0.050	2731188
Coronene	ug	<0.10	0.10	2731188
Dibenz(a,h)anthracene	ug	<0.050	0.050	2731188
Dibenzo(a,e)pyrene	ug	<0.20	0.20	2731188
Fluoranthene	ug	0.096	0.050	2731188
Fluorene	ug	0.234	0.050	2731188
Indeno(1,2,3-cd)pyrene	ug	<0.050	0.050	2731188
m-Terphenyl	ug	<0.10	0.10	2731188
Naphthalene	ug	0.458	0.072	2731188
o-Terphenyl	ug	<0.10	0.10	2731188
Perylene	ug	<0.10	0.10	2731188
Phenanthrene	ug	0.436	0.050	2731188

 RDL = Reportable Detection Limit
 QC Batch = Quality Control Batch

Maxxam Job #: B201227
 Report Date: 2012/01/13

SEMI-VOLATILE ORGANICS BY GC-MS (PUF AND FILTER)

Maxxam ID		MD5385		
Sampling Date		2011/12/29		
COC Number		09168		
	Units	LICAPUFF+QFF/CLS/DEC29,11	RDL	QC Batch
p-Terphenyl	ug	<0.10	0.10	2731188
Pyrene	ug	0.070	0.050	2731188
Quinoline	ug	<0.40	0.40	2731188
Tetralin	ug	<0.10	0.10	2731188
Surrogate Recovery (%)				
D10-2-Methylnaphthalene	%	86		2731188
D10-Fluoranthene	%	102		2731188
D10-Fluorene (FS)	%	50		2731188
D10-Phenanthrene	%	96		2731188
D12-Benzo(a)anthracene	%	98		2731188
D12-Benzo(a)pyrene	%	92		2731188
D12-Benzo(b)fluoranthene	%	94		2731188
D12-Benzo(ghi)perylene	%	92		2731188
D12-Benzo(k)fluoranthene	%	92		2731188
D12-Chrysene	%	86		2731188
D12-Indeno(1,2,3-cd)pyrene	%	92		2731188
D12-Perylene	%	90		2731188
D14-Dibenzo(a,h)anthracene	%	90		2731188
D14-Terphenyl (FS)	%	97		2731188
D8-Acenaphthylene	%	90		2731188
D8-Naphthalene	%	86		2731188
QC Batch = Quality Control Batch				

Maxxam Job #: B201227
Report Date: 2012/01/13

Test Summary

Maxxam ID MD5385
Sample ID LICAPUFF+QFF/CLS/DEC29,11
Matrix PUF AND FILTER

Collected 2011/12/29
Shipped
Received 2012/01/05

Test Description	Instrumentation	Batch	Extracted	Analyzed	Analyst
PAH's in Air (CARB429mod)	GC/MS	2731188	2012/01/08	2012/01/12	JIE WU

Maxxam Job #: B201227
Report Date: 2012/01/13

GENERAL COMMENTS

PAHMS-F

9.10-Dimethylanthracene, 7,12-dimethylbenzo(a)anthracene are above 25% RSD in initial calibration. No positives found for these 2 compounds.

9.10-Dimethylanthracene, 7,12-dimethylbenzo(a)anthracene and 3-methylcholanthrene are above 25% RSD in continuing calibration.

Sample extracted past hold time.

Not calibrated for benzo(b)anthracene, picene, dibenzo(a,c)anthracene and triphenylene. An estimated mdl for each of these compounds is 0.1ug.

Since dibenzo(a,c)anthracene co-elutes with dibenz(a,h)anthracene and triphenylene with chrysene each would have a value below estimated mdl.

Benzo(b)anthracene elutes after benzo(a)anthracene and chrysene. Picene elutes after dibenz(a,h)anthracene. Searched for ions specific to these 2 compounds in the appropriate retention time range with no possible positives detected.

Sample MD5385-01: Internal Std area response criteria was high. The vial was rerun with similar result. Original run reported.

Results relate only to the items tested.

Lakeland Industry & Community Assoc.
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report
 Maxxam Job Number: GB201227

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2731188 JIW	Spiked Blank	D10-2-Methylnaphthalene	2012/01/12		90	%	50 - 150
		D10-Fluoranthene	2012/01/12		100	%	50 - 150
		D10-Phenanthrene	2012/01/12		96	%	50 - 150
		D12-Benzo(a)anthracene	2012/01/12		94	%	50 - 150
		D12-Benzo(a)pyrene	2012/01/12		94	%	50 - 150
		D12-Benzo(b)fluoranthene	2012/01/12		100	%	50 - 150
		D12-Benzo(ghi)perylene	2012/01/12		90	%	50 - 150
		D12-Benzo(k)fluoranthene	2012/01/12		98	%	50 - 150
		D12-Chrysene	2012/01/12		88	%	50 - 150
		D12-Indeno(1,2,3-cd)pyrene	2012/01/12		92	%	50 - 150
		D12-Perylene	2012/01/12		92	%	50 - 150
		D14-Dibenzo(a,h)anthracene	2012/01/12		90	%	50 - 150
		D8-Acenaphthylene	2012/01/12		90	%	50 - 150
		D8-Naphthalene	2012/01/12		92	%	50 - 150
		RPD	Acenaphthene	2012/01/12		82	%
	RPD	Acenaphthene	2012/01/12	5.3		%	50
	Spiked Blank	Acenaphthylene	2012/01/12		85	%	60 - 130
	RPD	Acenaphthylene	2012/01/12	6.7		%	50
	Spiked Blank	Anthracene	2012/01/12		79	%	60 - 130
	RPD	Anthracene	2012/01/12	11.1		%	50
	Spiked Blank	Benzo(a)anthracene	2012/01/12		78	%	60 - 130
	RPD	Benzo(a)anthracene	2012/01/12	5.6		%	50
	Spiked Blank	Benzo(a)pyrene	2012/01/12		77	%	60 - 130
	RPD	Benzo(a)pyrene	2012/01/12	7.5		%	50
	Spiked Blank	Benzo(b)fluoranthene	2012/01/12		81	%	60 - 130
	RPD	Benzo(b)fluoranthene	2012/01/12	4.4		%	50
	Spiked Blank	Benzo(g,h,i)perylene	2012/01/12		79	%	60 - 130
	RPD	Benzo(g,h,i)perylene	2012/01/12	5.2		%	50
	Spiked Blank	Benzo(k)fluoranthene	2012/01/12		93	%	60 - 130
	RPD	Benzo(k)fluoranthene	2012/01/12	6.1		%	50
	Spiked Blank	Chrysene	2012/01/12		80	%	60 - 130
	RPD	Chrysene	2012/01/12	0.3		%	50
	Spiked Blank	Dibenz(a,h)anthracene	2012/01/12		80	%	60 - 130
	RPD	Dibenz(a,h)anthracene	2012/01/12	5.5		%	50
	Spiked Blank	Fluoranthene	2012/01/12		93	%	60 - 130
	RPD	Fluoranthene	2012/01/12	15.1		%	50
	Spiked Blank	Fluorene	2012/01/12		82	%	60 - 130
	RPD	Fluorene	2012/01/12	6.9		%	50
	Spiked Blank	Indeno(1,2,3-cd)pyrene	2012/01/12		81	%	60 - 130
	RPD	Indeno(1,2,3-cd)pyrene	2012/01/12	5.7		%	50
	Spiked Blank	Naphthalene	2012/01/12		88	%	60 - 130
	RPD	Naphthalene	2012/01/12	4.6		%	50
	Spiked Blank	Phenanthrene	2012/01/12		84	%	60 - 130
	RPD	Phenanthrene	2012/01/12	10.0		%	50
	Spiked Blank	Pyrene	2012/01/12		92	%	60 - 130
RPD	Pyrene	2012/01/12	14.8		%	50	
Method Blank	D10-2-Methylnaphthalene	2012/01/12		96	%	50 - 150	
	D10-Fluoranthene	2012/01/12		82	%	50 - 150	
	D10-Phenanthrene	2012/01/12		86	%	50 - 150	
	D12-Benzo(a)anthracene	2012/01/12		84	%	50 - 150	
	D12-Benzo(a)pyrene	2012/01/12		86	%	50 - 150	
	D12-Benzo(b)fluoranthene	2012/01/12		102	%	50 - 150	
	D12-Benzo(ghi)perylene	2012/01/12		82	%	50 - 150	
	D12-Benzo(k)fluoranthene	2012/01/12		90	%	50 - 150	
	D12-Chrysene	2012/01/12		92	%	50 - 150	

Lakeland Industry & Community Assoc.
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report (Continued)
 Maxxam Job Number: GB201227

QA/QC Batch Num Init	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2731188 JIW	Method Blank	D12-Indeno(1,2,3-cd)pyrene	2012/01/12		80	%	50 - 150
		D12-Perylene	2012/01/12		86	%	50 - 150
		D14-Dibenzo(a,h)anthracene	2012/01/12		80	%	50 - 150
		D8-Acenaphthylene	2012/01/12		88	%	50 - 150
		D8-Naphthalene	2012/01/12		98	%	50 - 150
		1-Methylnaphthalene	2012/01/12	<0.10		ug	
		1-Methylphenanthrene	2012/01/12	<0.10		ug	
		2-Chloronaphthalene	2012/01/12	<0.10		ug	
		2-Methylantracene	2012/01/12	<0.10		ug	
		2-Methylnaphthalene	2012/01/12	<0.10		ug	
		3-Methylcholanthrene	2012/01/12	<2.0		ug	
		7,12-Dimethylbenzo(a)anthracene	2012/01/12	<0.10		ug	
		9,10-Dimethylantracene	2012/01/12	<0.40		ug	
		Acenaphthene	2012/01/12	<0.050		ug	
		Acenaphthylene	2012/01/12	<0.050		ug	
		Anthracene	2012/01/12	<0.050		ug	
		Benzo(a)anthracene	2012/01/12	<0.050		ug	
		Benzo(a)fluorene	2012/01/12	<0.10		ug	
		Benzo(a)pyrene	2012/01/12	<0.050		ug	
		Benzo(b)fluoranthene	2012/01/12	<0.050		ug	
		Benzo(b)fluorene	2012/01/12	<0.10		ug	
		Benzo(e)pyrene	2012/01/12	<0.10		ug	
		Benzo(g,h,i)perylene	2012/01/12	<0.050		ug	
		Benzo(k)fluoranthene	2012/01/12	<0.050		ug	
		Biphenyl	2012/01/12	<0.10		ug	
		Chrysene	2012/01/12	<0.050		ug	
		Coronene	2012/01/12	<0.10		ug	
		Dibenz(a,h)anthracene	2012/01/12	<0.050		ug	
		Dibenzo(a,e)pyrene	2012/01/12	<0.20		ug	
		Fluoranthene	2012/01/12	<0.050		ug	
		Fluorene	2012/01/12	<0.050		ug	
		Indeno(1,2,3-cd)pyrene	2012/01/12	<0.050		ug	
		m-Terphenyl	2012/01/12	<0.10		ug	
		Naphthalene	2012/01/12	<0.072		ug	
		o-Terphenyl	2012/01/12	<0.10		ug	
		Perylene	2012/01/12	<0.10		ug	
		Phenanthrene	2012/01/12	<0.050		ug	
		p-Terphenyl	2012/01/12	<0.10		ug	
		Pyrene	2012/01/12	<0.050		ug	
		Quinoline	2012/01/12	<0.40		ug	
		Tetralin	2012/01/12	<0.10		ug	

Duplicate: Paired analysis of a separate portion of the same sample. Used to evaluate the variance in the measurement.
 Spiked Blank: A blank matrix to which a known amount of the analyte has been added. Used to evaluate analyte recovery.
 Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.
 Surrogate: A pure or isotopically labeled compound whose behavior mirrors the analytes of interest. Used to evaluate extraction efficiency.

MAXXAM

Tisch Hi-Vol PUF+ Sample Collection Data Sheet

Client: Lica
 Location: Cold Lake South
 Station ID: Lica1
 Field Sample ID: LICA PUF/CLS/Jan 04, 2012

Puf+ s/n: 100-1020
 Motor s/n: 1138
 Installation Date/Time: Jan 03, 2011 @ 09:14 mst
 Removal Date/Time: Jan 05, 2011 @ 11:45 mst

Date and Time Information			
Sample Date	Start Time (MST)	Finish Time (MST)	Elapsed Time (Hours)
04-Jan-12	01/04/2012 0:00	01/05/2012 0:00	24.000

PUF and QFF Information			
Date Received	Date Shipped	Puf Expiration Date	QFF Prep Date
30-Dec-11	05-Jan-12	10-Jan-12	????

Set Flow Rate (slpm): 230

Date of Last Calibration: 22-Sep-11

Sampling Data			
Average Pressure(mmHg)	AverageFlow (Qstd slpm)	Average Temperature (C)	Volume (Vstd m ³)
706	229	-3.0	330.35

Time set correctly prior to sampling? YES
Timer set correctly prior to sampling? YES
Sampling data saved to memory card after sampling? YES

Comments: COC# 08577

GB1K1355 PUFF # 1

Ran with a 102mm Quartz Fiber Filter - Sample ID - LICA QFF/CLS/Jan 04, 2012

Technician Signiture: Ting Xu

Your C.O.C. #: 08577

Attention: Michael BisagaMaxxam Analytics
2608 6A Ave.
Cold Lake, AB
CANADA T9M 2C7

Report Date: 2012/01/23

CERTIFICATE OF ANALYSIS**MAXXAM JOB #: B203958**

Received: 2012/01/11, 10:42

Sample Matrix: PUF AND FILTER

Samples Received: 1

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
PAH's in Air (CARB429mod)	1	2012/01/12	2012/01/19	BRL SOP-00201	CARB429(ARBM1,M2)mod

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

THERESA STEPHENSON, Project Manager
Email: TStephenson@maxxam.ca
Phone# (905) 817-5763

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Maxxam Analytics Inc. is a NELAC accredited laboratory. Certificate # CANA001. Use of the NELAC logo however does not insure that Maxxam is accredited for all of the methods indicated. This certificate shall not be reproduced except in full, without the written approval of Maxxam Analytics Inc. Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section.

Total cover pages: 1

Page 1 of 7

Maxxam Job #: B203958
Report Date: 2012/01/23

SEMI-VOLATILE ORGANICS BY GC-MS (PUF AND FILTER)

Maxxam ID		ME7770		
Sampling Date		2012/01/04		
COC Number		08577		
	Units	LICAPUFF+QFF/CLS/JAN	RDL	QC Batch
		04,12		

Semivolatile Organics				
1-Methylnaphthalene	ug	3.68	0.10	2735059
1-Methylphenanthrene	ug	<0.10	0.10	2735059
2-Chloronaphthalene	ug	<0.10	0.10	2735059
2-Methylanthracene	ug	<0.10	0.10	2735059
2-Methylnaphthalene	ug	7.61	0.10	2735059
3-Methylcholanthrene	ug	<2.0	2.0	2735059
7,12-Dimethylbenzo(a)anthracene	ug	<0.10	0.10	2735059
9,10-Dimethylanthracene	ug	<0.40	0.40	2735059
Acenaphthene	ug	0.324	0.050	2735059
Acenaphthylene	ug	1.11	0.050	2735059
Anthracene	ug	0.076	0.050	2735059
Benzo(a)anthracene	ug	0.052	0.050	2735059
Benzo(a)fluorene	ug	<0.10	0.10	2735059
Benzo(a)pyrene	ug	<0.050	0.050	2735059
Benzo(b)fluoranthene	ug	0.116	0.050	2735059
Benzo(b)fluorene	ug	<0.10	0.10	2735059
Benzo(e)pyrene	ug	<0.10	0.10	2735059
Benzo(g,h,i)perylene	ug	0.100	0.050	2735059
Benzo(k)fluoranthene	ug	<0.050	0.050	2735059
Biphenyl	ug	1.04	0.10	2735059
Chrysene	ug	0.102	0.050	2735059
Coronene	ug	<0.10	0.10	2735059
Dibenz(a,h)anthracene	ug	<0.050	0.050	2735059
Dibenzo(a,e)pyrene	ug	<0.20	0.20	2735059
Fluoranthene	ug	0.172	0.050	2735059
Fluorene	ug	0.722	0.050	2735059
Indeno(1,2,3-cd)pyrene	ug	0.060	0.050	2735059
m-Terphenyl	ug	<0.10	0.10	2735059
Naphthalene	ug	5.77	0.072	2735059
o-Terphenyl	ug	<0.10	0.10	2735059
Perylene	ug	<0.10	0.10	2735059
Phenanthrene	ug	0.774	0.050	2735059
RDL = Reportable Detection Limit QC Batch = Quality Control Batch				

Maxxam Job #: B203958
Report Date: 2012/01/23

SEMI-VOLATILE ORGANICS BY GC-MS (PUF AND FILTER)

Maxxam ID		ME7770		
Sampling Date		2012/01/04		
COC Number		08577		
	Units	LICAPUFF+QFF/CLS/JAN	RDL	QC Batch
		04,12		

p-Terphenyl	ug	<0.10	0.10	2735059
Pyrene	ug	0.160	0.050	2735059
Quinoline	ug	<0.40	0.40	2735059
Tetralin	ug	<0.10	0.10	2735059
Surrogate Recovery (%)				
D10-2-Methylnaphthalene	%	84		2735059
D10-Fluoranthene	%	82		2735059
D10-Fluorene (FS)	%	34 (1)		2735059
D10-Phenanthrene	%	84		2735059
D12-Benzo(a)anthracene	%	86		2735059
D12-Benzo(a)pyrene	%	84		2735059
D12-Benzo(b)fluoranthene	%	90		2735059
D12-Benzo(ghi)perylene	%	88		2735059
D12-Benzo(k)fluoranthene	%	92		2735059
D12-Chrysene	%	96		2735059
D12-Indeno(1,2,3-cd)pyrene	%	86		2735059
D12-Perylene	%	94		2735059
D14-Dibenzo(a,h)anthracene	%	78		2735059
D14-Terphenyl (FS)	%	77		2735059
D8-Acenaphthylene	%	88		2735059
D8-Naphthalene	%	88		2735059

QC Batch = Quality Control Batch
(1) Recovery or RPD for this parameter is outside control limits. The overall quality control for this analysis meets acceptability criteria.

Maxxam Job #: B203958
Report Date: 2012/01/23

Test Summary

Maxxam ID ME7770
Sample ID LICAPUFF+QFF/CLS/JAN 04,12
Matrix PUF AND FILTER

Collected 2012/01/04
Shipped
Received 2012/01/11

Test Description	Instrumentation	Batch	Extracted	Analyzed	Analyst
PAH's in Air (CARB429mod)	GC/MS	2735059	2012/01/12	2012/01/19	WENDY ZHAO

Maxxam Job #: B203958
Report Date: 2012/01/23

GENERAL COMMENTS

PAHMS-F

9,10-Dimethylanthracene and 7,12-Dimethylbenzo(a)anthracene and 3-Methylcholanthrene are above 25% RSD in initial calibration. No positives found for these compounds.

Sample ME7770-01: PAHMS-F

Low d10-fluorene field spike recovery. Suspect sample matrix as cause due to acceptable recovery of d14-terphenyl field spike.

Not calibrated for Benzo(b)Anthracene, Picene, Dibenzo(a,c) anthracene or Triphenylene. An estimated mdl for each of these compounds is 0.1ug. Since Dibenzo(a,c) anthracene co-elutes with Dibenzo(a,h) anthracene it would have a value below the estimated mdl.

Since Triphenylene co-elutes with Chrysene, the maximum possible value for this compound would be 0.102ug, which is the value reported for Chrysene.

Benzo(b)Anthracene elutes after Benzo(a)Anthracene and Chrysene. Searched for ions specific to this compound in the appropriate retention time range with no possible positive detected.

Picene elutes after Dibenzo(a,h) anthracene. Searched for ions specific to this compounds in the appropriate retention time range, possible positive detected, but would fall below the mdl using Dibenzo(a,h) anthracene calibration.

Results relate only to the items tested.

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report
 Maxxam Job Number: GB203958

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2735059 WZ	Spiked Blank	D10-2-Methylnaphthalene	2012/01/19		84	%	50 - 150
		D10-Fluoranthene	2012/01/19		80	%	50 - 150
		D10-Phenanthrene	2012/01/19		76	%	50 - 150
		D12-Benzo(a)anthracene	2012/01/19		74	%	50 - 150
		D12-Benzo(a)pyrene	2012/01/19		74	%	50 - 150
		D12-Benzo(b)fluoranthene	2012/01/19		86	%	50 - 150
		D12-Benzo(ghi)perylene	2012/01/19		84	%	50 - 150
		D12-Benzo(k)fluoranthene	2012/01/19		96	%	50 - 150
		D12-Chrysene	2012/01/19		86	%	50 - 150
		D12-Indeno(1,2,3-cd)pyrene	2012/01/19		78	%	50 - 150
		D12-Perylene	2012/01/19		88	%	50 - 150
		D14-Dibenzo(a,h)anthracene	2012/01/19		74	%	50 - 150
		RPD	D8-Acenaphthylene	2012/01/19		82	%
	D8-Naphthalene		2012/01/19		90	%	50 - 150
	RPD	Acenaphthene	2012/01/19		80	%	60 - 130
		Acenaphthene	2012/01/19	2.8		%	50
	Spiked Blank	Acenaphthylene	2012/01/19		77	%	60 - 130
		Acenaphthylene	2012/01/19	5.0		%	50
	Spiked Blank	Anthracene	2012/01/19		67	%	60 - 130
		Anthracene	2012/01/19	13.2		%	50
	Spiked Blank	Benzo(a)anthracene	2012/01/19		61	%	60 - 130
		Benzo(a)anthracene	2012/01/19	12.0		%	50
	Spiked Blank	Benzo(a)pyrene	2012/01/19		63	%	60 - 130
		Benzo(a)pyrene	2012/01/19	16.7		%	50
	Spiked Blank	Benzo(b)fluoranthene	2012/01/19		70	%	60 - 130
		Benzo(b)fluoranthene	2012/01/19	8.2		%	50
	Spiked Blank	Benzo(g,h,i)perylene	2012/01/19		70	%	60 - 130
		Benzo(g,h,i)perylene	2012/01/19	6.9		%	50
	Spiked Blank	Benzo(k)fluoranthene	2012/01/19		95	%	60 - 130
		Benzo(k)fluoranthene	2012/01/19	1.9		%	50
	Spiked Blank	Chrysene	2012/01/19		83	%	60 - 130
		Chrysene	2012/01/19	0.9		%	50
	Spiked Blank	Dibenz(a,h)anthracene	2012/01/19		64	%	60 - 130
		Dibenz(a,h)anthracene	2012/01/19	10.7		%	50
	Spiked Blank	Fluoranthene	2012/01/19		73	%	60 - 130
		Fluoranthene	2012/01/19	15.5		%	50
	Spiked Blank	Fluorene	2012/01/19		74	%	60 - 130
		Fluorene	2012/01/19	8.4		%	50
	Spiked Blank	Indeno(1,2,3-cd)pyrene	2012/01/19		68	%	60 - 130
		Indeno(1,2,3-cd)pyrene	2012/01/19	9.1		%	50
Spiked Blank	Naphthalene	2012/01/19		87	%	60 - 130	
	Naphthalene	2012/01/19	0.3		%	50	
Spiked Blank	Phenanthrene	2012/01/19		65	%	60 - 130	
	Phenanthrene	2012/01/19	16.7		%	50	
Spiked Blank	Pyrene	2012/01/19		72	%	60 - 130	
	Pyrene	2012/01/19	16.9		%	50	
Method Blank	D10-2-Methylnaphthalene	2012/01/19		84	%	50 - 150	
	D10-Fluoranthene	2012/01/19		86	%	50 - 150	
	D10-Phenanthrene	2012/01/19		86	%	50 - 150	
	D12-Benzo(a)anthracene	2012/01/19		74	%	50 - 150	
	D12-Benzo(a)pyrene	2012/01/19		76	%	50 - 150	
	D12-Benzo(b)fluoranthene	2012/01/19		88	%	50 - 150	
	D12-Benzo(ghi)perylene	2012/01/19		88	%	50 - 150	
	D12-Benzo(k)fluoranthene	2012/01/19		92	%	50 - 150	
	D12-Chrysene	2012/01/19		90	%	50 - 150	

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report (Continued)

Maxxam Job Number: GB203958

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2735059 WZ	Method Blank	D12-Indeno(1,2,3-cd)pyrene	2012/01/19		80	%	50 - 150
		D12-Perylene	2012/01/19		90	%	50 - 150
		D14-Dibenzo(a,h)anthracene	2012/01/19		76	%	50 - 150
		D8-Acenaphthylene	2012/01/19		84	%	50 - 150
		D8-Naphthalene	2012/01/19		90	%	50 - 150
		1-Methylnaphthalene	2012/01/19	<0.10		ug	
		1-Methylphenanthrene	2012/01/19	<0.10		ug	
		2-Chloronaphthalene	2012/01/19	<0.10		ug	
		2-Methylantracene	2012/01/19	<0.10		ug	
		2-Methylnaphthalene	2012/01/19	<0.10		ug	
		3-Methylcholanthrene	2012/01/19	<2.0		ug	
		7,12-Dimethylbenzo(a)anthracene	2012/01/19	<0.10		ug	
		9,10-Dimethylantracene	2012/01/19	<0.40		ug	
		Acenaphthene	2012/01/19	<0.050		ug	
		Acenaphthylene	2012/01/19	<0.050		ug	
		Anthracene	2012/01/19	<0.050		ug	
		Benzo(a)anthracene	2012/01/19	<0.050		ug	
		Benzo(a)fluorene	2012/01/19	<0.10		ug	
		Benzo(a)pyrene	2012/01/19	<0.050		ug	
		Benzo(b)fluoranthene	2012/01/19	<0.050		ug	
		Benzo(b)fluorene	2012/01/19	<0.10		ug	
		Benzo(e)pyrene	2012/01/19	<0.10		ug	
		Benzo(g,h,i)perylene	2012/01/19	<0.050		ug	
		Benzo(k)fluoranthene	2012/01/19	<0.050		ug	
		Biphenyl	2012/01/19	<0.10		ug	
		Chrysene	2012/01/19	<0.050		ug	
		Coronene	2012/01/19	<0.10		ug	
		Dibenz(a,h)anthracene	2012/01/19	<0.050		ug	
		Dibenzo(a,e)pyrene	2012/01/19	<0.20		ug	
		Fluoranthene	2012/01/19	<0.050		ug	
		Fluorene	2012/01/19	<0.050		ug	
		Indeno(1,2,3-cd)pyrene	2012/01/19	<0.050		ug	
		m-Terphenyl	2012/01/19	<0.10		ug	
		Naphthalene	2012/01/19	<0.072		ug	
		o-Terphenyl	2012/01/19	<0.10		ug	
		Perylene	2012/01/19	<0.10		ug	
		Phenanthrene	2012/01/19	<0.050		ug	
		p-Terphenyl	2012/01/19	<0.10		ug	
		Pyrene	2012/01/19	<0.050		ug	
		Quinoline	2012/01/19	<0.40		ug	
		Tetralin	2012/01/19	<0.10		ug	

Duplicate: Paired analysis of a separate portion of the same sample. Used to evaluate the variance in the measurement.

Spiked Blank: A blank matrix to which a known amount of the analyte has been added. Used to evaluate analyte recovery.

Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

Surrogate: A pure or isotopically labeled compound whose behavior mirrors the analytes of interest. Used to evaluate extraction efficiency.

MAXXAM

Tisch Hi-Vol PUF+ Sample Collection Data Sheet

Client: Lica
Location: Cold Lake South
Station ID: Lica1
Field Sample ID: LICA PUF/CLS/Jan 10, 2012

Puf+ s/n: 100-1020
Motor s/n: 1138
Installation Date/Time: Jan 09, 2011 @ 13:50 mst
Removal Date/Time: Jan 10, 2011 @ 12:17 mst

Date and Time Information			
Sample Date	Start Time (MST)	Finish Time (MST)	Elapsed Time (Hours)
10-Jan-12	01/10/2012 0:00	01/11/2012 0:00	

PUF and QFF Information			
Date Received	Date Shipped	Puf Expiration Date	QFF Prep Date
05-Jan-12	11-Jan-12	17-Jan-12	????

Set Flow Rate (slpm): 230

Date of Last Calibration: 22-Sep-11

Sampling Data			
Average Pressure(mmHg)	AverageFlow (Qstd slpm)	Average Temperature (C)	Volume (Vstd m ³)
714	229	-5.4	330.36

Time set correctly prior to sampling? YES
Timer set correctly prior to sampling? YES
Sampling data saved to memory card after sampling? YES

Comments: COC# 08578

GB1K1375 PUFF # 1

Ran with a 102mm Quartz Fiber Filter - Sample ID - LICA QFF/CLS/Jan 10, 2012

When took out the samples by accidently finger touched the QFF filter.

Technician Signiture: Ting Xu

Your C.O.C. #: 08578

Attention: Michael BisagaMaxxam Analytics
2608 6A Ave.
Cold Lake, AB
CANADA T9M 2C7

Report Date: 2012/01/23

CERTIFICATE OF ANALYSIS**MAXXAM JOB #: B205694****Received: 2012/01/13, 08:50**

Sample Matrix: PUF AND FILTER

Samples Received: 1

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
PAH's in Air (CARB429mod)	1	2012/01/17	2012/01/19	BRL SOP-00201	CARB429(ARBM1,M2)mod

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

THERESA STEPHENSON, Project Manager
Email: TStephenson@maxxam.ca
Phone# (905) 817-5763=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Maxxam Analytics Inc. is a NELAC accredited laboratory. Certificate # CANA001. Use of the NELAC logo however does not insure that Maxxam is accredited for all of the methods indicated. This certificate shall not be reproduced except in full, without the written approval of Maxxam Analytics Inc. Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section.

Total cover pages: 1

Page 1 of 7

SEMI-VOLATILE ORGANICS BY GC-MS (PUF AND FILTER)

Maxxam ID		MF5677		
Sampling Date		2012/01/10		
COC Number		08578		
	Units	LICA PUFF+QFF/ CLS/ JAN 10/12	RDL	QC Batch

Semivolatile Organics				
1-Methylnaphthalene	ug	0.19	0.10	2738198
1-Methylphenanthrene	ug	<0.10	0.10	2738198
2-Chloronaphthalene	ug	<0.10	0.10	2738198
2-Methylanthracene	ug	<0.10	0.10	2738198
2-Methylnaphthalene	ug	0.34	0.10	2738198
3-Methylcholanthrene	ug	<2.0	2.0	2738198
7,12-Dimethylbenzo(a)anthracene	ug	<0.10	0.10	2738198
9,10-Dimethylanthracene	ug	<0.40	0.40	2738198
Acenaphthene	ug	<0.050	0.050	2738198
Acenaphthylene	ug	<0.050	0.050	2738198
Anthracene	ug	<0.050	0.050	2738198
Benzo(a)anthracene	ug	<0.050	0.050	2738198
Benzo(a)fluorene	ug	<0.10	0.10	2738198
Benzo(a)pyrene	ug	<0.050	0.050	2738198
Benzo(b)fluoranthene	ug	<0.050	0.050	2738198
Benzo(b)fluorene	ug	<0.10	0.10	2738198
Benzo(e)pyrene	ug	<0.10	0.10	2738198
Benzo(g,h,i)perylene	ug	<0.050	0.050	2738198
Benzo(k)fluoranthene	ug	<0.050	0.050	2738198
Biphenyl	ug	0.28	0.10	2738198
Chrysene	ug	<0.050	0.050	2738198
Coronene	ug	<0.10	0.10	2738198
Dibenz(a,h)anthracene	ug	<0.050	0.050	2738198
Dibenzo(a,e)pyrene	ug	<0.20	0.20	2738198
Fluoranthene	ug	<0.050	0.050	2738198
Fluorene	ug	0.126	0.050	2738198
Indeno(1,2,3-cd)pyrene	ug	<0.050	0.050	2738198
m-Terphenyl	ug	<0.10	0.10	2738198
Naphthalene	ug	0.466	0.072	2738198
o-Terphenyl	ug	<0.10	0.10	2738198

RDL = Reportable Detection Limit
 QC Batch = Quality Control Batch

SEMI-VOLATILE ORGANICS BY GC-MS (PUF AND FILTER)

Maxxam ID		MF5677		
Sampling Date		2012/01/10		
COC Number		08578		
	Units	LICA PUFF+QFF/ CLS/ JAN 10/12	RDL	QC Batch

Perylene	ug	<0.10	0.10	2738198
Phenanthrene	ug	0.146	0.050	2738198
p-Terphenyl	ug	<0.10	0.10	2738198
Pyrene	ug	<0.050	0.050	2738198
Quinoline	ug	<0.40	0.40	2738198
Tetralin	ug	<0.10	0.10	2738198
Surrogate Recovery (%)				
D10-2-Methylnaphthalene	%	76		2738198
D10-Fluoranthene	%	96		2738198
D10-Fluorene (FS)	%	56		2738198
D10-Phenanthrene	%	88		2738198
D12-Benzo(a)anthracene	%	96		2738198
D12-Benzo(a)pyrene	%	88		2738198
D12-Benzo(b)fluoranthene	%	96		2738198
D12-Benzo(ghi)perylene	%	98		2738198
D12-Benzo(k)fluoranthene	%	88		2738198
D12-Chrysene	%	84		2738198
D12-Indeno(1,2,3-cd)pyrene	%	102		2738198
D12-Perylene	%	92		2738198
D14-Dibenzo(a,h)anthracene	%	96		2738198
D14-Terphenyl (FS)	%	91		2738198
D8-Acenaphthylene	%	78		2738198
D8-Naphthalene	%	74		2738198

QC Batch = Quality Control Batch

Maxxam Job #: B205694
Report Date: 2012/01/23

Test Summary

Maxxam ID MF5677
Sample ID LICA PUFF+QFF/ CLS/ JAN 10/12
Matrix PUF AND FILTER

Collected 2012/01/10
Shipped
Received 2012/01/13

Test Description	Instrumentation	Batch	Extracted	Analyzed	Analyst
PAH's in Air (CARB429mod)	GC/MS	2738198	2012/01/17	2012/01/19	WENDY ZHAO

Maxxam Job #: B205694
Report Date: 2012/01/23

GENERAL COMMENTS

PAHMS-F

9,10-Dimethylanthracene and 7,12-Dimethylbenzo(a)anthracene are above 25% RSD in initial calibration. No positives found for these 2 compounds.

Naphthalene, Benzo(g,h,i)perylene are positive found in blank. Sample should be considered to be possibly contaminated to the level found in the blank.

Not calibrated for Benzo(b)Anthracene, Picene, Dibenzo(a,c) anthracene or Triphenylene. An estimated mdl for each of these compounds is 0.1ug.

Since Dibenzo(a,c) anthracene co-elutes with Dibenzo(a,h) anthracene and Triphenylene with Chrysene each would have a value below estimated mdl.

Benzo(b)Anthracene elutes after Benzo(a)Anthracene and Chrysene. Picene elutes after Dibenzo(a,h) anthracene. Searched for ions specific to these 2 compounds in the appropriate retention time range with no possible positives detected.

Results relate only to the items tested.

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report
 Maxxam Job Number: GB205694

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2738198 WZ	Spiked Blank	D10-2-Methylnaphthalene	2012/01/19		86	%	50 - 150
		D10-Fluoranthene	2012/01/19		82	%	50 - 150
		D10-Phenanthrene	2012/01/19		84	%	50 - 150
		D12-Benzo(a)anthracene	2012/01/19		80	%	50 - 150
		D12-Benzo(a)pyrene	2012/01/19		78	%	50 - 150
		D12-Benzo(b)fluoranthene	2012/01/19		94	%	50 - 150
		D12-Benzo(ghi)perylene	2012/01/19		90	%	50 - 150
		D12-Benzo(k)fluoranthene	2012/01/19		82	%	50 - 150
		D12-Chrysene	2012/01/19		76	%	50 - 150
		D12-Indeno(1,2,3-cd)pyrene	2012/01/19		90	%	50 - 150
		D12-Perylene	2012/01/19		86	%	50 - 150
		D14-Dibenzo(a,h)anthracene	2012/01/19		88	%	50 - 150
		D8-Acenaphthylene	2012/01/19		84	%	50 - 150
		D8-Naphthalene	2012/01/19		86	%	50 - 150
		Acenaphthene	2012/01/19		78	%	60 - 130
	RPD	Acenaphthene	2012/01/19	0.6		%	50
	Spiked Blank	Acenaphthylene	2012/01/19		82	%	60 - 130
	RPD	Acenaphthylene	2012/01/19	0.3		%	50
	Spiked Blank	Anthracene	2012/01/19		70	%	60 - 130
	RPD	Anthracene	2012/01/19	4.9		%	50
	Spiked Blank	Benzo(a)anthracene	2012/01/19		69	%	60 - 130
	RPD	Benzo(a)anthracene	2012/01/19	11.2		%	50
	Spiked Blank	Benzo(a)pyrene	2012/01/19		70	%	60 - 130
	RPD	Benzo(a)pyrene	2012/01/19	8.9		%	50
	Spiked Blank	Benzo(b)fluoranthene	2012/01/19		80	%	60 - 130
	RPD	Benzo(b)fluoranthene	2012/01/19	0.3		%	50
	Spiked Blank	Benzo(g,h,i)perylene	2012/01/19		78	%	60 - 130
	RPD	Benzo(g,h,i)perylene	2012/01/19	4.7		%	50
	Spiked Blank	Benzo(k)fluoranthene	2012/01/19		73	%	60 - 130
	RPD	Benzo(k)fluoranthene	2012/01/19	21.1		%	50
	Spiked Blank	Chrysene	2012/01/19		71	%	60 - 130
	RPD	Chrysene	2012/01/19	9.1		%	50
	Spiked Blank	Dibenz(a,h)anthracene	2012/01/19		79	%	60 - 130
	RPD	Dibenz(a,h)anthracene	2012/01/19	5.6		%	50
	Spiked Blank	Fluoranthene	2012/01/19		77	%	60 - 130
	RPD	Fluoranthene	2012/01/19	6.9		%	50
	Spiked Blank	Fluorene	2012/01/19		75	%	60 - 130
	RPD	Fluorene	2012/01/19	1.7		%	50
	Spiked Blank	Indeno(1,2,3-cd)pyrene	2012/01/19		79	%	60 - 130
	RPD	Indeno(1,2,3-cd)pyrene	2012/01/19	6.4		%	50
	Spiked Blank	Naphthalene	2012/01/19		91	%	60 - 130
	RPD	Naphthalene	2012/01/19	2.5		%	50
	Spiked Blank	Phenanthrene	2012/01/19		74	%	60 - 130
	RPD	Phenanthrene	2012/01/19	3.6		%	50
	Spiked Blank	Pyrene	2012/01/19		77	%	60 - 130
	RPD	Pyrene	2012/01/19	6.9		%	50
	Method Blank	D10-2-Methylnaphthalene	2012/01/19		88	%	50 - 150
		D10-Fluoranthene	2012/01/19		88	%	50 - 150
		D10-Phenanthrene	2012/01/19		88	%	50 - 150
		D12-Benzo(a)anthracene	2012/01/19		90	%	50 - 150
		D12-Benzo(a)pyrene	2012/01/19		84	%	50 - 150
		D12-Benzo(b)fluoranthene	2012/01/19		104	%	50 - 150
		D12-Benzo(ghi)perylene	2012/01/19		94	%	50 - 150
		D12-Benzo(k)fluoranthene	2012/01/19		88	%	50 - 150
		D12-Chrysene	2012/01/19		84	%	50 - 150

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report (Continued)

Maxxam Job Number: GB205694

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2738198 WZ	Method Blank	D12-Indeno(1,2,3-cd)pyrene	2012/01/19		96	%	50 - 150
		D12-Perylene	2012/01/19		92	%	50 - 150
		D14-Dibenzo(a,h)anthracene	2012/01/19		92	%	50 - 150
		D8-Acenaphthylene	2012/01/19		90	%	50 - 150
		D8-Naphthalene	2012/01/19		88	%	50 - 150
		1-Methylnaphthalene	2012/01/19	<0.10		ug	
		1-Methylphenanthrene	2012/01/19	<0.10		ug	
		2-Chloronaphthalene	2012/01/19	<0.10		ug	
		2-Methylanthracene	2012/01/19	<0.10		ug	
		2-Methylnaphthalene	2012/01/19	<0.10		ug	
		3-Methylcholanthrene	2012/01/19	<2.0		ug	
		7,12-Dimethylbenzo(a)anthracene	2012/01/19	<0.10		ug	
		9,10-Dimethylanthracene	2012/01/19	<0.40		ug	
		Acenaphthene	2012/01/19	<0.050		ug	
		Acenaphthylene	2012/01/19	<0.050		ug	
		Anthracene	2012/01/19	<0.050		ug	
		Benzo(a)anthracene	2012/01/19	<0.050		ug	
		Benzo(a)fluorene	2012/01/19	<0.10		ug	
		Benzo(a)pyrene	2012/01/19	<0.050		ug	
		Benzo(b)fluoranthene	2012/01/19	<0.050		ug	
		Benzo(b)fluorene	2012/01/19	<0.10		ug	
		Benzo(e)pyrene	2012/01/19	<0.10		ug	
		Benzo(g,h,i)perylene	2012/01/19	0.052, RDL=0.050		ug	
		Benzo(k)fluoranthene	2012/01/19	<0.050		ug	
		Biphenyl	2012/01/19	<0.10		ug	
		Chrysene	2012/01/19	<0.050		ug	
		Coronene	2012/01/19	<0.10		ug	
		Dibenz(a,h)anthracene	2012/01/19	<0.050		ug	
		Dibenzo(a,e)pyrene	2012/01/19	<0.20		ug	
		Fluoranthene	2012/01/19	<0.050		ug	
		Fluorene	2012/01/19	<0.050		ug	
		Indeno(1,2,3-cd)pyrene	2012/01/19	<0.050		ug	
		m-Terphenyl	2012/01/19	<0.10		ug	
		Naphthalene	2012/01/19	0.110, RDL=0.072		ug	
		o-Terphenyl	2012/01/19	<0.10		ug	
		Perylene	2012/01/19	<0.10		ug	
		Phenanthrene	2012/01/19	<0.050		ug	
		p-Terphenyl	2012/01/19	<0.10		ug	
		Pyrene	2012/01/19	<0.050		ug	
		Quinoline	2012/01/19	<0.40		ug	
		Tetralin	2012/01/19	<0.10		ug	

Duplicate: Paired analysis of a separate portion of the same sample. Used to evaluate the variance in the measurement.

Spiked Blank: A blank matrix to which a known amount of the analyte has been added. Used to evaluate analyte recovery.

Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

Surrogate: A pure or isotopically labeled compound whose behavior mirrors the analytes of interest. Used to evaluate extraction efficiency.

MAXXAM

Tisch Hi-Vol PUF+ Sample Collection Data Sheet

Client: Lica
Location: Cold Lake South
Station ID: Lica1
Field Sample ID: LICA PUF/CLS/Jan 16, 2012

Puf+ s/n: 100-1020
Motor s/n: 1138
Installation Date/Time: Jan 11, 2012 @ 13:33 mst
Removal Date/Time: Jan 19, 2012 @ 9:30 mst

Date and Time Information			
Sample Date	Start Time (MST)	Finish Time (MST)	Elapsed Time (Hours)
16-Jan-12	01/16/2012 0:00	01/17/2012 0:00	24.000

PUF and QFF Information			
Date Received	Date Shipped	Puf Expiration Date	QFF Prep Date
10-Jan-12	11-Jan-12	23-Jan-12	????

Set Flow Rate (slpm): 230

Date of Last Calibration: 22-Sep-11

Sampling Data			
Average Pressure(mmHg)	AverageFlow (Qstd slpm)	Average Temperature (C)	Volume (Vstd m ³)
726	229.09	-26.3	330.35

Time set correctly prior to sampling? YES
Timer set correctly prior to sampling? YES
Sampling data saved to memory card after sampling? YES

Comments: COC# 08653

GB1K1656 PUFF # 1

Ran with a 102mm Quartz Fiber Filter - Sample ID - LICA QFF/CLS/Jan 16, 2012

Technician Signiture: Theo McLaren

Your C.O.C. #: 08653

Attention: Michael BisagaMaxxam Analytics
2608 6A Ave.
Cold Lake, AB
CANADA T9M 2C7

Report Date: 2012/01/31

CERTIFICATE OF ANALYSIS**MAXXAM JOB #: B209722**

Received: 2012/01/21, 09:49

Sample Matrix: PUF AND FILTER

Samples Received: 1

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
PAH's in Air (CARB429mod)	1	2012/01/23	2012/01/30	BRL SOP-00201	CARB429(ARBM1,M2)mod

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

THERESA STEPHENSON, Project Manager
Email: TStephenson@maxxam.ca
Phone# (905) 817-5763

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Maxxam Analytics Inc. is a NELAC accredited laboratory. Certificate # CANA001. Use of the NELAC logo however does not insure that Maxxam is accredited for all of the methods indicated. This certificate shall not be reproduced except in full, without the written approval of Maxxam Analytics Inc. Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section.

Total cover pages: 1

Page 1 of 7

Maxxam Job #: B209722
 Report Date: 2012/01/31

SEMI-VOLATILE ORGANICS BY GC-MS (PUF AND FILTER)

Maxxam ID		MH6050		
Sampling Date		2012/01/16		
COC Number		08653		
	Units	LICA	RDL	QC Batch
		PUFF+QFF/CLS/JAN16/2012		

Semivolatile Organics				
1-Methylnaphthalene	ug	0.68	0.10	2743916
1-Methylphenanthrene	ug	<0.10	0.10	2743916
2-Chloronaphthalene	ug	<0.10	0.10	2743916
2-Methylantracene	ug	<0.10	0.10	2743916
2-Methylnaphthalene	ug	0.92	0.10	2743916
3-Methylcholanthrene	ug	<2.0	2.0	2743916
7,12-Dimethylbenzo(a)anthracene	ug	<0.10	0.10	2743916
9,10-Dimethylantracene	ug	<0.40	0.40	2743916
Acenaphthene	ug	0.050	0.050	2743916
Acenaphthylene	ug	<0.050	0.050	2743916
Anthracene	ug	<0.050	0.050	2743916
Benzo(a)anthracene	ug	<0.050	0.050	2743916
Benzo(a)fluorene	ug	<0.10	0.10	2743916
Benzo(a)pyrene	ug	<0.050	0.050	2743916
Benzo(b)fluoranthene	ug	0.088	0.050	2743916
Benzo(b)fluorene	ug	<0.10	0.10	2743916
Benzo(e)pyrene	ug	<0.10	0.10	2743916
Benzo(g,h,i)perylene	ug	<0.050	0.050	2743916
Benzo(k)fluoranthene	ug	<0.050	0.050	2743916
Biphenyl	ug	0.59	0.10	2743916
Chrysene	ug	0.074	0.050	2743916
Coronene	ug	<0.10	0.10	2743916
Dibenz(a,h)anthracene	ug	<0.050	0.050	2743916
Dibenzo(a,e)pyrene	ug	<0.20	0.20	2743916
Fluoranthene	ug	0.192	0.050	2743916
Fluorene	ug	0.180	0.050	2743916
Indeno(1,2,3-cd)pyrene	ug	<0.050	0.050	2743916
m-Terphenyl	ug	<0.10	0.10	2743916
Naphthalene	ug	2.73	0.072	2743916
o-Terphenyl	ug	<0.10	0.10	2743916
Perylene	ug	<0.10	0.10	2743916
Phenanthrene	ug	0.336	0.050	2743916

 RDL = Reportable Detection Limit
 QC Batch = Quality Control Batch

Maxxam Job #: B209722
 Report Date: 2012/01/31

SEMI-VOLATILE ORGANICS BY GC-MS (PUF AND FILTER)

Maxxam ID		MH6050		
Sampling Date		2012/01/16		
COC Number		08653		
	Units	LICA	RDL	QC Batch
		PUFF+QFF/CLS/JAN16/2012		

p-Terphenyl	ug	<0.10	0.10	2743916
Pyrene	ug	0.124	0.050	2743916
Quinoline	ug	<0.40	0.40	2743916
Tetralin	ug	<0.10	0.10	2743916
Surrogate Recovery (%)				
D10-2-Methylnaphthalene	%	80		2743916
D10-Fluoranthene	%	88		2743916
D10-Fluorene (FS)	%	81		2743916
D10-Phenanthrene	%	88		2743916
D12-Benzo(a)anthracene	%	94		2743916
D12-Benzo(a)pyrene	%	92		2743916
D12-Benzo(b)fluoranthene	%	86		2743916
D12-Benzo(ghi)perylene	%	88		2743916
D12-Benzo(k)fluoranthene	%	82		2743916
D12-Chrysene	%	82		2743916
D12-Indeno(1,2,3-cd)pyrene	%	88		2743916
D12-Perylene	%	90		2743916
D14-Dibenzo(a,h)anthracene	%	88		2743916
D14-Terphenyl (FS)	%	73		2743916
D8-Acenaphthylene	%	90		2743916
D8-Naphthalene	%	76		2743916

QC Batch = Quality Control Batch

Maxxam Job #: B209722
Report Date: 2012/01/31

Test Summary

Maxxam ID MH6050
Sample ID LICA PUFF+QFF/CLS/JAN16/2012
Matrix PUF AND FILTER

Collected 2012/01/16
Shipped
Received 2012/01/21

Test Description	Instrumentation	Batch	Extracted	Analyzed	Analyst
PAH's in Air (CARB429mod)	GC/MS	2743916	2012/01/23	2012/01/30	JIE WU

Maxxam Job #: B209722
Report Date: 2012/01/31

GENERAL COMMENTS

PAHMS-F

9,10-Dimethylanthracene and 7,12-dimethylbenzo(a)anthracene are above 25% RSD in initial and continuing calibrations. No positives found for these 2 compounds.

Not calibrated for benzo(b)anthracene, picene, dibenzo(a,c)anthracene and triphenylene. An estimated mdl for each of these compounds is 0.1ug.

Since dibenzo(a,c)anthracene co-elutes with dibenz(a,h)anthracene and triphenylene with chrysene each would have a value below estimated mdl.

Benzo(b)anthracene elutes after benzo(a)anthracene and chrysene. Picene elutes after dibenz(a,h)anthracene. Searched for ions specific to these 2 compounds in the appropriate retention time range with no possible positives detected.

Results relate only to the items tested.

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report
 Maxxam Job Number: GB209722

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2743916 JIW	Spiked Blank	D10-2-Methylnaphthalene	2012/01/30		84	%	50 - 150
		D10-Fluoranthene	2012/01/30		88	%	50 - 150
		D10-Phenanthrene	2012/01/30		90	%	50 - 150
		D12-Benzo(a)anthracene	2012/01/30		92	%	50 - 150
		D12-Benzo(a)pyrene	2012/01/30		92	%	50 - 150
		D12-Benzo(b)fluoranthene	2012/01/30		86	%	50 - 150
		D12-Benzo(ghi)perylene	2012/01/30		90	%	50 - 150
		D12-Benzo(k)fluoranthene	2012/01/30		84	%	50 - 150
		D12-Chrysene	2012/01/30		82	%	50 - 150
		D12-Indeno(1,2,3-cd)pyrene	2012/01/30		84	%	50 - 150
		D12-Perylene	2012/01/30		88	%	50 - 150
		D14-Dibenzo(a,h)anthracene	2012/01/30		84	%	50 - 150
		RPD	D8-Acenaphthylene	2012/01/30		90	%
	D8-Naphthalene		2012/01/30		80	%	50 - 150
	RPD	Acenaphthene	2012/01/30		79	%	60 - 130
		Acenaphthene	2012/01/30	0.3		%	50
	Spiked Blank	Acenaphthylene	2012/01/30		82	%	60 - 130
		Acenaphthylene	2012/01/30	0.6		%	50
	Spiked Blank	Anthracene	2012/01/30		75	%	60 - 130
		Anthracene	2012/01/30	1.7		%	50
	Spiked Blank	Benzo(a)anthracene	2012/01/30		77	%	60 - 130
		Benzo(a)anthracene	2012/01/30	1.9		%	50
	Spiked Blank	Benzo(a)pyrene	2012/01/30		69	%	60 - 130
		Benzo(a)pyrene	2012/01/30	0		%	50
	Spiked Blank	Benzo(b)fluoranthene	2012/01/30		76	%	60 - 130
		Benzo(b)fluoranthene	2012/01/30	1.3		%	50
	Spiked Blank	Benzo(g,h,i)perylene	2012/01/30		77	%	60 - 130
		Benzo(g,h,i)perylene	2012/01/30	0.3		%	50
	Spiked Blank	Benzo(k)fluoranthene	2012/01/30		78	%	60 - 130
		Benzo(k)fluoranthene	2012/01/30	1.3		%	50
	Spiked Blank	Chrysene	2012/01/30		75	%	60 - 130
		Chrysene	2012/01/30	2.9		%	50
	Spiked Blank	Dibenz(a,h)anthracene	2012/01/30		71	%	60 - 130
		Dibenz(a,h)anthracene	2012/01/30	3.4		%	50
	Spiked Blank	Fluoranthene	2012/01/30		81	%	60 - 130
		Fluoranthene	2012/01/30	2.2		%	50
	Spiked Blank	Fluorene	2012/01/30		78	%	60 - 130
		Fluorene	2012/01/30	2.3		%	50
	Spiked Blank	Indeno(1,2,3-cd)pyrene	2012/01/30		75	%	60 - 130
		Indeno(1,2,3-cd)pyrene	2012/01/30	0.7		%	50
Spiked Blank	Naphthalene	2012/01/30		74	%	60 - 130	
	Naphthalene	2012/01/30	0.7		%	50	
Spiked Blank	Phenanthrene	2012/01/30		78	%	60 - 130	
	Phenanthrene	2012/01/30	2.6		%	50	
Spiked Blank	Pyrene	2012/01/30		79	%	60 - 130	
	Pyrene	2012/01/30	1.6		%	50	
Method Blank	D10-2-Methylnaphthalene	2012/01/30		82	%	50 - 150	
	D10-Fluoranthene	2012/01/30		88	%	50 - 150	
	D10-Phenanthrene	2012/01/30		86	%	50 - 150	
	D12-Benzo(a)anthracene	2012/01/30		92	%	50 - 150	
	D12-Benzo(a)pyrene	2012/01/30		92	%	50 - 150	
	D12-Benzo(b)fluoranthene	2012/01/30		86	%	50 - 150	
	D12-Benzo(ghi)perylene	2012/01/30		88	%	50 - 150	
	D12-Benzo(k)fluoranthene	2012/01/30		82	%	50 - 150	
	D12-Chrysene	2012/01/30		82	%	50 - 150	

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report (Continued)

Maxxam Job Number: GB209722

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2743916 JIW	Method Blank	D12-Indeno(1,2,3-cd)pyrene	2012/01/30		86	%	50 - 150
		D12-Perylene	2012/01/30		90	%	50 - 150
		D14-Dibenzo(a,h)anthracene	2012/01/30		84	%	50 - 150
		D8-Acenaphthylene	2012/01/30		88	%	50 - 150
		D8-Naphthalene	2012/01/30		80	%	50 - 150
		1-Methylnaphthalene	2012/01/30	<0.10		ug	
		1-Methylphenanthrene	2012/01/30	<0.10		ug	
		2-Chloronaphthalene	2012/01/30	<0.10		ug	
		2-Methylanthracene	2012/01/30	<0.10		ug	
		2-Methylnaphthalene	2012/01/30	<0.10		ug	
		3-Methylcholanthrene	2012/01/30	<2.0		ug	
		7,12-Dimethylbenzo(a)anthracene	2012/01/30	<0.10		ug	
		9,10-Dimethylanthracene	2012/01/30	<0.40		ug	
		Acenaphthene	2012/01/30	<0.050		ug	
		Acenaphthylene	2012/01/30	<0.050		ug	
		Anthracene	2012/01/30	<0.050		ug	
		Benzo(a)anthracene	2012/01/30	<0.050		ug	
		Benzo(a)fluorene	2012/01/30	<0.10		ug	
		Benzo(a)pyrene	2012/01/30	<0.050		ug	
		Benzo(b)fluoranthene	2012/01/30	<0.050		ug	
		Benzo(b)fluorene	2012/01/30	<0.10		ug	
		Benzo(e)pyrene	2012/01/30	<0.10		ug	
		Benzo(g,h,i)perylene	2012/01/30	<0.050		ug	
		Benzo(k)fluoranthene	2012/01/30	<0.050		ug	
		Biphenyl	2012/01/30	<0.10		ug	
		Chrysene	2012/01/30	<0.050		ug	
		Coronene	2012/01/30	<0.10		ug	
		Dibenz(a,h)anthracene	2012/01/30	<0.050		ug	
		Dibenzo(a,e)pyrene	2012/01/30	<0.20		ug	
		Fluoranthene	2012/01/30	<0.050		ug	
		Fluorene	2012/01/30	<0.050		ug	
		Indeno(1,2,3-cd)pyrene	2012/01/30	<0.050		ug	
		m-Terphenyl	2012/01/30	<0.10		ug	
		Naphthalene	2012/01/30	<0.072		ug	
		o-Terphenyl	2012/01/30	<0.10		ug	
		Perylene	2012/01/30	<0.10		ug	
		Phenanthrene	2012/01/30	<0.050		ug	
		p-Terphenyl	2012/01/30	<0.10		ug	
		Pyrene	2012/01/30	<0.050		ug	
		Quinoline	2012/01/30	<0.40		ug	
		Tetralin	2012/01/30	<0.10		ug	

Duplicate: Paired analysis of a separate portion of the same sample. Used to evaluate the variance in the measurement.

Spiked Blank: A blank matrix to which a known amount of the analyte has been added. Used to evaluate analyte recovery.

Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.

Surrogate: A pure or isotopically labeled compound whose behavior mirrors the analytes of interest. Used to evaluate extraction efficiency.

MAXXAM

Tisch Hi-Vol PUF+ Sample Collection Data Sheet

Client: Lica
Location: Cold Lake South
Station ID: Lica1
Field Sample ID: LICA PUF/CLS/Jan 22, 2012

Puf+ s/n: 100-1020
Motor s/n: 1138
Installation Date/Time: Jan 18, 2012 @ 11:05 mst
Removal Date/Time: Jan 25, 2012 @ 5:00

Date and Time Information			
Sample Date	Start Time (MST)	Finish Time (MST)	Elapsed Time (Hours)
22-Jan-12	01/23/2012 0:00	01/23/2012 0:00	24.000

PUF and QFF Information			
Date Received	Date Shipped	Puf Expiration Date	QFF Prep Date
18-Jan-12	25-Jan-12	31-Jan-12	????

Set Flow Rate (slpm): 230

Date of Last Calibration: 22-Sep-11

Sampling Data			
Average Pressure(mmHg)	AverageFlow (Qstd slpm)	Average Temperature (C)	Volume (Vstd m ³)
706	229	-11.3	330.34

Time set correctly prior to sampling? YES
Timer set correctly prior to sampling? YES
Sampling data saved to memory card after sampling? YES

Comments: COC# 08702

GB1K1656 PUFF # 1

Ran with a 102mm Quartz Fiber Filter - Sample ID - LICA QFF/CLS/Jan 22, 2012

Technician Signiture: Ting Xu

Your C.O.C. #: 08702

Attention: Michael BisagaMaxxam Analytics
2608 6A Ave.
Cold Lake, AB
CANADA T9M 2C7

Report Date: 2012/02/07

CERTIFICATE OF ANALYSIS**MAXXAM JOB #: B213398****Received: 2012/01/28, 10:43**

Sample Matrix: PUF AND FILTER

Samples Received: 1

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
PAH's in Air (CARB429mod)	1	2012/01/31	2012/02/03	BRL SOP-00201	CARB429(ARBM1,M2)mod

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

THERESA STEPHENSON, Project Manager
Email: TStephenson@maxxam.ca
Phone# (905) 817-5763=====
Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Maxxam Analytics Inc. is a NELAC accredited laboratory. Certificate # CANA001. Use of the NELAC logo however does not insure that Maxxam is accredited for all of the methods indicated. This certificate shall not be reproduced except in full, without the written approval of Maxxam Analytics Inc. Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section.

Total cover pages: 1

Page 1 of 7

Maxxam Job #: B213398
 Report Date: 2012/02/07

SEMI-VOLATILE ORGANICS BY GC-MS (PUF AND FILTER)

Maxxam ID		MJ4700		
Sampling Date		2012/01/22		
		00:00		
COC Number		08702		
	Units	LICA	RDL	QC Batch
		PUFF+QFF/CLS/JAN22,12		

Semivolatile Organics				
1-Methylnaphthalene	ug	1.94	0.10	2750997
1-Methylphenanthrene	ug	<0.10	0.10	2750997
2-Chloronaphthalene	ug	<0.10	0.10	2750997
2-Methylanthracene	ug	<0.10	0.10	2750997
2-Methylnaphthalene	ug	3.82	0.10	2750997
3-Methylcholanthrene	ug	<2.0	2.0	2750997
7,12-Dimethylbenzo(a)anthracene	ug	<0.10	0.10	2750997
9,10-Dimethylanthracene	ug	<0.40	0.40	2750997
Acenaphthene	ug	0.224	0.050	2750997
Acenaphthylene	ug	1.09	0.050	2750997
Anthracene	ug	0.120	0.050	2750997
Benzo(a)anthracene	ug	<0.050	0.050	2750997
Benzo(a)fluorene	ug	<0.10	0.10	2750997
Benzo(a)pyrene	ug	<0.050	0.050	2750997
Benzo(b)fluoranthene	ug	0.138	0.050	2750997
Benzo(b)fluorene	ug	<0.10	0.10	2750997
Benzo(e)pyrene	ug	<0.10	0.10	2750997
Benzo(g,h,i)perylene	ug	0.056	0.050	2750997
Benzo(k)fluoranthene	ug	<0.050	0.050	2750997
Biphenyl	ug	1.08	0.10	2750997
Chrysene	ug	0.108	0.050	2750997
Coronene	ug	<0.10	0.10	2750997
Dibenz(a,h)anthracene	ug	<0.050	0.050	2750997
Dibenzo(a,e)pyrene	ug	<0.20	0.20	2750997
Fluoranthene	ug	0.414	0.050	2750997
Fluorene	ug	0.556	0.050	2750997
Indeno(1,2,3-cd)pyrene	ug	0.052	0.050	2750997
m-Terphenyl	ug	<0.10	0.10	2750997
Naphthalene	ug	3.06	0.072	2750997
o-Terphenyl	ug	<0.10	0.10	2750997
Perylene	ug	<0.10	0.10	2750997
RDL = Reportable Detection Limit QC Batch = Quality Control Batch				

Maxxam Job #: B213398
 Report Date: 2012/02/07

SEMI-VOLATILE ORGANICS BY GC-MS (PUF AND FILTER)

Maxxam ID		MJ4700		
Sampling Date		2012/01/22 00:00		
COC Number		08702		
	Units	LICA	RDL	QC Batch
		PUFF+QFF/CLS/JAN22,12		

Phenanthrene	ug	1.16	0.050	2750997
p-Terphenyl	ug	<0.10	0.10	2750997
Pyrene	ug	0.244	0.050	2750997
Quinoline	ug	<0.40	0.40	2750997
Tetralin	ug	<0.10	0.10	2750997
Surrogate Recovery (%)				
D10-2-Methylnaphthalene	%	68		2750997
D10-Fluoranthene	%	92		2750997
D10-Fluorene (FS)	%	61		2750997
D10-Phenanthrene	%	86		2750997
D12-Benzo(a)anthracene	%	98		2750997
D12-Benzo(a)pyrene	%	92		2750997
D12-Benzo(b)fluoranthene	%	92		2750997
D12-Benzo(ghi)perylene	%	90		2750997
D12-Benzo(k)fluoranthene	%	86		2750997
D12-Chrysene	%	86		2750997
D12-Indeno(1,2,3-cd)pyrene	%	90		2750997
D12-Perylene	%	88		2750997
D14-Dibenzo(a,h)anthracene	%	90		2750997
D14-Terphenyl (FS)	%	86		2750997
D8-Acenaphthylene	%	80		2750997
D8-Naphthalene	%	66		2750997
QC Batch = Quality Control Batch				

Maxxam Job #: B213398
Report Date: 2012/02/07

Test Summary

Maxxam ID MJ4700
Sample ID LICA PUFF+QFF/CLS/JAN22,12
Matrix PUF AND FILTER

Collected 2012/01/22
Shipped
Received 2012/01/28

Test Description	Instrumentation	Batch	Extracted	Analyzed	Analyst
PAH's in Air (CARB429mod)	GC/MS	2750997	2012/01/31	2012/02/03	WENDY ZHAO

Maxxam Job #: B213398
Report Date: 2012/02/07

GENERAL COMMENTS

PAHMS-F

9,10-Dimethylanthracene and 7,12-Dimethylbenzo(a)anthracene are above 25% RSD in initial calibration. No positives found for these 2 compounds.

Sample MJ4700-01: PAHMS-F

Not calibrated for Benzo(b)Anthracene, Picene, Dibenzo(a,c) anthracene or Triphenylene. An estimated mdl for each of these compounds is 0.1ug. Since Dibenzo(a,c) anthracene co-elutes with Dibenzo(a,h) anthracene it would have a value below the estimated mdl.

Since Triphenylene co-elutes with Chrysene, the maximum possible value for this compound would be 0.108ug, which is the value reported for Chrysene.

Benzo(b)Anthracene elutes after Benzo(a)Anthracene and Chrysene. Searched for ions specific to this compound in the appropriate retention time range with no possible positive detected.

Picene elutes after Dibenzo(a,h) anthracene. Searched for ions specific to this compounds in the appropriate retention time range, possible positive detected, but would fall below the mdl using Dibenzo(a,h) anthracene calibration.

Results relate only to the items tested.

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report
 Maxxam Job Number: GB213398

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2750997 WZ	Spiked Blank	D10-2-Methylnaphthalene	2012/02/02		82	%	50 - 150
		D10-Fluoranthene	2012/02/02		94	%	50 - 150
		D10-Phenanthrene	2012/02/02		92	%	50 - 150
		D12-Benzo(a)anthracene	2012/02/02		94	%	50 - 150
		D12-Benzo(a)pyrene	2012/02/02		90	%	50 - 150
		D12-Benzo(b)fluoranthene	2012/02/02		88	%	50 - 150
		D12-Benzo(ghi)perylene	2012/02/02		92	%	50 - 150
		D12-Benzo(k)fluoranthene	2012/02/02		90	%	50 - 150
		D12-Chrysene	2012/02/02		90	%	50 - 150
		D12-Indeno(1,2,3-cd)pyrene	2012/02/02		90	%	50 - 150
		D12-Perylene	2012/02/02		86	%	50 - 150
		D14-Dibenzo(a,h)anthracene	2012/02/02		90	%	50 - 150
		D8-Acenaphthylene	2012/02/02		88	%	50 - 150
		D8-Naphthalene	2012/02/02		82	%	50 - 150
		Acenaphthene	2012/02/02		81	%	60 - 130
	RPD	Acenaphthene	2012/02/02	1.9		%	50
	Spiked Blank	Acenaphthylene	2012/02/02		82	%	60 - 130
	RPD	Acenaphthylene	2012/02/02	3.4		%	50
	Spiked Blank	Anthracene	2012/02/02		81	%	60 - 130
	RPD	Anthracene	2012/02/02	4.1		%	50
	Spiked Blank	Benzo(a)anthracene	2012/02/02		80	%	60 - 130
	RPD	Benzo(a)anthracene	2012/02/02	1.3		%	50
	Spiked Blank	Benzo(a)pyrene	2012/02/02		69	%	60 - 130
	RPD	Benzo(a)pyrene	2012/02/02	2.6		%	50
	Spiked Blank	Benzo(b)fluoranthene	2012/02/02		79	%	60 - 130
	RPD	Benzo(b)fluoranthene	2012/02/02	1.9		%	50
	Spiked Blank	Benzo(g,h,i)perylene	2012/02/02		77	%	60 - 130
	RPD	Benzo(g,h,i)perylene	2012/02/02	0.3		%	50
	Spiked Blank	Benzo(k)fluoranthene	2012/02/02		85	%	60 - 130
	RPD	Benzo(k)fluoranthene	2012/02/02	0		%	50
	Spiked Blank	Chrysene	2012/02/02		81	%	60 - 130
	RPD	Chrysene	2012/02/02	1.2		%	50
	Spiked Blank	Dibenz(a,h)anthracene	2012/02/02		76	%	60 - 130
	RPD	Dibenz(a,h)anthracene	2012/02/02	1		%	50
	Spiked Blank	Fluoranthene	2012/02/02		87	%	60 - 130
	RPD	Fluoranthene	2012/02/02	2.9		%	50
	Spiked Blank	Fluorene	2012/02/02		81	%	60 - 130
	RPD	Fluorene	2012/02/02	2.8		%	50
	Spiked Blank	Indeno(1,2,3-cd)pyrene	2012/02/02		79	%	60 - 130
	RPD	Indeno(1,2,3-cd)pyrene	2012/02/02	1.3		%	50
	Spiked Blank	Naphthalene	2012/02/02		74	%	60 - 130
	RPD	Naphthalene	2012/02/02	2.0		%	50
	Spiked Blank	Phenanthrene	2012/02/02		82	%	60 - 130
	RPD	Phenanthrene	2012/02/02	1.8		%	50
	Spiked Blank	Pyrene	2012/02/02		86	%	60 - 130
	RPD	Pyrene	2012/02/02	2.1		%	50
	Method Blank	D10-2-Methylnaphthalene	2012/02/02		82	%	50 - 150
		D10-Fluoranthene	2012/02/02		96	%	50 - 150
		D10-Phenanthrene	2012/02/02		92	%	50 - 150
		D12-Benzo(a)anthracene	2012/02/02		94	%	50 - 150
		D12-Benzo(a)pyrene	2012/02/02		92	%	50 - 150
		D12-Benzo(b)fluoranthene	2012/02/02		90	%	50 - 150
		D12-Benzo(ghi)perylene	2012/02/02		90	%	50 - 150
		D12-Benzo(k)fluoranthene	2012/02/02		86	%	50 - 150
		D12-Chrysene	2012/02/02		86	%	50 - 150

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report (Continued)

Maxxam Job Number: GB213398

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2750997 WZ	Method Blank	D12-Indeno(1,2,3-cd)pyrene	2012/02/02		90	%	50 - 150
		D12-Perylene	2012/02/02		88	%	50 - 150
		D14-Dibenzo(a,h)anthracene	2012/02/02		90	%	50 - 150
		D8-Acenaphthylene	2012/02/02		88	%	50 - 150
		D8-Naphthalene	2012/02/02		80	%	50 - 150
		1-Methylnaphthalene	2012/02/02	<0.10		ug	
		1-Methylphenanthrene	2012/02/02	<0.10		ug	
		2-Chloronaphthalene	2012/02/02	<0.10		ug	
		2-Methylantracene	2012/02/02	<0.10		ug	
		2-Methylnaphthalene	2012/02/02	<0.10		ug	
		3-Methylcholanthrene	2012/02/02	<2.0		ug	
		7,12-Dimethylbenzo(a)anthracene	2012/02/02	<0.10		ug	
		9,10-Dimethylantracene	2012/02/02	<0.40		ug	
		Acenaphthene	2012/02/02	<0.050		ug	
		Acenaphthylene	2012/02/02	<0.050		ug	
		Anthracene	2012/02/02	<0.050		ug	
		Benzo(a)anthracene	2012/02/02	<0.050		ug	
		Benzo(a)fluorene	2012/02/02	<0.10		ug	
		Benzo(a)pyrene	2012/02/02	<0.050		ug	
		Benzo(b)fluoranthene	2012/02/02	<0.050		ug	
		Benzo(b)fluorene	2012/02/02	<0.10		ug	
		Benzo(e)pyrene	2012/02/02	<0.10		ug	
		Benzo(g,h,i)perylene	2012/02/02	<0.050		ug	
		Benzo(k)fluoranthene	2012/02/02	<0.050		ug	
		Biphenyl	2012/02/02	<0.10		ug	
		Chrysene	2012/02/02	<0.050		ug	
		Coronene	2012/02/02	<0.10		ug	
		Dibenz(a,h)anthracene	2012/02/02	<0.050		ug	
		Dibenzo(a,e)pyrene	2012/02/02	<0.20		ug	
		Fluoranthene	2012/02/02	<0.050		ug	
		Fluorene	2012/02/02	<0.050		ug	
		Indeno(1,2,3-cd)pyrene	2012/02/02	<0.050		ug	
		m-Terphenyl	2012/02/02	<0.10		ug	
		Naphthalene	2012/02/02	<0.072		ug	
		o-Terphenyl	2012/02/02	<0.10		ug	
		Perylene	2012/02/02	<0.10		ug	
		Phenanthrene	2012/02/02	<0.050		ug	
		p-Terphenyl	2012/02/02	<0.10		ug	
		Pyrene	2012/02/02	<0.050		ug	
		Quinoline	2012/02/02	<0.40		ug	
		Tetralin	2012/02/02	<0.10		ug	

Duplicate: Paired analysis of a separate portion of the same sample. Used to evaluate the variance in the measurement.
 Spiked Blank: A blank matrix to which a known amount of the analyte has been added. Used to evaluate analyte recovery.
 Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.
 Surrogate: A pure or isotopically labeled compound whose behavior mirrors the analytes of interest. Used to evaluate extraction efficiency.

MAXXAM

Tisch Hi-Vol PUF+ Sample Collection Data Sheet

Client: Lica
 Location: Cold Lake South
 Station ID: Lica1
 Field Sample ID: LICA PUF/CLS/Jan 28, 2012

Puf+ s/n: 100-1020
 Motor s/n: 1138
 Installation Date/Time: Jan 25, 2012 @ 15:45 mst
 Removal Date/Time: Feb 1, 2012 @ 15:15 mst

Date and Time Information			
Sample Date	Start Time (MST)	Finish Time (MST)	Elapsed Time (Hours)
28-Jan-12	01/28/2012 0:00	01/29/2012 0:00	24.000

PUF and QFF Information			
Date Received	Date Shipped	Puf Expiration Date	QFF Prep Date
25-Jan-12	01-Feb-12	06-Feb-12	????

Set Flow Rate (slpm): 230

Date of Last Calibration: 22-Sep-11

Sampling Data			
Average Pressure(mmHg)	AverageFlow (Qstd slpm)	Average Temperature (C)	Volume (Vstd m ³)
715	229	-8.8	330.36

Time set correctly prior to sampling? YES
Timer set correctly prior to sampling? YES
Sampling data saved to memory card after sampling? YES

Comments: COC# 08763

GB1K1656 PUFF # 1

Ran with a 102mm Quartz Fiber Filter - Sample ID - LICA QFF/CLS/Jan 28, 2012

Technician Signiture: Theo McLaren

Your C.O.C. #: 08763

Attention: Michael BisagaMaxxam Analytics
2608 6A Ave.
Cold Lake, AB
CANADA T9M 2C7

Report Date: 2012/02/10

CERTIFICATE OF ANALYSIS**MAXXAM JOB #: B216831****Received: 2012/02/04, 09:35**

Sample Matrix: PUF AND FILTER

Samples Received: 1

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Method Reference
PAH's in Air (CARB429mod)	1	2012/02/07	2012/02/09	BRL SOP-00201	CARB429(ARBM1,M2)mod

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

THERESA STEPHENSON, Project Manager
Email: TStephenson@maxxam.ca
Phone# (905) 817-5763

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section 5.10.2 of ISO/IEC 17025:2005(E), signing the reports. For Service Group specific validation please refer to the Validation Signature Page.

Maxxam Analytics Inc. is a NELAC accredited laboratory. Certificate # CANA001. Use of the NELAC logo however does not insure that Maxxam is accredited for all of the methods indicated. This certificate shall not be reproduced except in full, without the written approval of Maxxam Analytics Inc. Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section.

Total cover pages: 1

Page 1 of 7

Maxxam Job #: B216831
 Report Date: 2012/02/10

SEMI-VOLATILE ORGANICS BY GC-MS (PUF AND FILTER)

Maxxam ID		ML1119		
Sampling Date		2012/01/28		
COC Number		08763		
	Units	LICA PUFF+QFF/CLS/JAN 28,12	RDL	QC Batch

Semivolatile Organics				
1-Methylnaphthalene	ug	1.12	0.10	2757532
1-Methylphenanthrene	ug	<0.10	0.10	2757532
2-Chloronaphthalene	ug	<0.10	0.10	2757532
2-Methylantracene	ug	<0.10	0.10	2757532
2-Methylnaphthalene	ug	2.24	0.10	2757532
3-Methylcholanthrene	ug	<2.0	2.0	2757532
7,12-Dimethylbenzo(a)anthracene	ug	<0.10	0.10	2757532
9,10-Dimethylantracene	ug	<0.40	0.40	2757532
Acenaphthene	ug	0.104	0.050	2757532
Acenaphthylene	ug	0.212	0.050	2757532
Anthracene	ug	<0.050	0.050	2757532
Benzo(a)anthracene	ug	<0.050	0.050	2757532
Benzo(a)fluorene	ug	<0.10	0.10	2757532
Benzo(a)pyrene	ug	<0.050	0.050	2757532
Benzo(b)fluoranthene	ug	<0.050	0.050	2757532
Benzo(b)fluorene	ug	<0.10	0.10	2757532
Benzo(e)pyrene	ug	<0.10	0.10	2757532
Benzo(g,h,i)perylene	ug	<0.050	0.050	2757532
Benzo(k)fluoranthene	ug	<0.050	0.050	2757532
Biphenyl	ug	0.50	0.10	2757532
Chrysene	ug	<0.050	0.050	2757532
Coronene	ug	<0.10	0.10	2757532
Dibenz(a,h)anthracene	ug	<0.050	0.050	2757532
Dibenzo(a,e)pyrene	ug	<0.20	0.20	2757532
Fluoranthene	ug	0.120	0.050	2757532
Fluorene	ug	0.234	0.050	2757532
Indeno(1,2,3-cd)pyrene	ug	<0.050	0.050	2757532
m-Terphenyl	ug	<0.10	0.10	2757532
Naphthalene	ug	1.36	0.072	2757532
o-Terphenyl	ug	<0.10	0.10	2757532
Perylene	ug	<0.10	0.10	2757532

 RDL = Reportable Detection Limit
 QC Batch = Quality Control Batch

Maxxam Job #: B216831
 Report Date: 2012/02/10

SEMI-VOLATILE ORGANICS BY GC-MS (PUF AND FILTER)

Maxxam ID		ML1119		
Sampling Date		2012/01/28		
COC Number		08763		
	Units	LICA PUFF+QFF/CLS/JAN 28,12	RDL	QC Batch

Phenanthrene	ug	0.466	0.050	2757532
p-Terphenyl	ug	<0.10	0.10	2757532
Pyrene	ug	0.084	0.050	2757532
Quinoline	ug	<0.40	0.40	2757532
Tetralin	ug	<0.10	0.10	2757532
Surrogate Recovery (%)				
D10-2-Methylnaphthalene	%	74		2757532
D10-Fluoranthene	%	96		2757532
D10-Fluorene (FS)	%	52		2757532
D10-Phenanthrene	%	90		2757532
D12-Benzo(a)anthracene	%	92		2757532
D12-Benzo(a)pyrene	%	92		2757532
D12-Benzo(b)fluoranthene	%	88		2757532
D12-Benzo(ghi)perylene	%	96		2757532
D12-Benzo(k)fluoranthene	%	82		2757532
D12-Chrysene	%	82		2757532
D12-Indeno(1,2,3-cd)pyrene	%	94		2757532
D12-Perylene	%	88		2757532
D14-Dibenzo(a,h)anthracene	%	94		2757532
D14-Terphenyl (FS)	%	93		2757532
D8-Acenaphthylene	%	86		2757532
D8-Naphthalene	%	70		2757532
QC Batch = Quality Control Batch				

Maxxam Job #: B216831
Report Date: 2012/02/10

Test Summary

Maxxam ID ML1119
Sample ID LICA PUFF+QFF/CLS/JAN 28,12
Matrix PUF AND FILTER

Collected 2012/01/28
Shipped
Received 2012/02/04

Test Description	Instrumentation	Batch	Extracted	Analyzed	Analyst
PAH's in Air (CARB429mod)	GC/MS	2757532	2012/02/07	2012/02/09	JIE WU

Maxxam Job #: B216831
Report Date: 2012/02/10

GENERAL COMMENTS

PAHMS-F

9,10-Dimethylanthracene and 7,12-dimethylbenzo(a)anthracene are above 25% RSD in initial calibration. No positives found for these 2 compounds.

7,12-dimethylbenzo(a)anthracene is above 25% RSD in continuing calibration.

Samples were extracted past holdtime.

Not calibrated for benzo(b)anthracene, picene, dibenzo(a,c)anthracene and triphenylene. An estimated mdl for each of these compounds is 0.1ug.

Since dibenzo(a,c)anthracene co-elutes with dibenz(a,h)anthracene and triphenylene with chrysene each would have a value below estimated mdl.

Benzo(b)anthracene elutes after benzo(a)anthracene and chrysene. Picene elutes after dibenz(a,h)anthracene. Searched for ions specific to these 2 compounds in the appropriate retention time range with no possible positives detected.

Sample ML1119-01: D12-benzo(e)pyrene internal standard area response criteria was high in sample. The vial was rerun with similar result. Original run reported.

Results relate only to the items tested.

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report
 Maxxam Job Number: GB216831

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2757532 JIW	Spiked Blank	D10-2-Methylnaphthalene	2012/02/09		80	%	50 - 150
		D10-Fluoranthene	2012/02/09		94	%	50 - 150
		D10-Phenanthrene	2012/02/09		90	%	50 - 150
		D12-Benzo(a)anthracene	2012/02/09		92	%	50 - 150
		D12-Benzo(a)pyrene	2012/02/09		94	%	50 - 150
		D12-Benzo(b)fluoranthene	2012/02/09		90	%	50 - 150
		D12-Benzo(ghi)perylene	2012/02/09		94	%	50 - 150
		D12-Benzo(k)fluoranthene	2012/02/09		88	%	50 - 150
		D12-Chrysene	2012/02/09		88	%	50 - 150
		D12-Indeno(1,2,3-cd)pyrene	2012/02/09		92	%	50 - 150
		D12-Perylene	2012/02/09		90	%	50 - 150
		D14-Dibenzo(a,h)anthracene	2012/02/09		90	%	50 - 150
		D8-Acenaphthylene	2012/02/09		88	%	50 - 150
		D8-Naphthalene	2012/02/09		78	%	50 - 150
		Acenaphthene	2012/02/09		78	%	60 - 130
	RPD	Acenaphthene	2012/02/09	0.6		%	50
	Spiked Blank	Acenaphthylene	2012/02/09		83	%	60 - 130
	RPD	Acenaphthylene	2012/02/09	3.1		%	50
	Spiked Blank	Anthracene	2012/02/09		76	%	60 - 130
	RPD	Anthracene	2012/02/09	0.3		%	50
	Spiked Blank	Benzo(a)anthracene	2012/02/09		78	%	60 - 130
	RPD	Benzo(a)anthracene	2012/02/09	0		%	50
	Spiked Blank	Benzo(a)pyrene	2012/02/09		69	%	60 - 130
	RPD	Benzo(a)pyrene	2012/02/09	0.7		%	50
	Spiked Blank	Benzo(b)fluoranthene	2012/02/09		77	%	60 - 130
	RPD	Benzo(b)fluoranthene	2012/02/09	0		%	50
	Spiked Blank	Benzo(g,h,i)perylene	2012/02/09		80	%	60 - 130
	RPD	Benzo(g,h,i)perylene	2012/02/09	0.9		%	50
	Spiked Blank	Benzo(k)fluoranthene	2012/02/09		84	%	60 - 130
	RPD	Benzo(k)fluoranthene	2012/02/09	0		%	50
	Spiked Blank	Chrysene	2012/02/09		80	%	60 - 130
	RPD	Chrysene	2012/02/09	1.6		%	50
	Spiked Blank	Dibenz(a,h)anthracene	2012/02/09		79	%	60 - 130
	RPD	Dibenz(a,h)anthracene	2012/02/09	0.3		%	50
	Spiked Blank	Fluoranthene	2012/02/09		85	%	60 - 130
	RPD	Fluoranthene	2012/02/09	0.9		%	50
	Spiked Blank	Fluorene	2012/02/09		77	%	60 - 130
	RPD	Fluorene	2012/02/09	1.3		%	50
	Spiked Blank	Indeno(1,2,3-cd)pyrene	2012/02/09		80	%	60 - 130
	RPD	Indeno(1,2,3-cd)pyrene	2012/02/09	1.9		%	50
Spiked Blank	Naphthalene	2012/02/09		74	%	60 - 130	
RPD	Naphthalene	2012/02/09	3.8		%	50	
Spiked Blank	Phenanthrene	2012/02/09		79	%	60 - 130	
RPD	Phenanthrene	2012/02/09	0.6		%	50	
Spiked Blank	Pyrene	2012/02/09		84	%	60 - 130	
RPD	Pyrene	2012/02/09	0.9		%	50	
Method Blank	D10-2-Methylnaphthalene	2012/02/09		82	%	50 - 150	
	D10-Fluoranthene	2012/02/09		88	%	50 - 150	
	D10-Phenanthrene	2012/02/09		86	%	50 - 150	
	D12-Benzo(a)anthracene	2012/02/09		94	%	50 - 150	
	D12-Benzo(a)pyrene	2012/02/09		90	%	50 - 150	
	D12-Benzo(b)fluoranthene	2012/02/09		88	%	50 - 150	
	D12-Benzo(ghi)perylene	2012/02/09		92	%	50 - 150	
	D12-Benzo(k)fluoranthene	2012/02/09		84	%	50 - 150	
	D12-Chrysene	2012/02/09		88	%	50 - 150	

Maxxam Analytics
 Attention: Michael Bisaga
 Client Project #:
 P.O. #:
 Site Location:

Quality Assurance Report (Continued)

Maxxam Job Number: GB216831

QA/QC Batch	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	%Recovery	Units	QC Limits
2757532 JIW	Method Blank	D12-Indeno(1,2,3-cd)pyrene	2012/02/09		88	%	50 - 150
		D12-Perylene	2012/02/09		90	%	50 - 150
		D14-Dibenzo(a,h)anthracene	2012/02/09		88	%	50 - 150
		D8-Acenaphthylene	2012/02/09		90	%	50 - 150
		D8-Naphthalene	2012/02/09		80	%	50 - 150
		1-Methylnaphthalene	2012/02/09	<0.10		ug	
		1-Methylphenanthrene	2012/02/09	<0.10		ug	
		2-Chloronaphthalene	2012/02/09	<0.10		ug	
		2-Methylanthracene	2012/02/09	<0.10		ug	
		2-Methylnaphthalene	2012/02/09	<0.10		ug	
		3-Methylcholanthrene	2012/02/09	<2.0		ug	
		7,12-Dimethylbenzo(a)anthracene	2012/02/09	<0.10		ug	
		9,10-Dimethylanthracene	2012/02/09	<0.40		ug	
		Acenaphthene	2012/02/09	<0.050		ug	
		Acenaphthylene	2012/02/09	<0.050		ug	
		Anthracene	2012/02/09	<0.050		ug	
		Benzo(a)anthracene	2012/02/09	<0.050		ug	
		Benzo(a)fluorene	2012/02/09	<0.10		ug	
		Benzo(a)pyrene	2012/02/09	<0.050		ug	
		Benzo(b)fluoranthene	2012/02/09	<0.050		ug	
		Benzo(b)fluorene	2012/02/09	<0.10		ug	
		Benzo(e)pyrene	2012/02/09	<0.10		ug	
		Benzo(g,h,i)perylene	2012/02/09	<0.050		ug	
		Benzo(k)fluoranthene	2012/02/09	<0.050		ug	
		Biphenyl	2012/02/09	<0.10		ug	
		Chrysene	2012/02/09	<0.050		ug	
		Coronene	2012/02/09	<0.10		ug	
		Dibenz(a,h)anthracene	2012/02/09	<0.050		ug	
		Dibenzo(a,e)pyrene	2012/02/09	<0.20		ug	
		Fluoranthene	2012/02/09	<0.050		ug	
		Fluorene	2012/02/09	<0.050		ug	
		Indeno(1,2,3-cd)pyrene	2012/02/09	<0.050		ug	
		m-Terphenyl	2012/02/09	<0.10		ug	
		Naphthalene	2012/02/09	<0.072		ug	
		o-Terphenyl	2012/02/09	<0.10		ug	
		Perylene	2012/02/09	<0.10		ug	
		Phenanthrene	2012/02/09	<0.050		ug	
		p-Terphenyl	2012/02/09	<0.10		ug	
		Pyrene	2012/02/09	<0.050		ug	
		Quinoline	2012/02/09	<0.40		ug	
		Tetralin	2012/02/09	<0.10		ug	

Duplicate: Paired analysis of a separate portion of the same sample. Used to evaluate the variance in the measurement.
 Spiked Blank: A blank matrix to which a known amount of the analyte has been added. Used to evaluate analyte recovery.
 Method Blank: A blank matrix containing all reagents used in the analytical procedure. Used to identify laboratory contamination.
 Surrogate: A pure or isotopically labeled compound whose behavior mirrors the analytes of interest. Used to evaluate extraction efficiency.