

July 4, 2007

Lakeland Industry & Community Association

Box8237
5006-50 Avenue
Bonnyville, Alberta
T9N 2J5

ATTENTION: Mr. Mike Bisaga

REFERENCE: Ambient Air Monitoring Report For May 2007

Maxxam Analytics Inc. is pleased to submit this report of data collected at the Ambient Air Monitoring Station located at the Lakeland Industry & Community Assoc. Cold Lake site for the month of May 2007.

Included is a summary of the monthly continuous and hourly average reports, equipment calibration reports, as well as a brief description of the calibration procedure. The passive network data are also included in this report.

During the month of May 2007 the following proceedings were noted:

Cold Lake South Site

- All analyzers and wind systems were all above 90% uptime objective with the exception of the NO_x, NO, NO₂ parameters were at 87.1% uptime for the month.
- All data was within Provincial objectives for the month.
- All data was corrected using daily zero calibration data. Furthermore the PM 2.5 data was corrected using Alberta Environment correction standards.
- After the power failure on May 5th the analyzer did not automatically re-light, a technician was sent out to re-light the analyzer, thus one hour of data was invalidated. It was agreed to with the LICA Program Manager to invalidate all data after zero correction, which falls below the historical background average of 1.5 ppm. As a result 0 hours of data was invalidated.
- The PM 2.5 was unstable for 1 hour during the month the data was subsequently invalidated.
- There were two power failures during the month; each power failure was for one-hour in duration. The power failures occurred on May 5th and 11th. The data was subsequently invalidated during these periods.
- The NO_x analyzer was found to have a break in the exhaust line on May 14th, which caused daily spans to decline. The problem was repaired on site and the analyzer re-calibrated. As a result of this situation the data was invalidated back to the last valid span, which occurred on May 11th. On May 15th the technician was sent out to the trailer as the daily spans declined overnight, the investigation revealed that the pump for the analyzer required new diaphragms, this problem was repaired onsite. As a result of this situation the data was invalidated back to the last valid span. As the data was invalidated during

the time of a power failure the analyzer only experienced one hour of power failures on May 5th.

- The PM 2.5 flows were within specifications but the measured flows were drifting away from the indicated values. The flows were adjusted such that measured flows and indicated flows were reading similar.
- The Ozone analyzer in the early hours of May 6th detected an hourly average alarm. The technician investigated the situation and with the analysis of one-minute data the situation was determined to be characteristic of a power failure rather than that of a reading. The data was flagged appropriately and invalidated. Also during the month there were high maximum one-minute readings on three occasions. These readings were investigated and again were determined to be characteristic of a power spike and not an actual reading. The data was not invalidated but is noted here in the report.

Passive Network

A summary of the passive monitoring are reported as follows:

- Monitoring period averages for O₃ ranged from 26.8 – 37.3 ppb.
- Monitoring period averages for SO₂ ranged from 0.1 – 0.8 ppb.
- Monitoring period averages for NO₂ ranged from 0.1 – 3.4 ppb.
- Monitoring period averages for H₂S ranged from 0.03 – 0.14 ppb.
- Site #10 shelter was replaced.

Please feel free to contact either of Craig Snider at (403) 219-3689 or Darren Morissette (403)-219-3661, should you have any questions concerning this report.

Sincerely,

Maxxam Analytics Inc.

Prepared by:



Darren Morissette, CEPIT
Senior Technologist

Reviewed by:



Craig Snider, CET
Ambient Manager

Lakeland Industry & Community Association
Cold Lake Monitoring Site
Ambient Air Monitoring
Data Report
For
May 2007

Prepared By:

MAXXAM ANALYTICS INC.

Lakeland Industry & Community Assoc.

COLD LAKE

AMBIENT AIR MONITORING STATION

TABLE OF CONTENTS

CALIBRATION PROCEDURE	3
MONTHLY CONTINUOUS SUMMARY – COLD LAKE	4
PASSIVE NETWORK DATA SUMMARY	5
GENERAL MONTHLY SUMMARY- COLD LAKE	6
MONTHLY GRAPHS, SUMMARIES AND WIND ROSES	8
COLD LAKE SOUTH	
AIR QUALITY INDEX MONTHLY SUMMARY	10
SULPHUR DIOXIDE MONTHLY SUMMARY	12
TOTAL REDUCED SULPHUR MONTHLY SUMMARY	20
TOTAL HYDROCARBONS MONTHLY SUMMARY	28
PARTICULATE MATTER 2.5 MONTHLY SUMMARY	36
NITROGEN DIOXIDE MONTHLY SUMMARY	43
NITRIC OXIDE MONTHLY SUMMARY	51
OXIDES OF NITROGEN MONTHLY SUMMARY	58
OZONE MONTHLY SUMMARY	66
VECTOR WIND SPEED MONTHLY SUMMARY	74
VECTOR WIND DIRECTION MONTHLY SUMMARY	81
TEMPURATURE MONTHLY SUMMARY	86
RELATIVE HUMIDITY MONTHLY SUMMARY	89
MAY 2007 CALIBRATION REPORTS	92
COLD LAKE SOUTH	
SULPHUR DIOXIDE	93
TOTAL REDUCED SULPHUR	97
TOTAL HYDROCARBONS	101
PARTICULATE MATTER 2.5	105
NITROGEN DIOXIDE	107
OZONE	
123	
MAY 2007 PASSIVE BUBBLE MAPS	127
MAY 2007 PASSIVE AMBIENT AIR MONITORING ANALYSIS	132
MAY 2007 PASSIVE FIELD DATA	138

CALIBRATION PROCEDURE

The following calibration procedure applies to all calibrations conducted at the Lakeland Industry & Community Association Air Monitoring Station.

Calibration gas concentrations are generated using a dynamic mass flow controlled calibrator. EPA Protocol one gases are diluted with zero air generated on site. The Mass Flow Controllers in the calibrator are referenced using an NIST traceable flow meter once per month. All listed flows are reported as corrected to Standard Temperature and Pressure (STP).

Generated zero gas is introduced to the analyzer first. Three concentrations of calibration gas are then generated in order to introduce points at approximately 50-80%, 25-40% & 10-20% of the analyzer's full-scale range. An auto zero and span are then performed to validate the daily zero and span values recorded to the next multi-point calibration.

All indicated concentrations are taken from the ESC data logger used to collect the data for monthly reporting.

Conformance of each calibration to Alberta Environment regulations is outlined in the individual calibration reports. The slope and correlation coefficient are derived from the calculated and indicated analyzer responses. The percent change is calculated using the previous calibration correction factor and the current correction factor before adjustment. The calibration conforms to the procedure outlined in the *Air Monitoring Directive, Appendix A-10, Section 1.6*.

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION

MONTHLY CONTINUOUS DATA SUMMARY

COLD LAKE

Continuous Ambient Monitoring – May 2007

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION COLD LAKE SITE					MAXIMUM VALUES					OPERATIONAL TIME (PERCENT)	
					1-HOUR				24-HOUR		
PARAMETER	OBJECTIVES		EXCEEDENCES		MONTHLY AVERAGE	READING	DAY	HOUR	READING	DAY	
	1-HR	24-HR	1-HR	24-HR							
SO ₂ (PPB)	172	57	0	0	0.01	1	14,17,2 3	VARIOUS	0.1	14,17,23	99.7
TRS (PPB)	-	-	-	-	0.01	1	17,27,2 8	VARIOUS	0.1	17,27	99.7
NO ₂ (PPB)	212	106	0	0	1.65	36	17	8	4	17	87.1
NO (PPB)	-	-	-	-	0.33	37	28	10	2.3	15	87.1
NOx (PPB)	-	-	-	-	2.17	51	17,28	8,10	5.2	17	87.1
O ₃ (PPB)	82	-	0	-	32.39	60	16	17,18	49.8	16	99.6
THC (PPM)	-	-	-	-	1.82	3.4	23	4	2.1	22	99.7
PM 2.5 (UG/M ³)	-	30	-	0	3.40	20.6	17	8	9.2	17	99.6
TEMPERATURE (DEG C)	-	-	-	-	10.62	24.7	16	17	17.5	16	99.7
RELATIVE HUMIDITY (%)	-	-	-	-	62.21	98.3	2	23	88.1	28	99.7
VECTOR WS (KPH)	-	-	-	-	6.9	25.2	5	11	13.6	5	99.7
VECTOR WD (DEGREES)	-	-	-	-	ENE	-	-	-	-	-	99.7

**LAKELAND INDUSTRY & COMMUNITY ASSOCIATION
Passive Ambient Monitoring Network – May 2007**

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION PASSIVE NETWORK			
NETWORK MAXIMUM (PPB)		NETWORK AVERAGE (PPB)	
PARAMETER	STATION	READING	READING
NO ₂	25	3.4	1.1
SO ₂	13,24	0.8	0.3
H ₂ S	16,24	0.14	0.09
O ₃	7	37.3	31.6

GENERAL MONTHLY SUMMARY – COLD LAKE

Equipment Operation

The following summary outlines the analyzer performance. Any non-conformances, problems or maintenance performed are detailed at the end of each section.

AQM STATION – LICA – COLD LAKE

SO2

- Analyzer make / model TECO 43A

No operational issues during the month. The inlet filter was changed before the monthly calibration was started. Data was corrected using daily zero information. There were two hours of power failures during the month; the data was subsequently invalidated.

TRS

- Analyzer make / model TECO 43A
CD NOVA CDN 101 H₂S Converter

No operational issues during the month. The inlet filter was changed before the monthly calibration was started. Data was corrected using daily zero information. There were two hours of power failures during the month; the data was subsequently invalidated.

THC

- Analyzer make / model TECO 51C-LT

No operational issues during the month. The inlet filter was changed before the monthly calibration was started. Data was corrected using daily zero information. It was agreed to with the LICA Program Manager to invalidate all data, after zero correction, which falls below the historical background average of 1.5 ppm. As a result 0 hours of data was invalidated and the uptime was at 99.7%. It is noted that since the detector was rebuilt, no data has fallen below the historical background average. There were two hours of power failures during the month; the data was subsequently invalidated. During one of the power failures the analyzer did not re-light and therefore the data for one-hour was invalidated. Testing of alarms was completed during the month, a portion of data was temporarily flagged, the data and database have since had the flags removed.

NOx

- Analyzer make / model

TECO 42

On May 12th the daily spans began to drop off, the situation was monitored. The technician investigated the decline in spans on May 14th. The analyzer was found to have a cut in the exhaust line. The problem was fixed but the pump vacuum was still low, the technician rebuilt the pump and re-calibrated the analyzer. As a result data was invalidated back to the last valid span, which was May 11th. On May 15th the technician responded to a low daily span, an investigation revealed the pump that was rebuilt the night before, required diaphragms to be rebuilt also, the parts were ordered and the pump was replaced temporarily with a Maxxam owned pump and the analyzer was re-calibrated. As a result data was invalidated back to the last valid span, and in this case was May 11th. The parameters for this analyzer were below the 90% uptime target for the month. The inlet filter was changed before the monthly calibration was started. Data was corrected using daily zero information. There was one hour of power failures during the month; the data was subsequently invalidated.

O₃

- Analyzer make / model

TECO 49

In the early hours of May 6th an hourly average alarm was detected. An investigation by the technician found the analyzer to be operating properly and no alarms with the analyzer. Further examination of the minute data showed that the data was characteristic of a power spike and not that of a reading, the data for one-hour was invalidated. During the month it is noted that 3 high Ozone Maximums were recorded. The readings were checked out and determined to be associated with a power spike, the three hours of data was not invalidated but is noted here within the report. The inlet filter was changed before the monthly calibration was started. Data was corrected using daily zero information. There were two hours of power failures during the month; the data was subsequently invalidated.

PM 2.5

- Analyzer make / model

TEOM 1400A

No operational issues observed during the month. During the monthly audit of the equipment the technician adjusted the flows in order that the measured flows and indicated flows were similar. Also the Bypass inline filter was changed as well as the two inline filters for the MFC. The sample inlet was checked and cleaned. Data for the month was corrected using Alberta Environment standards. There were two hours of power failures and one hour of instability during the month; the data was subsequently invalidated.

Wind Speed & Direction

- System make / model

MET ONE 50.5

No operational issues observed during the month. The wind system is reported as vector wind speed and vector wind direction. There were two hours of power failures during the month; the data was subsequently invalidated.

- System make / model Rotronic Hygroclip-S3
- No operational issues observed during the month. There were two hours of power failures during the month; the data was subsequently invalidated.

Temperature

- System make / model Rotronic Hygroclip-S3
- No operational issues observed during the month. There were two hours of power failures during the month; the data was subsequently invalidated.

Datalogger

- System make / model ESC 8832
 - Software make / version ESC v 5.51a
- The ESC 8832 is connected to a modem with DSL for continuous connection with the base computer.

Air Quality Index (AQI)

The AQI data was adjusted to reflect regular monthly calibrations, maintenance, downtime and daily calibrations. Due to the downtime of the NO_x analyzer the AQI was affected during the period May 11th – 15th.

Trailer

General comments from technician during monthly calibration:

- Sample manifold cleaned during regular visit.

Passive Network

- Site #10 shelter was replaced.

LICA - COLD LAKE SITE

MONTHLY SUMMARIES,

GRAPHS

&

WIND ROSES

AIR QUALITY INDEX

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

MAY 2007

AIR QUALITY INDEX (AQI)

HOUR START HOUR END	0:00 1:00	1:00 2:00	2:00 3:00	3:00 4:00	4:00 5:00	5:00 6:00	6:00 7:00	7:00 8:00	8:00 9:00	9:00 10:00	10:00 11:00	11:00 12:00	12:00 13:00	13:00 14:00	14:00 15:00	15:00 16:00	16:00 17:00	17:00 18:00	18:00 19:00	19:00 20:00	20:00 21:00	21:00 22:00	22:00 23:00	23:00 0:00	DAILY MAX.
DAY																									
1	8 O3	6 O3	8 O3	8 O3	8 O3	8 O3	8 O3	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	
2	23 O3	22 O3	20 O3	20 O3	21 O3	20 O3	19 O3	19 O3	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	
3	15 O3	14 O3	13 O3	12 O3	NA -	11 O3	11 O3	10 O3	10 O3	12 O3	16 O3	16 O3	17 O3	17 O3	16 O3	NA -	NA -								
4	12 O3	12 O3	12 O3	11 O3	10 O3	10 O3	11 O3	12 O3	14 O3	16 O3	16 O3	17 O3	17 O3	17 O3	NA -										
5	19 O3	19 O3	19 O3	19 O3	19 O3	18 O3	17 O3	18 O3	19 O3	20 O3	20 O3	NA -													
6	21 O3	NA -	13 O3	8 O3	7 O3	5 O3	11 O3	19 O3	22 O3	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -		
7	22 O3	25 O3	23 O3	24 O3	23 O3	23 O3	24 O3	24 O3	24 O3	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -		
8	8 O3	7 O3	9 O3	10 O3	11 O3	11 O3	11 O3	13 O3	18 O3	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -		
9	17 O3	16 O3	15 O3	14 O3	16 O3	17 O3	17 O3	16 O3	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -		
10	9 O3	5 O3	3 O3	2 O3	3 O3	7 O3	6 O3	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -		
11	18 O3	18 O3	17 O3	16 O3	14 O3	13 O3	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -		
12	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -											
13	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -											
14	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -											
15	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -											
16	21 O3	20 O3	20 O3	20 O3	20 O3	20 O3	21 O3	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -	NA -		
17	19 O3	14 O3	11 O3	10 O3	13 O3	NA -	17 O3	20 O3	23 O3	27 O3	27 O3	26 O3	26 O3	28 O3	27 O3	27 O3	28 O3	27 O3	27 O3	26 O3	27 O3	22 O3	15 O3	13 O3	
18	13 O3	12 O3	13 O3	14 O3	14 O3	13 O3	13 O3	13 O3	14 O3	14 O3	14 O3	13 O3	12 O3	11 O3	10 O3	10 O3	10 O3	10 O3	10 O3	11 O3	12 O3	11 O3	11 O3	14 O3	
19	11 O3	13 O3	12 O3	14 O3	NA -	17 O3	15 O3	15 O3	15 O3	16 O3	16 O3	16 O3	15 O3	15 O3	14 O3	15 O3	15 O3	16 O3	15 O3	16 O3	13 O3	12 O3	11 O3	17 O3	
20	11 O3	10 O3	9 O3	NA -	8 O3	9 O3	9 O3	9 O3	8 O3	8 O3	8 O3	8 O3	8 O3	8 O3	8 O3	8 O3	8 O3	8 O3	8 O3	8 O3	8 O3	8 O3	PM2 O3		
21	9 O3	6 O3	6 O3	3 O3	4 O3	7 O3	7 O3	6 O3	7 O3	8 O3	13 O3	13 O3	14 O3	14 O3	13 O3	12 O3	11 O3	10 O3	10 O3	10 O3	11 O3	12 O3	11 O3	11 O3	
22	4 O3	NA -	2 O3	1 O3	3 O3	6 O3	6 O3	10 O3	12 O3	13 O3	15 O3	17 O3	17 O3	18 O3	19 O3	20 O3	20 O3	20 O3	20 O3	20 O3	21 O3	15 O3	11 O3	9 O3	
23	NA -	5 O3	4 O3	5 O3	10 O3	11 O3	11 O3	12 O3	12 O3	14 O3	16 O3	16 O3	17 O3	NA -											
24	14 O3	12 O3	11 O3	7 O3	5 O3	7 O3	11 O3	13 O3	15 O3	16 O3	18 O3	O3 -													
25	16 O3	15 O3	14 O3	11 O3	7 O3	11 O3	12 O3	13 O3	15 O3	19 O3	20 O3	22 O3	23 O3	21 O3	21 O3	21 O3	23 O3	23 O3	23 O3	21 O3	19 O3	15 O3	14 O3	23 O3	
26	10 O3	6 O3	4 O3	5 O3	11 O3	13 O3	13 O3	16 O3	19 O3	21 O3	22 O3	23 O3	24 O3	24 O3	25 O3	25 O3	26 O3	27 O3	28 O3	23 O3	NA -	14 O3	14 O3		
27	13 O3	10 O3	7 O3	4 O3	6 O3	8 O3	13 O3	16 O3	19 O3	22 O3	25 O3	24 O3	22 O3	23 O3	24 O3	24 O3	24 O3	24 O3	24 O3	20 O3	16 O3	20 O3	21 O3	25 O3	
28	18 O3	14 O3	15 O3	13 O3	9 O3	8 O3	11 O3	12 O3	13 O3	12 O3	11 O3	NA -													
29	10 O3	9 O3	9 O3	9 O3	10 O3	11 O3	12 O3	12 O3	13 O3	13 O3	13 O3	13 O3	13 O3	13 O3	14 O3	15 O3	NA -	NA -							
30	2 O3	1 O3	1 O3	1 O3	3 O3	10 O3	6 O3	9 O3	12 O3	15 O3	18 O3	19 O3	20 O3	21 O3	22 O3	NA -	NA -								
31	14 O3	10 O3	11 O3	11 O3	8 O3	10 O3	10 O3	12 O3	17 O3	19 O3	21 O3	23 O3	25 O3	25 O3	25 O3	NA -	NA -								
PEAK	23 O3	25 O3	23 O3	24 O3	23 O3	23 O3	24 O3	24 O3	24 O3	28 O3	30 O3	31 O3	30 O3	31 O3	33 O3	33 O3	33 O3	33 O3	31 O3	30 O3	27 O3	25 O3	23 O3		

STATUS FLAG CODES

NA - NOT APPLICABLE

AQI SUMMARY

AQI CLASS	O3	PM 2.5	NO2	SO2	FREQ
VERY POOR (101 - 255)	0 hrs 0.00%	0 hrs 0.00%	0 hrs 0.00%	0 hrs 0.00%	0 hrs 0.00%
POOR (51 - 100)	0 hrs 0.00%	0 hrs 0.00%	0 hrs 0.00%	0 hrs 0.00%	0 hrs 0.00%
FAIR (26 - 50)	48 hrs 6.45%	0 hrs 0.00%	0 hrs 0.00%	0 hrs 0.00%	48 hrs 6.45%
GOOD (1 - 25)	524 hrs 70.43%	23 hrs 3.09%	0 hrs 0.00%	0 hrs 0.00%	547 hrs 73.52%
OVERALL	572 hrs 76.88%	23 hrs 3.09%	0 hrs 0.00%	0 hrs 0.00%	677 hrs 79.97%
UNAVAILABLE	-	-	-	-	149 hrs 20.03%

MOUNTAIN STANDARD TIME

SO₂

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE


MAY 2007

SULPHUR DIOXIDE (SO₂) hourly averages in ppb

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR				
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.			
DAY																														
1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	C	C	C	IZS	0	0	0	0	0	0	0.0	24			
2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0.0	24			
3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0.0	24			
4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0.0	24			
5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	P	IZS	0	0	0	0	0	0	0	0	0.0	23			
6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0.0	24			
7	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0.0	24			
8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0.0	24			
9	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0.0	24			
10	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0.0	24			
11	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	P	0	0	0	0	0	0.0	23			
12	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0.0	24			
13	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0.0	24			
14	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	1	0.1	24		
15	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0.0	24		
16	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0.0	24		
17	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	1	1	0	0	0	0	0	0	0	1	0.1	24	
18	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0.0	24		
19	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0.0	24		
20	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0.0	24		
21	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0.0	24		
22	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0.0	24		
23	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	IZS	1	0.1	24
24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0.0	24		
25	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0.0	24		
26	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0.0	24		
27	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0.0	24		
28	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0.0	24		
29	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0.0	24		
30	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0.0	24		
31	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0.0	24		
HOURLY MAX	0	0	0	0	0	0	0	1	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0				
HOURLY AVG	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					

STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE



OBJECTIVE LIMIT:

ALBERTA ENVIRONMENT: 1-HR 172 PPB 24-HR 57 PPB


MONTHLY SUMMARY

NUMBER OF 1-HR EXCEEDENCES:	0
NUMBER OF 24-HR EXCEEDENCES:	0
NUMBER OF NON-ZERO READINGS:	6
MAXIMUM 1-HR AVERAGE:	1 PPB @ HOUR(S) VARIOUS ON DAY(S) 14,17,23
MAXIMUM 24-HR AVERAGE:	0.1 PPB ON DAY(S) 14,17,23

Izs Calibration Time:	32 HRS	Operational Time:	742 HRS
Monthly Calibration Time:	3 HRS	AmD Operation Uptime:	99.7 %
Standard Deviation:	0.09	Monthly Average:	0.01 PPB

MOUNTAIN STANDARD TIME

01 Hour Averages



LICA
SO2 / WD Joint Frequency Distribution (Percent)

May 2007

Distribution By % Of Samples

Logger Id : 01
 Site Name : LICA
 Parameter : SO2
 Units : PPB

Wind Parameter : WD
 Instrument Height : 10 Meters

Direction

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 20	3.67	6.93	11.59	3.39	6.22	9.33	12.44	5.51	4.24	4.66	5.23	7.07	5.79	4.95	5.09	3.81	100.00
< 60	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
< 110	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
< 170	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
< 340	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
>= 340	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
Totals	3.67	6.93	11.59	3.39	6.22	9.33	12.44	5.51	4.24	4.66	5.23	7.07	5.79	4.95	5.09	3.81	

Calm : .00 %

Total # Operational Hours : 707

Distribution By Samples

Direction

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 20	26	49	82	24	44	66	88	39	30	33	37	50	41	35	36	27	707
< 60																	
< 110																	
< 170																	
< 340																	
>= 340																	
Totals	26	49	82	24	44	66	88	39	30	33	37	50	41	35	36	27	

Calm : .00 %

Total # Operational Hours : 707

Logger : 01 Parameter : SO2


Class Limits (PPB)




Site : LICA

Period : 05/01/07-05/31/07

Level : 10



Calibration Graph for Site: LICA Parameter: SO2 Sequence: SO2 Phase: SPAN



LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

MAY 2007

SULPHUR DIOXIDE MAX instantaneous maximum in ppt

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY MAX.	24-HOUR AVG.	RDGS.			
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00						
DAY																														
1	0	0	0	0	0	0	0	1	1	1	0	0	0	0	C	C	C	IZS	0	0	0	0	0	0	0	1	0.2	24		
2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0.0	24			
3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0.0	24			
4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0.0	24			
5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	P	IZS	0	0	0	0	0	0	0	0	0	0.0	23			
6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	1	0	0	0	0	0	0	0	0.0	24	
7	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
9	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
10	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
11	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	1	1	0	0	P	0	1	0	0	0	0	1	0.2	23
12	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
13	0	0	0	0	0	0	0	IZS	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24		
14	0	0	0	0	0	0	IZS	0	0	1	1	1	5	0	0	0	0	0	0	0	0	0	1	1	0	0	0.4	24		
15	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24			
16	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24			
17	0	0	0	0	0	0	0	IZS	2	2	2	1	0	0	0	0	0	0	0	0	0	0	1	1	0	0	0.4	24		
18	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24		
19	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24		
20	0	0	0	0	0	0	0	IZS	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	1	0.0	24		
21	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24		
22	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24		
23	IZS	0	0	0	0	0	0	1	2	2	2	1	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	2	0.4	24	
24	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24		
25	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24		
26	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0.0	24		
27	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24		
28	0	0	0	0	0	0	0	0	0	0	4	0	1	0	0	0	0	1	0	IZS	0	0	0	0	0	4	0.3	24		
29	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0.0	24		
30	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	IZS	0	0	0	0	0	0	0.0	24		
31	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24		
HOURLY MAX	0	0	0	0	0	0	1	2	2	2	5	1	1	0	0	0	0	1	1	0	1	1	1	1	0	0				
HOURLY AVG	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.3	0.5	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0					

STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

MONTHLY SUMMARY


NUMBER OF NON-ZERO READINGS:	30
MAXIMUM INSTANTANEOUS VALUE:	5 PPB @ HOUR(S) 10 ON DAY(S) 14

Izs Calibration Time:	32 HRS	Operational Time:	742 HRS
Monthly Calibration Time:	3 HRS		
Standard Deviation:	0.35		

MOUNTAIN STANDARD TIME



01 Hour Averages



TRS

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE


MAY 2007

TOTAL REDUCED SULPHUR (TRS) hourly averages in ppb

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY	24-HOUR		
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	MAX.	AVG.	RDGS.	
DAY																												
1	0	0	0	0	0	0	0	C	C	C	C	Izs	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0.0	24	
2	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0.0	24	
3	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0.0	24	
4	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0.0	24	
5	0	0	0	0	0	0	0	0	0	0	0	P	Izs	0	0	0	0	Izs	0	0	0	0	0	0	0	0.0	23	
6	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0.0	24	
7	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0.0	24	
8	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0.0	24	
9	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0.0	24	
10	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0.0	24	
11	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0.0	23	
12	0	0	0	0	0	0	0	Izs	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0.0	24	
13	0	0	0	0	Izs	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0.0	24	
14	0	0	0	Izs	0	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0.0	24	
15	0	0	Izs	0	0	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0.0	24	
16	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0.0	24	
17	0	0	0	0	1	0	Izs	1	0	0	0	Izs	1	0	0	0	Izs	1	0	0	0	0	0	0	0	0.1	24	
18	0	0	0	0	Izs	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0.0	24	
19	0	0	0	0	Izs	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0.0	24	
20	0	0	0	Izs	0	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0.0	24	
21	0	0	Izs	0	0	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0.0	24	
22	0	Izs	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0.0	24	
23	Izs	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0	0	0	Izs	0.0	24	
24	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0	0	Izs	0	0.0	24	
25	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0	Izs	0	0	0.0	24	
26	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0.0	24	
27	0	0	0	0	1	1	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	1	0.1	24
28	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0.0	24
29	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0.0	24
30	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0.0	24
31	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	Izs	0	0	0	0	0.0	24
HOURLY MAX	0	0	0	0	1	1	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
HOURLY AVG	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	

STATUS FLAG CODES

S	- OUT OF SERVICE	Izs	- DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE



OBJECTIVE LIMIT:

ALBERTA ENVIRONMENT: 1-HR 172 PPB 24-HR 57 PPB

MONTHLY SUMMARY


NUMBER OF 1-HR EXCEEDENCES: 0
NUMBER OF 24-HR EXCEEDENCES: 0

NUMBER OF NON-ZERO READINGS: 5
MAXIMUM 1-HR AVERAGE: 1 PPB @ HOUR(S) VARIOUS ON DAY(S) 17,27,28
MAXIMUM 24-HR AVERAGE: 0.1 PPB ON DAY(S) 17,27

Izs CALIBRATION TIME:	33 HRS	OPERATIONAL TIME:	742 HRS
MONTHLY CALIBRATION TIME:	4 HRS	AMD OPERATION UPTIME:	99.7 %
STANDARD DEVIATION:	0.08	MONTHLY AVERAGE:	0.01 PPB

MOUNTAIN STANDARD TIME

01 Hour Averages



LICA
TRS / WD Joint Frequency Distribution (Percent)

May 2007

Distribution By % Of Samples

Logger Id : 01
 Site Name : LICA
 Parameter : TRS
 Units : PPB

Wind Parameter : WD
 Instrument Height : 10 Meters

Direction

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 3	3.68	6.95	11.63	3.40	6.09	9.07	12.62	5.81	4.25	4.68	4.96	7.09	5.81	4.96	5.10	3.82	100.00
< 10	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 50	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 50	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	3.68	6.95	11.63	3.40	6.09	9.07	12.62	5.81	4.25	4.68	4.96	7.09	5.81	4.96	5.10	3.82	

Calm : .00 %

Total # Operational Hours : 705

Distribution By Samples

Direction

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 3	26	49	82	24	43	64	89	41	30	33	35	50	41	35	36	27	705
< 10																	
< 50																	
>= 50																	
Totals	26	49	82	24	43	64	89	41	30	33	35	50	41	35	36	27	

Calm : .00 %

Total # Operational Hours : 705

Logger : 01 Parameter : TRS


Class Limits (PPB)




Site : LICA

Period : 05/01/07-05/31/07

Level : 10



Calibration Graph for Site: LICA Parameter: TRS Sequence: TRS Phase: SPAN



LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

MAY 2007

TOTAL REDUCED SULPHUR MAX instantaneous maximum in ppb

HOUR START HOUR END	0:00 1:00	1:00 2:00	2:00 3:00	3:00 4:00	4:00 5:00	5:00 6:00	6:00 7:00	7:00 8:00	8:00 9:00	9:00 10:00	10:00 11:00	11:00 12:00	12:00 13:00	13:00 14:00	14:00 15:00	15:00 16:00	16:00 17:00	17:00 18:00	18:00 19:00	19:00 20:00	20:00 21:00	21:00 22:00	22:00 23:00	23:00 0:00	DAILY MAX. MAX.	24-HOUR AVG. AVG.	RDGS. RDGS.		
DAY																													
1	1	1	1	1	1	1	1	C	C	C	C	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	1.0	24		
2	1	1	1	1	1	1	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	1.0	24		
3	1	1	1	1	1	1	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	1.0	24		
4	1	1	1	1	1	1	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	1.0	24		
5	1	1	1	1	1	1	1	1	1	1	1	P	Izs	1	1	Izs	1	1	1	1	1	1	1	1	1	1.0	23		
6	2	1	1	1	1	1	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	2	1.0	24	
7	1	1	1	1	1	1	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	1	1.0	24	
8	1	1	1	1	1	1	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	1	1.0	24	
9	1	1	1	1	1	1	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	1	1.0	24	
10	1	1	1	1	1	1	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	1	1.0	24	
11	1	1	1	1	1	1	1	1	1	1	1	Izs	1	1	1	P	1	1	1	1	1	1	1	1	1	1	1.0	23	
12	1	1	1	1	1	1	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	1	1.0	24	
13	1	1	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	1	1.0	24	
14	1	1	1	1	1	1	Izs	1	1	1	1	3	1	1	Izs	1	1	1	1	1	1	1	1	1	1	3	1.1	24	
15	1	1	Izs	1	1	1	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	1	1.0	24	
16	1	1	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	1	1.0	24	
17	1	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	1	1	1.0	24	
18	1	1	1	1	1	Izs	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	1	1.0	24	
19	1	1	1	1	Izs	1	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	1	1.0	24	
20	1	1	1	Izs	1	1	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	1	1.0	24	
21	1	1	Izs	1	1	1	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	1	1.0	24	
22	1	Izs	1	1	1	1	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	1	1.0	24	
23	Izs	1	1	1	1	1	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	Izs	1	1.0	24
24	1	1	1	1	1	1	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	Izs	1	1.0	24
25	1	1	1	1	1	1	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	Izs	1	1.0	24
26	1	1	1	1	1	1	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	Izs	1	1.0	24
27	1	1	1	1	1	1	1	1	1	1	1	Izs	1	1	1	Izs	1	1	1	1	1	1	1	1	1	Izs	1	1.0	24
28	1	1	1	1	1	1	1	1	1	1	1	5	1	1	Izs	1	1	1	1	1	1	1	1	1	1	5	1.2	24	
29	1	1	1	1	1	1	1	1	1	1	1	Izs	1	1	Izs	1	1	1	1	1	1	1	1	1	1	Izs	1	1.0	24
30	1	1	1	1	1	1	1	1	1	1	1	Izs	1	1	Izs	1	1	1	1	1	1	1	1	1	1	Izs	1	1.0	24
31	1	1	1	1	1	1	1	1	1	1	1	Izs	1	1	Izs	1	1	1	1	1	1	1	1	1	1	Izs	1	1.0	24
HOURLY MAX	2	1	1	1	1	1	1	1	1	5	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
HOURLY AVG	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.2	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0			

STATUS FLAG CODES

S	- OUT OF SERVICE	Izs	- Izs - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

MONTHLY SUMMARY


NUMBER OF NON-ZERO READINGS:	705
MAXIMUM INSTANTANEOUS VALUE:	5 PPB @ HOUR(S) 10 ON DAY(S) 28

Izs CALIBRATION TIME:	33 HRS	OPERATIONAL TIME:	742 HRS
MONTHLY CALIBRATION TIME:	4 HRS		
STANDARD DEVIATION:	0.17		

MOUNTAIN STANDARD TIME




01 Hour Averages



THC

01 Hour Averages



LICA
THC / WD Joint Frequency Distribution (Percent)

May 2007

Distribution By % Of Samples

Logger Id : 01
 Site Name : LICA
 Parameter : THC
 Units : PPM

Wind Parameter : WD
 Instrument Height : 10 Meters

Direction

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 3.0	3.69	6.97	11.66	3.41	6.25	9.38	12.51	5.26	4.26	4.69	4.83	6.54	5.83	4.97	5.12	3.84	99.28
< 10.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.28	.42	.00	.00	.00	.00	.71
< 50.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 50.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	3.69	6.97	11.66	3.41	6.25	9.38	12.51	5.26	4.26	4.69	5.12	6.97	5.83	4.97	5.12	3.84	

Calm : .00 %

Total # Operational Hours : 703

Distribution By Samples

Direction

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 3.0	26	49	82	24	44	66	88	37	30	33	34	46	41	35	36	27	698
< 10.0											2	3					5
< 50.0																	
>= 50.0																	
Totals	26	49	82	24	44	66	88	37	30	33	36	49	41	35	36	27	

Calm : .00 %

Total # Operational Hours : 703

Logger : 01 Parameter : THC


Class Limits (PPM)




Site : LICA

Period : 05/01/07-05/31/07


Level : 10



Calibration Graph for Site: LICA Parameter: THC Sequence: THC Phase: SPAII




01 Hour Averages



PARTICULATE MATTER

2.5

01 Hour Averages



LICA
PM2 / WD Joint Frequency Distribution (Percent)

May 2007

Distribution By % Of Samples

Logger Id : 01
 Site Name : LICA
 Parameter : PM2
 Units : UG/M3

Wind Parameter : WD
 Instrument Height : 10 Meters

Direction

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 30.0	3.70	6.86	11.40	3.29	6.18	9.06	12.77	5.63	4.39	4.67	5.21	7.55	5.76	4.67	4.94	3.84	100.00
< 60.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 80.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 120.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 240.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 240.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	3.70	6.86	11.40	3.29	6.18	9.06	12.77	5.63	4.39	4.67	5.21	7.55	5.76	4.67	4.94	3.84	

Calm : .00 %

Total # Operational Hours : 728

Distribution By Samples

Direction


Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 30.0	27	50	83	24	45	66	93	41	32	34	38	55	42	34	36	28	728
< 60.0																	
< 80.0																	
< 120.0																	
< 240.0																	
>= 240.0																	
Totals	27	50	83	24	45	66	93	41	32	34	38	55	42	34	36	28	

Calm : .00 %

Total # Operational Hours : 728

Logger : 01 Parameter : PM2


Class Limits (UG/M3)




Site : LICA

Period : 05/01/07-05/31/07

Level : 10



01 Hour Averages



NO₂

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

MAY 2007

NITROGEN DIOXIDE hourly averages in ppt

HOUR START HOUR END	0:00 1:00	1:00 2:00	2:00 3:00	3:00 4:00	4:00 5:00	5:00 6:00	6:00 7:00	7:00 8:00	8:00 9:00	9:00 10:00	10:00 11:00	11:00 12:00	12:00 13:00	13:00 14:00	14:00 15:00	15:00 16:00	16:00 17:00	17:00 18:00	18:00 19:00	19:00 20:00	20:00 21:00	21:00 22:00	22:00 23:00	23:00 0:00	DAILY MAX.	24-HOUR AVG.	RDGS.	
DAY																												
1	5	4	4	4	5	7	9	C	C	C	C	C	C	C	Izs	1	1	0	0	2	1	1	1	1	9	3.0	24	
2	0	0	0	1	1	2	2	2	1	1	1	1	1	1	Izs	3	2	2	2	1	1	1	1	1	3	1.3	24	
3	1	1	1	1	1	2	2	3	2	1	2	1	1	1	Izs	2	1	1	1	0	0	0	0	0	3	1.1	24	
4	0	0	0	1	2	4	4	3	4	2	3	2	2	2	Izs	2	3	1	2	2	1	1	0	0	4	1.8	24	
5	0	0	0	0	0	0	0	1	1	0	P	Izs	0	0	0	0	0	1	3	2	1	1	1	3	0.5	23		
6	1	2	1	2	1	3	7	3	1	1	0	Izs	0	0	0	0	1	0	1	1	1	2	1	3	7	1.4	24	
7	2	1	2	0	1	1	1	0	0	0	Izs	0	0	0	0	0	0	0	0	0	5	8	6	5	8	1.4	24	
8	4	5	7	5	6	4	5	5	2	Izs	1	0	0	0	0	0	0	1	1	2	3	1	1	0	0	7	2.3	24
9	0	0	0	0	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0	2	6	6	1	1	6	0.7	24		
10	0	1	3	4	7	9	4	Izs	3	1	1	0	0	0	0	1	1	1	0	1	1	1	2	2	9	1.9	24	
11	1	0	0	1	2	2	Izs	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	2	1.0	7	
12	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	NA	NA	0		
13	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	NA	NA	0		
14	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	NA	NA	0		
15	N	N	N	N	N	N	C	C	C	C	Izs	2	0	9	0	1	1	1	1	4	2	1	1	9	1.9	18		
16	1	1	1	1	1	2	Izs	0	4	1	1	1	5	1	1	1	1	1	1	2	2	2	2	5	1.4	24		
17	3	4	4	5	5	7	Izs	36	19	4	1	1	1	0	0	0	0	1	1	1	0	0	0	0	36	4.0	24	
18	0	0	0	0	0	0	Izs	1	1	0	0	0	0	0	1	1	1	1	0	1	1	0	0	1	0.4	24		
19	0	0	0	0	0	Izs	0	0	1	1	1	1	1	1	1	1	1	1	2	2	2	2	2	2	1.0	24		
20	1	1	2	Izs	2	1	1	1	3	3	1	1	1	1	0	1	1	1	2	3	4	7	8	4	8	2.2	24	
21	2	2	Izs	2	3	4	2	1	0	1	1	0	0	1	0	0	0	1	1	2	2	3	3	2	4	1.4	24	
22	2	Izs	4	4	3	3	1	0	0	0	0	0	0	0	0	0	0	1	2	4	5	4	8	8	1.9	24		
23	Izs	6	4	3	3	2	3	2	1	1	1	0	0	0	0	0	0	1	1	0	0	0	Izs	6	1.3	24		
24	1	0	1	1	1	3	2	1	1	0	1	0	0	0	0	0	0	1	2	4	6	Izs	1	6	1.1	24		
25	0	1	1	1	4	3	4	2	2	1	1	1	1	1	2	2	2	1	1	2	Izs	2	2	4	1.7	24		
26	3	2	2	1	1	1	1	1	1	1	1	1	1	1	0	0	0	1	2	Izs	5	4	2	5	1.4	24		
27	3	1	3	4	5	4	2	2	2	1	1	1	1	1	1	2	3	Izs	2	2	3	1	5	2.0	24			
28	2	4	1	1	2	5	4	3	2	34	5	3	4	3	3	3	3	Izs	1	0	0	0	0	34	3.7	24		
29	0	0	0	0	0	1	1	1	0	0	0	0	0	1	0	0	Izs	1	1	2	3	3	1	3	0.7	24		
30	1	1	1	1	1	3	2	1	0	1	0	1	0	0	0	0	Izs	1	1	1	2	5	3	2	5	1.2	24	
31	2	3	2	2	4	2	2	2	1	1	1	1	1	1	Izs	1	1	1	2	6	8	6	4	8	2.4	24		
HOURLY MAX	5	6	7	5	7	9	9	36	19	34	5	3	4	3	9	3	3	2	3	3	6	8	8	8				
HOURLY AVG	1.3	1.5	1.7	1.7	2.3	2.9	2.5	3.2	2.0	2.5	1.0	0.7	0.7	0.6	1.1	0.8	0.8	0.8	1.1	1.5	2.2	2.8	2.1	1.8				

STATUS FLAG CODES

S	- OUT OF SERVICE	Izs	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

OBJECTIVE LIMIT:

ALBERTA ENVIRONMENT: 1-HR 212 PPB 24-HR 106 PPB


MONTHLY SUMMARY

NUMBER OF 1-HR EXCEEDENCES:	0
NUMBER OF 24-HR EXCEEDENCES:	0
NUMBER OF NON-ZERO READINGS:	434
MAXIMUM 1-HR AVERAGE:	36 PPB @ HOUR(S) 8 ON DAY(S) 17
MAXIMUM 24-HR AVERAGE:	4.0 PPB ON DAY(S) 17

Izs CALIBRATION TIME: 29 HRS OPERATIONAL TIME: 648 HRS


MONTHLY CALIBRATION TIME: 13 HRS AMD OPERATION UPTIME: 87.1 %

STANDARD DEVIATION: 2.63 MONTHLY AVERAGE: 1.65 PPB



MOUNTAIN STANDARD TIME

01 Hour Averages



LICA
NO2 / WD Joint Frequency Distribution (Percent)

May 2007

Distribution By % Of Samples

Logger Id : 01
 Site Name : LICA
 Parameter : NO2
 Units : PPB

Wind Parameter : WD
 Instrument Height : 10 Meters

Direction

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	4.29	7.42	12.54	3.63	6.27	8.74	13.53	5.44	4.78	4.62	4.95	6.43	5.94	3.46	3.79	4.12	100.00
< 110	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
< 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
Totals	4.29	7.42	12.54	3.63	6.27	8.74	13.53	5.44	4.78	4.62	4.95	6.43	5.94	3.46	3.79	4.12	

Calm : .00 %

Total # Operational Hours : 606

Distribution By Samples

Direction


Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	26	45	76	22	38	53	82	33	29	28	30	39	36	21	23	25	606
< 110																	
< 210																	
>= 210																	
Totals	26	45	76	22	38	53	82	33	29	28	30	39	36	21	23	25	

Calm : .00 %

Total # Operational Hours : 606

Logger : 01 Parameter : NO₂


Class Limits (PPB)




Site : LICA

Period : 05/01/07-05/31/07

Level : 10



Calibration Graph for Site: LICA Parameter: NO2 Sequence: NO2 Phase: SPAN



LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

MAY 2007

NITROGEN DIOXIDE MAX instantaneous maximum in ppb

HOUR START HOUR END	0:00 1:00	1:00 2:00	2:00 3:00	3:00 4:00	4:00 5:00	5:00 6:00	6:00 7:00	7:00 8:00	8:00 9:00	9:00 10:00	10:00 11:00	11:00 12:00	12:00 13:00	13:00 14:00	14:00 15:00	15:00 16:00	16:00 17:00	17:00 18:00	18:00 19:00	19:00 20:00	20:00 21:00	21:00 22:00	22:00 23:00	23:00 0:00	DAILY MAX.	24-HOUR AVG.	RDGS.	
DAY																												
1	10	5	5	6	7	29	14	C	C	C	C	C	C	C	Izs	5	9	1	2	7	4	2	2	29	7.2	24		
2	1	1	1	2	2	16	3	6	25	20	5	3	3	2	4	Izs	12	3	7	4	3	1	2	1	25	5.5	24	
3	1	2	3	5	3	4	9	10	4	4	20	3	5	2	Izs	82	7	6	1	1	0	1	1	82	7.6	24		
4	0	3	1	2	6	6	5	6	69	4	22	4	2	Izs	7	18	6	2	5	3	2	19	1	2	69	8.5	24	
5	0	0	0	0	0	0	0	1	1	2	1	P	Izs	1	2	1	1	1	11	5	5	5	3	4	11	2.0	23	
6	4	12	4	5	4	5	10	7	2	1	1	Izs	5	0	1	4	2	1	4	1	2	7	1	9	12	4.0	24	
7	9	4	5	1	3	2	2	1	1	0	Izs	1	1	1	0	1	1	0	1	16	13	8	11	16	3.6	24		
8	7	8	11	9	10	8	9	8	4	Izs	2	1	1	0	4	1	9	2	9	16	4	2	1	1	16	5.5	24	
9	0	0	0	0	1	4	0	1	Izs	3	3	6	2	1	1	1	1	1	5	18	18	4	2	18	3.2	24		
10	1	2	5	5	27	21	9	Izs	5	2	1	1	1	3	1	12	5	3	1	4	5	2	3	3	27	5.3	24	
11	2	1	1	1	7	7	Izs	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	7	3.2	7	
12	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	NA	NA	0		
13	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	NA	NA	0		
14	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	NA	NA	0		
15	N	N	N	N	N	C	C	C	C	Izs	18	231	1	5	14	2	4	8	5	1	2	231	26.5	18				
16	2	2	2	1	2	2	Izs	12	48	33	2	5	51	62	3	1	1	1	2	2	5	0	4	1	500	46.5	24	
17	6	12	6	9	10	9	Izs	345	500	147	2	1	4	1	1	1	1	1	2	2	4	2	1	0	20	3.0	24	
18	0	0	0	0	1	Izs	20	7	4	1	2	6	1	1	3	2	5	2	4	2	4	2	1	0	20	3.0	24	
19	0	0	0	0	0	Izs	1	3	33	2	1	11	8	7	4	3	2	2	3	3	4	5	4	3	4	33	4.5	24
20	2	7	4	Izs	3	3	1	3	4	3	2	1	3	1	1	2	5	3	3	5	15	12	10	8	15	4.4	24	
21	2	3	Izs	5	6	7	4	2	1	1	2	1	6	5	1	1	1	5	2	8	5	6	6	4	8	3.7	24	
22	3	Izs	5	4	7	5	5	7	7	2	3	1	7	2	2	1	2	2	8	13	11	8	7	11	13	5.3	24	
23	Izs	9	5	4	4	3	3	4	5	4	2	3	1	0	1	1	4	2	1	7	0	0	1	Izs	9	2.9	24	
24	4	3	5	3	5	7	4	22	6	5	12	5	3	12	1	2	1	1	11	11	9	9	Izs	2	22	6.2	24	
25	0	2	2	3	11	8	7	3	3	1	8	2	1	2	13	8	6	2	2	6	7	Izs	4	4	13	4.6	24	
26	6	4	4	2	2	1	2	3	3	5	5	3	7	4	4	3	1	0	7	5	Izs	8	16	3	16	4.3	24	
27	8	3	4	6	6	5	3	2	5	2	2	3	6	7	1	2	2	6	6	Izs	5	2	13	1	13	4.3	24	
28	3	5	2	2	4	12	5	4	4	500	89	5	5	4	3	4	3	2	Izs	1	0	0	0	0	500	28.6	24	
29	0	0	0	0	0	2	4	3	12	16	5	5	4	40	1	6	4	Izs	3	7	4	4	6	2	40	5.6	24	
30	3	2	2	2	6	3	5	2	1	2	1	13	1	4	5	5	Izs	2	2	1	10	20	5	5	20	4.4	24	
31	3	4	3	3	17	3	2	7	2	1	4	4	2	9	2	Izs	4	2	1	6	12	23	10	8	23	5.7	24	
HOURLY MAX	10	12	11	9	27	29	20	345	500	500	89	13	7	51	231	82	12	14	11	16	18	23	16	11				
HOURLY AVG	3.0	3.6	3.1	3.1	5.9	6.7	5.2	21.2	28.4	32.3	9.9	3.6	3.5	7.0	14.2	6.8	3.7	3.0	3.8	5.1	6.3	6.8	4.5	3.7				

STATUS FLAG CODES

S	- OUT OF SERVICE	Izs	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

MONTHLY SUMMARY


NUMBER OF NON-ZERO READINGS:	562
MAXIMUM INSTANTANEOUS VALUE:	500 PPB @ HOUR(S) 9,10 ON DAY(S) 17,28

Izs CALIBRATION TIME:	29 HRS	OPERATIONAL TIME:	648 HRS
MONTHLY CALIBRATION TIME:	14 HRS		

MOUNTAIN STANDARD TIME



01 Hour Averages



NO

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

MAY 2007

NITRIC OXIDE hourly averages in ppt

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	DAILY MAX.	24-HOUR AVG.	RDGS.	
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00				
DAY																												
1	0	0	0	0	0	2	4	C	C	C	C	C	C	C	Izs	0	0	0	0	0	0	0	0	0	4	0.4	24	
2	0	0	0	0	0	1	0	0	0	0	0	0	0	0	Izs	0	0	0	0	0	0	0	0	1	0.0	24		
3	0	0	0	0	0	0	0	1	0	1	1	0	0	0	Izs	0	0	0	0	0	0	0	0	1	0.1	24		
4	0	0	0	0	0	0	0	0	1	0	0	0	0	0	Izs	0	0	0	0	0	0	0	0	1	0.0	24		
5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	P	Izs	0	0	0	0	0	0	0	0	0	0.0	23	
6	0	0	0	0	0	1	2	1	0	0	0	0	0	0	Izs	0	0	0	0	0	0	0	0	2	0.2	24		
7	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0	0.0	24		
8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0	0.0	24		
9	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0	0.0	24		
10	0	0	0	0	9	25	4	Izs	1	0	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0	25	1.7	24	
11	0	0	0	0	0	0	0	Izs	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	0	0.0	7
12	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	NA	NA	0	
13	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	NA	NA	0	
14	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	NA	NA	0	
15	N	N	N	N	N	N	C	C	C	Izs	9	3	16	0	0	0	0	0	0	0	0	0	0	0	16	2.3	18	
16	0	0	0	0	0	0	0	Izs	1	6	6	0	0	3	1	0	0	0	0	0	0	0	0	0	6	0.7	24	
17	0	0	0	0	0	0	0	Izs	17	4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	17	0.9	24	
18	0	0	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0.0	24	
19	0	0	0	0	0	Izs	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0.0	24	
20	0	0	0	0	Izs	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0.0	24	
21	0	0	Izs	0	1	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0.1	24	
22	0	Izs	0	0	3	6	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	6	0.4	24	
23	Izs	0	0	0	0	0	0	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	Izs	1	0.1	24		
24	0	0	0	0	0	1	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0.1	24		
25	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	1	0.0	24	
26	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0.0	24		
27	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	0.0	24		
28	0	0	0	0	0	0	0	0	0	37	5	0	0	0	0	0	0	Izs	0	0	0	0	0	37	1.8	24		
29	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0.0	24		
30	0	0	1	1	2	7	3	0	0	0	0	0	0	0	0	Izs	0	0	0	0	0	0	0	0	7	0.6	24	
31	0	0	0	0	1	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	0	0	0	0	1	0.0	24		
HOURLY MAX	0	0	1	1	9	25	4	17	4	37	6	0	9	3	16	0	0	0	0	0	0	0	0	0	0	0		
HOURLY AVG	0.0	0.0	0.0	0.0	0.6	1.7	0.6	1.0	0.3	1.9	0.5	0.0	0.4	0.2	0.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		

STATUS FLAG CODES

S	- OUT OF SERVICE	Izs	- Izs - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

MONTHLY SUMMARY


NUMBER OF NON-ZERO READINGS:	46
MAXIMUM 1-HR AVERAGE:	37 PPB
MAXIMUM 24-HR AVERAGE:	2.3 PPB

Izs Calibration Time:	29 HRS	Operational Time:	648 HRS
Monthly Calibration Time:	13 HRS	AMD Operation Uptime:	87.1 %
Standard Deviation:	2.20	Monthly Average:	0.33 PPB

MOUNTAIN STANDARD TIME



01 Hour Averages



LICA
NO / WD Joint Frequency Distribution (Percent)

May 2007

Distribution By % Of Samples

Logger Id : 01
 Site Name : LICA
 Parameter : NO
 Units : PPB

Wind Parameter : WD
 Instrument Height : 10 Meters

Direction

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	4.29	7.42	12.54	3.63	6.27	8.74	13.53	5.44	4.78	4.62	4.95	6.43	5.94	3.46	3.79	4.12	100.00
< 110	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	4.29	7.42	12.54	3.63	6.27	8.74	13.53	5.44	4.78	4.62	4.95	6.43	5.94	3.46	3.79	4.12	

Calm : .00 %

Total # Operational Hours : 606

Distribution By Samples

Direction


Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	26	45	76	22	38	53	82	33	29	28	30	39	36	21	23	25	606
< 110																	
< 210																	
>= 210																	
Totals	26	45	76	22	38	53	82	33	29	28	30	39	36	21	23	25	

Calm : .00 %

Total # Operational Hours : 606

Logger : 01 Parameter : NO


Class Limits (PPB)



Site : LICA

Period : 05/01/07-05/31/07

Level : 10



LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

MARCH 2007

NITRIC OXIDE MAX instantaneous maximum in ppb

HOUR START HOUR END	0:00 1:00	1:00 2:00	2:00 3:00	3:00 4:00	4:00 5:00	5:00 6:00	6:00 7:00	7:00 8:00	8:00 9:00	9:00 10:00	10:00 11:00	11:00 12:00	12:00 13:00	13:00 14:00	14:00 15:00	15:00 16:00	16:00 17:00	17:00 18:00	18:00 19:00	19:00 20:00	20:00 21:00	21:00 22:00	22:00 23:00	23:00 0:00	DAILY MAX.	24-HOUR AVG.	RDGS.		
DAY																													
1	2	0	0	0	0	0	23	7	C	C	C	C	C	C	C	Izs	3	1	0	17	1	0	0	0	23	3.6	24		
2	0	0	0	0	0	19	0	19	4	3	1	2	1	3	4	Izs	2	0	2	2	4	1	0	1	19	3.0	24		
3	0	1	0	0	1	2	7	7	6	23	63	3	2	2	2	Izs	12	4	3	0	0	3	0	0	0	63	6.0	24	
4	0	1	0	0	7	4	3	6	22	3	17	3	3	Izs	4	5	3	1	3	4	0	13	0	0	0	22	4.4	24	
5	0	0	0	0	0	0	0	0	0	0	0	P	Izs	0	7	1	0	0	2	0	2	0	0	0	0	7	0.5	23	
6	0	298	0	0	0	2	3	2	0	0	0	Izs	1	0	0	1	0	0	0	0	0	0	0	0	0	298	13.3	24	
7	0	0	0	0	0	0	0	0	0	0	Izs	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0.1	24	
8	0	2	1	2	0	0	0	1	0	Izs	0	0	0	0	1	0	4	0	2	5	1	0	0	0	0	5	0.8	24	
9	0	0	0	0	1	5	0	6	Izs	2	1	0	1	0	0	0	0	0	0	0	10	6	0	0	0	10	1.4	24	
10	0	0	0	1	46	75	27	Izs	6	1	0	0	0	0	1	6	2	0	3	2	2	0	0	0	0	75	7.5	24	
11	0	0	0	0	10	8	Izs	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	10	3.0	7	
12	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	NA	NA	0		
13	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	NA	NA	0		
14	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	NA	NA	0		
15	N	N	N	N	N	N	C	C	C	C	Izs	142	489	0	7	1	0	0	0	4	0	0	0	0	0	489	58.5	18	
16	0	0	0	0	0	0	Izs	42	72	213	6	4	90	39	1	0	0	0	1	0	0	0	0	0	0	0	213	20.3	24
17	0	0	0	2	1	2	Izs	190	60	14	0	0	1	0	0	0	0	0	0	2	3	0	1	0	190	12.0	24		
18	0	0	0	0	0	Izs	1	8	4	4	8	2	4	10	7	1	6	1	2	3	2	0	0	0	0	10	2.7	24	
19	0	0	0	0	Izs	0	0	33	5	0	4	5	6	6	7	3	0	1	1	2	2	0	1	0	33	3.3	24		
20	1	12	1	Izs	0	3	0	0	1	1	0	0	0	0	1	2	0	0	1	7	1	2	0	12	1.4	24			
21	0	2	Izs	4	5	4	1	0	0	0	0	0	4	0	0	0	0	1	0	1	1	0	0	2	5	1.1	24		
22	2	Izs	2	3	14	17	5	2	17	9	2	1	15	0	1	2	2	0	2	8	2	0	0	1	17	4.7	24		
23	Izs	4	1	1	0	0	0	6	8	5	1	9	1	1	0	0	1	0	0	4	0	0	0	5	Izs	9	2.1	24	
24	1	0	0	1	2	3	6	17	9	1	8	6	4	15	2	2	4	8	12	14	0	0	Izs	0	0	17	5.0	24	
25	0	0	0	0	5	1	2	2	3	0	3	0	0	0	11	5	10	1	0	0	3	Izs	0	0	0	11	2.0	24	
26	2	0	1	1	0	0	0	2	8	3	6	1	2	3	2	0	0	0	0	0	0	Izs	0	7	0	8	1.7	24	
27	0	0	0	0	1	1	0	0	0	5	8	1	1	3	7	1	0	14	0	0	Izs	0	0	2	0	14	1.9	24	
28	0	0	0	0	0	2	0	0	0	500	79	0	0	0	0	0	0	0	Izs	0	0	0	0	4	500	25.4	24		
29	0	0	0	0	0	0	2	13	6	1	2	2	19	7	0	2	5	Izs	4	2	1	0	3	0	19	3.0	24		
30	1	2	3	3	7	13	9	2	1	0	0	7	1	5	4	3	Izs	0	0	0	1	7	0	0	13	3.0	24		
31	0	0	0	0	16	0	0	3	0	0	0	1	1	33	0	Izs	2	0	0	0	0	13	0	1	33	3.0	24		
HOURLY MAX	2	298	3	4	46	75	27	190	60	500	213	9	19	142	489	12	14	8	12	17	10	13	7	4					
HOURLY AVG	0.3	12.4	0.3	0.7	4.5	7.1	2.9	13.9	8.6	27.1	17.0	2.1	3.0	13.0	23.2	1.9	2.7	0.7	1.3	2.6	1.7	1.8	0.8	0.3					

STATUS FLAG CODES

S	- OUT OF SERVICE	Izs	- Izs - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

MONTHLY SUMMARY


NUMBER OF NON-ZERO READINGS:	296
MAXIMUM INSTANTANEOUS VALUE:	500 PPB @ HOUR(S) 10 ON DAY(S) 28

Izs CALIBRATION TIME:	29 HRS	OPERATIONAL TIME:	648 HRS
MONTHLY CALIBRATION TIME:	14 HRS		

MOUNTAIN STANDARD TIME



01 Hour Averages



NO_x

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

MAY 2007


OXIDES OF NITROGEN hourly averages in ppb

HOUR START HOUR END	0:00 1:00	1:00 2:00	2:00 3:00	3:00 4:00	4:00 5:00	5:00 6:00	6:00 7:00	7:00 8:00	8:00 9:00	9:00 10:00	10:00 11:00	11:00 12:00	12:00 13:00	13:00 14:00	14:00 15:00	15:00 16:00	16:00 17:00	17:00 18:00	18:00 19:00	19:00 20:00	20:00 21:00	21:00 22:00	22:00 23:00	23:00 0:00	DAILY MAX.	24-HOUR AVG.	RDGS.
DAY																											
1	5	4	4	4	5	9	14	C	C	C	C	C	C	C	Izs	1	1	0	1	2	2	1	1	14	3.6	24	
2	0	0	0	1	1	4	2	3	2	2	1	1	1	2	Izs	3	2	3	2	1	1	1	1	4	1.6	24	
3	1	1	1	1	2	3	3	4	3	3	2	1	1	1	Izs	3	2	1	1	1	0	0	0	4	1.7	24	
4	0	1	1	1	1	3	4	4	3	5	3	4	3	2	Izs	3	3	2	2	2	1	2	1	0	5	2.3	24
5	0	0	0	0	0	0	0	1	1	1	1	P	Izs	1	1	0	0	1	1	3	2	1	1	3	0.7	23	
6	2	2	1	2	2	4	10	4	2	1	0	Izs	0	0	0	1	1	0	1	1	1	2	1	3	10	1.8	24
7	2	1	2	0	1	1	1	0	0	0	0	Izs	0	0	0	0	0	0	0	0	5	8	6	5	8	1.4	24
8	4	5	7	5	7	4	6	6	3	Izs	1	1	0	0	0	0	1	2	3	3	2	1	0	0	7	2.7	24
9	0	0	0	0	0	1	0	0	Izs	1	0	0	0	0	0	1	0	0	2	7	7	1	1	7	0.9	24	
10	0	1	3	4	17	35	9	Izs	4	1	1	0	0	0	0	1	1	1	0	1	1	1	2	2	35	3.7	24
11	1	0	0	1	2	3	Izs	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	3	1.2	7
12	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	NA	NA	0	
13	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	NA	NA	0	
14	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	N	NA	NA	0	
15	N	N	N	N	N	N	C	C	C	C	C	Izs	7	2	17	1	1	1	1	4	2	1	1	17	3.3	18	
16	1	1	1	1	1	2	1	Izs	2	10	3	1	1	5	7	1	1	1	1	1	2	2	2	10	2.1	24	
17	3	4	4	5	6	8	Izs	51	24	4	1	1	1	1	1	0	1	1	1	0	0	0	0	51	5.2	24	
18	0	0	0	0	0	Izs	1	1	1	1	1	1	0	0	2	1	1	1	1	1	1	0	0	0	2	0.7	24
19	0	0	0	0	0	Izs	1	0	2	1	1	1	1	1	1	2	1	2	3	2	2	2	2	3	1.2	24	
20	1	2	3	Izs	2	1	1	4	4	2	1	1	1	0	1	1	2	2	3	5	7	8	4	8	2.5	24	
21	2	2	Izs	3	5	6	3	2	1	1	2	1	1	1	1	1	1	1	1	2	2	3	3	6	2.1	24	
22	2	Izs	4	5	6	9	5	2	1	1	0	0	1	0	0	0	0	1	1	2	4	5	4	8	9	2.7	24
23	Izs	6	4	3	3	2	3	3	3	3	1	1	0	0	0	0	0	0	1	1	0	0	0	Izs	6	1.5	24
24	1	0	1	2	2	5	3	3	2	1	1	0	0	1	0	0	0	0	1	3	4	6	Izs	1	6	1.6	24
25	0	1	1	1	5	4	5	3	3	1	2	1	1	1	2	2	3	1	1	1	2	Izs	3	2	5	2.0	24
26	3	3	3	1	1	1	2	2	2	1	1	1	1	1	1	0	0	1	2	Izs	5	4	2	5	1.7	24	
27	3	2	3	4	6	4	3	2	2	2	1	1	1	1	1	1	1	3	3	Izs	2	2	3	1	6	2.3	24
28	2	4	1	1	2	6	4	3	3	51	10	4	5	3	3	4	3	1	Izs	1	0	0	0	0	51	4.8	24
29	0	0	0	0	0	1	2	1	1	1	1	1	1	1	1	Izs	1	1	2	3	4	1	4	1.1	24		
30	2	2	2	3	4	10	6	2	1	1	1	1	1	1	1	Izs	1	1	1	3	5	3	2	10	2.4	24	
31	2	3	2	2	5	3	3	1	1	1	1	Izs	1	1	1	1	2	6	9	6	4	9	2.6	24			
HOURLY MAX	5	6	7	5	17	35	14	51	24	51	10	4	7	5	17	4	3	3	3	7	9	8	8				
HOURLY AVG	1.4	1.7	1.8	1.9	3.4	5.0	3.6	4.4	3.0	4.0	1.7	1.0	1.1	1.0	1.8	1.1	1.0	1.0	1.2	1.6	2.4	3.0	2.2	1.8			

STATUS FLAG CODES

S	- OUT OF SERVICE	Izs	- DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

24 HOUR AVERAGES FOR MAY 2007




MONTHLY SUMMARY

NUMBER OF NON-ZERO READINGS:	488
MAXIMUM 1-HR AVERAGE:	51 PPB
MAXIMUM 24-HR AVERAGE:	5.2 PPB

Izs CALIBRATION TIME:	29 HRS	OPERATIONAL TIME:	648 HRS
MONTHLY CALIBRATION TIME:	13 HRS	AMD OPERATION UPTIME:	87.1 %
STANDARD DEVIATION:	3.86	MONTHLY AVERAGE:	2.17 PPB

MOUNTAIN STANDARD TIME

01 Hour Averages



LICA
NOX / WD Joint Frequency Distribution (Percent)

May 2007

Distribution By % Of Samples

Logger Id : 01
 Site Name : LICA
 Parameter : NOX
 Units : PPB

Wind Parameter : WD
 Instrument Height : 10 Meters

Direction

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	4.29	7.42	12.54	3.63	6.27	8.74	13.53	5.44	4.78	4.62	4.78	6.43	5.94	3.46	3.63	4.12	99.66
< 110	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.16	.00	.00	.00	.16	.00	.33
< 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	4.29	7.42	12.54	3.63	6.27	8.74	13.53	5.44	4.78	4.62	4.95	6.43	5.94	3.46	3.79	4.12	

Calm : .00 %

Total # Operational Hours : 606

Distribution By Samples

Direction

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	26	45	76	22	38	53	82	33	29	28	29	39	36	21	22	25	604
< 110												1			1		2
< 210																	
>= 210																	
Totals	26	45	76	22	38	53	82	33	29	28	30	39	36	21	23	25	

Calm : .00 %

Total # Operational Hours : 606

Logger : 01 Parameter : NOX


Class Limits (PPB)




Site : LICA

Period : 05/01/07-05/31/07

Level : 10



Calibration Graph for Site: LICA Parameter: HOX Sequence: HO2 Phase: SPAII



LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

MAY 2007

OXIDES OF NITROGEN MAX instantaneous maximum in ppb

HOUR START HOUR END	0:00 1:00	1:00 2:00	2:00 3:00	3:00 4:00	4:00 5:00	5:00 6:00	6:00 7:00	7:00 8:00	8:00 9:00	9:00 10:00	10:00 11:00	11:00 12:00	12:00 13:00	13:00 14:00	14:00 15:00	15:00 16:00	16:00 17:00	17:00 18:00	18:00 19:00	19:00 20:00	20:00 21:00	21:00 22:00	22:00 23:00	23:00 0:00	DAILY MAX.	24-HOUR AVG.	RDGS.			
DAY																														
1	13	5	5	6	7	52	22	C	C	C	C	C	C	C	Izs	6	10	1	3	8	4	2	3	52	9.8	24				
2	1	1	1	3	3	31	3	9	29	21	7	5	4	5	Izs	15	4	9	5	7	2	3	2	31	7.8	24				
3	1	3	3	6	5	6	16	17	7	10	60	5	7	4	Izs	94	12	9	2	1	2	1	1	94	11.9	24				
4	1	4	2	3	13	12	6	11	92	7	23	6	4	Izs	9	23	7	3	6	4	2	33	1	2	92	11.9	24			
5	0	0	0	0	0	0	0	1	2	2	1	P	Izs	2	6	2	1	1	13	5	5	5	4	4	13	2.5	23			
6	4	15	5	5	4	7	14	9	2	2	2	Izs	6	1	1	6	2	2	5	1	2	7	2	9	15	4.9	24			
7	9	4	5	1	3	2	3	1	1	0	Izs	1	1	1	Izs	1	1	1	1	0	1	16	16	8	11	16	3.8	24		
8	8	10	12	10	11	8	10	9	4	Izs	2	1	1	1	Izs	2	1	1	6	2	13	3	10	20	4	2	1	20	6.5	24
9	1	0	0	0	2	5	0	5	Izs	5	4	7	3	2	Izs	5	4	7	3	1	1	5	24	25	4	2	25	4.3	24	
10	1	2	5	6	73	93	35	Izs	8	3	2	1	1	3	Izs	8	3	2	15	8	3	1	5	7	2	3	3	93	12.3	24
11	3	1	2	1	16	14	Izs	N	N	N	N	N	N	N	Izs	N	N	N	N	N	N	N	N	N	N	N	N	16	6.2	7
12	N	N	N	N	N	N	N	N	N	N	N	N	N	N	Izs	N	N	N	N	N	N	N	N	N	N	N	NA	NA	0	
13	N	N	N	N	N	N	N	N	N	N	N	N	N	N	Izs	N	N	N	N	N	N	N	N	N	N	N	NA	NA	0	
14	N	N	N	N	N	N	N	N	N	N	N	N	N	N	Izs	N	N	N	N	N	N	N	N	N	N	N	NA	NA	0	
15	N	N	N	N	N	N	C	C	C	C	Izs	58	310	1	10	15	2	4	9	10	2	2	310	38.5	18					
16	2	2	2	1	2	2	2	Izs	27	71	35	8	8	64	Izs	63	4	1	2	1	9	2	3	3	4	71	13.8	24		
17	6	14	6	11	11	11	Izs	374	500	161	3	2	5	1	Izs	1	1	1	1	2	2	7	1	4	2	500	49.0	24		
18	0	0	0	0	1	Izs	20	14	8	3	8	9	2	3	Izs	5	3	10	3	7	4	6	2	1	1	20	4.8	24		
19	0	0	0	1	Izs	1	4	49	4	2	15	8	14	11	Izs	4	5	2	5	5	6	7	4	5	4	49	6.8	24		
20	3	19	6	Izs	4	5	2	3	6	4	3	2	4	1	Izs	2	3	6	3	4	5	21	14	11	9	21	6.1	24		
21	2	5	Izs	10	11	11	6	2	1	2	3	1	8	5	Izs	1	1	1	6	3	9	6	8	7	6	11	5.0	24		
22	5	Izs	7	7	20	21	11	8	10	7	3	2	10	3	Izs	3	1	2	3	10	22	11	8	8	11	22	8.4	24		
23	Izs	13	7	5	5	3	4	10	12	9	3	8	2	1	Izs	1	1	5	3	2	9	0	1	7	Izs	13	5.0	24		
24	5	3	6	4	7	10	8	26	15	5	21	9	7	14	Izs	2	5	2	3	18	26	9	10	Izs	2	26	9.4	24		
25	1	2	2	3	16	9	9	5	4	2	12	2	2	3	Izs	24	13	9	4	2	7	11	Izs	5	4	24	6.6	24		
26	9	4	6	3	3	2	3	5	7	8	10	4	8	5	Izs	6	3	2	1	7	5	Izs	8	23	3	23	5.9	24		
27	8	4	4	6	8	7	3	3	8	7	4	5	8	7	Izs	2	3	9	6	7	Izs	6	2	15	2	15	5.8	24		
28	3	5	2	2	5	14	6	5	4	500	102	5	6	4	Izs	3	4	3	2	Izs	1	0	0	0	4	500	29.6	24		
29	0	0	0	0	1	3	7	14	19	18	8	5	19	44	Izs	2	7	5	Izs	7	9	5	5	10	3	44	8.3	24		
30	4	4	5	5	13	16	14	4	3	3	1	17	2	4	Izs	5	8	2	Izs	2	3	1	11	28	6	5	28	7.1	24	
31	3	4	3	3	33	3	3	8	3	2	4	6	3	20	Izs	6	2	2	7	12	36	11	9	36	8.0	24				
HOURLY MAX	13	19	12	11	73	93	35	374	500	500	102	17	19	64	Izs	310	94	15	15	18	26	24	36	23	11					
HOURLY AVG	3.6	4.8	3.7	3.9	10.7	13.4	8.4	25.7	32.3	35.6	14.0	5.2	5.6	10.7	Izs	18.8	8.6	5.4	3.8	5.0	6.8	7.7	9.1	5.7	4.2					

STATUS FLAG CODES

S	- OUT OF SERVICE	Izs	- Izs - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

MONTHLY SUMMARY


NUMBER OF NON-ZERO READINGS:	577
MAXIMUM INSTANTANEOUS VALUE:	500 PPB @ HOUR(S) 9,10 ON DAY(S) 17,28

Izs CALIBRATION TIME:	29 HRS	OPERATIONAL TIME:	648 HRS
MONTHLY CALIBRATION TIME:	14 HRS		
STANDARD DEVIATION:	36.53		

MOUNTAIN STANDARD TIME




01 Hour Averages



O₃

01 Hour Averages



LICA
O3 / WD Joint Frequency Distribution (Percent)

May 2007

Distribution By % Of Samples

Logger Id : 01
 Site Name : LICA
 Parameter : O3
 Units : PPB

Wind Parameter : WD
 Instrument Height : 10 Meters

Direction

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	3.68	6.95	11.48	3.40	6.09	9.21	12.19	4.39	2.69	3.54	4.39	5.67	4.53	2.69	4.25	3.68	88.93
< 110	.00	.00	.14	.00	.14	.00	.28	1.13	1.56	1.13	.85	1.27	1.27	2.26	.85	.14	11.06
< 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	
Totals	3.68	6.95	11.63	3.40	6.24	9.21	12.48	5.53	4.25	4.68	5.24	6.95	5.81	4.96	5.10	3.82	

Calm : .00 %

Total # Operational Hours : 705

Distribution By Samples

Direction


Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	26	49	81	24	43	65	86	31	19	25	31	40	32	19	30	26	627
< 110			1		1		2	8	11	8	6	9	9	16	6	1	78
< 210																	
>= 210																	
Totals	26	49	82	24	44	65	88	39	30	33	37	49	41	35	36	27	

Calm : .00 %

Total # Operational Hours : 705

Logger : 01 Parameter : 03


Class Limits (PPB)




Site : LICA

Period : 05/01/07-05/31/07


Level : 10



Calibration Graph for Site: LICA Parameter: 03 Sequence: 03 Phase: SPAN



01 Hour Averages



VECTOR WIND SPEED

LICA
WS / WD Joint Frequency Distribution (Percent)

May 2007

Distribution By % Of Samples

Logger Id : 01
Site Name : LICA
Parameter : WS
Units : KPH

Wind Parameter : WD
Instrument Height : 10 Meters

Direction

Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 6.0	1.61	1.61	3.63	1.75	3.36	3.90	7.27	3.36	3.09	2.69	3.90	4.04	1.88	1.21	1.61	2.29	47.30
< 12.0	1.61	4.31	6.87	1.48	1.88	4.71	3.50	2.02	.80	1.21	.67	1.61	1.88	2.56	2.02	.67	37.87
< 20.0	.26	.67	.80	.13	1.07	.53	.94	.00	.26	.53	.40	1.61	1.61	.80	1.34	.80	11.85
< 29.0	.00	.00	.00	.00	.00	.00	.67	.00	.00	.00	.40	.13	.00	.13	.00	.00	1.34
< 39.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 39.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	3.50	6.60	11.32	3.36	6.33	9.16	12.39	5.39	4.17	4.44	5.39	7.41	5.39	4.71	4.98	3.77	

Calm : 1.61 %

Total # Operational Hours : 742

Distribution By Samples

Direction


Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 6.0	12	12	27	13	25	29	54	25	23	20	29	30	14	9	12	17	351
< 12.0	12	32	51	11	14	35	26	15	6	9	5	12	14	19	15	5	281
< 20.0	2	5	6	1	8	4	7		2	4	3	12	12	6	10	6	88
< 29.0							5			3	1		1				10
< 39.0																	
>= 39.0																	
Totals	26	49	84	25	47	68	92	40	31	33	40	55	40	35	37	28	

Calm : 1.61 %

Total # Operational Hours : 742

Logger : 01 Parameter : WS


Class Limits (KPH)




Site : LICA

Period : 05/01/07-05/31/07


Level : 10



01 Hour Averages



01 Hour Averages



VECTOR WIND DIRECTION

LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

MAY 2007

VECTOR WIND DIRECTION (WD) hourly averages in degrees

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24-HOUR AVG	24-HOUR AVG	QUADRANT	RDGS.	
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00					
DAY																													
1	251	115	148	149	132	137	204	235	225	111	105	79	151	157	157	136	138	155	151	137	118	116	112	108	132	SE	24		
2	83	82	86	78	76	84	87	85	89	76	83	45	49	27	52	64	41	25	32	33	41	39	40	23	63	ENE	24		
3	38	38	28	43	45	45	34	41	31	46	95	68	58	41	36	32	35	34	33	36	38	38	43	46	42	NE	24		
4	40	48	45	32	41	53	50	16	63	70	86	84	80	81	83	105	129	130	134	135	134	129	135	135	103	ESE	24		
5	137	135	136	149	155	168	211	212	217	228	232	P	235	237	235	247	246	253	246	156	144	135	136	213	204	SSW	23		
6	322	118	229	154	237	265	234	227	245	244	244	251	246	242	251	243	238	245	232	214	221	270	311	260	242	WSW	24		
7	293	241	262	274	252	252	256	271	280	269	278	268	263	267	266	274	271	269	283	282	264	141	349	183	268	W	24		
8	181	248	276	219	232	221	241	242	248	254	270	269	274	275	286	275	10	44	51	39	42	62	64	35	290	WNW	24		
9	55	32	20	28	32	13	1	16	3	350	329	0	352	331	329	321	313	296	270	228	131	112	140	149	356	N	24		
10	218	235	277	279	89	77	136	255	31	242	156	184	161	134	143	131	151	126	135	193	201	120	123	148	SE	24			
11	125	126	125	124	121	122	128	122	116	121	132	152	147	P	195	197	31	29	41	163	155	144	99	121	125	SE	23		
12	118	92	120	89	73	97	117	129	128	144	181	158	215	248	276	294	285	303	290	295	307	296	281	248	272	W	24		
13	232	226	245	237	251	251	257	248	346	279	285	297	274	264	296	283	292	306	306	39	24	144	253	235	279	W	24		
14	193	246	212	234	207	240	233	283	326	306	301	308	320	313	306	316	321	331	324	313	290	42	50	32	313	NW	24		
15	54	60	243	243	50	99	124	114	112	110	116	91	68	106	178	223	127	216	222	143	139	138	140	143	130	SE	24		
16	149	168	140	141	165	157	171	159	151	172	190	173	173	173	183	200	201	204	203	179	169	209	201	243	181	S	24		
17	194	243	269	171	223	243	240	235	241	321	315	298	316	291	285	292	290	296	320	345	20	30	38	36	320	NW	24		
18	15	27	23	24	34	44	38	30	32	33	33	27	29	28	87	102	108	119	115	113	108	102	108	119	57	ENE	24		
19	123	125	115	124	106	100	119	111	108	102	105	101	96	110	106	124	111	112	104	89	92	90	88	85	107	ESE	24		
20	84	86	55	82	359	10	340	286	285	303	283	281	263	276	280	43	82	55	66	77	99	76	57	66	0	N	24		
21	91	142	230	42	125	52	48	359	333	290	315	342	359	20	11	22	21	21	6	9	351	35	261	242	8	N	24		
22	235	253	237	232	229	252	334	6	19	28	40	45	47	54	49	49	47	49	48	330	218	243	250	36	NE	24			
23	174	211	215	246	293	298	299	314	357	332	347	55	42	19	34	1	0	331	34	11	345	348	9	30	350	N	24		
24	36	346	358	254	216	44	50	63	32	32	46	54	43	34	41	44	48	48	83	81	213	118	113	122	51	NE	24		
25	130	125	152	127	75	116	119	127	132	157	138	228	240	245	174	59	93	219	213	206	196	138	142	146	167	SSE	24		
26	133	120	157	130	134	146	177	177	157	194	207	197	196	169	189	162	193	152	165	164	125	125	134	130	170	SSE	24		
27	139	25	27	84	79	106	114	134	121	135	120	122	119	133	134	137	132	106	278	307	334	347	27	342	111	ESE	24		
28	303	310	334	357	277	313	316	311	318	313	316	310	299	307	308	306	308	317	331	333	338	346	351	355	321	NW	24		
29	354	338	346	345	1	19	35	38	37	24	37	48	61	72	88	80	65	94	120	128	131	191	127	133	48	NE	24		
30	99	274	108	253	138	280	120	128	174	262	122	119	114	133	152	146	201	209	203	207	182	139	134	137	158	SSE	24		
31	157	151	138	143	119	200	176	142	171	146	182	173	166	157	180	177	188	186	199	155	147	87	88	226	166	SSE	24		
HOURLY AVG	354	346	358	357	359	313	340	359	357	350	347	342	359	331	329	321	321	331	345	351	348	351	355						

STATUS FLAG CODES


S	- OUT OF SERVICE	Izs	- Izs - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE

LAST CALIBRATION:	NA
DECLINATION :	19 DEGREES FROM MAGNETIC NORTH
MONTHLY CALIBRATION TIME:	0 HRS
STANDARD DEVIATION	97.93
OPERATIONAL TIME:	742 HRS
AMD OPERATION UPTIME	99.7 %
MONTHLY AVERAGE	63.00 DEG



MOUNTAIN STANDARD TIME

01 Hour Averages



LAKELAND INDUSTRY & COMMUNITY ASSOCIATION - COLD LAKE

MAY 2007

STANDARD DEVIATION WIND DIRECTION (STDWDIR) hourly averages in degrees

HOUR START	0:00	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	
HOUR END	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	0:00	
DAY																									
1	51	56	59	63	56	61	47	39	58	51	40	62	35	39	45	31	35	38	31	18	17	19	19	21	
2	19	22	21	20	21	19	18	21	19	20	16	18	18	18	17	17	16	18	18	19	17	19	15		
3	22	19	19	18	19	17	17	16	17	24	21	21	18	18	17	17	17	17	17	17	18	16	16	15	
4	16	16	16	21	25	19	26	20	20	17	17	17	16	17	17	14	14	15	15	14	14	15	15	16	
5	17	16	16	30	32	36	28	25	20	19	18	P	19	19	18	21	24	23	19	27	26	19	25	23	
6	52	49	53	62	32	48	24	20	21	22	21	24	23	24	22	20	21	19	17	14	17	26	40	55	
7	23	19	16	17	15	15	19	20	21	21	22	23	22	23	22	22	21	22	19	16	17	38	51	55	
8	58	64	29	23	15	17	20	18	18	21	21	24	20	25	24	25	29	21	21	19	19	18	18	21	
9	20	21	28	19	18	22	18	20	19	18	17	24	25	20	19	21	19	21	22	19	23	17	27	36	
10	43	46	49	39	31	47	38	43	58	58	41	54	45	33	31	17	31	17	18	20	35	24	23	12	
11	10	10	11	11	14	13	16	25	32	33	47	39	35	P	59	50	33	32	40	36	36	34	17	15	
12	16	18	22	21	15	20	19	18	30	36	36	60	40	26	24	17	20	15	18	15	12	14	12	10	
13	24	27	25	7	12	13	23	40	38	37	32	27	33	34	52	43	64	36	32	26	59	61	41	31	
14	63	44	31	48	57	49	24	48	28	21	24	24	26	26	23	22	20	20	14	11	25	18	28	59	
15	42	36	73	53	45	25	16	23	22	32	46	49	54	70	48	54	55	43	30	23	11	16	22	24	
16	49	55	49	32	50	38	40	41	38	41	39	39	40	40	39	32	35	31	31	38	37	28	30	43	
17	28	39	61	26	47	33	20	29	35	53	38	49	19	26	26	27	22	15	14	17	20	18	17	18	
18	21	21	20	19	19	17	18	18	19	21	19	19	20	22	29	23	21	18	19	20	21	21	20	18	
19	16	15	19	15	21	21	18	21	21	21	22	22	22	20	21	17	20	22	21	17	20	19	20	19	
20	19	21	20	26	22	23	29	32	19	20	28	29	33	38	34	51	31	22	21	21	25	26	60	32	
21	18	33	22	40	51	46	38	30	42	35	28	40	38	19	24	23	22	19	21	26	23	42	39	38	
22	59	15	34	38	47	54	31	21	23	25	24	24	29	24	26	28	23	24	20	18	31	44	17	31	
23	54	65	44	14	14	15	15	24	32	55	61	54	48	36	38	39	43	32	19	23	21	21	18	20	
24	21	31	47	64	44	24	21	38	34	23	27	22	27	28	29	32	30	26	19	34	34	53	18	16	
25	10	11	42	41	42	36	41	51	35	44	46	47	33	32	41	26	27	33	27	27	26	20	29	35	
26	14	33	30	31	14	40	42	39	40	38	35	35	41	42	41	45	36	33	36	27	12	12	10	25	
27	30	47	42	24	34	19	37	41	21	46	32	30	25	26	31	50	42	24	44	38	38	40	25	20	
28	14	13	20	28	44	39	21	19	15	14	15	15	13	14	15	14	14	18	19	18	19	19	20		
29	20	17	19	18	23	20	20	21	20	21	21	22	24	25	32	33	45	31	20	13	13	60	28	32	
30	69	36	46	55	61	69	25	37	66	63	44	42	44	57	56	41	47	41	35	25	24	40	58	14	
31	48	47	46	41	37	61	46	34	45	41	54	50	47	45	53	53	48	39	36	27	29	17	51	45	

STATUS FLAG CODES

S	- OUT OF SERVICE	IZS	- IZS - DAILY ZERO/SPAN CHECK
N	- INVALID DATA	M	- MAINTENANCE
D	- INSTRUMENT DRIFT	P	- POWER FAILURE
C	- CALIBRATION	NA	- NOT APPLICABLE


LAST CALIBRATION: NA

IZS CALIBRATION TIME: 0 HRS OPERATIONAL TIME: 742 HRS




MOUNTAIN STANDARD TIME

01 Hour Averages




TEMPERATURE

01 Hour Averages



RELATIVE HUMIDITY

01 Hour Averages



MAY 2007
CALIBRATION REPORTS

LICA – COLD LAKE

SO₂

SO₂ Calibration Report

Station Information

Calibration Date	May 1, 2007	Previous Calibration	April 2, 2007
Company	Lakeland Industry & Community Association		
Plant / Location	LICA 1 - Cold Lake South		
Start Time (MST)	14:50	End Time (MST)	19:00
Reason:	Monthly/Repair Calibration		
Barometric Pressure	714 mmHg	Station Temperature	23 Deg C
Cal Gas	47.6 ppm	Cal Gas Expiry date	06/23/2007
DAS Output Voltage	0 - 10 Volts		

Equipment Information

Analyzer Make / Model:	TECO 43A	S/N :	43A-4468-272	Method:	Fluorescent
Converter Make / Model:	-	S/N :	-		
Calibrator Make / Model:	Environics 2000	S/N :	1991	Method:	Dilution
DAS Make / Model:	ESC 8832	S/N :	263		
Flow Meter:	Environics 2000	S/N :	1991		

Analyzer Settings

Concentration Range	Before Calibration			After Calibration		
	0 - 500 ppb					
Sample Flow / Box Temp	725 ccm	OK	Deg C	725 ccm	OK	Deg C
HVPS / Lamp Setting	OK	843		OK	845	
PMT / RxCell Temp	OK Deg C	OK	50	OK Deg C	OK	Deg C
Converter / IZS Temp	NA Deg C	OK	40	NA Deg C	OK	Deg C
Offset / Slope	98	852		98	852	

Calibration Data

Dilution Flow Rate	Source Gas Flow Rate	Calculated Concentration	Indicated Conc. (DAS)	Correction Factor
ZERO	ZERO	0	0	N/A
4958	42	400	394	1.0148
4958	42	400	400	0.9996
4979	21	200	199	1.0046
4989	10.5	100	98	1.0201
ZERO	ZERO	0	0	N/A
Sum of Least Squares				1.0015
New Correction Factor				0.9996

Before Calibration

After Calibration

Auto Zero	0	0
Auto Span	347	353
Sample Lines Connected		YES
Percent Change from Previous Calibration		-1.5%


Notes: During As Found span the daily calibration program started, problem fixed immediately, repeated As Found span point.

Calibration Performed by: Shea Beaton


SO₂ Calibration Curve

Calibration Date	May 1, 2007		
Company	Lakeland Industry & Community Association		
Plant / Location	LICA 1 - Cold Lake South		
Start Time (MST)	14:50	End Time (MST)	19:00

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient	(≥ 0.995) (0.85 to 1.15)	0.999970
			Slope	(± 3% F.S.)	1.001838
			Intercept		-1.003983
0	0	n/a			
100	98	1.0201			
200	199	1.0046			
400	400	0.9996			



01 Minute Averages



TRS

TRS Calibration Report

Station Information

Calibration Date	May 1, 2007		Previous Calibration	April 2, 2007	
Company	Lakeland Industry & Community Association				
Plant / Location	LICA 1 - Cold Lake South				
Start Time (MST)	8:15	End Time (MST)	11:55		
Reason:	Monthly Calibration				
Barometric Pressure	714	mm Hg	Station Temperature	24	Deg C
Cal Gas	10.2	ppm	Cal Gas Expiry date	09/05/2007	
DAS Output Voltage	0 - 10	Volts			

Equipment Information

Analyzer Make / Model:	TECO 43A	S/N :	43A-35786-254	Method:	Fluorescent
Converter Make / Model:	CD Nova CDN 101	S/N :	250		
Calibrator Make / Model:	Environics 2000	S/N :	1991	Method:	Dilution
DAS Make / Model:	ESC 8832	S/N :	263		
Flow Meter:	Environics 2000	S/N :	1991		

Analyzer Settings

	Before Calibration			After Calibration		
	Concentration Range	0 - 100	ppb	Sample Flow / Box Temp	ccm	Deg C
HVPS / Lamp Setting	400 ccm	OK	Deg C	400	OK	Deg C
PMT / RxCell Temp	OK	886		OK	886	
Converter / IZS Temp	850 Deg C	OK	Deg C	850	OK	Deg C
Offset / Slope	820	762		820	828	

Calibration Data

Dilution Flow Rate	Source Gas Flow Rate	Calculated Concentration	Indicated Conc. (DAS)	Correction Factor
ZERO	ZERO	0	0	N/A
5000	40	81	79	1.0247
5000	40	81	81	0.9994
5000	20	41	41	0.9912
5000	10	20	20	1.0180
ZERO	ZERO	0	0	N/A
Sum of Least Squares				0.9987
New Correction Factor				0.9994

Before Calibration

After Calibration

Auto Zero	0	0
Auto Span	88	87
Sample Lines Connected		YES
Percent Change from Previous Calibration		-2.5%


Notes: Checked pump vacuum after as found points, vacuum at pump - 12.2 inHg

Calibration Performed by: Shea Beaton


TRS Calibration Curve

Calibration Date	May 1, 2007		
Company	Lakeland Industry & Community Association		
Plant / Location	LICA 1 - Cold Lake South		
Start Time (MST)	8:15	End Time (MST)	11:55

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient	(≥ 0.995) (0.85 to 1.15) (± 3% F.S.)	0.999934 1.002643 -0.081078
0	0	n/a			
20	20	1.0180			
41	41	0.9912			
81	81	0.9994			



01 Minute Averages



THC

THC Calibration Report

Station Information

Calibration Date:	May 1, 2007	Previous Calibration	April 19, 2007
Lakeland Industry and Community Association			
LICA1/Cold Lake			
Start Time (MST)	12:00	End Time (MST)	15:35
Reason: Monthly Calibration			
Barometric Pressure:	713 mmHg	Station Temperature:	22 Deg C
Calibrator:	Enivironics 2000	S/N:	1991
Cal Gas Concentration:	1010 ppm	Cal Gas Expiry Date:	Jan-10
DAS make & Model:	ESC 8832	S/N :	263
Output Voltage Range:	0 - 10 VDC		

Analyzer Information

Make / Model	TECO 51C-LT	S/N :	51CLT-42740-8718	Method	Flame Ionization
Analyzer Settings					

	Before Calibration		After Calibration	
Concentration Range	0 - 50	ppm	0 - 50	ppm
Sample Pressure	6.5	psi	6.5	psi
Hydrogen Pressure	8	psi	8	psi
Air Pressure	18	psi	18	psi

Calibration Data

Dilution Flow	Source Gas Flow	Calculated Concentration	Indicated Concentration	Correction Factor
ZERO	ZERO	0.0	-0.1	N/A
ZERO	ZERO	0.0	0.0	N/A
2000	80.0	38.8	39.8	0.9760
2000	80.0	38.8	39.0	0.9961
2000	45.0	22.2	21.9	1.0148
2000	20.0	10.0	9.6	1.0417
ZERO	ZERO	0.0	N/A	N/A
Correction Factor:				0.9961

Percent Change

Previous Calibration Correction Factor:	0.9978
Current Correction Factor Before Span Adjust:	0.9760
Percent Change:	2.2%

IZS Calibration Data


	Before Calibration		After Calibration
Auto Zero	0.0		0.0
Auto Span	32.1		31.3
Sample Lines Connected			YES

Notes:	Cylinder Pressures	
Span	950 psi	
Hydrogen	1200 psi	
Zero Air	Maxxam-owned API 701 zero air supply with catalytic oxidizer	


Calibration Performed by: _____ Shea Beaton _____

THC Calibration Curve

Calibration Date	May 1, 2007				
Company	Lakeland Industry and Community Association				
Plant / Location	LICA1/Cold Lake				
Start Time (MST)	12:00	End Time (MST)	15:35		
Calculated Conc. ppm	Indicated Response ppm	Correction Factor	Correlation Coefficient (≥ 0.995) Slope Intercept	(0.85 to 1.15) ($\pm 3\%$ F.S.)	0.999789 1.005834 -0.246429
0.0	0.0				
10.0	9.6	1.0417			
22.2	21.9	1.0148			
38.8	39.0	0.9961			



01 Minute Averages



PARTICULATE MATTER

2.5

TEOM® Calibration

Station

Date: May 1, 2007
 Station Name: LICA
 Location: Cold Lake - South
 Operator: Maxxam Analytics

Transfer Standard

Make/Model: Bios DC-2
 Serial Number: 1193
 Cell s/n: 2272
 Thermometer s/n: 14-990A

Sampler

Make/Model R & P Series 1400 a TEOM
 Unit # AMU 1494
 Control unit s/n 140AB213859701
 Transducer s/n 140AB213859701
 Parameter PM 2.5

Set-up and current Sampler readings

F-Main Set Pt (l/min)	3.00
F-Aux Set Pt (l/min)	13.67
Filter Load (%)	69
K _o Factor	11095
Temp (°C)	6.1
Press (ATM)	0.944

Conversion from mmHg or "Hg to ATM (Atmospheres)

$$\text{ATM} = (\text{mmHg}) \times (1.316 \times 10^{-3}) \quad \text{or} \quad \text{ATM} = ("Hg) \times (3.34207 \times 10^{-2})$$

Note: Tolerances are noted as **BOLD** in Brackets

Calibration

Zero flow

Pump Off

F-Main (l/min) 0.00
 F-Aux (l/min) 0.00

Pump On (Time to reach set points)

(45-60 Sec)	40
(45-60 Sec)	54

Temperature/Pressure

Measured Temp ($\pm 1^\circ\text{C}$) 5.6
 Measured Press ($\pm 1.5\%$ ATM) 0.938

$\Delta^\circ\text{C}$	-0.5
$\Delta \% \text{ ATM}$	-0.6%

Flow Audit

Indicated Main/Aux Flow (l/min) 3.00 / 13.65
 Total Flow = Main + Aux (l/min) 16.65
 Measured Total Flow (l/min) 16.35
 Measured Main Flow (l/min) 2.91

$\Delta \% \text{ from Set-pt}$

($\pm 2\%$)	0.0%	/	0.1%
($\pm 2\%$)	0.1%		
($\pm 1.0 \text{ l/min. (5.65\%)}$)	1.8%		
($\pm 0.2 \text{ l/min. (6.25\%)}$)	3.1%		

Leak Check

Main (< 0.15 l/min) 0.03
 Aux (< 0.15 l/min) 0.03

Actual leakage = Pump On - Pump Off

0.03

0.03

K_o Factor

Measured NA
 K_o Difference ($\pm 2.5\%$) NA

Start Time: 7:00

Finish Time:

10:30

Sample Inlet Cleaned:

YES

Sample Inlet Connected:

YES

Comments: Fadj Main=0.960 Fadj Aux=0.945 before audit-Fadj Main=0.980 Fadj Aux=0.970 After audit

After audit the flow adjusts were changed to bring measured flows closer to indicated. Total

now 16.72 lpm Main flow now 2.99 lpm. Changed TEOM filter, large in line bypass filter and

MFC filters

Calibrator/s:

Shea Beaton

NO₂

NOx - NO- NO₂ Calibration Report
Station Information

Calibration Date	May 1, 2007		Previous Calibration	April 3, 2007	
Company	Lakeland Ind & Comm. Assoc.		Plant/Location	LICA 1 - Cold Lake South	
Start Time (MST)	7:20		End Time (MST)	15:55	
Reason:	Monthly Calibration				
Barometric Pressure	713	mmHg	Station Temperature	24.0	Deg C
Cal Gas Concentration	NOx	52.7 ppm	NO	52.2 ppm	Cal Gas Expiry date 23/06/2008
DAS Output Voltage	0 - 5	Volts			

Equipment Information

Analyzer Make / Model:	TECO 42	S/N :	42-33684-247	Method:	Chemiluminescent
Calibrator Make / Model:	API 700	S/N:	690		
DAS Make / Model:	ESC 8832	S/N :	263		
Flow Meter:	BIOS Dry Cal - DC 2	S/N :	1193		

Analyzer Settings

Concentration Range	Before Calibration				After Calibration			
	592	ccm	332	Deg C	0 - 500	ppb	333	Deg C
Sample Flow/Conv. Temp	OK	ccm	-24.5	"Hg-A	596	ccm	-25	"Hg-A
Ozone Flow / Vacuum	OK	ccm	-24.5	"Hg-A	OK	ccm	-25	"Hg-A
HVPS	OK	Volts			OK	Volts		
Rx/ Temp / PMT Temp	50.5	Deg C	-2.9	Deg C	50.5	Deg C	-2.9	Deg C
Box Temp / IZS Temp	31.7	Deg C	OK	Deg C	33.6	Deg C	OK	Deg C
Offset	2.6	NOx	2.5	NO	3.5	NOx	3	NO
Slope	1.006	NOx	0.995	NO	1.005	NOx	1.177	NO

Gas Phase Titration Calibration Data

Dilution Air Flow Rate	Source Flow Rate	O3 Set Point	Calculated Concentration		Indicated Concentration			Correction Factor	
			NOx	NO	NOx	NO	NO2	NOx	NO
ZERO	N/A	N/A	0	0	0	0	0	N/A	N/A
ZERO	N/A	N/A	0	0	0	0	0	N/A	N/A
4961	38.3	N/A	404	400	350	347	3	1.1535	1.1525
4961	38.3	N/A	404	400	402	398	3	1.0043	1.0048
								Converter Efficiency	
4961	38.3	250	404	N/A	399	128	271	99%	
4961	38.3	150	404	N/A	400	226	173	99%	
4961	38.3	75	404	N/A	399	309	89	97%	
4961	38.3	N/A	404	400	396	392	4	N/A	
4961	38.3	N/A	404	400	405	402	3	0.9969	0.9948
								Converter Efficiency	
4961	38.3	250	404	N/A	404	82	323	101%	
4961	38.3	150	404	N/A	404	228	176	102%	
4961	38.3	75	404	N/A	403	313	90	102%	
4961	38.3	N/A	404	400	403	399	3	N/A	
								Correction Factor	
4976	23.9	N/A	252	250	249	246	2	1.0117	1.0143
4985	14.4	N/A	152	150	148	146	1	1.0256	1.0298
ZERO	N/A	N/A	0	0	0	0	0	N/A	N/A
Linearity OK?			Yes	No	Sum of Least Squares			1.0081	1.0095
Flows Checked on-site?			Yes	No	New Correction Factor			1.0043	1.0048
					Average Converter Efficiency			98%	

Before Calibration	After Calibration								
	Auto Zero	0	NOx	0	NO2	0	NOx	0	NO2
Auto Span	289	NOx	286	NO2	307	NOx	305	NO2	
Sample Lines Connected									
Percent Change from Previous Calibration									


After first GPT converter efficiency was not constant, return to high point, came in lower than expected.

Checked calibrator flows and repeated span adjustment and GPT

Calibration Performed by: Shea Beaton


NOx Calibration Curve

Calibration Date	May 1, 2007		
Company	Lakeland Ind & Comm. Assoc.		
Plant / Location	LICA 1 - Cold Lake South		
Start Time (MST)	7:20	End Time (MST)	15:55
Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient (≥ 0.995) Slope Intercept (0.85 to 1.15) ($\pm 3\%$ F.S.)
0	0	N/A	0.999919
152	148	1.0256	0.996455
252	249	1.0117	-1.395323
404	402	1.0043	



NO₂ Calibration Curve


Calibration Date	May 1, 2007		
Company	Lakeland Ind & Comm. Assoc.		
Plant / Location	LICA 1 - Cold Lake South		
Start Time (MST)	7:20	End Time (MST)	15:55
Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient (≥ 0.995) Slope Intercept (0.85 to 1.15) ($\pm 3\%$ F.S.)
0	3	N/A	0.999953 1.001533 2.026625
89	90	0.9889	
174	176	0.9886	
320	323	0.9907	




NO Calibration Curve

Calibration Date	May 1, 2007		
Company	Lakeland Ind & Comm. Assoc.		
Plant / Location	LICA 1 - Cold Lake South		
Start Time (MST)	7:20	End Time (MST)	15:55

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient	(≥ 0.995) (0.85 to 1.15)	0.999885
			Slope	(± 3% F.S.)	0.995993
			Intercept		-1.644479
0	0	N/A			
150	146	1.0298			
250	246	1.0143			
400	398	1.0048			



01 Minute Averages



NOx - NO- NO₂ Calibration Report

Station Information

Calibration Date	May 14, 2007		Previous Calibration	May 1, 2007	
Company	Lakeland Ind & Comm. Assoc.		Plant/Location	LICA 1 - Cold Lake South	
Start Time (MST)	9:00		End Time (MST)	16:40	
Reason:	Monthly Calibration				
Barometric Pressure	718	mmHg	Station Temperature	23.0	Deg C
Cal Gas Concentration	NOx	52.7 ppm	NO	52.2 ppm	Cal Gas Expiry date
DAS Output Voltage	0 - 5	Volts			23/06/2008

Equipment Information

Analyzer Make / Model:	TECO 42	S/N :	42-33684-247	Method:	Chemiluminescent
Calibrator Make / Model:	API 700	S/N:	690		
DAS Make / Model:	ESC 8832	S/N :	263		
Flow Meter:	BIOS Dry Cal - DC 2	S/N :	1193		

Analyzer Settings

Concentration Range	Before Calibration				After Calibration			
	589	ccm	332	Deg C	0 - 500	ppb	332	Deg C
Sample Flow/Conv. Temp	OK	ccm	-22	"Hg-A	603	ccm	-25	"Hg-A
Ozone Flow / Vacuum	OK	ccm	-22	"Hg-A	OK	ccm	-25	"Hg-A
HVPS	OK	Volts			OK	Volts		
Rx/ Temp / PMT Temp	50.5	Deg C	-2.9	Deg C	50.5	Deg C	-2.9	Deg C
Box Temp / IZS Temp	31.7	Deg C	OK	Deg C	32.1	Deg C	OK	Deg C
Offset	3.5	NOx	3	NO	2.8	NOx	2.7	NO
Slope	1.005	NOx	1.177	NO	1.005	NOx	1.063	NO

Gas Phase Titration Calibration Data

Dilution Air Flow Rate	Source Flow Rate	O3 Set Point	Calculated Concentration		Indicated Concentration			Correction Factor	
			NOx	NO	NOx	NO	NO2	NOx	NO
ZERO	N/A	N/A	0	0	0	0	0	N/A	N/A
4961	38.3	N/A	404		328	326	2	1.2309	1.2267
ZERO	N/A	N/A	0	0	0	0	0	N/A	N/A
4961	38.3	N/A	404		403	400	3	1.0018	0.9998
								Converter Efficiency	
4961	38.3	250	404	N/A	409	81	328	102%	
4961	38.3	150	404	N/A	406	203	203	102%	
4961	38.3	75	404	N/A	404	301	103	101%	
4961	38.3	N/A	404	400	402	398	3	N/A	
								Correction Factor	
4976	23.9	N/A	252	250	247	245	2	1.0199	1.0185
4985	14.4	N/A	152	150	147	146	0	1.0326	1.0298
ZERO	N/A	N/A	0	0	0	0	0	N/A	N/A
Linearity OK?		Yes	No	Sum of Least Squares			1.0092	1.0072	
Flows Checked on-site?		Yes	No	New Correction Factor			1.0018	0.9998	
				Average Converter Efficiency			101%		

Auto Zero	Before Calibration				After Calibration			
	0	NOx	0	NO2	0	NOx	0	NO2
Auto Span	55	NOx	54	NO2	299	NOx	297	NO2

Sample Lines Connected

Percent Change from Previous Calibration

NOx -19.0% NO -18.9%

Rebuilt pump after as found points. Allowed to stabilize. First O3 conc. Incorrect. Problem corrected

Span phase of daily cal configured to short. Changed and repeated span phase.

Calibration Performed by: Shea Beaton

NOx Calibration Curve

Calibration Date
Company
Plant / Location
Start Time (MST)

May 14, 2007

Lakeland Ind & Comm. Assoc.

LICA 1 - Cold Lake South

9:00

End Time

(MST)

16:40

Calculated Conc.

ppb

0

152

252

404

Indicated Response

ppb

0

147

247

403

Correction Factor

N/A

1.0326

1.0199

1.0018

Correlation Coefficient

(≥ 0.995)

(0.85 to 1.15)

Slope

Intercept

($\pm 3\%$ F.S.)


0.999767

0.998210

-2.249617

Indicated Conc. PPB


NOx Calibration Curve



NO₂ Calibration Curve

Calibration Date	May 14, 2007		
Company	Lakeland Ind & Comm. Assoc.		
Plant / Location	LICA 1 - Cold Lake South		
Start Time (MST)	9:00	End Time (MST)	16:40


Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient (≥ 0.995) (0.85 to 1.15)	0.999989 1.019108 2.562168
0	3	N/A		
99	103	0.9612		
197	203	0.9704		
319	328	0.9726		




NO Calibration Curve

Calibration Date	May 14, 2007		
Company	Lakeland Ind & Comm. Assoc.		
Plant / Location	LICA 1 - Cold Lake South		
Start Time (MST)	9:00	End Time (MST)	16:40

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient (≥ 0.995) Slope Intercept	0.999763 1.000120 $(\pm 3\% \text{ F.S.})$ -2.219769
0	0	N/A		
150	146	1.0298		
250	245	1.0185		
400	400	0.9998		



01 Minute Averages



NOx - NO- NO₂ Calibration Report

Station Information

Calibration Date	May 15, 2007	Previous Calibration	May 14, 2007
Company	Lakeland Ind & Comm. Assoc.	Plant/Location	LICA 1 - Cold Lake South
Start Time (MST)	7:00	End Time (MST)	12:10
Reason:	Monthly/Repair Calibration		
Barometric Pressure	720 mmHg	Station Temperature	23.0 Deg C
Cal Gas Concentration	NOx 52.7 ppm	NO 52.2 ppm	Cal Gas Expiry date 23/06/2008
DAS Output Voltage	0 - 5 Volts		

Equipment Information

Analyzer Make / Model:	TECO 42	S/N :	42-33684-247	Method:	Chemiluminescent
Calibrator Make / Model:	API 700	S/N:	690		
DAS Make / Model:	ESC 8832	S/N :	263		
Flow Meter:	BIOS Dry Cal - DC 2	S/N :	1193		

Analyzer Settings

Concentration Range	Before Calibration				After Calibration			
	595	ccm	332	Deg C	0 - 500	ppb	333	Deg C
Sample Flow/Conv. Temp	OK	ccm	-23	"Hg-A	OK	ccm	-23	"Hg-A
Ozone Flow / Vacuum	OK	ccm	-23	"Hg-A	OK	ccm	-23	"Hg-A
HVPS	OK	Volts			OK	Volts		
Rx/ Temp / PMT Temp	50.5	Deg C	-2.9	Deg C	50.5	Deg C	-2.9	Deg C
Box Temp / IZS Temp	31.6	Deg C	OK	Deg C	33.3	Deg C	OK	Deg C
Offset	2.8	NOx	2.7	NO	3.6	NOx	3.4	NO
Slope	1.005	NOx	1.063	NO	1.006	NOx	1.341	NO

Gas Phase Titration Calibration Data

Dilution Air Flow Rate	Source Flow Rate	O3 Set Point	Calculated Concentration		Indicated Concentration			Correction Factor	
			NOx	NO	NOx	NO	NO2	NOx	NO
ZERO	N/A	N/A	0	0	0	0	0	N/A	N/A
4961	38.3	N/A	404		321	317	3	1.2578	1.2615
4961	38.3	N/A	404		403	399	3	1.0018	1.0023
								Converter Efficiency	
4961	38.3	250	404	N/A	409	75	334	102%	
4961	38.3	150	404	N/A	408	136	272	102%	
4961	38.3	75	404	N/A	406	267	139	103%	
4961	38.3	N/A	404	400	404	400	4	N/A	
								Correction Factor	
4976	23.9	N/A	252	250	247	245	2	1.0199	1.0185
4985	14.4	N/A	152	150	146	144	2	1.0397	1.0441
ZERO	N/A	N/A	0	0	0	0	0	N/A	N/A
Linearity OK?			Yes	No	Sum of Least Squares			1.0098	1.0101
Flows Checked on-site?			Yes	No	New Correction Factor			1.0018	1.0023
					Average Converter Efficiency			102%	

Auto Zero	Before Calibration				After Calibration			
	0	NOx	0	NO2	0	NOx	0	NO2
Auto Span	188	NOx	187	NO2	301	NOx	299	NO2

Sample Lines Connected

Percent Change from Previous Calibration

NOx -20.3% NO -20.8%

Last span low, checked analyzer, pump vaccum low 15inHg, pump diaphragms eroded.

Replaced charcoal scrubber, installed Maxxam-owned Wobble pump and ordered new rebuild kit

Calibration Performed by: Shea Beaton

NOx Calibration Curve

Calibration Date
Company
Plant / Location
Start Time (MST)

May 15, 2007

Lakeland Ind & Comm. Assoc.

LICA 1 - Cold Lake South

7:00

End Time

(MST)

12:10

Calculated Conc.

ppb

0

152

252

404

Indicated Response

ppb

0

146

247

403

Correction Factor

N/A

1.0397

1.0199

1.0018

Correlation Coefficient

(≥ 0.995)

(0.85 to 1.15)

($\pm 3\%$ F.S.)


0.999706

0.998789

-2.616436

Indicated Conc. PPB

NOx Calibration Curve



NO₂ Calibration Curve

Calibration Date
Company
Plant / Location
Start Time (MST)


May 15, 2007

Lakeland Ind & Comm. Assoc.
LICA 1 - Cold Lake South

7:00

End Time (MST) 12:10


Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient (≥ 0.995) (0.85 to 1.15)	0.999997 1.018266 4.216678
			Slope Intercept	($\pm 3\%$ F.S.)
0	4	N/A		
132	139	0.9496		
263	272	0.9669		
324	334	0.9701		




NO Calibration Curve

Calibration Date	May 15, 2007		
Company	Lakeland Ind & Comm. Assoc.		
Plant / Location	LICA 1 - Cold Lake South		
Start Time (MST)	7:00	End Time (MST)	12:10

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient (≥ 0.995) Slope Intercept	0.999683 0.998933 $(\pm 3\% \text{ F.S.})$ -2.732372
0	0	N/A		
150	144	1.0441		
250	245	1.0185		
400	399	1.0023		



01 Minute Averages



OZONE

O₃ Calibration Report

Station Information

Calibration Date	May 1, 2007	Previous Calibration	April 3, 2007
Company	Lakeland Industry & Community Association		
Plant / Location	LICA 1 - Cold Lake South		
Start Time (MST)	15:20	End Time (MST)	18:45
Reason:	Monthly Calibration		
Barometric Pressure	714 mm Hg	Station Temperature	23 Deg C
DAS Output Voltage	0 - 10 Volts		

Equipment Information

Analyzer Make / Model:	TECO 49	S/N :	AOM-13892-143	Method:	Fluorescent
Calibrator Make / Model:	API 700	S/N :	690	Method:	Dilution
DAS Make / Model:	ESC 8832	S/N :	263		
Flow Meter:	API 700	S/N :	690		

Analyzer Settings

	Before Calibration				After Calibration			
	Concentration Range	0 - 500 ppb			OK	3.75		
Box Temp	OK				OK			
O ₃ Set Level	3.75				3.75			
Sample Flow A/B	1 LPM	1 LPM			1 LPM	1 LPM		
Offset / Slope	51	0.69			51	0.61		

Calibration Data

Dilution Flow Rate	Ozone Set Point	Calculated Concentration	Indicated Conc. (DAS)	Correction Factor
ZERO	ZERO	0	1	N/A
5000	300	320	361	0.8864
5000	300	320	321	0.9969
5000	150	174	168	1.0357
5000	75	89	83	1.0723
ZERO	ZERO	0	1	N/A
				Sum of Least Squares
				New Correction Factor
				0.9969

Before Calibration

After Calibration

Auto Zero	1	1
Auto Span	279	249
Sample Lines Connected		YES
Percent Change from Previous Calibration		13.9%


Notes: During As Found span point the daily calibration program started, problem fixed immediately and repeated As Found point

Calibration Performed by: Shea Beaton


O₃ Calibration Curve

Calibration Date	May 1, 2007		
Company	Lakeland Industry & Community Association		
Plant / Location	LICA 1 - Cold Lake South		
Start Time (MST)	15:20	End Time (MST)	18:45

Calculated Conc. ppb	Indicated Response ppb	Correction Factor	Correlation Coefficient	(≥ 0.995) (0.85 to 1.15)	0.999139
			Slope	(± 3% F.S.)	1.003587
			Intercept		-3.022737
0	1	n/a			
89	83	1.0723			
174	168	1.0357			
320	321	0.9969			





01 Minute Averages



MAY 2007
LICA
PASSIVE BUBBLE MAPS



PASSIVE BUBBLE MAP

May 2007





PASSIVE BUBBLE MAP

May 2007





PASSIVE BUBBLE MAP

May 2007



PASSIVE BUBBLE MAP

May 2007



MAY 2007

LICA PASSIVE NETWORK

LAB ANALYSIS

Attention: MICHAEL BISAGA

LAKELAND INDUSTRY AND COMMUNITY ASSOCIATION
BONNYVILLE
PO BOX 8237
5006 - 50TH AVENUE
BONNYVILLE, AB, AB
CANADA T9N 2J5

Report Date: 2007/06/19

CERTIFICATE OF ANALYSIS

MAXXAM JOB #: A723237

Received: 2007/06/04, 9:00

Sample Matrix: Air

Samples Received: 1

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Analytical Method
H2S Passive Analysis (1)	1	2007/06/18	2007/06/19		EDM SOP-0320
NO2 Passive Analysis (1)	1	2007/06/18	2007/06/19		EDM SOP-0318
O3 Passive Analysis (1)	1	2007/06/18	2007/06/19		EDM SOP-0317
SO2 Passive Analysis (1)	1	2007/06/18	2007/06/19		EDM SOP-0319

Sample Matrix: Air

Samples Received: 25

Analyses	Quantity	Date Extracted	Date Analyzed	Laboratory Method	Analytical Method
H2S Passive Analysis (1)	16	2007/06/18	2007/06/19		EDM SOP-0320
NO2 Passive Analysis (1)	22	2007/06/18	2007/06/19		EDM SOP-0318
O3 Passive Analysis (1)	22	2007/06/18	2007/06/19		EDM SOP-0317
SO2 Passive Analysis (1)	25	2007/06/18	2007/06/19		EDM SOP-0319

(1) The detection limit is based on a 30 day sampling period.

Encryption Key

Please direct all questions regarding this Certificate of Analysis to your Project Manager.

JODI HANSON, Project Manager, Customer Service
Email: jodi.hanson@maxxamanalytics.com
Phone# (780) 468-3500

=====

Maxxam has procedures in place to guard against improper use of the electronic signature and have the required "signatories", as per section

Attention: MICHAEL BISAGA

LAKELAND INDUSTRY AND COMMUNITY ASSOCIATION
BONNYVILLE
PO BOX 8237
5006 - 50TH AVENUE
BONNYVILLE, AB, AB
CANADA T9N 2J5

Report Date: 2007/06/19

CERTIFICATE OF ANALYSIS

-2-

5.10.2 of ISO/IEC 17025:2005(E), signing the reports. SCC and CAEAL have approved this reporting process and electronic report format.

Total cover pages: 2

Edmonton: 9331 - 48th Street T6B 2R4 Telephone(780) 468-3500 FAX(780) 466-3332

Maxxam Job Number : PA723237
 Report Date : 2007/06/19

Sample Description	Set Number	Matrix	Date Sampled	Calculated H2S ppb	Calculated NO2 ppb	Calculated O3 ppb
1	F47658	Air	2007/04/26	N/A	0.7	26.8
2	F47659	Air	2007/04/26	0.10	1.1	32.7
3	F47660	Air	2007/04/27	N/A	1.3	33.8
4	F47661	Air	2007/04/27	0.09	0.7	33.0
5	F47662	Air	2007/04/27	N/A	1.7	29.6
7	F47663	Air	2007/04/27	N/A	0.9	37.3
8	F47664	Air	2007/04/26	N/A	0.9	34.6
9	F47665	Air	2007/04/26	0.11	1.0	32.0
10	F47666	Air	2007/04/26	0.05	0.5	30.5
11	F47667	Air	2007/04/26	0.08	0.5	31.1
12	F47668	Air	2007/04/26	0.03	0.8	34.7
13	F47669	Air	2007/04/26	0.13	1.1	34.3
14	F47670	Air	2007/04/26	N/A	0.8	33.2
15	F47671	Air	2007/04/27	0.09	1.0	32.8
16	F47672	Air	2007/04/27	0.14	1.4	32.7
17	F47673	Air	2007/04/27	0.08	1.1	33.7
18	F47674	Air	2007/04/27	N/A	0.8	34.0
19	F47675	Air	2007/04/27	0.09	1.4	30.0
20	F47676	Air	2007/04/26	N/A	0.1	27.8
21	F47677	Air	2007/04/27	0.06	2.5	20.9
10A	F47679	Air	2007/04/26	0.06	0.4	28.5
11A	F47680	Air	2007/04/26	0.07	0.5	31.5
22	F47683	Air	2007/04/26	0.06	N/A	N/A
23	F47684	Air	2007/04/26	0.07	N/A	N/A
24	F47685	Air	2007/04/26	0.14	N/A	N/A
25	F47686	Air	2007/04/26	N/A	3.4	30.6

LAKELAND INDUSTRY AND COMMUNITY ASSOCIATION
 Attention: MICHAEL BISAGA
 Client Project #: MAY 2007
 P.O. #:
 Site Reference: LICA

Maxxam Job Number : PA723237
 Report Date : 2007/06/19

Sample Description	Set Number	Matrix	Date Sampled	Calculated SO2 ppb
1	F47658	Air	2007/04/26	0.1
2	F47659	Air	2007/04/26	0.3
3	F47660	Air	2007/04/27	0.5
4	F47661	Air	2007/04/27	0.3
5	F47662	Air	2007/04/27	0.2
7	F47663	Air	2007/04/27	0.4
8	F47664	Air	2007/04/26	0.3
9	F47665	Air	2007/04/26	0.2
10	F47666	Air	2007/04/26	0.1
11	F47667	Air	2007/04/26	0.2
12	F47668	Air	2007/04/26	0.2
13	F47669	Air	2007/04/26	0.8
14	F47670	Air	2007/04/26	0.3
15	F47671	Air	2007/04/27	0.2
16	F47672	Air	2007/04/27	0.3
17	F47673	Air	2007/04/27	0.3
18	F47674	Air	2007/04/27	0.2
19	F47675	Air	2007/04/27	0.2
20	F47676	Air	2007/04/26	0.2
21	F47677	Air	2007/04/27	0.2
10A	F47679	Air	2007/04/26	0.2
11A	F47680	Air	2007/04/26	0.3
22	F47683	Air	2007/04/26	0.2
23	F47684	Air	2007/04/26	0.6
24	F47685	Air	2007/04/26	0.8
25	F47686	Air	2007/04/26	0.2



LAKELAND INDUSTRY AND COMMUNITY ASSOCIATION

Attention: MICHAEL BISAGA

Client Project #: MAY 2007

P.O. #:

Site Reference: LICA

Quality Assurance Report

Maxxam Job Number: PA723237

QA/QC Batch Num Init	QC Type	Parameter	Date Analyzed yyyy/mm/dd	Value	Recovery	Units	QC Limits
1682934 DF4	Calibration Check	Calculated NO2	2007/06/19	99	%	76 - 118	
	SPIKE	Calculated NO2	2007/06/19	102	%	N/A	
	BLANK	Calculated NO2	2007/06/19	ND, RDL=0.1	ppb		
1682935 LM1	Calibration Check	Calculated O3	2007/06/19	100	%	91 - 107	
	SPIKE	Calculated O3	2007/06/19	99	%	N/A	
	BLANK	Calculated O3	2007/06/19	ND, RDL=0.1	ppb		
1682940 DF4	Calibration Check	Calculated SO2	2007/06/19	101	%	95 - 105	
	SPIKE	Calculated SO2	2007/06/19	103	%	N/A	
	BLANK	Calculated SO2	2007/06/19	ND, RDL=0.1	ppb		

ND = Not detected

N/A = Not Applicable

MAY 2007
PASSIVE FIELD DATA

**LAKELAND INDUSTRY & COMMUNITY ASSOCIATION
PASSIVE FIELD DATA**

SAMPLER	ID	START		END		NOTES
		DATE	TIME	DATE	TIME	
SO ₂ /NO ₂ /O ₃	1	04/26/07	9:35	05/29/07	8:55	
H ₂ S/SO ₂ /NO ₂ /O ₃	2	04/26/07	8:55	05/29/07	8:20	
SO ₂ /NO ₂ /O ₃	3	04/27/07	15:05	05/30/07	15:00	
H ₂ S/SO ₂ /NO ₂ /O ₃	4	04/27/07	14:00	05/30/07	14:00	
SO ₂ /NO ₂ /O ₃	5	04/27/07	12:35	05/30/07	12:35	
SO ₂ /NO ₂ /O ₃	7	04/27/07	15:55	05/30/07	15:40	
SO ₂ /NO ₂ /O ₃	8	04/26/07	8:20	05/29/07	7:45	
H ₂ S/SO ₂ /NO ₂ /O ₃	9	04/26/07	13:35	05/29/07	12:55	
H ₂ S/SO ₂ /NO ₂ /O ₃	10	04/26/07	10:45	05/29/07	10:00	
H ₂ S/SO ₂ /NO ₂ /O ₃	11	04/26/07	12:10	05/29/07	11:30	
H ₂ S/SO ₂ /NO ₂ /O ₃	12	04/26/07	15:20	05/29/07	14:30	
H ₂ S/SO ₂ /NO ₂ /O ₃	13	04/26/07	16:15	05/29/07	15:40	
SO ₂ /NO ₂ /O ₃	14	04/26/07	7:20	05/29/07	6:40	
H ₂ S/SO ₂ /NO ₂ /O ₃	15	04/27/07	11:00	05/30/07	10:50	
H ₂ S/SO ₂ /NO ₂ /O ₃	16	04/27/07	11:55	05/30/07	11:50	
H ₂ S/SO ₂ /NO ₂ /O ₃	17	04/27/07	10:15	05/30/07	10:05	
SO ₂ /NO ₂ /O ₃	18	04/27/07	9:20	05/30/07	9:10	
H ₂ S/SO ₂ /NO ₂ /O ₃	19	04/27/07	8:30	05/30/07	16:40	
SO ₂ /NO ₂ /O ₃	20	04/26/07	17:30	05/29/07	17:20	
H ₂ S/SO ₂ /NO ₂ /O ₃	21	04/27/07	13:10	05/30/07	13:10	
H ₂ S/SO ₂	22	04/26/07	15:00	05/29/07	14:15	
H ₂ S/SO ₂	23	04/26/07	16:00	05/29/07	15:25	
H ₂ S/SO ₂	24	04/26/07	16:35	05/29/07	16:15	
SO ₂ /NO ₂ /O ₃	25	04/26/07	8:00	05/29/07	7:20	
H ₂ S/SO ₂ /NO ₂ /O ₃	10A	04/26/07	10:45	05/29/07	10:00	
H ₂ S/SO ₂ /NO ₂ /O ₃	11A	04/26/07	12:10	05/29/07	11:30	