

# Lakeland Industry & Community Association

Cold Lake Monitoring Site  
Ambient Annual Data Report

For  
2008

Prepared By:



February 25, 2009

# Lakeland Industry & Community Association Ambient Air Monitoring

<b>Table of Contents</b>	<b>Page</b>
<b>Introduction</b>	<b>3</b>
<b>Calibration Procedure</b>	<b>4</b>
<b>General Continuous Monitoring Annual Summary</b>	<b>5</b>
<b>Continuous Monitoring</b>	<b>15</b>
• <b>Monthly Summaries, Graphs &amp; Wind Roses</b>	<b>16</b>
○ <b>Sulphur Dioxide</b>	<b>17</b>
○ <b>Total Reduced Sulphur</b>	<b>24</b>
○ <b>Total Hydrocarbons</b>	<b>31</b>
○ <b>Particulate Matter 2.5</b>	<b>36</b>
○ <b>Nitrogen Dioxide</b>	<b>43</b>
○ <b>Nitric Oxide</b>	<b>50</b>
○ <b>Oxides of Nitrogen</b>	<b>57</b>
○ <b>Ozone</b>	<b>64</b>
○ <b>Ambient Temperature</b>	<b>71</b>
○ <b>Relative Humidity</b>	<b>74</b>
○ <b>Vector Wind Speed</b>	<b>77</b>
<b>Passive Monitoring Annual Summaries</b>	<b>81</b>
• <b>Sulphur Dioxide</b>	<b>82</b>
• <b>Hydrogen Sulphide</b>	<b>84</b>
• <b>Nitrogen Dioxide</b>	<b>86</b>
• <b>Ozone</b>	<b>88</b>

## Introduction

The following Ambient Air Monitoring report was prepared for:

Mr. Mike Bisaga  
**Lakeland Industry & Community Association**  
Box 8237  
5107W – 50 Street  
Bonnyville, Alberta  
T9N 2J5

Monitoring Location: Cold Lake  
Data Period: January 2008 to December 2008

The monthly ambient data report:

- Prepared by Lily Lin
- Reviewed by Craig Snider

The monthly analytical report for passive monitoring:  
Authorized by Levi Manchak

# Calibration Procedure

The following calibration procedure applies to all calibrations conducted at the Lakeland Industry & Community Association Air Monitoring Station.

Calibration gas concentrations are generated using a dynamic mass flow controlled calibrator. EPA Protocol one gases are diluted with zero air generated on site. The Mass Flow Controllers in the calibrator are referenced using an NIST traceable flow meter once per month. All listed flows are reported as corrected to Standard Temperature and Pressure (STP).

Generated zero gas is introduced to the analyzer first. Three concentrations of calibration gas are then generated in order to introduce points at approximately 50-80%, 25-40% & 10-20% of the analyzer's full-scale range. An auto zero and span are then performed to validate the daily zero and span values recorded to the next multi-point calibration.

All indicated concentrations are taken from the ESC data logger used to collect the data for monthly reporting.

Conformance of each calibration to Alberta Environment regulations is outlined in the individual calibration reports. The slope and correlation coefficient are derived from the calculated and indicated analyzer responses. The percent change is calculated using the previous calibration correction factor and the current correction factor before adjustment. The calibration conforms to the procedure outlined in the *Air Monitoring Directive, Appendix A-10, Section 1.6*.

## General Monthly Summary - Cold Lake

### Equipment Operation

The following summary outlines the analyzer performance. Any non-conformances, problems or maintenance performed are detailed at the end of each section.

### AQM STATION – LICA – COLD LAKE

#### Sulphur Dioxide (PPB)

- Analyzer make / model - TECO 43A replaced to Thermo 43i
  - ❖ On May 1<sup>st</sup>, the SO<sub>2</sub> values were less stable during the initial span point, observed the UV lamp voltage was fluctuating more than expected. Installed a difference UV lamp and allowed the analyzer time to stabilize.
  - ❖ The vacuum pump was rebuilt on May 21<sup>st</sup>.
  - ❖ The temporary Maxxam-owned UV lamp was removed and an AENV-owned lamp was installed on June 4<sup>th</sup>.
  - ❖ The permeation tube was replaced on July 21<sup>st</sup> because daily span started dropping on July 18<sup>th</sup>.
  - ❖ There was one hour of data invalid due to a power failure on September 15<sup>th</sup>.
  - ❖ A removal calibration on the TECO 43A SO<sub>2</sub> analyzer and an installation calibration on a new Thermo 43i SO<sub>2</sub> analyzer were performed on December 31<sup>st</sup>. A new SO<sub>2</sub> permeation tube was also installed on the same day.
  - ❖ A power failure occurred on December 21<sup>st</sup> for three hours.

# General Monthly Summary - Cold Lake

## AQM STATION – LICA – COLD LAKE

### Total Reduced Sulphur (PPB)

- Analyzer make / model -TEI 43A replaced to TEI 450i
- Converter - CD NOVA CDN 101
  - ❖ The pump was rebuilt after the “As Found” points were completed in March.
  - ❖ On September 11<sup>th</sup>, a replacement lamp was installed and the PMT gain was changed due to the low daily span reading occurring on September 10<sup>th</sup>.
  - ❖ The Hydrogen cylinder was replaced on September 16<sup>th</sup>.
  - ❖ There was one hour of data invalid due to a power failure on September 15<sup>th</sup>. When the power was restored to the TRS converter, a fault appeared on the temperature controller. Thus, the thermo-couple was replaced with the LICA-owned spare, and then the TRS converter was restarted.
  - ❖ A permeation tube was replaced due to the TRS span was 17% lower than expected value on October 28<sup>th</sup>.
  - ❖ A removal calibration on the TEI 43A TRS analyzer was performed on December 18<sup>th</sup>. The AENV supplied TEI 450i analyzer was installed and calibrated on the same day, but the calibration was non-linear. On December 19<sup>th</sup>, the factory-supplied capillary was removed and the capillary from the TEI 43A was installed. The analyzer showed linear response. A total of 28 hours of data was invalidated due to this issue.
  - ❖ The daily span of TRS was stabilizing between on 19<sup>th</sup> and the 25<sup>th</sup> of December as a new analyzer and new permeation tube device.
  - ❖ A power failure occurred on December 21<sup>st</sup> for three hours.

# General Monthly Summary - Cold Lake

## AQM STATION – LICA – COLD LAKE

### Total HydroCarbon (PPM)

- Analyzer make / model -TECO 51C-LT
  - ❖ It was agreed to with the LICA Program Manager to invalidate all data, after zero correction, which falls below the historical background average of 1.5 ppm in January..
  - ❖ The pump diaphragm was changed after the 'As Found' points were completed in February.
  - ❖ The zero air pump was rebuilt following the as found points on August 1<sup>st</sup>. A new 4-way valve in the zero air supply was replaced on August 25<sup>th</sup>.
  - ❖ The analyzer was relighted on September 16<sup>th</sup> due to a power failure occurred on September 15<sup>th</sup>. Because of the power failure, there were 15 hours of data invalid.
  - ❖ The total of 7 hours of data were also invalidated as the concentrations fell below the historical background average of 1.5 ppm in September.
  - ❖ The CH4 span gas cylinder was replaced on October 1<sup>st</sup>.
  - ❖ The Hydrogen gas cylinder was replaced on November 4<sup>th</sup> following the as-found points.
  - ❖ The result of the monthly calibration in November showed poor linearity. The technician performed crosschecks with other calibrator, but still got same poor results. Thus, flows were measured and adjusted, and allow the analyzer time to stabilize overnight. On November 5<sup>th</sup>, the as-found points calibration was performed, but the linearity was still poor. Thus, sample and H2 pressures were changed back to values prior to optimization on November 4<sup>th</sup>. The calibration linearity is better but still passible.
  - ❖ A power failure occurred on December 21<sup>st</sup> for three hours.

# General Monthly Summary - Cold Lake

## AQM STATION – LICA – COLD LAKE

### Nitrogen Dioxide (PPB)

- Analyzer make / model - TECO 42C
- ❖ The scrubbing materials were replaced in the exhaust scrubber in February.
- ❖ A slight leak developed in the exhaust tubing/scrubber of the analyzer, this was repaired and the analyzer re-calibrated during the month calibration in April. No data was invalidated due to this leak.
- ❖ The Maxxam-owned Thomas wobble pump was removed and an AENV-owned 2 cylinder Thomas diaphragm pump was installed on July 2<sup>nd</sup>.
- ❖ On August 20<sup>th</sup>, the analyzer was put on the maintenance mode for checking high span values issue for 12 hours.
- ❖ The analyzer was relighted on September 16<sup>th</sup> due to a power failure occurred on September 15<sup>th</sup>.
- ❖ The pump was rebuilt and the charcoal in the exhaust scrubber was replaced on November 13<sup>th</sup> because the pump was much noisier than usual.
- ❖ It was noticed on December 12<sup>th</sup> during the daily data review that the channels on the Nox analyzer did not add up. It was due to a loose wire NO output. The problem was fixed on December 13<sup>th</sup>. As a result, a total of 24 hours of data was invalidated.
- ❖ A power failure occurred on December 21<sup>st</sup> for three hours.

### Ozone (PPB)

- Analyzer make / model - TECO 49I
- ❖ The analyzer was relighted on September 16<sup>th</sup> due to a power failure occurred on September 15<sup>th</sup>.
- ❖ The pump was rebuilt following an as found point on October 1<sup>st</sup>, and the charcoal in the exhaust scrubber was replaced during the pump rebuild.
- ❖ A power failure occurred on December 21<sup>st</sup> for three hours.



# General Monthly Summary - Cold Lake

## AQM STATION – LICA – COLD LAKE

### Particulate Matter 2.5 (ug/m<sup>3</sup>)

- Analyzer make / model - TEOM 1400A
- ❖ During the February monthly calibration the filter was replaced, the inlet was cleaned and o-rings lubricated. As a new filter was installed, the sampler was unstable until full conditioning of the filter was completed; as a result 21 hours of data was invalidated.
- ❖ During the March monthly calibration the bypass and sensor in-line filters were replaced. As a new filter was installed, the sampler was unstable until full conditioning of the filter was completed; as a result 32 hours of data was invalidated.
- ❖ Following the calibration and filter change, the analyzer was allowed to stabilize full conditioning of the filter was completed, as a result 15 hours of data was invalidated in April.
- ❖ One hour of data was invalidated as it was below  $-3.0 \text{ ug/m}^3$  in April.
- ❖ During the Teom audit in May, the aux flow displayed on the Teom was fluctuating. The total flow was low and fluctuating (still within tolerance), and the main flow was low (outside tolerance). A leak was found in the brass elbow fitting screwed into the bottom of the mass transducer unit. The brass elbow fitting was wrapped with Teflon tap as a temporary fix. After the repair until a new part arrived, all audited parameters were within allowable tolerances. Following the calibration and filter change, the analyzer was allowed to stabilize full conditioning of the filter was completed, as a result 17 hours of data was invalidated.
- ❖ Four hours of data were invalidated as it was below  $-3.0 \text{ ug/m}^3$  in May.
- ❖ The Teom audit was performed on June 5<sup>th</sup>, 2008 showing all parameters were within tolerances. On June 6<sup>th</sup>, 2008, the Teom analyzer was reading excessively negative. Thus, the technician repeated the audit, changed a leaking fitting in the bottom of the transducer housing, and installed a new filter. After the repair, all audit values were within allowable tolerance. There were 45 hours of data invalid during this period.
- ❖ There were high readings from mid-day of June 7<sup>th</sup> until 10:00am of June 8<sup>th</sup> due to smoke in the air, which may be a result of a fire burning near by, or smoke carried in from a fire to the North.
- ❖ Twenty hours of data were invalidated as it was below  $-3.0 \text{ ug/m}^3$  in June.

(To Be Continued...)

# General Monthly Summary - Cold Lake

## AQM STATION – LICA – COLD LAKE

### Particulate Matter 2.5 (ug/m<sup>3</sup>)

- ❖ (Continued)The Teom audit and KO confirmation were performed on July 4<sup>th</sup> showing all parameters were within tolerances. The Teom was put in maintenance mode following the audit to allow it to stabilize until July 5<sup>th</sup>, 9:00. A new teom filter was installed following the audit. On July 21<sup>st</sup>, the teom screen was noticed frozen and was not able to navigate within the main screen likely due to power outage on the 19<sup>th</sup>. The maintenance mode was again entered until the screen returned to normal and the analyzer stabilized. As a result, 30 hours of data was invalidated due to these two maintenances.
- ❖ There were 39 hours data invalid, which is likely due to a problem with the mass transducer on the 5<sup>th</sup> and 6<sup>th</sup>.
- ❖ Fifty-five hours of data were invalidated as it was below  $-3.0 \text{ ug/m}^3$  in this month in July.
- ❖ The Teom audit was performed on August 25<sup>th</sup> showing all parameters were within tolerances. The technician performed an audit on the AENV-Owned Teom, and then replaced it with a Maxxam-Owned Teom on August 25<sup>th</sup>. The Teom was put up on the maintenance mode overnight to allow it stable. There were 24 hours of data invalid during this period.
- ❖ Seventy-nine hours of data were invalidated as it was below  $-3.0 \text{ ug/m}^3$  in August.
- ❖ The flow adjust factors were changed in order to bring the actual flows closer to the expected values on September 04<sup>th</sup>.
- ❖ There was one hour of data invalid due to a power failure on September 15<sup>th</sup>.
- ❖ Two hours of data were invalidated as it was below  $-3.0 \text{ ug/m}^3$  in September.
- ❖ Four hours of data were invalidated as it was below  $-3.0 \text{ ug/m}^3$  in October.
- ❖ A Teom audit including leak check and Ko verification were performed on November 5<sup>th</sup>. Following the audit, the flow adjust factors were changed to bring actual flows closer to the expected values. The large inline bypass filter was replaced on the same day.
- ❖ A TEOM audit and a full calibration were performed on December 1<sup>st</sup>. Hardware calibrations, including analog in/out calibration, flows calibration, and a temperature sensor calibration, were conducted on the same day. After this, a post-calibration audit was performed, and all parameters were within tolerance.
- ❖ The filter was replaced due to noise issue in December.
- ❖ A power failure occurred on December 21<sup>st</sup> for three hours.
- ❖ One hour of data was invalidated as it was below  $-3.0 \text{ ug/m}^3$ .

# General Monthly Summary - Cold Lake

## AQM STATION – LICA – COLD LAKE

### Vector Wind Speed (KPH) & Vector Wind Direction (DEG)

- System make / model – Met One 50.5
  - ❖ On January 4<sup>th</sup> there was one hour of data missing for the parameter of standard deviation of vector wind direction.
  - ❖ There was one hour of data invalid due to a power failure on September 15<sup>th</sup>.
  - ❖ The Met One 50.5 wind system was checked using the zero/span method in the manual. A Maxxam-Owned RM Young 5103VK (S/N# 2068) wind system was installed as a temporary replacement for the AENV-Owned Met One 50.5 wind system, which was shipped to the manufacturer for factory calibration on October 10<sup>th</sup>.
  - ❖ The temporary replacement Maxxam-Owned RM Young 5103VK (S/N# 2068) wind system was removed and the AENV-Owned Met One 50.5 wind system was installed on November 5<sup>th</sup>. The Met One 50.5 wind system had been shipped to the manufacturer for a routine calibration, and the results were within tolerance according to the manufacturer. The heater control board was found by Met One to be faulty and had to be replaced. The zero/span test outlined in the manual was performed on November 5<sup>th</sup>.
  - ❖ A spike of 95 km/hr showed on one reading of one-minute data for wind speed system on December 13<sup>th</sup>, at 21:37. It is likely due to electrical problem.
  - ❖ A power failure occurred on December 21<sup>st</sup> for three hours.

### Relative Humidity (PERCENT)

- System make / model - Rotronic Hygroclip-S3
  - ❖ There was one hour of data invalid due to a power failure on September 15<sup>th</sup>.
  - ❖ A power failure occurred on December 21<sup>st</sup> for three hours.

### Ambient Temperature (DEGC)

- System make / model - Rotronic Hygroclip-S3
  - ❖ There was one hour of data invalid due to a power failure on September 15<sup>th</sup>.
  - ❖ A power failure occurred on December 21<sup>st</sup> for three hours.

# General Monthly Summary - Cold Lake

## AQM STATION – LICA – COLD LAKE

### Trailer Temperature (DEGC)

- System make / model - R&R 61
- ❖ There was one hour of data invalid due to a power failure on September 15<sup>th</sup>.
- ❖ A power failure occurred on December 21<sup>st</sup> for three hours.

### Datalogger

- System make / model - ESC 8832
- Software make / version - ESC v 5.51a

The ESC 8832 is connected to a modem with DSL for continuous connection with the base computer.

### Trailer

- ❖ The manifold and inlet lines were cleaned on October 2<sup>nd</sup>. A/C heat exchanger and filters on the Bard HVAC unit were cleaned and throw-away filter was replaced on October 2<sup>nd</sup>.

# General Monthly Summary - Cold Lake

## AQM STATION – LICA – COLD LAKE

### Air Quality Index (AQI)

- ❖ There were no fair AQI values recorded in January 2008. The highest offending pollutant was Ozone with an hourly concentration of 40.0 ppb and an AQI value of 20 on January 20<sup>th</sup>.
- ❖ There were no fair AQI values recorded in February 2008. The highest offending pollutant was Ozone with an hourly concentration of 49.0 ppb and an AQI value of 25 on February 22<sup>nd</sup> and two on February 27<sup>th</sup>.
- ❖ There were 43 hours of fair AQI values recorded in March 2008, all of these due to Ozone. The highest hourly concentration of Ozone was 59.0 ppb and an AQI value of 33 on March 9<sup>th</sup> hour 15 and hour 16.
- ❖ There were 154 hours of fair AQI values recorded in April 2008, all of these due to Ozone. The highest hourly concentration of Ozone was 63.0 ppb and an AQI value of 36 on April 25<sup>th</sup>, hour 14, April 27<sup>th</sup>, hour 21, and April 28<sup>th</sup>, hour 16.
- ❖ There were 145 hours of fair AQI values recorded in May 2008, all of these due to Ozone. The highest hourly concentration of Ozone was 63.0 ppb and an AQI value of 36 on May 16<sup>th</sup>, hour 17 and hour 18.
- ❖ There were 6 hours of poor AQI values and 47 hours of fair AQI values recorded in June. All the poor AQI values were due to PM2.5, which may be a result of a smoke in the air at that time period. 35 hours of fair AQI values were due to Ozone and 12 hours were due to PM2.5. The highest hourly concentration of PM2.5 was 93.0 UG/M3 and an AQI value of 57 on June 8<sup>th</sup>, hour 3. The highest hourly concentration of Ozone was 62.0 ppb and an AQI value of 35 on June 13<sup>th</sup>, hour 15.
- ❖ There were 3 hours of fair AQI values recorded in July 2008. All the fair AQI values were due to ozone. The highest hourly concentration of Ozone was 56 ppb and an AQI value of 30 on July 25<sup>th</sup>, hour 14.
- ❖ 10 hours of fair AQI values recorded in August 2008. 9 hours of fair AQI values were due to Ozone and 1 hour was due to PM2.5. The highest hourly concentration of PM2.5 was 37.1 UG/M3 and an AQI value of 29 on August 15<sup>th</sup>, hour 18. The highest hourly concentration of Ozone was 57.0 ppb and an AQI value of 31 on June 15<sup>th</sup>, hour 16 and hour 17.
- ❖ All AQI values recorded in September were within the good range in September.
- ❖ All AQI values recorded in October were within the good range in October.
- ❖ All AQI values recorded in November were within the good range in November.
- ❖ 2 hours of fair AQI values recorded in December, both were due to PM2.5. The highest hourly concentration of PM2.5 was 44.9 UG/M3 and an AQI value of 33 on December 11<sup>th</sup>.

# General Monthly Summary - Cold Lake

## AQM STATION – LICA – COLD LAKE

### Passive Network

- ❖ Site #21: the ozone sampler was missing at the station upon change out in February.
- ❖ The results of the H2S duplicate sampling showed large variation in the concentration results. The field and laboratory data was reviewed, but failed to provide information on the reason for the discrepancies. Due to the large variations, the H2S duplicates were not utilized in the data reporting in June.
- ❖ The result of the sample #5 H2S duplicate sampling showed large variation in the concentration result. The field and laboratory data was reviewed, but failed to provide information on the reason for the discrepancies. Due to the large variation, the H2S duplicate was not utilized in the data reporting in October.
- ❖ NO2 sample duplicate at station#10 and NO2 sample at station #23 were missing in November.
- ❖ SO2 sample at station#8 and NO2 sample at station #23 were missing in December.

# Continuous Monitoring

# Annual Summaries Graphs & Wind Roses



# Sulphur Dioxide

S02

Current Date : 02/25/09  
Current Time : 11:29

Annual Parameter Summary Report - Hourly  
Maxxam Analytics

Year : 2008

Logger Name : LICA            Logger Id : 01            Parameter : S02\_            Units : PPB

	Readings	Valid Readings	Min	Max	Mean
January	744	707	0	4	0
February	696	661	0	8	0
March	744	706	0	4	0
April	720	685	0	2	0
May	744	691	0	0	0
June	720	678	0	7	0
July	744	705	0	1	0
August	744	704	0	1	0
September	720	684	0	3	0
October	744	706	0	4	0
November	720	682	0	2	0
December	744	697	0	5	0
Yearly Total	8784	8306	0	8	0

## SO<sub>2</sub> Monthly Averages and Frequency Distributions of One Hour Readings - 2008

Plant Operator: Lakeland Industry & Community Plant Location: Cold Lake

Month	Number of Readings	% Readings in Concentration Range (ppb SO <sub>2</sub> )						SO <sub>2</sub> ppb Monthly Average
		0 to 19 ppb	20 to 59 ppb	60 to 109 ppb	110 to 169 ppb	170 to 340 ppb	>341 ppb	
January	707	100.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.34
February	661	100.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.82
March	706	100.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.12
April	685	100.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.03
May	690	100.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.00
June	678	100.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.03
July	705	100.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.00
August	704	100.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.01
September	684	100.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.02
October	706	100.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.14
November	682	100.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.07
December	697	100.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.56
							Annual Average	<b>0.18</b>

## SO<sub>2</sub> Exceedances of One Hour Averages for 2008

Plant Operator: Lakeland Industry & Community Plant Location: Cold Lake

Month	Number of Exceedances	SO2 ppb Peak Reading
January	0	4
February	0	8
March	0	5
April	0	2
May	0	0
June	0	7
July	0	1
August	0	1
September	0	3
October	0	4
November	0	2
December	0	5
<b>TOTAL EXCEED</b>	<b>0</b>	
<b>ANNUAL PEAK</b>		<b>8</b>

## SO<sub>2</sub> 24 - Hour Averages for 2008

Plant Operator: Lakeland Industry & Community

Plant Location: Cold Lake

Month	SO2 ppb 24-Hour Peak Reading
January	1.0
February	2.3
March	0.7
April	0.4
May	0.0
June	0.7
July	0.0
August	0.0
September	0.2
October	0.7
November	0.6
December	1.9
<b>ANNUAL PEAK</b>	<b>2.3</b>

LICA  
 SO2\_ / WDR Joint Frequency Distribution (Percent)

01/01/08 thru 12/31/08

Distribution By % Of Samples

Logger Id : 01  
 Site Name : LICA  
 Parameter : SO2\_  
 Units : PPB

Wind Parameter : WDR  
 Instrument Height : 10 Meters

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 20	2.49	4.31	5.09	3.48	8.58	9.66	10.60	2.83	2.95	3.35	11.32	12.66	9.05	6.20	5.12	2.25	100.00
< 60	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 110	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 170	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 340	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 340	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	2.49	4.31	5.09	3.48	8.58	9.66	10.60	2.83	2.95	3.35	11.32	12.66	9.05	6.20	5.12	2.25	

Calm : .00 %

Total # Operational Hours : 8298



Distribution By Samples

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 20	207	358	423	289	712	802	880	235	245	278	940	1051	751	515	425	187	8298
< 60																	
< 110																	
< 170																	
< 340																	
>= 340																	
Totals	207	358	423	289	712	802	880	235	245	278	940	1051	751	515	425	187	

Calm : .00 %

Total # Operational Hours : 8298

Class Limits (PPB)



# Total Reduced Sulphur



TRS

Current Date : 02/25/09  
 Current Time : 11:29

Annual Parameter Summary Report - Hourly  
 Maxxam Analytics

Year : 2008

Logger Name : LICA                      Logger Id : 01                      Parameter : TRS\_                      Units : PPB

	Valid				
	Readings	Readings	Min	Max	Mean
January	744	704	0	1	0
February	696	661	0	1	0
March	744	703	0	6	0
April	720	685	0	0	0
May	744	706	0	0	0
June	720	685	0	1	0
July	744	700	0	3	0
August	744	705	0	4	0
September	720	643	0	1	0
October	744	695	0	0	0
November	720	684	0	0	0
December	744	675	0	0	0
Yearly Total	8784	8246	0	6	0

## TRS Monthly Averages and Frequency Distributions of One Hour Readings - 2008

Plant Operator: Lakeland Industry & Community Association Plant Location: Cold Lake

Month	Number of Readings	% Readings in Concentration Range (ppb TRS)				TRS ppb Monthly Average
		0 to 3 ppb	4 to 10 ppb	11 to 50 ppb	>50 ppb	
January	704	100.0%	0.0%	0.0%	0.0%	0.03
February	661	100.0%	0.0%	0.0%	0.0%	0.00
March	703	100.0%	0.0%	0.0%	0.0%	0.02
April	685	100.0%	0.0%	0.0%	0.0%	0.00
May	706	100.0%	0.0%	0.0%	0.0%	0.00
June	685	100.0%	0.0%	0.0%	0.3%	0.00
July	699	100.0%	0.0%	0.0%	0.0%	0.02
August	705	100.0%	0.0%	0.0%	0.0%	0.01
September	643	100.0%	0.0%	0.0%	0.0%	0.02
October	695	100.0%	0.0%	0.0%	0.0%	0.00
November	684	100.0%	0.0%	0.0%	0.0%	0.00
December	675	100.0%	0.0%	0.0%	0.0%	0.00
<b>Annual Average</b>						<b>0.01</b>

## TRS One - Hour Averages for 2008

Plant Operator: Lakeland Industry & Community Association Plant Location: Cold Lake

Month	TRS ppb One-Hour Peak Reading
January	1.0
February	1.0
March	6.0
April	0.0
May	0.0
June	1.0
July	3.0
August	4.0
September	1.0
October	0.0
November	0.0
December	0.0
<b>ANNUAL PEAK</b>	<b>6.0</b>

## TRS 24 - Hour Averages for 2008

Plant Operator: Lakeland Industry & Community Association Plant Location: Cold Lake

Month	TRS ppb 24-Hour Peak Reading
January	0.2
February	0.0
March	0.5
April	0.0
May	0.0
June	0.0
July	0.2
August	0.3
September	0.3
October	0.0
November	0.0
December	0.0
<b>ANNUAL PEAK</b>	<b>0.5</b>

LICA  
 TRS\_ / WD Joint Frequency Distribution (Percent)

01/01/08 thru 12/31/08

Distribution By % Of Samples

Logger Id : 01  
 Site Name : LICA  
 Parameter : TRS\_  
 Units : PPB

Wind Parameter : WD  
 Instrument Height : 10 Meters

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 3	2.47	4.27	5.08	3.50	8.66	9.82	10.71	2.81	2.91	3.27	11.27	12.53	9.03	6.19	5.08	2.26	99.95
< 10	.00	.00	.00	.01	.01	.00	.00	.00	.00	.00	.02	.00	.00	.00	.00	.00	.04
< 50	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 50	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	2.47	4.27	5.08	3.52	8.67	9.82	10.71	2.81	2.91	3.27	11.30	12.53	9.03	6.19	5.08	2.26	

Calm : .00 %

Total # Operational Hours : 8238

Distribution By Samples

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 3	204	352	419	289	714	809	883	232	240	270	929	1033	744	510	419	187	8234
< 10				1	1						2						4
< 50																	
>= 50																	
Totals	204	352	419	290	715	809	883	232	240	270	931	1033	744	510	419	187	



Calm : .00 %

Total # Operational Hours : 8238

Class Limits (PPB)

Period : 01/01/08-12/31/08

Level : 10



# Total Hydrocarbons

THC

Current Date : 02/25/09  
Current Time : 11:29

Annual Parameter Summary Report - Hourly  
Maxxam Analytics

Year : 2008

Logger Name : LICA                      Logger Id : 01                      Parameter : THC                      Units : PPM

	Readings	Valid Readings	Min	Max	Mean
January	744	708	1.7	4.5	2.2
February	696	660	1.6	4.4	2.1
March	744	707	1.6	2.9	1.8
April	720	683	1.7	2.8	1.8
May	744	706	1.5	6.6	1.7
June	720	682	1.5	2.6	1.8
July	744	706	1.6	2.8	1.8
August	744	693	1.7	3.1	1.8
September	720	665	1.5	3.6	1.8
October	744	707	1.5	3.6	1.7
November	720	675	1.5	2.8	1.8
December	744	699	1.7	6	2.2
Yearly Total	8784	8291	1.5	6.6	1.9



## THC Monthly Averages and Frequency Distributions of One Hour Readings - 2008

Plant Operator: Lakeland Industry & Community Association Plant Location: Cold Lake

Month	Number of Readings	% Readings in Concentration Range (ppm THC)				THC ppm Monthly Average
		0 to 3 ppm	4 to 10 ppm	11 to 50 ppm	>50 ppm	
January	708	92.7%	7.3%	0.0%	0.0%	2.22
February	661	95.8%	4.2%	0.0%	0.0%	2.11
March	707	100.0%	0.0%	0.0%	0.0%	1.86
April	683	100.0%	0.0%	0.0%	0.0%	1.83
May	706	99.7%	0.3%	0.0%	0.0%	1.70
June	682	100.0%	0.0%	0.0%	0.0%	1.86
July	706	100.0%	0.0%	0.0%	0.0%	1.82
August	693	99.6%	0.4%	0.0%	0.0%	1.90
September	664	98.9%	1.1%	0.0%	0.0%	1.80
October	707	99.4%	0.6%	0.0%	0.0%	1.78
November	675	100.0%	0.0%	0.0%	0.0%	1.82
December	699	92.4%	7.6%	0.0%	0.0%	2.22
<b>Annual Average</b>						<b>1.91</b>

LICA  
 THC / WD Joint Frequency Distribution (Percent)

01/01/08 thru 12/31/08

Distribution By % Of Samples

Logger Id : 01  
 Site Name : LICA  
 Parameter : THC  
 Units : PPM

Wind Parameter : WD  
 Instrument Height : 10 Meters

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 3.0	2.47	4.24	4.96	3.42	8.59	9.66	10.53	2.73	2.84	3.24	10.86	12.40	8.82	6.07	5.08	2.23	98.21
< 10.0	.01	.02	.09	.13	.07	.07	.09	.08	.08	.09	.42	.27	.19	.07	.02	.02	1.78
< 50.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 50.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	2.48	4.27	5.05	3.56	8.66	9.73	10.63	2.82	2.93	3.34	11.28	12.68	9.01	6.14	5.10	2.25	

Calm : .00 %

Total # Operational Hours : 8286


Distribution By Samples

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 3.0	205	352	411	284	712	801	873	227	236	269	900	1028	731	503	421	185	8138
< 10.0	1	2	8	11	6	6	8	7	7	8	35	23	16	6	2	2	148
< 50.0																	
>= 50.0																	
Totals	206	354	419	295	718	807	881	234	243	277	935	1051	747	509	423	187	

Calm : .00 %

Total # Operational Hours : 8286

Class Limits (PPM)



# Particulate Matter 2.5

PM2.5

Current Date : 02/25/09  
 Current Time : 11:29

Annual Parameter Summary Report - Hourly  
 Maxxam Analytics

Year : 2008

Logger Name : LICA                      Logger Id : 01                      Parameter : PM2                      Units : UG/M3

	Valid		Min	Max	Mean
	Readings	Readings			
January	744	738	0	17.2	3.6
February	696	675	0	26.7	4.2
March	744	708	0	19.4	2.9
April	720	701	0	12.8	3.2
May	744	710	0	25.4	4.6
June	696	653	0	93	6.1
July	696	618	0	24.1	4.2
August	744	635	0	37.1	3.6
September	720	713	0	12.6	2.1
October	744	736	0	19.9	3
November	720	716	0	11.4	2.8
December	744	726	0	44.9	3.5
Yearly Total	8712	8329	0	93	3.6

## PM 2.5 Monthly Averages and Frequency Distributions of Daily Average Rea

Plant Operator: Lakeland Industry & Community Association

Plant Location: Cold Lake

Month	Valid Readings* Hours	% Readings in Concentration Range (ug/m <sup>3</sup> )						Total Emissions Readings > 30 ug/m <sup>3</sup>
		≤ 30 ug/m <sup>3</sup>	30 < C ≤ 60 ug/m <sup>3</sup>	60 < C ≤ 80 ug/m <sup>3</sup>	80 < C ≤ 120 ug/m <sup>3</sup>	120 < C ≤ 240 ug/m <sup>3</sup>	> 240 ug/m <sup>3</sup>	
January	738	100.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0
February	673	99.9%	0.1%	0.0%	0.0%	0.0%	0.0%	0
March	707	100.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0
April	701	100.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0
May	710	99.9%	0.1%	0.0%	0.0%	0.0%	0.0%	0
June	652	93.7%	5.2%	1.1%	0.0%	0.0%	0.0%	1
July	618	99.8%	0.2%	0.0%	0.0%	0.0%	0.0%	0
August	636	99.4%	0.6%	0.0%	0.0%	0.0%	0.0%	1
September	713	100.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0
October	736	100.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0
November	716	100.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0
December	726	99.7%	0.3%	0.0%	0.3%	0.0%	0.0%	0
								Annual A

C - Concentration

\* Valid readings - does not include calibration hours and downtime hours

## PM2.5 One - Hour Averages for 2008

Plant Operator: Lakeland Industry & Community      Plant Cold Lake

Month	PM2.5 ppb One-Hour Peak Reading
January	17.2
February	21.0
March	19.4
April	12.8
May	25.4
June	93.0
July	24.1
August	37.1
September	12.6
October	19.9
November	11.4
December	44.9
<b>ANNUAL PEAK</b>	<b>93.0</b>

## PM2.5 Exceedances of 24 - Hour Averages for 2008

Plant Operator: Lakeland Industry & Community      Plant Cold Lake

Month	Number of Exceedances	PM2.5 ppb Peak Reading
January	0	8.8
February	0	13.5
March	0	6.3
April	0	6.8
May	0	11.4
June	1	33.2
July	0	9.3
August	1	8.6
September	0	4.7
October	0	11.1
November	0	6.4
December	0	8.6
<b>TOTAL EXCEED</b>	<b>2</b>	
<b>ANNUAL PEAK</b>		<b>33.2</b>



LICA  
PM2 / WD Joint Frequency Distribution (Percent)

01/01/08 thru 12/31/08

Distribution By % Of Samples

Logger Id : 01  
Site Name : LICA  
Parameter : PM2  
Units : UG/M3

Wind Parameter : WD  
Instrument Height : 10 Meters

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 30.0	2.37	4.31	5.16	3.59	8.86	9.56	10.61	2.83	2.92	3.38	11.40	12.65	8.79	6.09	4.93	2.16	99.69
< 60.0	.01	.01	.01	.02	.01	.01	.00	.01	.00	.00	.02	.02	.00	.01	.02	.03	.21
< 80.0	.00	.00	.01	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01
< 120.0	.02	.01	.01	.01	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.01	.07
< 240.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 240.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	2.41	4.33	5.20	3.62	8.88	9.57	10.61	2.84	2.92	3.38	11.42	12.67	8.79	6.10	4.96	2.21	

Calm : .00 %



Total # Operational Hours : 8321

Distribution By Samples

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 30.0	198	359	430	299	738	796	883	236	243	282	949	1053	732	507	411	180	8296
< 60.0	1	1	1	2	1	1		1			2	2		1	2	3	18
< 80.0			1														1
< 120.0	2	1	1	1												1	6
< 240.0																	
>= 240.0																	
Totals	201	361	433	302	739	797	883	237	243	282	951	1055	732	508	413	184	

Calm : .00 %

Total # Operational Hours : 8321



# Nitrogen Dioxide

N02

Current Date : 02/25/09  
 Current Time : 11:29

Annual Parameter Summary Report - Hourly  
 Maxxam Analytics

Year : 2008

Logger Name : LICA                      Logger Id : 01                      Parameter : N02\_                      Units : PPB

	Valid				
	Readings	Readings	Min	Max	Mean
January	744	704	0	37	10
February	696	657	1	47	10
March	744	704	0	41	6
April	720	664	0	22	3
May	744	703	0	19	2
June	720	681	0	9	1
July	744	702	0	10	1
August	744	681	0	7	1
September	720	682	0	15	1
October	744	704	0	23	3
November	720	671	0	34	4
December	744	700	0	31	9
Yearly Total	8784	8253	0	47	4

## NO<sub>2</sub> Monthly Averages and Frequency Distributions of One Hour Readings - 2008

Plant Operator: Lakeland Industry & Community Association      Plant Location: Cold Lake

Month	Number of Readings	% Readings in Concentration Range (ppm NO <sub>2</sub> )				NO <sub>2</sub> ppb Monthly Average
		0 to 0.05 ppm	0.06 to 0.11 ppm	0.12 to 0.21 ppm	> 0.21 ppm	
January	704	100%	0%	0%	0%	10.55
February	659	100%	0%	0%	0%	10.80
March	704	100%	0%	0%	0%	6.19
April	664	100%	0%	0%	0%	3.11
May	703	100%	0%	0%	0%	2.06
June	681	100%	0%	0%	0%	1.94
July	702	100%	0%	0%	0%	1.44
August	681	100%	0%	0%	0%	1.42
September	682	100%	0%	0%	0%	1.99
October	704	100%	0%	0%	0%	3.96
November	671	100%	0%	0%	0%	4.40
December	700	100%	0%	0%	0%	9.02
<b>Annual Average</b>						<b>4.74</b>

## NO<sub>2</sub> Exceedances of One Hour Averages for 2008

Plant Operator: Lakeland Industry & Community Association      Plant Location: Cold Lake

Month	Number of Exceedances	NO2 ppb Peak Reading
January	0	37
February	0	47
March	0	41
April	0	22
May	0	19
June	0	9
July	0	10
August	0	7
September	0	15
October	0	37
November	0	34
December	0	31
<b>TOTAL EXCEED</b>	<b>0</b>	
<b>ANNUAL PEAK</b>		<b>47</b>

## NO<sub>2</sub> Exceedances of 24-Hour Averages for 2008

Plant Operator: Lakeland Industry & Community Association Plant Location: Cold Lake

Month	Number of Exceedances	NO2 ppb Peak Reading
January	0	20.1
February	0	28.4
March	0	15.8
April	0	5.8
May	0	4.9
June	0	3.4
July	0	2.7
August	0	2.4
September	0	4.1
October	0	13.9
November	0	15.3
December	0	21.2
<b>TOTAL EXCEED</b>	<b>0</b>	
<b>ANNUAL PEAK</b>		<b>28.4</b>

LICA  
 NO2\_ / WD Joint Frequency Distribution (Percent)

01/01/08 thru 12/31/08

Distribution By % Of Samples

Logger Id : 01  
 Site Name : LICA  
 Parameter : NO2\_  
 Units : PPB

Wind Parameter : WD  
 Instrument Height : 10 Meters

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 50	2.44	4.24	5.11	3.60	8.63	9.81	10.69	2.82	2.95	3.34	11.31	12.67	8.90	6.11	5.09	2.20	100.00
< 110	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
< 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	2.44	4.24	5.11	3.60	8.63	9.81	10.69	2.82	2.95	3.34	11.31	12.67	8.90	6.11	5.09	2.20	

Calm : .00 %

Total # Operational Hours : 8245

Distribution By Samples



Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 50	202	350	422	297	712	809	882	233	244	276	933	1045	734	504	420	182	8245
< 110																	
< 210																	
>= 210																	
Totals	202	350	422	297	712	809	882	233	244	276	933	1045	734	504	420	182	

Calm : .00 %

Total # Operational Hours : 8245



Class Limits (PPB)



# Nitric Oxide

NO

Current Date : 02/25/09  
Current Time : 11:29

Annual Parameter Summary Report - Hourly  
Maxxam Analytics

Year : 2008

Logger Name : LICA            Logger Id : 01            Parameter : NO\_            Units : PPB

	Readings	Valid Readings	Min	Max	Mean
January	744	704	0	87	3
February	696	657	0	103	3
March	744	704	0	53	1
April	720	664	0	10	0
May	744	703	0	10	0
June	720	681	0	5	0
July	744	702	0	22	0
August	744	681	0	11	0
September	720	682	0	19	0
October	744	704	0	64	1
November	720	671	0	49	1
December	744	701	0	48	3
Yearly Total	8784	8254	0	103	1

## NO Monthly Averages and Frequency Distributions of One Hour Readings - 2008

Plant Operator: Lakeland Industry & Community Association    Plant Location: Cold Lake

Month	Number of Readings	% Readings in Concentration Range (ppm NO)				NO ppb Monthly Average
		0 to 0.05 ppm	0.06 to 0.11 ppm	0.12 to 0.21 ppm	> 0.21 ppm	
January	704	99.4%	0.6%	0.0%	0.0%	3.78
February	659	98.9%	1.1%	0.0%	0.0%	3.99
March	704	99.9%	0.1%	0.0%	0.0%	1.17
April	664	100.0%	0.0%	0.0%	0.0%	0.23
May	703	100.0%	0.0%	0.0%	0.0%	0.12
June	681	100.0%	0.0%	0.0%	0.0%	0.14
July	702	100.0%	0.0%	0.0%	0.0%	0.30
August	681	100.0%	0.0%	0.0%	0.0%	0.31
September	682	100.0%	0.0%	0.0%	0.0%	0.69
October	704	99.7%	0.3%	0.0%	0.0%	1.62
November	671	100.0%	0.0%	0.0%	0.0%	1.44
December	700	100.0%	0.0%	0.0%	0.0%	3.90
<b>Annual Average</b>						<b>1.47</b>

## NO One - Hour Averages for 2008

Plant Operator: Lakeland Industry & Community Association Plant Location: Cold Lake

Month	NO ppb One - Hour Peak Reading
January	87
February	103
March	53
April	10
May	10
June	5
July	22
August	11
September	19
October	64
November	49
December	48
<b>ANNUAL PEAK</b>	<b>103</b>

## NO 24 - Hour Averages for 2008

Plant Operator: Lakeland Industry & Community Association Plant Location: Cold Lake

Month	NO ppb 24 - Hour Peak Reading
January	15.8
February	26.3
March	7.2
April	1.0
May	0.7
June	0.8
July	2.4
August	2.4
September	3.8
October	15.0
November	15.9
December	18.3
<b>ANNUAL PEAK</b>	<b>26.3</b>

LICA  
 NO\_ / WD Joint Frequency Distribution (Percent)

01/01/08 thru 12/31/08

Distribution By % Of Samples

Logger Id : 01  
 Site Name : LICA  
 Parameter : NO\_  
 Units : PPB

Wind Parameter : WD  
 Instrument Height : 10 Meters

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 50	2.44	4.24	5.11	3.51	8.59	9.79	10.69	2.81	2.95	3.34	11.30	12.67	8.91	6.11	5.09	2.19	99.83
< 110	.00	.00	.00	.08	.03	.01	.00	.01	.00	.00	.01	.00	.00	.00	.00	.01	.16
< 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	2.44	4.24	5.11	3.60	8.63	9.81	10.69	2.82	2.95	3.34	11.31	12.67	8.91	6.11	5.09	2.20	

Calm : .00 %

Total # Operational Hours : 8246



Distribution By Samples

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 50	202	350	422	290	709	808	882	232	244	276	932	1045	735	504	420	181	8232
< 110				7	3	1		1			1					1	14
< 210																	
>= 210																	
Totals	202	350	422	297	712	809	882	233	244	276	933	1045	735	504	420	182	

Calm : .00 %

Total # Operational Hours : 8246

Class Limits (PPB)





# Oxides of Nitrogen

NOX

Current Date : 02/25/09  
 Current Time : 11:29

Annual Parameter Summary Report - Hourly  
 Maxxam Analytics

Year : 2008

Logger Name : LICA                      Logger Id : 01                      Parameter : NOX\_                      Units : PPB

	Readings	Valid Readings	Min	Max	Mean
January	744	704	0	120	14
February	696	657	1	149	15
March	744	704	0	86	7
April	720	664	0	32	3
May	744	703	0	27	2
June	720	681	0	11	2
July	744	702	0	26	1
August	744	681	0	16	1
September	720	682	0	25	2
October	744	704	0	82	5
November	720	671	0	74	6
December	744	678	0	70	13
Yearly Total	8784	8231	0	149	6

## NO<sub>x</sub> Monthly Averages and Frequency Distributions of One Hour Readings - 2008

Plant Operator: Lakeland Industry & Community Association      Plant Location: Cold Lake

Month	Number of Readings	% Readings in Concentration Range (ppm NO <sub>x</sub> )				NO <sub>x</sub> ppb Monthly Average
		0 to 0.05 ppm	0.06 to 0.11 ppm	0.12 to 0.21 ppm	> 0.21 ppm	
January	704	95.3%	4.5%	0.1%	0.0%	14.66
February	659	95.8%	3.8%	0.5%	0.0%	15.21
March	704	98.4%	1.6%	0.0%	0.0%	7.74
April	664	100.0%	0.0%	0.0%	0.0%	3.39
May	703	100.0%	0.0%	0.0%	0.0%	2.35
June	681	100.0%	0.0%	0.0%	0.0%	2.28
July	702	100.0%	0.0%	0.0%	0.0%	1.93
August	681	100.0%	0.0%	0.0%	0.0%	1.90
September	682	100.0%	0.0%	0.0%	0.0%	2.96
October	704	99.1%	0.9%	0.0%	0.0%	5.83
November	671	99.1%	0.9%	0.0%	0.0%	6.10
December	677	96.6%	3.4%	0.0%	0.0%	13.53
					<b>Annual Average</b>	<b>6.49</b>

## NO<sub>x</sub> One Hour Averages for 2008

Plant Operator: Lakeland Industry & Community Association Plant Location: Cold Lake

Month	NO <sub>x</sub> ppb One-Hour Peak Reading
January	120
February	149
March	86
April	32
May	27
June	11
July	26
August	16
September	25
October	82
November	74
December	70
<b>ANNUAL PEAK</b>	<b>149</b>

## NO<sub>x</sub> 24 - Hour Averages for 2008

Plant Operator: Lakeland Industry & Community Association Plant Location: Cold Lake

Month	NO <sub>x</sub> ppb 24-Hour Peak Reading
January	33.1
February	55.0
March	22.6
April	6.9
May	5.6
June	3.8
July	5.3
August	4.1
September	8.3
October	28.1
November	31.7
December	38.5
<b>ANNUAL PEAK</b>	<b>55.0</b>

LICA  
NOX\_ / WD Joint Frequency Distribution (Percent)

01/01/08 thru 12/31/08

Distribution By % Of Samples

Logger Id : 01  
Site Name : LICA  
Parameter : NOX\_  
Units : PPB

Wind Parameter : WD  
Instrument Height : 10 Meters

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	2.44	4.24	5.01	3.34	8.47	9.74	10.62	2.78	2.93	3.30	11.20	12.58	8.88	6.08	4.88	2.14	98.69
< 110	.01	.01	.12	.21	.18	.09	.09	.04	.03	.04	.14	.12	.03	.03	.02	.01	1.25
< 210	.00	.00	.00	.04	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.04
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	2.45	4.25	5.13	3.61	8.65	9.83	10.72	2.83	2.96	3.35	11.34	12.70	8.92	6.11	4.91	2.15	

Calm : .00 %

Total # Operational Hours : 8223

Distribution By Samples

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	201	349	412	275	697	801	874	229	241	272	921	1035	731	500	402	176	8116
< 110	1	1	10	18	15	8	8	4	3	4	12	10	3	3	2	1	103
< 210				4													4
>= 210																	
Totals	202	350	422	297	712	809	882	233	244	276	933	1045	734	503	404	177	



Calm : .00 %

Total # Operational Hours : 8223

Class Limits (PPB)

Period : 01/01/08-12/31/08

Level : 10



# Ozone



Current Date : 02/25/09  
 Current Time : 11:29

Annual Parameter Summary Report - Hourly  
 Maxxam Analytics

Year : 2008

Logger Name : LICA                      Logger Id : 01                      Parameter : 03\_                      Units : PPB

	Valid				
	Readings	Readings	Min	Max	Mean
January	744	707	0	40	19
February	696	662	0	49	25
March	744	707	0	59	35
April	720	685	3	63	41
May	744	706	3	63	38
June	720	685	0	62	29
July	744	708	0	59	24
August	744	707	0	57	21
September	720	685	0	36	16
October	744	703	0	44	21
November	720	684	0	34	17
December	744	705	0	39	18
Yearly Total	8784	8344	0	63	25

## O<sub>3</sub> Monthly Averages and Frequency Distributions of One Hour Readings - 2008

Plant Operator: Lakeland Industry & Community Association    Plant Location: Cold Lake

Month	Number of Readings	% Readings in Concentration Range (ppmO <sub>3</sub> )				O <sub>3</sub> ppb Monthly Average
		0 to 0.05 ppm	0.06 to 0.11 ppm	0.12 to 0.21 ppm	> 0.21 ppm	
January	706	100.0%	0.0%	0.0%	0.0%	19.90
February	663	100.0%	0.0%	0.0%	0.0%	25.93
March	707	92.2%	7.8%	0.0%	0.0%	35.76
April	684	72.1%	27.9%	0.0%	0.0%	41.07
May	706	76.3%	23.7%	0.0%	0.0%	38.58
June	685	91.2%	8.8%	0.0%	0.0%	29.77
July	708	98.7%	1.3%	0.0%	0.0%	24.43
August	707	98.3%	1.7%	0.0%	0.0%	21.92
September	685	100.0%	0.0%	0.0%	0.0%	16.33
October	703	100.0%	0.0%	0.0%	0.0%	21.62
November	684	100.0%	0.0%	0.0%	0.0%	17.66
December	705	100.0%	0.0%	0.0%	0.0%	18.23
<b>Annual Average</b>						<b>25.93</b>

### O<sub>3</sub> One - Hour Averages for 2008

Plant Operator: Lakeland Industry & Community Association Plant Location: Cold Lake

Month	O <sub>3</sub> ppb One - Hour Peak Reading
January	40
February	49
March	59
April	63
May	63
June	62
July	59
August	57
September	36
October	44
November	34
December	39
<b>ANNUAL PEAK</b>	<b>63</b>

## O<sub>3</sub> 24 - Hour Averages for 2008

Plant Operator: Lakeland Industry & Community Association Plant Location: Cold Lake

Month	O <sub>3</sub> ppb 24 - Hour Peak Reading
January	32.0
February	39.0
March	45.0
April	56.4
May	47.0
June	43.5
July	33.3
August	38.1
September	25.5
October	32.0
November	27.9
December	31.2
<b>ANNUAL PEAK</b>	<b>56.4</b>

LICA  
O3\_ / WD Joint Frequency Distribution (Percent)

01/01/08 thru 12/31/08

Distribution By % Of Samples

Logger Id : 01  
Site Name : LICA  
Parameter : O3\_  
Units : PPB

Wind Parameter : WD  
Instrument Height : 10 Meters

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	2.37	3.93	4.53	3.41	8.07	9.15	9.96	2.63	2.77	3.23	10.26	12.29	8.65	5.88	4.76	2.09	94.06
< 110	.14	.31	.55	.16	.62	.53	.57	.19	.17	.13	1.04	.35	.38	.28	.29	.14	5.93
< 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
>= 210	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	2.51	4.24	5.08	3.58	8.69	9.69	10.54	2.83	2.95	3.37	11.30	12.65	9.04	6.17	5.06	2.24	

Calm : .00 %



Total # Operational Hours : 8338

Distribution By Samples

	Direction																
Limit	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	Freq
< 50	198	328	378	285	673	763	831	220	231	270	856	1025	722	491	397	175	7843
< 110	12	26	46	14	52	45	48	16	15	11	87	30	32	24	25	12	495
< 210																	
>= 210																	
Totals	210	354	424	299	725	808	879	236	246	281	943	1055	754	515	422	187	

Calm : .00 %

Total # Operational Hours : 8338



# Ambient Temperature

TEMP

Current Date : 02/25/09  
 Current Time : 11:30

Annual Parameter Summary Report - Hourly  
 Maxxam Analytics

Year : 2008

Logger Name : LICA                      Logger Id : 01                      Parameter : TPX                      Units : DGC

	Readings	Valid Readings	Min	Max	Mean
January	744	744	-40	0	-15.4
February	696	696	-36.6	4.5	-14.5
March	744	743	-29.7	8.3	-5.6
April	720	720	-14.5	17.1	0.2
May	744	744	-3.2	25.2	11
June	720	720	0.5	29.3	15.4
July	744	744	6.4	29.2	16.8
August	744	744	-0.1	30.1	16.2
September	720	719	-1.6	23.1	9.7
October	744	744	-8	25.2	5.1
November	720	720	-16.2	8.4	-2
December	744	741	-39.2	6.7	-20.1
Yearly Total	8784	8779	-40	30.1	1.4



## Temperature - Monthly Averages for 2008

Plant Operator: Lakeland Industry & Community Plant Location: Cold Lake

Month	Monthly Averages (Deg.C)	Maximum Hourly Average	Minimum Hourly Average	Maximum Daily Average
January	-15.43	-0.8	-40.0	-4.3
February	-14.60	4.5	-36.6	-0.4
March	-5.67	8.3	-29.7	2.1
April	0.23	17.1	-14.5	10.1
May	11.01	25.2	-3.2	17.7
June	15.45	29.3	0.5	22.9
July	16.82	29.2	6.4	22.7
August	16.24	30.1	-0.1	23.2
September	9.77	23.1	-1.6	14.7
October	5.15	25.2	-8.0	17.3
November	-2.03	8.4	-16.2	5.2
December	-20.17	6.7	-39.2	1.5
<b>ANNUAL AVERAGE</b>	<b>1.40</b>	<b>-</b>	<b>-</b>	<b>-</b>

# Relative Humidity

RH

Current Date : 02/25/09  
Current Time : 11:30

Annual Parameter Summary Report - Hourly  
Maxxam Analytics

Year : 2008

Logger Name : LICA                      Logger Id : 01                      Parameter : RH                      Units : %FS

	Valid				
	Readings	Readings	Min	Max	Mean
January	744	744	51.3	93	77
February	696	696	43.3	92.4	71.4
March	744	743	32.3	95	68
April	720	720	24.8	94.7	62.4
May	744	744	14.9	95.3	51
June	720	720	17.9	97.8	63.9
July	744	744	28.3	98.8	71.4
August	744	744	32.5	98.9	73
September	720	719	30.6	99.1	72.1
October	744	744	18.8	95.6	61.4
November	720	720	48.4	98	79.8
December	744	741	45.2	93.3	73.2
Yearly Total	8784	8779	14.9	99.1	68.7

## RELATIVE HUMIDITY - Monthly Averages for 2008

Plant Operator: Lakeland Industry & Community Plant Location: Cold Lake

Month	Monthly Averages (%)	Maximum Hourly Average	Maximum Daily Average
January	77.09	93.00	88.01
February	71.49	92.40	79.48
March	68.09	95.00	78.48
April	62.45	94.70	86.53
May	51.05	95.30	75.90
June	63.97	97.80	90.48
July	71.43	98.80	91.00
August	73.06	98.90	93.91
September	72.19	99.10	88.24
October	61.49	95.60	89.65
November	79.80	98.00	93.52
December	73.28	93.30	83.42
<b>ANNUAL AVERAGE</b>	<b>68.78</b>	-	-

# Vector Wind Speed

WS

Current Date : 02/25/09  
Current Time : 11:30

Annual Parameter Summary Report - Hourly  
Maxxam Analytics

Year : 2008

Logger Name : LICA                      Logger Id : 01                      Parameter : WSP                      Units : KPH

	Readings	Valid Readings	Min	Max	Mean
January	744	744	0	25.5	4.9
February	696	696	0	23.8	5.3
March	744	743	0	21.8	5.9
April	720	720	0	20.7	7.4
May	744	744	0	25.4	6.9
June	720	720	0	19.5	5.2
July	744	744	0	19.1	5.7
August	744	744	0	17.7	6.1
September	720	719	0	19.9	5.4
October	744	739	0	31.1	7
November	720	717	0	18.4	6
December	744	741	0	30.1	5.6
Yearly Total	8784	8771	0	31.1	5.9

LICA  
WSP / WD Joint Frequency Distribution (Percent)

01/01/08 thru 12/31/08

Distribution By % Of Samples

Logger Id : 01  
Site Name : LICA  
Parameter : WSP  
Units : KPH

Wind Parameter : WD  
Instrument Height : 10 Meters

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 6.0	1.03	1.82	3.24	2.72	4.02	4.69	5.41	2.39	2.26	2.63	7.06	6.46	3.32	1.89	1.24	.83	51.10
< 12.0	1.02	1.66	1.50	.62	3.96	4.05	4.07	.21	.20	.23	3.37	4.77	3.59	2.28	1.99	.99	34.59
< 20.0	.38	.82	.17	.01	.37	.58	.78	.00	.00	.00	.37	.95	1.77	1.71	1.44	.31	9.72
< 29.0	.00	.00	.01	.00	.00	.00	.00	.00	.00	.00	.00	.00	.12	.21	.26	.01	.62
< 39.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.02	.00	.00	.02
>= 39.0	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00	.00
Totals	2.45	4.30	4.93	3.36	8.36	9.33	10.27	2.61	2.47	2.87	10.81	12.19	8.82	6.12	4.94	2.15	

Calm : 3.93 %

Total # Operational Hours : 8771



Distribution By Samples

Limit	Direction																Freq
	N	NNE	NE	ENE	E	ESE	SE	SSE	S	SSW	SW	WSW	W	WNW	NW	NNW	
< 6.0	91	160	285	239	353	412	475	210	199	231	620	567	292	166	109	73	4482
< 12.0	90	146	132	55	348	356	357	19	18	21	296	419	315	200	175	87	3034
< 20.0	34	72	15	1	33	51	69				33	84	156	150	127	28	853
< 29.0				1									11	19	23	1	55
< 39.0															2		2
>= 39.0																	
Totals	215	378	433	295	734	819	901	229	217	252	949	1070	774	537	434	189	

Calm : 3.93 %

Total # Operational Hours : 8771

Class Limits (KPH)





# Passive Monitoring Annual Summary

# Sulphur Dioxide

**PASSIVE AMBIENT AIR MONITORING ANNUAL**

LAKELAND INDUSTRY AND COMMUNITY ASSOCIATION

BONNYVILLE

Company

Project Number

BONNYVILLE

01/01/2008

12/01/2008

Location

Date Samples Start

Date Sampled End

**SO2 (ppb)**

Station	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sep.	Oct.	Nov.	Dec.	Average	Maximum
1	0.3	0.6	0.3	0.1	0.3	<0.1	0.3	0.2	<0.1	0.2	0.1	0.2	<b>&lt;0.2</b>	<b>0.6</b>
2	0.8	1.1	0.4	0.2	0.3	0.1	0.4	0.3	<0.1	0.3	0.2	0.6	<b>&lt;0.4</b>	<b>1.1</b>
2A	NA	NA	NA	0.4	NA	NA	NA	NA	NA	0.3	NA	NA	<b>0.4</b>	<b>0.4</b>
3	1.7	1.7	0.7	0.3	0.2	0.2	0.5	0.3	0.2	0.4	0.3	0.8	<b>0.6</b>	<b>1.7</b>
4	1.0	1.3	0.5	0.3	0.2	0.3	0.4	0.4	0.3	0.3	0.3	0.7	<b>0.5</b>	<b>1.3</b>
4A	NA	0.5	NA	NA	NA	NA	NA	NA	NA	0.3	NA	NA	<b>0.3</b>	<b>0.3</b>
5	1.0	1.1	0.4	0.3	0.2	0.4	0.6	0.5	0.3	0.2	0.2	0.6	<b>0.5</b>	<b>1.1</b>
7	0.9	1.4	0.5	0.4	0.4	0.8	0.4	0.3	0.5	0.3	0.4	NA	<b>0.6</b>	<b>1.4</b>
8	0.9	1.3	0.6	0.2	0.2	0.2	0.4	0.3	0.1	0.3	0.2	0.5	<b>0.4</b>	<b>1.3</b>
9	0.6	1.1	0.5	0.2	0.3	0.3	0.4	0.2	0.1	0.1	0.3	0.4	<b>0.4</b>	<b>1.1</b>
9A	NA	NA	NA	0.2	NA	NA	NA	NA	NA	NA	0.3	NA	<b>0.3</b>	<b>0.3</b>
10	0.4	1.0	0.6	0.2	0.3	<0.1	0.4	0.1	<0.1	0.2	0.3	0.3	<b>&lt;0.3</b>	<b>1.0</b>
10A	NA	NA	NA	NA	0.3	NA	NA	NA	NA	NA	0.3	NA	<b>0.3</b>	<b>0.3</b>
11	0.6	1.0	0.4	0.2	0.2	<0.1	0.4	0.2	<0.1	0.3	0.3	0.5	<b>&lt;0.4</b>	<b>1.0</b>
11A	NA	NA	NA	NA	0.3	NA	NA	NA	NA	NA	NA	0.5	<b>0.4</b>	<b>0.5</b>
12	0.7	1.3	0.6	0.4	0.2	0.2	0.6	0.3	0.1	0.4	0.4	0.8	<b>0.5</b>	<b>1.3</b>
12A	NA	NA	NA	NA	NA	0.2	NA	NA	NA	NA	NA	0.8	<b>0.5</b>	<b>0.8</b>
13	1.0	2.1	1.7	0.8	1.2	0.9	1.2	0.8	0.7	1.5	1.6	1.3	<b>1.2</b>	<b>2.1</b>
13A	NA	NA	NA	NA	NA	1.2	NA	NA	NA	NA	NA	NA	<b>1.2</b>	<b>1.2</b>
14	0.6	1.0	0.5	0.2	0.2	0.2	0.5	0.2	0.1	0.1	0.2	0.5	<b>0.4</b>	<b>1.0</b>
15	0.7	1.2	0.4	0.2	0.2	0.2	0.4	0.3	0.1	0.3	0.3	0.6	<b>0.4</b>	<b>1.2</b>
15A	NA	1.3	NA	NA	NA	NA	NA	0.3	NA	NA	NA	NA	<b>0.8</b>	<b>1.3</b>
16	0.8	1.1	0.4	0.2	0.3	0.5	0.5	0.4	0.2	0.3	0.2	0.7	<b>0.5</b>	<b>1.1</b>
16A	NA	1.2	NA	NA	NA	NA	NA	NA	0.3	NA	NA	NA	<b>0.8</b>	<b>1.2</b>
17	0.6	1.2	0.3	0.2	0.2	0.1	0.3	0.2	<0.1	0.2	0.2	0.5	<b>&lt;0.3</b>	<b>1.2</b>
17A	0.7	NA	NA	NA	NA	NA	NA	0.2	NA	NA	NA	NA	<b>0.4</b>	<b>0.7</b>
18	0.7	1.2	0.5	0.2	0.2	0.2	0.3	0.2	<0.1	0.2	0.2	0.6	<b>&lt;0.4</b>	<b>1.2</b>
19	0.6	0.8	0.5	0.2	0.3	0.2	0.4	0.3	0.2	0.1	0.3	0.4	<b>0.4</b>	<b>0.8</b>
19A	0.5	NA	NA	NA	NA	NA	0.5	NA	NA	NA	NA	NA	<b>0.5</b>	<b>0.5</b>
20	0.4	0.8	0.3	0.2	0.2	0.1	0.2	0.2	<0.1	<0.1	0.2	0.3	<b>&lt;0.3</b>	<b>0.8</b>
21	0.7	1.1	0.4	0.2	0.2	0.3	0.5	0.3	0.1	0.2	0.2	0.7	<b>0.4</b>	<b>1.1</b>
21A	NA	NA	0.5	NA	NA	NA	NA	NA	0.1	NA	NA	NA	<b>0.3</b>	<b>0.5</b>
22	0.7	1.3	0.6	0.2	0.2	0.1	0.2	0.2	<0.1	0.2	0.3	0.8	<b>&lt;0.4</b>	<b>1.3</b>
23	0.6	1.3	1.1	0.5	0.6	0.4	0.4	0.4	0.4	0.4	0.6	0.7	<b>0.6</b>	<b>1.3</b>
24	1.5	1.9	1.4	1.1	0.6	0.9	0.7	0.6	0.7	0.8	0.7	1.5	<b>1.0</b>	<b>1.9</b>
25	0.6	1.1	0.6	0.3	0.5	0.4	0.8	0.4	0.4	0.4	0.3	0.4	<b>0.5</b>	<b>1.1</b>
26	NA	NA	NA	NA	NA	NA	0.5	0.2	<0.1	0.1	0.3	0.4	<b>&lt;0.3</b>	<b>0.5</b>
26A	NA	NA	NA	NA	NA	NA	0.3	NA	NA	NA	NA	NA	<b>0.3</b>	<b>0.3</b>
<b>Average</b>	<b>0.8</b>	<b>1.2</b>	<b>0.6</b>	<b>0.3</b>	<b>0.3</b>	<b>&lt;0.3</b>	<b>0.5</b>	<b>0.3</b>	<b>&lt;0.2</b>	<b>&lt;0.3</b>	<b>0.3</b>	<b>0.6</b>		
<b>Maximum</b>	<b>1.7</b>	<b>2.1</b>	<b>1.7</b>	<b>1.1</b>	<b>1.2</b>	<b>1.2</b>	<b>1.2</b>	<b>0.8</b>	<b>0.7</b>	<b>1.5</b>	<b>1.6</b>	<b>1.5</b>		

# Hydrogen Sulphide

**PASSIVE AMBIENT AIR MONITORING ANNUAL**

**LAKELAND INDUSTRY AND COMMUNITY ASSOCIATION**

Company

**BONNYVILLE**

Project Number

BONNYVILLE

Location

01/01/2008

Date Samples Start

12/01/2008

Date Sampled End

**H2S (ppb)**

Station	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sep.	Oct.	Nov.	Dec.	Average	Maximum
2	0.23	0.22	0.09	0.04	0.12	0.15	0.19	0.26	0.12	0.08	0.06	0.17	<b>0.14</b>	<b>0.26</b>
2A	NA	NA	NA	0.05	NA	NA	NA	NA	NA	0.05	NA	NA	<b>0.05</b>	<b>0.05</b>
4	0.20	0.22	0.14	0.17	0.17	0.35	0.48	1.02	0.40	0.08	0.08	0.18	<b>0.29</b>	<b>1.02</b>
4A	NA	NA	0.13	NA	NA	NA	NA	NA	NA	0.28	NA	NA	<b>0.28</b>	<b>0.28</b>
9	0.20	0.24	0.14	0.06	0.14	0.20	0.46	0.33	0.10	0.13	0.06	0.13	<b>0.18</b>	<b>0.46</b>
9A	NA	NA	NA	0.06	NA	NA	NA	NA	NA	NA	0.10	NA	<b>0.08</b>	<b>0.10</b>
10	0.16	0.19	0.07	0.04	0.04	0.04	0.08	0.14	0.05	0.10	0.06	0.14	<b>0.09</b>	<b>0.19</b>
10A	NA	NA	NA	NA	0.05	NA	NA	NA	NA	NA	0.07	NA	<b>0.06</b>	<b>0.07</b>
11	0.07	0.15	0.06	0.04	0.07	0.04	0.09	0.14	0.06	0.10	0.09	0.13	<b>0.09</b>	<b>0.15</b>
11A	NA	NA	NA	NA	0.07	NA	NA	NA	NA	NA	NA	0.25	<b>0.16</b>	<b>0.25</b>
12	0.16	0.18	0.09	0.03	0.05	0.04	0.10	0.15	0.06	0.10	0.08	0.14	<b>0.10</b>	<b>0.18</b>
12A	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	0.13	<b>0.13</b>	<b>0.13</b>
13	0.16	0.26	0.13	0.06	0.10	0.11	0.19	0.26	0.18	0.20	0.17	0.26	<b>0.17</b>	<b>0.26</b>
13A	NA	NA	NA	NA	NA	0.04	NA	NA	NA	NA	NA	NA	<b>0.04</b>	<b>0.04</b>
15	0.20	0.23	0.14	0.08	0.13	0.16	0.27	0.39	0.14	0.15	0.13	0.16	<b>0.18</b>	<b>0.39</b>
15A	NA	0.23	NA	NA	NA	NA	NA	0.41	NA	NA	NA	NA	<b>0.32</b>	<b>0.41</b>
16	0.22	0.26	0.13	0.09	0.16	0.54	0.46	0.51	0.21	0.21	0.14	0.15	<b>0.26</b>	<b>0.54</b>
16A	NA	0.25	NA	NA	NA	NA	NA	NA	0.24	NA	NA	NA	<b>0.25</b>	<b>0.25</b>
17	0.18	0.19	0.08	0.06	0.10	0.14	0.16	0.19	0.08	0.10	0.09	0.15	<b>0.13</b>	<b>0.19</b>
17A	0.20	NA	NA	NA	NA	0.03	NA	0.20	NA	NA	NA	NA	<b>0.14</b>	<b>0.20</b>
19	0.21	0.20	0.10	0.05	0.08	0.21	0.27	0.28	0.12	0.14	0.11	0.14	<b>0.16</b>	<b>0.28</b>
19A	0.22	NA	NA	NA	NA	NA	0.28	NA	NA	NA	NA	NA	<b>0.25</b>	<b>0.28</b>
21	0.24	0.23	0.13	0.06	0.11	0.24	0.30	0.40	0.14	0.17	0.11	0.16	<b>0.19</b>	<b>0.40</b>
21A	NA	NA	0.11	NA	NA	NA	NA	NA	0.14	NA	NA	NA	<b>0.13</b>	<b>0.14</b>
22	0.14	0.15	0.06	<0.02	0.05	0.04	0.09	0.11	0.04	0.10	0.11	0.13	<b>&lt;0.09</b>	<b>0.15</b>
23	0.16	0.21	0.11	0.05	0.12	0.11	0.17	0.30	0.16	0.17	0.13	0.28	<b>0.16</b>	<b>0.30</b>
24	0.17	0.21	0.11	0.07	0.09	0.23	0.26	0.33	0.26	0.32	0.11	0.18	<b>0.19</b>	<b>0.33</b>
26	NA	NA	NA	NA	NA	NA	0.28	0.32	0.12	0.13	0.12	0.16	<b>0.19</b>	<b>0.32</b>
26A	NA	NA	NA	NA	NA	NA	0.25	NA	NA	NA	NA	NA	<b>0.25</b>	<b>0.25</b>
<b>Average</b>	<b>0.18</b>	<b>0.21</b>	<b>0.11</b>	<b>&lt;0.06</b>	<b>0.10</b>	<b>0.16</b>	<b>0.24</b>	<b>0.32</b>	<b>0.15</b>	<b>0.14</b>	<b>0.10</b>	<b>0.17</b>		
<b>Maximum</b>	<b>0.24</b>	<b>0.26</b>	<b>0.14</b>	<b>0.17</b>	<b>0.17</b>	<b>0.54</b>	<b>0.48</b>	<b>1.02</b>	<b>0.40</b>	<b>0.32</b>	<b>0.17</b>	<b>0.28</b>		

# Nitrogen Dioxide

**PASSIVE AMBIENT AIR MONITORING ANNUAL**

LAKELAND INDUSTRY AND COMMUNITY ASSOCIATION

Company

BONNYVILLE

Project Number

BONNYVILLE

Location

01/01/2008

Date Samples Start

12/01/2008

Date Sampled End

**NO2 (ppb)**

Station	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sep.	Oct.	Nov.	Dec.	Average	Maximum
1	2.4	2.9	1.3	0.5	1.0	0.8	0.9	0.9	0.9	1.5	1.8	1.9	1.4	2.9
2	3.7	4.3	1.6	0.9	1.6	1.9	1.2	1.0	1.5	2.4	2.0	3.8	2.2	4.3
2A	NA	NA	NA	0.8	NA	NA	NA	NA	NA	2.4	NA	NA	1.6	2.4
3	4.8	4.0	1.3	0.6	1.4	1.7	1.0	0.9	0.4	2.3	2.4	3.3	2.0	4.8
4	4.3	3.4	1.4	0.8	1.0	1.2	0.7	0.6	0.8	1.8	1.8	2.7	1.7	4.3
4A	NA	NA	1.4	NA	NA	NA	NA	NA	NA	1.9	NA	NA	1.9	1.9
5	4.4	4.8	2.4	1.4	2.1	2.4	1.3	1.2	1.9	3.0	2.3	4.1	2.6	4.8
7	2.9	2.7	1.3	0.7	1.1	0.8	0.8	0.7	0.6	1.7	1.6	2.5	1.5	2.9
8	3.6	4.4	1.7	1.0	1.2	1.4	1.2	1.6	1.2	3.0	2.0	3.5	2.2	4.4
9	4.5	5.5	2.2	1.3	1.4	1.8	1.5	1.1	1.4	3.0	2.6	3.8	2.5	5.5
9A	NA	NA	NA	1.3	NA	NA	NA	NA	NA	NA	NA	NA	1.3	1.3
10	1.7	2.3	0.8	0.4	0.8	0.6	0.6	0.3	0.4	1.1	2.3	1.5	1.1	2.3
10A	NA	NA	NA	NA	0.8	NA	NA	NA	NA	NA	1.0	NA	0.9	1.0
11	3.6	6.0	2.2	1.1	1.6	1.4	1.0	1.7	0.9	2.1	0.9	4.7	2.3	6.0
11A	NA	NA	NA	NA	2.2	NA	NA	NA	NA	NA	NA	5.1	3.7	5.1
12	3.3	3.4	1.3	0.6	1.1	0.8	0.8	0.5	0.8	1.7	2.2	2.3	1.6	3.4
12A	NA	NA	NA	NA	NA	0.7	NA	NA	NA	NA	NA	2.4	1.6	2.4
13	3.0	3.8	2.3	1.1	1.7	1.3	1.7	1.4	1.9	3.3	3.4	3.6	2.4	3.8
13A	NA	NA	NA	NA	NA	1.3	NA	NA	NA	NA	NA	NA	1.3	1.3
14	3.6	4.4	1.5	1.0	0.8	1.0	1.1	0.8	1.2	1.8	1.6	3.2	1.8	4.4
15	4.4	4.5	1.8	1.1	1.2	1.5	1.2	1.2	1.2	2.9	2.4	3.5	2.2	4.5
15A	NA	4.1	NA	NA	NA	NA	NA	1.7	NA	NA	NA	NA	2.9	4.1
16	4.1	5.0	2.1	0.9	1.5	2.8	1.5	1.4	3.1	2.9	2.5	3.6	2.6	5.0
16A	NA	5.1	NA	NA	NA	NA	NA	NA	1.6	NA	NA	NA	3.3	5.1
17	3.0	3.2	1.5	0.8	0.8	0.9	1.0	0.8	0.9	2.1	1.7	2.4	1.6	3.2
17A	2.7	NA	NA	NA	NA	NA	NA	0.8	NA	NA	NA	NA	1.8	2.7
18	3.2	2.8	0.8	0.4	0.7	0.9	0.7	1.0	0.8	1.4	1.5	2.7	1.4	3.2
19	5.9	6.8	3.6	1.8	1.5	1.6	1.5	0.9	1.6	2.9	2.5	5.1	3.0	6.8
19A	5.8	NA	NA	NA	NA	NA	1.2	NA	NA	NA	NA	NA	3.5	5.8
20	1.2	1.4	0.4	0.2	0.3	0.4	0.3	0.2	0.2	2.8	NA	NA	0.7	2.8
21	5.1	6.6	3.5	2.3	2.1	2.5	1.7	1.7	2.3	3.7	3.3	4.3	3.3	6.6
21A	NA	NA	3.6	NA	NA	NA	NA	NA	2.6	NA	NA	NA	3.1	3.6
25	11.6	13.2	9.0	4.5	4.5	4.5	3.4	3.1	3.7	7.8	5.7	8.9	6.7	13.2
26	NA	NA	NA	NA	NA	NA	1.4	1.2	1.4	3.5	3.2	5.3	2.7	5.3
26A	NA	NA	NA	NA	NA	NA	1.3	NA	NA	NA	NA	NA	1.3	1.3
<b>Average</b>	<b>4.0</b>	<b>4.5</b>	<b>2.1</b>	<b>1.1</b>	<b>1.4</b>	<b>1.5</b>	<b>1.2</b>	<b>1.1</b>	<b>1.4</b>	<b>2.6</b>	<b>2.3</b>	<b>3.7</b>		
<b>Maximum</b>	<b>11.6</b>	<b>13.2</b>	<b>9.0</b>	<b>4.5</b>	<b>4.5</b>	<b>4.5</b>	<b>3.4</b>	<b>3.1</b>	<b>3.7</b>	<b>7.8</b>	<b>5.7</b>	<b>8.9</b>		

# Ozone



**PASSIVE AMBIENT AIR MONITORING ANNUAL**

**LAKELAND INDUSTRY AND COMMUNITY ASSOCIATION**

Company

**BONNYVILLE**

Project Number

BONNYVILLE

Location

01/01/2008

Date Samples Start

12/01/2008

Date Sampled End

**O3 (ppb)**

Station	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sep.	Oct.	Nov.	Dec.	Average	Maximum
1	20.9	26.4	37.0	39.1	35.4	21.0	16.6	12.8	12.8	18.7	15.1	18.6	22.9	39.1
2	25.0	32.0	43.6	43.6	47.6	29.6	23.1	17.8	18.9	22.2	18.0	21.9	28.6	47.6
2A	NA	NA	NA	43.4	NA	NA	NA	NA	NA	21.3	NA	NA	32.4	43.4
3	27.5	35.4	54.5	52.6	48.2	31.4	25.2	22.7	20.8	26.2	21.7	31.4	33.1	54.5
4	23.8	37.1	46.9	44.5	45.4	30.7	23.3	17.8	18.2	25.3	18.4	22.5	29.5	46.9
4A	NA	NA	48.1	NA	NA	NA	NA	NA	NA	17.1	NA	NA	17.1	17.1
5	25.3	35.6	47.6	46.9	44.8	30.2	24.7	19.6	18.2	22.4	20.2	24.2	30.0	47.6
7	27.8	35.3	45.5	41.7	47.2	33.8	26.2	23.5	23.3	27.6	18.5	26.3	31.4	47.2
8	27.4	34.8	43.1	45.4	42.2	28.8	29.0	19.4	19.8	25.0	19.3	24.5	29.9	45.4
9	22.6	29.2	44.3	42.5	40.5	37.3	26.5	21.6	17.7	22.5	16.3	18.8	28.3	44.3
9A	NA	NA	NA	41.3	NA	NA	NA	NA	NA	NA	16.1	NA	28.7	41.3
10	23.2	33.8	40.1	37.6	35.9	24.2	17.1	15.3	12.6	21.6	17.0	20.4	24.9	40.1
10A	NA	NA	NA	NA	33.7	NA	NA	NA	NA	NA	15.7	NA	24.7	33.7
11	23.1	25.9	35.1	41.9	41.8	29.5	19.5	15.8	14.1	17.9	16.3	17.9	24.9	41.9
11A	NA	NA	NA	NA	41.7	NA	NA	NA	NA	NA	NA	18.7	30.2	41.7
12	25.6	35.4	43.3	36.3	48.2	36.5	21.8	21.8	17.2	23.2	20.2	24.4	29.5	48.2
12A	NA	NA	NA	NA	NA	38.9	NA	NA	NA	NA	NA	23.0	31.0	38.9
13	23.2	32.6	40.4	43.9	43.7	33.1	29.1	29.0	21.3	22.6	17.8	21.0	29.8	43.9
13A	NA	NA	NA	NA	NA	33.5	NA	NA	NA	NA	NA	NA	33.5	33.5
14	23.7	34.4	45.2	40.6	50.3	31.0	23.8	16.9	17.4	22.2	18.5	22.4	28.9	50.3
15	26.1	33.8	47.7	41.4	40.7	30.8	24.8	18.8	19.5	22.4	19.5	21.8	28.9	47.7
15A	NA	30.9	NA	NA	NA	NA	NA	25.3	NA	NA	NA	NA	28.1	30.9
16	26.0	37.7	52.9	52.9	48.2	34.2	25.5	20.6	21.8	23.2	16.6	26.2	32.2	52.9
16A	NA	32.9	NA	NA	NA	NA	NA	NA	18.8	NA	NA	NA	25.8	32.9
17	23.5	33.0	45.4	39.8	38.4	25.6	18.3	13.7	15.4	19.3	17.9	23.3	26.1	45.4
17A	25.9	NA	NA	NA	NA	NA	NA	13.9	NA	NA	NA	NA	19.9	25.9
18	28.8	38.4	46.8	45.0	42.7	31.1	26.2	28.0	20.9	25.9	21.5	24.6	31.7	46.8
19	20.3	32.8	35.7	40.4	39.8	29.6	19.6	22.5	15.7	20.7	18.0	18.7	26.1	40.4
19A	22.2	NA	NA	NA	NA	NA	22.2	NA	NA	NA	NA	NA	22.2	22.2
20	22.3	30.7	34.8	36.9	35.7	26.1	18.3	13.4	14.3	18.0	16.4	18.5	23.8	36.9
21	23.6	NA	41.2	41.6	51.1	31.6	24.7	27.4	21.3	22.2	17.7	21.9	29.5	51.1
21A	NA	NA	37.0	NA	NA	NA	NA	NA	19.5	NA	NA	NA	28.3	37.0
25	18.4	27.1	35.2	37.8	45.9	28.1	36.0	21.3	17.5	21.0	15.5	17.7	26.8	45.9
26	NA	NA	NA	NA	NA	NA	26.8	19.9	17.7	22.2	20.0	19.3	21.0	26.8
26A	NA	NA	NA	NA	NA	NA	26.7	NA	NA	NA	NA	NA	26.7	26.7
<b>Average</b>	<b>24.2</b>	<b>33.0</b>	<b>43.1</b>	<b>42.5</b>	<b>43.0</b>	<b>30.7</b>	<b>24.0</b>	<b>20.0</b>	<b>18.1</b>	<b>22.1</b>	<b>18.0</b>	<b>22.0</b>		
<b>Maximum</b>	<b>28.8</b>	<b>38.4</b>	<b>54.5</b>	<b>52.9</b>	<b>51.1</b>	<b>38.9</b>	<b>36.0</b>	<b>29.0</b>	<b>23.3</b>	<b>27.6</b>	<b>21.7</b>	<b>31.4</b>		