

March 21, 2012

File No(s): 2012 – 444A / 465A

Mr. Michael Bisaga
Program Manager
Lica Airshed
13440 – 62 street
Edmonton, AB T5A 0V7

Dear Mr. Bisaga:

Re: LICA Ambient Air Monitoring Station Audits

Please see attached audit summary for all audit findings from the audits conducted on the LICA ambient air monitoring stations. Please note that site documentation findings are repeat findings from the previous 2010 audit and must be addressed. AEW will require the site documentation for the sites noted indicating the findings have been addressed before the audit will be considered closed. Please refer to the AMD for the complete list of requirements.

Please review all documentation and address the issues noted by April 27, 2012, in writing indicating what corrective actions that will or have been taken. If you have any questions, please contact the undersigned at 780-427-7888.

Yours truly,



Al Clark
Monitoring Systems Auditor
Environmental Assurance

Attachment(s): Audit Summary Report

cc: Pat Marriot: District Approvals Manager
Jeff Toering: District Compliance Manager
Marilyn Albert: Air Quality Data Supervisor
Janine Ross: Ambient Air Specialist



Audit Summary

Facility / Zone	Lica
Total # of parameters that passed	22
Total # of parameters audited in the network	22
Date(s) of the audit	March 13-16, 2012
Issue Date of Audit Summary	March 21, 2012

Station Name	St Lina
Auditor	Al Clark
Audit Date	March 13, 2012

Critical	Pass	Fail
H ₂ S	√	
SO ₂	√	
TRS		
NO / NO ₂ / NO _x	√	
O ₃	√	
THC	√	
TEOM/BAM PM _{2.5}	√	
Wind Speed / Wind Direction	√	
Wind head Orientation	√	
Manifold Fan	√	
Precipitation Sampler	√	
Zero/Span Systems Operational	√	

Inspection Items	OK	Need for Improvement
Sample pump venting/scrubbing	√	
Heating / Air Conditioning	√	
Manifold	√	
Sample Lines	√	
TEOM/BAM PM _{2.5}	√	
Safety	√	
Site Conditions	√	

Non-critical	OK	Opportunity for Improvement
RH	√	
Station Temperature	√	
Ambient Temperature	√	
Barometric Pressure	√	
Tipping bucket	√	
Station Condition	√	
Station Documentation		X Needs review / or missing

Not monitored at this location

Audit Summary

Facility / Zone	Lica
Total # of parameters that passed	22
Total # of parameters audited in the network	22
Date(s) of the audit	March 13-16, 2012
Issue Date of Audit Summary	March 21, 2012

Station Name	Elk Point Airport
Auditor	Al Clark
Audit Date	March 14, 2012

Critical	Pass	Fail
H ₂ S	√	
SO ₂	√	
TRS		
NO / NO ₂ / NO _x	√	
O ₃	√	
THC	√	
TEOM/BAM PM _{2.5}	√	
Wind Speed / Wind Direction	√	
Wind head Orientation	√	
Manifold Fan	√	
Precipitation Sampler		
Zero/Span Systems Operational	√	

Inspection Items	OK	Need for Improvement
Sample pump venting/scrubbing	√	
Heating / Air Conditioning	√	
Manifold	√	
Sample Lines	√	
TEOM/BAM PM _{2.5}	√	
Safety	√	
Site Conditions	√	

Non-critical	OK	Opportunity for Improvement
RH		
Station Temperature	√	
Ambient Temperature		
Barometric Pressure		
Tipping bucket		
Station Condition	√	
Station Documentation		X Needs review / or missing

Not monitored at this location

Audit Summary

Facility / Zone	Lica
Total # of parameters that passed	22
Total # of parameters audited in the network	22
Date(s) of the audit	March 13-16, 2012
Issue Date of Audit Summary	March 21, 2012

Station Name	Cold Lake South
Auditor	Al Clark
Audit Date	March 15, 2012

Critical	Pass	Fail
H ₂ S		
SO ₂	√	
TRS	√	
NO / NO ₂ / NO _x	√	
O ₃	√	
THC	√	
TEOM/BAM PM _{2.5}	√	
Wind Speed / Wind Direction	√	
Wind head Orientation	√	
Manifold Fan	√	
Precipitation Sampler		
Zero/Span Systems Operational	√	

Inspection Items	OK	Need for Improvement
Sample pump venting/scrubbing	√	
Heating / Air Conditioning	√	
Manifold	√	
Sample Lines	√	
TEOM/BAM PM _{2.5}	√	
Safety	√	
Site Conditions	√	

Non-critical	OK	Opportunity for Improvement
RH	√	
Station Temperature	√	
Ambient Temperature	√	
Barometric Pressure		
Tipping bucket		
Station Condition	√	
Station Documentation	√	

Not monitored at this location

Audit Summary

Facility / Zone	Lica
Total # of parameters that passed	22
Total # of parameters audited in the network	22
Date(s) of the audit	March 13-16, 2012
Issue Date of Audit Summary	March 21, 2012

Station Name	Maskwa
Auditor	Al Clark
Audit Date	March 16, 2012

Critical	Pass	Fail
H ₂ S	√	
SO ₂	√	
TRS		
NO / NO ₂ / NO _x	√	
O ₃		
THC	√	
TEOM/BAM PM _{2.5}		
Wind Speed / Wind Direction	√	
Wind head Orientation	√	
Manifold Fan	√	
Precipitation Sampler	√	
Zero/Span Systems Operational	√	

Inspection Items	OK	Need for Improvement
Sample pump venting/scrubbing	√	
Heating / Air Conditioning	√	
Manifold	√	
Sample Lines	√	
TEOM/BAM PM _{2.5}		
Safety	√	
Site Conditions	√	

Non-critical	OK	Opportunity for Improvement
RH	√	
Station Temperature	√	
Ambient Temperature	√	
Barometric Pressure	√	
Tipping bucket	√	
Station Condition	√	
Station Documentation	√	

Not monitored at this location

STATION AUDIT

File No. 2012 - 456A / 461A

Date: March 15, 2012

Performed by: Al Clark

Station

Name: Cold Lake

Location: Cold Lake South

Facility/Zone: Lica

Operator: Maxxam

Temp: 23.5 C

Barometric Press: 706 mm/hg

Location

Latitude N 54° 24' 50.9"

Longitude W 110° 13' 58.3"

Elevation 528 m

Status of Site Documentation On site - OK

Manifold Material Glass
Manifold Condition Good

Meteorological

	Observed	Audit Value
Wind Speed Direction	<u>7 kph / 155 deg</u>	<u>5-10 kph / NE</u>
Station Temperature	<u>23.4 C</u>	<u>23.6 C</u>
Relative Humidity	<u>40.1 %</u>	<u>38.4 %</u>
Ambient Temperature	<u>4.8 C</u>	<u>5.8 C</u>
BP	<u>N/A</u>	<u>N/A</u>
Precipitation	<u>N/A</u>	<u>N/A</u>

Remarks:

There is an operational API 701 zero air supply sitting on the back bench. As a result of this placement of this unit the counter top is being damaged and there is significant amount of black stains from the unit. These stains could also contain mould due to the moisture being exhausted from the unit. This unit must be rack mounted to prevent further damage. Care must be taken to reduce vibrations so other instruments are not affected by the installation.

SO₂ ANALYZER AUDIT

File No. 2012 - 456A

Date: March 15, 2012

Performed by: Al Clark

Station

Name: Cold Lake

Location: Cold Lake South

Facility/Zone: Lica

Operator: Maxxam

Temp: 21.5 C

Barometric Press: 706 mm/hg

Monitor

Make/Model: Teco 43i Serial No: 0806528242

Inlet flow (sccm): 350 Full Scale Range ppm: 0.5

Last cal. Date: Feb 24/12 Old C.F. 0.9975

Zero/Bkg 13.8

Span Coef 1.334

Calibrator

Calibration Method: GAS DILUTION

Make/Model: R&R MFC 201

AMU #: 1691

Cylinder #: CLM004813

SO₂ Concentration PPM: 50.4

Calibrator Flow (sccm)			Calculated Conc. (ppm)	Indicated Concentration (ppm)	% Difference	
Air	Gas	Total			vs Audit Gas	Limits
5107	0.0	5107	0.000	0.000		
5115	38.5	5153	0.377	0.373	-1%	± 15%
5132	17.5	5149	0.171	0.165	-4%	± 15%
5095	8.3	5103	0.082	0.081	-1%	± 15%
Absolute Average Percent Difference					2%	

Linear Regression Analysis:

$y=mx+b$ (where x =calculated concentration, y =indicated concentration)

Correlation Coeff.= 0.9999

m (Slope)= 0.9899

b (Intercept as % of full scale)= -0.2241

LIMITS

≥ **0.995**

0.85-1.15

± **3% F.S.**

Remarks:

TRS ANALYZER AUDIT

File No. 2012 - 457A

Date: March 15, 2012

Performed by: Al Clark

Station

Name: Cold Lake

Location: Cold Lake South

Facility/Zone: Lica

Operator: Maxxam

Temp: 21.5 C

Barometric Press: 706 mm/hg

Monitor

Make/Model: Teco 450i Serial No: 0812728560

Inlet flow (sccm): 350 Full Scale Range ppm: 0.1

Last cal. Date: Feb 24/12 Old C.F. 0.9989

Zero/Bkg 13.8

Span Coef 1.334

Calibrator

Calibration Method: GAS DILUTION

Make/Model: R&R MFC 201

AMU #: 1691

Cylinder #: CAL011014

H₂S Concentration PPM: 9.4

Calibrator Flow (sccm)			Calculated Conc. (ppm)	Indicated Concentration (ppm)	% Difference	
Air	Gas	Total			vs Audit Gas	Limits
5107	0.0	5107	0.000	0.000		
5115	38.4	5153	0.070	0.074	6%	± 15%
5131	17.8	5149	0.032	0.035	8%	± 15%
5094	9.0	5103	0.017	0.018	9%	± 15%
Absolute Average Percent Difference					7%	

Linear Regression Analysis:

$y=mx+b$ (where x =calculated concentration, y =indicated concentration)

Correlation Coeff.= 0.9999

m (Slope)= 1.0547

b (Intercept as % of full scale)= 0.3403

LIMITS

≥ **0.995**

0.85-1.15

± **3% F.S.**

Remarks:

HC ANALYZER AUDIT

File No. 2012 - 458A

Date: March 15, 2012

Performed by: Al Clark

Station

Name: Cold Lake

Location: Cold Lake South

Facility/Zone: Lica

Operator: Maxxam

Temp: 23.5 C

Barometric Press: 706 mm/hg

Monitor

Make/Model: Teco 51CLT Serial No: 0427408718

Inlet flow (sccm): 6.50 psi Full Scale Range ppm: 50.0

Last cal. Date: Feb 24/12 Old C.F. 0.9954

Calibrator

Calibration Method: Gas Dilution

Make/Model: Sabio 2010

AMU #: 1778

HC cylinder #: SG090044A

HC concentration ppm: 1057

Calibrator Flow (sccm)			Calculated Conc. (ppm)	Indicated Concentration (ppm)	% Difference	
Air	Gas	Total			vs Audit Gas	Limits
2976	0.0	2976	0.0	0.6		
2983	82.6	3066	28.5	26.9	-8%	± 15%
2958	40.5	2998	14.3	13.7	-8%	± 15%
2984	20.0	3004	7.0	7.2	-6%	± 15%
Absolute Average Percent Difference					7%	

Linear Regression Analysis:

$y=mx+b$ (where x =calculated concentration, y =indicated concentration)

Correlation Coeff.= 1.0000
 m (Slope)= 0.9220
 b (Intercept as % of full scale)= 1.2459

LIMITS
≥ 0.995
0.85-1.15
± 3% F.S.

Remarks:

NO-NOx-NO2 Analyzer Audit

File No. 2012 - 459A

Date: March 15, 2012 Performed by: Al Clark

Station: Name: Cold Lake Location: Cold Lake South Operator: Maxxam
 Facility/Zone: Lica Temp. 23.5 C BP: 706 mm/hg

Monitor: Make/Model: Teco 42C Serial No. 0427408716
 Inlet flow (sccm): 728/727 Range ppm: 0.5
 Last cal. Date: Mar 7/12 Old C.F.'s NO: 0.999
 NOx: 1.000
 NO2: 1.000
 NO Bkg 3.5
 NOx Bkg 3.7
 NO Coef 0.888
 NOx Coef 1.007
 NO2 Coef 0.998

Calibration Method: Gas Dilution / GPT
Calibrator: Make/Model: Sabio 2010 AMU# 1749
 NO cylinder # CLM006307 NO conc. ppm 49.5 NOx conc. ppm 50.9

Calibrator Flows			Calc. Conc.		Indicated Concentration		% Difference vs Audit Gas	
			NO (ppm)	NOx (ppm)	NO (ppm)	NOx (ppm)	NO	NOx
Air	Gas	Total						
4938	0.0	4938	0.000	0.000	0.000	0.000	Limit ± 15%	
4942	40.0	4982	0.397	0.409	0.375	0.390	-6%	-5%
4964	19.8	4984	0.197	0.202	0.186	0.196	-5%	-3%
4945	9.9	4955	0.099	0.102	0.092	0.099	-7%	-3%
Absolute Average Percent Difference							6%	3%

Linear Regression Analysis:

y=mx+b (where x=calculated concentration, y=indicated concentration)

	NO	NOx	NO ₂	LIMITS
Correlation Coeff.=	<u>1.0000</u>	<u>1.0000</u>	<u>1.0000</u>	≥ 0.995
m (Slope)=	<u>0.9448</u>	<u>0.9535</u>	<u>1.0056</u>	0.85-1.15
b (Intercept as % of full scale)=	<u>-0.0870</u>	<u>0.2785</u>	<u>-0.2521</u>	± 3% F.S.

O ₃ Setting	Flow Rate	Indicated Conc. (ppm)			NO Decrease	NO ₂ Increase	% Difference vs Audit Gas	
		NO	NOx	NO ₂				
0.000 V	4982	0.379	0.391	0.012	0.255	0.255	0%	%Dif Limit
0.760 V	4982	0.124	0.391	0.267	0.255	0.255	0%	± 15%
0.444 V	4982	0.214	0.390	0.177	0.165	0.165	0%	± 15%
0.280 V	4982	0.302	0.390	0.088	0.077	0.076	-1%	± 15%
Absolute Average Percent Difference							0%	

Converter Efficiency

Average Converter Efficiency 99.6%

Remarks: _____

O₃ ANALYZER AUDIT

File No. 2012 - 460A

Date: March 15, 2012

Performed by: Al Clark

Station

Name: Cold Lake

Location: Cold Lake South

Facility/Zone: Lica

Operator: Maxxam

Temp: 23.5 C

Barometric Press: 706 mm/hg

Monitor

Make/Model: Teco 49i Serial No: 0700419951

Inlet flow (sccm): 698 / 736 Full Scale Range ppm: 0.5

Last cal. Date: Feb 24/12 Old C.F. 1.0025

Zero/Bkg -0.1

Span Coeff. 1.004

Calibrator

Calibration Method: Generator

Make/Model: Sabio 2010

NO cylinder #: N/A

AMU #: 1749

NO concentration ppm: N/A

Ozone Setting	Calibrator Flow (sccm)			Calculated Conc. (ppm)	Indicated Conc. (ppm)	% Difference	
	Air	Gas	Total			vs Audit Gas	Limits
0.000 V	4953	X	4953	0.000	0.000		
0.760 V	4953	X	4953	0.401	0.387	-3%	± 15%
0.444 V	4953	X	4953	0.201	0.195	-3%	± 15%
0.280 V	4953	X	4953	0.098	0.097	-1%	± 15%
Absolute Average Percent Difference						2%	

Linear Regression Analysis:

$y=mx+b$ (where x =calculated concentration, y =indicated concentration)

Correlation Coeff.= 1.0000
 m (Slope)= 0.9633
 b (Intercept as % of full scale)= 0.2354

LIMITS
≥ 0.995
0.85-1.15
± 3% F.S.

Remarks:

TEOM AUDIT

Date: March 15, 2012 File #: 2012 - 461A
 Performed by: Al Clark

Station			
Name:	<u>Cold Lake</u>	Location:	<u>Cold Lake South</u>
Facility/Zone:	<u>Lica</u>	Operator:	<u>Maxxam</u>
Temperature:	<u>-1.6</u>	Barometric Press.:	<u>706 mm/hg</u>

Audit Transfer Standard			
Make/Model:	<u>DeltaCal</u>	Cell s/n:	<u>1002</u>
Serial Number:	<u>1858</u>		
Sampler Set-up and Current Readings			
Make/Model	<u>Teom 1405-F</u>	F-Main Set Pt (l/min)	<u>3.00</u>
Unit #	<u>PM2.5</u>	F-Aux Set Pt (l/min)	<u>13.67</u>
Control unit s/n	<u>1405A2016208814</u>	Filter Load (%)	<u>30</u>
Transducer s/n	<u>1405A2016208814</u>	K _O Factor	<u>14578</u>
		Temp (°C)	<u>-1.6</u>
		Press (ATM)	<u>0.921</u>

Conversion from mm Hg or " Hg to ATM (Atmospheres)

$ATM = (mm\ Hg) \times (1.316 \times 10^{-3})$ or $ATM = ("Hg) \times (3.34207 \times 10^{-2})$

Note: Tolerances are noted as **BOLD** in Brackets

Zero Flow			
Pump Off		Pump On (Time to reach set points)	
F-Main (l/min)	<u>N/A</u>	(45-60 Sec)	<u>N/A</u>
F-Aux (l/min)	<u>N/A</u>	(45-60 Sec)	<u>N/A</u>

Temperature/Pressure			
Measured Temp (± 2 °C)	<u>-0.9</u>	Δ°C	<u>0.7</u>
Measured Press (± 1.5% ATM)	<u>0.929</u>	Δ% ATM	<u>0.87%</u>

Flow Audit			
Indicated Main/Aux Flow (l/min)	<u>3.00</u> <u>13.66</u>	Δ% of Measured Flow from Set-point	
Total Flow = Main + Aux (l/min)	<u>16.66</u>	(± 2%)	<u>0.0%</u> <u>-0.1%</u>
		(± 2%)	<u>-0.1%</u>
Δ of Measured Flow from Indicated			
Measured Total Flow (l/min)	<u>17.05</u>	(± 1.00 l/min)	<u>0.39</u>
Measured Main Flow (l/min)	<u>3.02</u>	(± 0.20 l/min.)	<u>0.02</u>

Leak Check			
Base (< 0.15 l/min)	<u>Pass</u>	Actual leakage = Pump On – Pump Off	<u>0.07</u>
Ref (< 0.65 l/min)	<u>Pass</u>		<u>0.28</u>

K_O Factor			
Measured	<u>14535</u>		
K _O % Difference (± 2.5%)	<u>0.29</u>		

Remarks: Heads clean.

Station Performance Audit Summary

Company: Lica Facility Name: Cold Lake
 Approval No.: N/A Site Name: Cold Lake
 AENV Region: Northern AENV District: North East

Parameters audited:

H ₂ S	X	SO ₂	X	NO _x	X	NH ₃		O ₃	X
CO		CH ₄		NonCH ₄		THC	X	Ethylene	
PM _{2.5}	X	PM ₁₀		TSP		BTEX		Wind Speed	X
Wind Dir	X	Amb. Temp	X	Stn.Temp	X	RH	X	Solar Radiation	
Rainfall		Precip		VWS		Other			
All parameters monitored as per approval: Yes _____ No _____ N/A _____									

GENERAL

Has the location remained unchanged from previous audit?
 Is site secure?
 Are station operating conditions adequate?

YES NO N/A

X		
X		
X		

DATA ACQUISITION

Are strip charts in use?
 Is a telemetry system for data acquisition in use?

	X	
X		

SYSTEM COMPONENTS

Is a glass sampling manifold installed?
 Is sampling manifold clean?
 Is a manifold trap in place?
 Are spare manifold ports capped?
 Is manifold oriented so it is not exactly horizontal?
 Are manifold ports situated to prevent water entering monitors?
 Is manifold pump properly installed and operative?
 Do sample lines extend at least 3/4" into manifold?
 Are monitor sampling lines connected to manifold?
 Are sampling lines clean?
 Are monitors properly mounted and secure?
 Are monitors properly exhausted from room or scrubbed?
 Are zero and span systems operational?

X		
X		
X		
X		
X		
X		
X		
X		
X		
X		
X		
X		

WIND EQUIPMENT

Is wind sensor properly oriented?
 Does wind equipment appear to be functioning properly?
 Date of last calibration. Date: Nov 23/10

X		
X		

COMMENTS: Wind Head calibration is required in 2012 as per the AMD.

AUDITOR: Al Clark DATE: March 15, 2012

STATION AUDIT

File No. 2012 - 450A / 455A

Date: March 14, 2012

Performed by: Al Clark

Station

Name: Elk Point

Location: Elk Point Airport

Facility/Zone: Lica

Operator: Maxxam

Temp: 21.0 C

Barometric Press: 700 mm/hg

Location

Latitude N N/A

Longitude W N/A

Elevation N/A

Status of Site Documentation Not on site

Manifold Material Glass
Manifold Condition Good

Meteorological

	Observed	Audit Value
Wind Speed Direction	<u>25 kph / 295deg</u>	<u>25-30 kph / W</u>
Station Temperature	<u>23.6 C</u>	<u>24.4 C</u>
Relative Humidity	<u>N/A</u>	<u>N/A</u>
Ambient Temperature	<u>N/A</u>	<u>N/A</u>
BP	<u>N/A</u>	<u>N/A</u>
Precipitation	<u>N/A</u>	<u>N/A</u>

Remarks:

SO₂ ANALYZER AUDIT

File No. 2012 - 450A

Date: March 14, 2012

Performed by: Al Clark

Station

Name: Elk Point

Location: Elk Point Airport

Facility/Zone: Lica

Operator: Maxxam

Temp. 19.5 C

Barometric Press. 700 mm/hg

Monitor

Make/Model: API 100E Serial No: 467

Inlet flow (sccm): 584 Full Scale Range ppm: 1.0

Last cal. Date: Mar 8/12 Old C.F. 0.9928

Zero/Bkg 91.5

Span Coef 1.041

Calibrator

Calibration Method: GAS DILUTION

Make/Model: R&R MFC 201

AMU #: 1691

Cylinder #: CLM004813

SO₂ Concentration PPM: 50.4

Calibrator Flow (sccm)			Calculated Conc. (ppm)	Indicated Concentration (ppm)	% Difference	
Air	Gas	Total			vs Audit Gas	Limits
5080	0.0	5080	0.000	0.002		
5092	52.4	5144	0.513	0.498	-3%	± 15%
5107	22.3	5129	0.219	0.219	-1%	± 15%
5079	8.2	5087	0.081	0.082	-2%	± 15%
Absolute Average Percent Difference					2%	

Linear Regression Analysis:

$y=mx+b$ (where x =calculated concentration, y =indicated concentration)

Correlation Coeff.= 0.9999

m (Slope)= 0.9654

b (Intercept as % of full scale)= 0.3838

LIMITS

≥ **0.995**

0.85-1.15

± **3% F.S.**

Remarks:

H₂S ANALYZER AUDIT

File No. 2012 - 451A

Date: March 14, 2012

Performed by: Al Clark

Station

Name: Elk Point

Location: Elk Point Airport

Facility/Zone: Lica

Operator: Maxxam

Temp. 19.5 C

Barometric Press. 700 mm/hg

Monitor

Make/Model: API 101E Serial No: 509

Inlet flow (sccm): 516 Full Scale Range ppm: 0.1

Last cal. Date: Mar 7/12 Old C.F. 1.0000

Zero/Bkg 71.5

Span Coef 1.012

Calibrator

Calibration Method: GAS DILUTION

Make/Model: R&R MFC 201

AMU #: 1691

Cylinder #: CAL011014

H₂S Concentration PPM: 9.4

Calibrator Flow (sccm)			Calculated Conc. (ppm)	Indicated Concentration (ppm)	% Difference	
Air	Gas	Total			vs Audit Gas	Limits
5080	0.0	5080	0.000	0.001		
5105	38.6	5144	0.071	0.076	6%	± 15%
5111	17.7	5129	0.032	0.037	11%	± 15%
5078	9.0	5087	0.017	0.020	14%	± 15%
Absolute Average Percent Difference					11%	

Linear Regression Analysis:

$y=mx+b$ (where x =calculated concentration, y =indicated concentration)

Correlation Coeff.= 0.9997

m (Slope)= 1.0583

b (Intercept as % of full scale)= 1.8559

LIMITS

≥ **0.995**

0.85-1.15

± **3% F.S.**

Remarks:

HC ANALYZER AUDIT

File No. 2012 - 452A

Date: March 14, 2012 Performed by: Al Clark

Station

Name: Elk Point Location: Elk Point Airport
 Facility/Zone: Lica Operator: Maxxam
 Temp. 25.0 C Barometric Press. 699 mm/hg

Monitor

Make/Model: Teco 51CLT Serial No: 0436609739
 Inlet flow (sccm): 6.80 psi Full Scale Range ppm: 50.0
 Last cal. Date: Mar 7/12 Old C.F. 0.9930

Calibrator

Calibration Method: Gas Dilution
 Make/Model: Sabio 2010 AMU #: 1778
 HC cylinder #: SG090044A HC concentration ppm: 1057

Calibrator Flow (sccm)			Calculated Conc. (ppm)	Indicated Concentration (ppm)	% Difference	
Air	Gas	Total			vs Audit Gas	Limits
2960	0.0	2960	0.0	0.3		
2975	82.6	3058	28.6	25.5	-12%	± 15%
2964	41.3	3005	14.5	12.9	-13%	± 15%
2977	20.2	2997	7.1	6.6	-12%	± 15%
Absolute Average Percent Difference					12%	

Linear Regression Analysis:

$y=mx+b$ (where x =calculated concentration, y =indicated concentration)

Correlation Coeff.= 0.9999
 m (Slope)= 0.8815
 b (Intercept as % of full scale)= 0.5231

LIMITS
≥ 0.995
0.85-1.15
± 3% F.S.

Remarks:

NO-NOx-NO2 Analyzer Audit

File No. 2012 - 453A

Date: March 14, 2012 Performed by: Al Clark

Station: Name: Elk Point Location: Elk Point Airport Operator: Maxxam
Facility/Zone: Lica Temp. 21.0 C BP: 700 mm/hg

Monitor: Make/Model: API 200E Serial No. 593
Inlet flow (sccm): 466 Range ppm: 1.0
Last cal. Date: Mar 7/12 Old C.F.'s NO: 1.0000
NOx: 1.0000
NO2: 1.0057
NO Bkg 0.4
NOx Bkg 0.7
NO Coef 1.057
NOx Coef 1.069
NO2 Coef N/A

Calibration Method: Gas Dilution / GPT
Calibrator: Make/Model: Sabio 2010 AMU# 1749
NO cylinder # CLM006307 NO conc. ppm 49.5 NOx conc. ppm 50.9

Calibrator Flows			Calc. Conc.		Indicated Concentration		% Difference vs Audit Gas	
Air	Gas	Total	NO (ppm)	NOx (ppm)	NO (ppm)	NOx (ppm)	NO	NOx
4948	0.0	4948	0.000	0.000	0.000	0.000	Limit ± 15%	
4943	81.8	5025	0.806	0.829	0.746	0.760	-7%	-8%
4976	40.7	5017	0.402	0.413	0.376	0.382	-6%	-7%
4971	19.7	4991	0.195	0.201	0.189	0.193	-3%	-4%
Absolute Average Percent Difference							6%	7%

Linear Regression Analysis:

y=mx+b (where x=calculated concentration, y=indicated concentration)

	NO	NOx	NO ₂	LIMITS
Correlation Coeff.=	<u>0.9999</u>	<u>0.9999</u>	<u>1.0000</u>	≥ 0.995
m (Slope)=	<u>0.9229</u>	<u>0.9140</u>	<u>0.9869</u>	0.85-1.15
b (Intercept as % of full scale)=	<u>0.4114</u>	<u>0.4163</u>	<u>0.7446</u>	± 3% F.S.

O ₃ Setting	Flow Rate	Indicated Conc. (ppm)			NO Decrease	NO ₂ Increase	% Difference vs Audit Gas	
		NO	NOx	NO ₂				
0.000 V	5025	0.754	0.761	0.007	0.368	0.371	1%	± 15%
0.760 V	5025	0.386	0.763	0.378	0.368	0.371	1%	± 15%
0.444 V	5025	0.569	0.765	0.196	0.185	0.189	2%	± 15%
0.280 V	5025	0.669	0.768	0.099	0.085	0.092	8%	± 15%
Absolute Average Percent Difference							4%	

Converter Efficiency

Average Converter Efficiency 103.7%

Remarks: _____

O₃ ANALYZER AUDIT

File No. 2012 - 454A

Date: March 14, 2012

Performed by: Al Clark

Station

Name: Elk Point

Location: Elk Point Airport

Facility/Zone: Lica

Operator: Maxxam

Temp. 25.0 C

Barometric Press. 700 mm/hg

Monitor

Make/Model: Teco 49i Serial No: 1002240372

Inlet flow (sccm): 751 / 756 Full Scale Range ppm: 0.5

Last cal. Date: Mar 8/12 Old C.F. 1.0191

Zero/Bkg -0.0

Span Coeff. 0.974

Calibrator

Calibration Method: Generator

Make/Model: Sabio 2010

AMU # : 1749

NO cylinder # : N/A

NO concentration ppm: N/A

Ozone Setting	Calibrator Flow (sccm)			Calculated Conc. (ppm)	Indicated Conc. (ppm)	% Difference	
	Air	Gas	Total			vs Audit Gas	Limits
0.000 V	4952	4952	4952	0.000	0.000		
0.760 V	4952	4952	4952	0.401	0.375	-6%	± 15%
0.444 V	4952	4952	4952	0.201	0.188	-6%	± 15%
0.280 V	4952	4952	4952	0.098	0.092	-6%	± 15%
Absolute Average Percent Difference						6%	

Linear Regression Analysis:

$y=mx+b$ (where x =calculated concentration, y =indicated concentration)

Correlation Coeff.= 1.0000
 m (Slope)= 0.9349
 b (Intercept as % of full scale)= 0.0298

LIMITS
≥ 0.995
0.85-1.15
± 3% F.S.

Remarks:

TEOM AUDIT

Date: March 14, 2012 File #: 2012 - 455A
 Performed by: Al Clark

Station			
Name:	<u>Elk Point</u>	Location:	<u>Elk Point Airport</u>
Facility/Zone:	<u>Lica</u>	Operator:	<u>Maxxam</u>
Temperature:	<u>-1.0</u>	Barometric Press.:	<u>700 mm/hg</u>

Audit Transfer Standard			
Make/Model:	<u>DeltaCal</u>	Cell s/n:	<u>1002</u>
Serial Number:	<u>1858</u>		
Sampler Set-up and Current Readings			
Make/Model	<u>Teom 1405-F</u>	F-Main Set Pt (l/min)	<u>3.00</u>
Unit #	<u>PM2.5</u>	F-Aux Set Pt (l/min)	<u>13.67</u>
Control unit s/n	<u>1405A208301003</u>	Filter Load (%)	<u>27.3</u>
Transducer s/n	<u>1405A208301003</u>	K _O Factor	<u>13125</u>
		Temp (°C)	<u>-0.9</u>
		Press (ATM)	<u>0.92</u>

Conversion from mm Hg or " Hg to ATM (Atmospheres)

$ATM = (mm\ Hg) \times (1.316 \times 10^{-3})$ or $ATM = ("Hg) \times (3.34207 \times 10^{-2})$

Note: Tolerances are noted as **BOLD** in Brackets

Zero Flow			
Pump Off		Pump On (Time to reach set points)	
F-Main (l/min)	<u>N/A</u>	(45-60 Sec)	<u>N/A</u>
F-Aux (l/min)	<u>N/A</u>	(45-60 Sec)	<u>N/A</u>

Temperature/Pressure			
Measured Temp (± 2 °C)	<u>-1.0</u>	Δ°C	<u>0.10</u>
Measured Press (± 1.5% ATM)	<u>0.921</u>	Δ% ATM	<u>0.11%</u>

Flow Audit			
Indicated Main/Aux Flow (l/min)	<u>3.00</u> <u>13.66</u>	Δ% of Measured Flow from Set-point	
Total Flow = Main + Aux (l/min)	<u>16.66</u>	(± 2%)	<u>0.0%</u> <u>-0.1%</u>
		(± 2%)	<u>-0.1%</u>
Δ of Measured Flow from Indicated			
Measured Total Flow (l/min)	<u>17.15</u>	(± 1.00 l/min)	<u>0.49</u>
Measured Main Flow (l/min)	<u>3.05</u>	(± 0.20 l/min.)	<u>0.05</u>

Leak Check			
Base (< 0.15 l/min)	<u>Pass</u>	Actual leakage = Pump On – Pump Off	<u>-0.02</u>
Ref (< 0.65 l/min)	<u>Pass</u>		<u>-0.03</u>

K_O Factor			
Measured	<u>12896</u>		
K _O % Difference (± 2.5%)	<u>1.74</u>		

Remarks: Heads clean.

Station Performance Audit Summary

Company: Lica Facility Name: Elk Point
 Approval No.: N/A Site Name: Elk Point Airport
 AENV Region: Northern AENV District: North East

Parameters audited:

H ₂ S	X	SO ₂	X	NO _x	X	NH ₃		O ₃	X
CO		CH ₄		NonCH ₄		THC	X	Ethylene	
PM _{2.5}	X	PM ₁₀		TSP		BTEX		Wind Speed	X
Wind Dir	X	Amb. Temp		Stn.Temp	X	RH		Solar Radiation	
Rainfall		Precip		VWS		Other			
All parameters monitored as per approval: Yes _____ No _____ N/A _____									

GENERAL

Has the location remained unchanged from previous audit?
 Is site secure?
 Are station operating conditions adequate?

YES NO N/A

X		
X		
X		

DATA ACQUISITION

Are strip charts in use?
 Is a telemetry system for data acquisition in use?

	X	
X		

SYSTEM COMPONENTS

Is a glass sampling manifold installed?
 Is sampling manifold clean?
 Is a manifold trap in place?
 Are spare manifold ports capped?
 Is manifold oriented so it is not exactly horizontal?
 Are manifold ports situated to prevent water entering monitors?
 Is manifold pump properly installed and operative?
 Do sample lines extend at least 3/4" into manifold?
 Are monitor sampling lines connected to manifold?
 Are sampling lines clean?
 Are monitors properly mounted and secure?
 Are monitors properly exhausted from room or scrubbed?
 Are zero and span systems operational?

X		
X		
X		
X		
X		
X		
X		
X		
X		
X		
X		
X		
X		

WIND EQUIPMENT

Is wind sensor properly oriented?
 Does wind equipment appear to be functioning properly?
 Date of last calibration. Date: Nov 24/11

X		
X		

COMMENTS:

AUDITOR: Al Clark

DATE: March 14, 2012

STATION AUDIT

File No. 2012 - 462A / 465A

Date: March 16, 2012

Performed by: Al Clark

Station

Name: Maskwa

Location: IOL Cold Lake

Facility/Zone: Lica

Operator: Maxxam

Temp: 20.0 C

Barometric Press: 692 mm/hg

Location

Latitude N 54° 36' 18.5"

Longitude W 110° 27' 10.3"

Elevation 606m

Status of Site Documentation On site - OK

Manifold Material Glass
Manifold Condition Good

Meteorological

	Observed	Audit Value
Wind Speed Direction	<u>5.8 kph / 208 deg</u>	<u>5-10 kph / S</u>
Station Temperature	<u>21.6 C</u>	<u>21.3 C</u>
Relative Humidity	<u>42.9 %</u>	<u>38.5 %</u>
Ambient Temperature	<u>10.8 C</u>	<u>11.1 C</u>
BP	<u>0.921</u>	<u>0.911</u>
Precipitation	<u>1.1 mils</u>	<u>11 tips</u>

Remarks:

SO₂ ANALYZER AUDIT

File No. 2012 - 462A

Date: March 16, 2012

Performed by: Al Clark

Station

Name: Maskwa

Location: IOL Cold Lake

Facility/Zone: Lica

Operator: Maxxam

Temp. 19.0 C

Barometric Press. 692 mm/hg

Monitor

Make/Model: API 100E Serial No: 508

Inlet flow (sccm): 584 Full Scale Range ppm: 1.0

Last cal. Date: Feb15/12 Old C.F. 1.0046

Zero/Bkg 40.2

Span Coef 1.254

Calibrator

Calibration Method: GAS DILUTION

Make/Model: R&R MFC 201

AMU #: 1691

Cylinder #: CLM004813

SO₂ Concentration PPM: 50.4

Calibrator Flow (sccm)			Calculated Conc. (ppm)	Indicated Concentration (ppm)	% Difference	
Air	Gas	Total			vs Audit Gas	Limits
5089	0.0	5089	0.000	0.002		
5101	52.7	5154	0.515	0.502	-3%	± 15%
5114	22.2	5136	0.218	0.219	0%	± 15%
5084	8.2	5092	0.081	0.082	-1%	± 15%
Absolute Average Percent Difference					2%	

Linear Regression Analysis:

$y=mx+b$ (where x =calculated concentration, y =indicated concentration)

Correlation Coeff.= 0.9999

m (Slope)= 0.9698

b (Intercept as % of full scale)= 0.3819

LIMITS

≥ **0.995**

0.85-1.15

± **3% F.S.**

Remarks:

H₂S ANALYZER AUDIT

File No. 2012 - 463A

Date: March 16, 2012

Performed by: Al Clark

Station

Name: Maskwa

Location: IOL Cold Lake

Facility/Zone: Lica

Operator: Maxxam

Temp. 19.0 C

Barometric Press. 692 mm/hg

Monitor

Make/Model: API 101E Serial No: 511

Inlet flow (sccm): 467 Full Scale Range ppm: 0.1

Last cal. Date: Feb 15/12 Old C.F. 0.9927

Zero/Bkg 35.7

Span Coef 0.834

Calibrator

Calibration Method: GAS DILUTION

Make/Model: R&R MFC 201

AMU #: 1691

Cylinder #: CAL011014

H₂S Concentration PPM: 9.4

Calibrator Flow (sccm)			Calculated Conc. (ppm)	Indicated Concentration (ppm)	% Difference	
Air	Gas	Total			vs Audit Gas	Limits
5089	0.0	5089	0.000	0.001		
5116	38.5	5154	0.070	0.077	8%	± 15%
5118	17.8	5136	0.033	0.036	7%	± 15%
5083	9.0	5092	0.017	0.019	8%	± 15%
Absolute Average Percent Difference					8%	

Linear Regression Analysis:

$y=mx+b$ (where x =calculated concentration, y =indicated concentration)

Correlation Coeff.= 1.0000

m (Slope)= 1.0820

b (Intercept as % of full scale)= 0.9496

LIMITS

≥ **0.995**

0.85-1.15

± **3% F.S.**

Remarks:

HC ANALYZER AUDIT

File No. 2012 - 464A

Date: March 16, 2012 Performed by: Al Clark

Station

Name: Maskwa Location: IOL Cold Lake
 Facility/Zone: Lica Operator: Maxxam
 Temp. 22.0C Barometric Press. 691 mm/hg

Monitor

Make/Model: Teco 51CLT Serial No: 0436609738
 Inlet flow (sccm): 7.50 psi Full Scale Range ppm: 50.0
 Last cal. Date: Feb 15/12 Old C.F. 0.9954

Calibrator

Calibration Method: Gas Dilution
 Make/Model: Sabio 2010 AMU #: 1778
 HC cylinder #: SG090044A HC concentration ppm: 1057

Calibrator Flow (sccm)			Calculated Conc. (ppm)	Indicated Concentration (ppm)	% Difference	
Air	Gas	Total			vs Audit Gas	Limits
2986	0.0	2986	0.0	0.1		
3001	82.3	3083	28.2	26.1	-8%	± 15%
2989	41.0	3030	14.3	13.2	-8%	± 15%
3005	20.1	3025	7.0	6.6	-7%	± 15%
Absolute Average Percent Difference					8%	

Linear Regression Analysis:

$y=mx+b$ (where x =calculated concentration, y =indicated concentration)

Correlation Coeff.= 1.0000
 m (Slope)= 0.9208
 b (Intercept as % of full scale)= 0.1918

LIMITS
≥ 0.995
0.85-1.15
± 3% F.S.

Remarks:

NO-NOx-NO2 Analyzer Audit

File No. 2012 - 465A

Date: March 16, 2012 Performed by: Al Clark

Station: Name: Maskwa Location: IOL Cold Lake Operator: Maxxam
Facility/Zone: Lica Temp. 20.0 C BP: 692 mm/hg

Monitor: Make/Model: API 200E Serial No. 594
Inlet flow (sccm): 451 Range ppm: 1.0
Last cal. Date: Feb 15/12 Old C.F.'s NO: 0.998
NOx: 1.000
NO2: 1.001
NO Bkg 0.8
NOx Bkg 0.9
NO Coef 1.196
NOx Coef 1.205
NO2 Coef N/A

Calibration Method: Gas Dilution / GPT
Calibrator: Make/Model: Sabio 2010 AMU# 1749
NO cylinder # CLM006307 NO conc. ppm 49.5 NOx conc. ppm 50.9

Calibrator Flows			Calc. Conc.		Indicated Concentration		% Difference vs Audit Gas	
			NO (ppm)	NOx (ppm)	NO (ppm)	NOx (ppm)	NO	NOx
Air	Gas	Total						
4914	0.0	4914	0.000	0.000	0.001	0.001	Limit ± 15%	
4926	81.8	5008	0.809	0.831	0.757	0.768	-6%	-8%
4945	40.7	4986	0.404	0.415	0.381	0.386	-6%	-7%
4955	19.7	4975	0.196	0.202	0.191	0.195	-3%	-4%
Absolute Average Percent Difference							5%	6%

Linear Regression Analysis: $y=mx+b$ (where x =calculated concentration, y =indicated concentration)

	NO	NOx	NO ₂	LIMITS
Correlation Coeff.=	<u>1.0000</u>	<u>0.9999</u>	<u>1.0000</u>	≥ 0.995
m (Slope)=	<u>0.9324</u>	<u>0.9194</u>	<u>0.9953</u>	0.85-1.15
b (Intercept as % of full scale)=	<u>0.4146</u>	<u>0.4584</u>	<u>-0.0019</u>	± 3% F.S.

O ₃ Setting	Flow Rate	Indicated Conc. (ppm)			NO Decrease	NO ₂ Increase	% Difference vs Audit Gas	
		NO	NOx	NO ₂				
0.000 V	5008	0.758	0.768	0.011	X	X	X	%Dif Limit
0.760 V	5008	0.397	0.765	0.370	0.361	0.359	-1%	± 15%
0.444 V	5008	0.577	0.768	0.192	0.181	0.181	0%	± 15%
0.280 V	5008	0.670	0.767	0.098	0.088	0.087	-1%	± 15%
Absolute Average Percent Difference							-1%	

Converter Efficiency
Average Converter Efficiency 99.4%

Remarks: _____

Station Performance Audit Summary

Company: Lica Facility Name: IOL Cold Lake
 Approval No.: N/A Site Name: Maskwa
 AENV Region: Northern AENV District: North East

Parameters audited:

H ₂ S	X	SO ₂	X	NO _x	X	NH ₃		O ₃	
CO		CH ₄		NonCH ₄		THC	X	Ethylene	
PM _{2.5}		PM ₁₀		TSP		BTEX		Wind Speed	X
Wind Dir	X	Amb. Temp	X	Stn.Temp	X	RH	X	Solar Radiation	
Rainfall	X	Precip		VWS		BP	X		
All parameters monitored as per approval: Yes _____ No _____ N/A _____									

GENERAL

Has the location remained unchanged from previous audit?
 Is site secure?
 Are station operating conditions adequate?

YES NO N/A

X		
X		
X		

DATA ACQUISITION

Are strip charts in use?
 Is a telemetry system for data acquisition in use?

	X	
X		

SYSTEM COMPONENTS

Is a glass sampling manifold installed?
 Is sampling manifold clean?
 Is a manifold trap in place?
 Are spare manifold ports capped?
 Is manifold oriented so it is not exactly horizontal?
 Are manifold ports situated to prevent water entering monitors?
 Is manifold pump properly installed and operative?
 Do sample lines extend at least 3/4" into manifold?
 Are monitor sampling lines connected to manifold?
 Are sampling lines clean?
 Are monitors properly mounted and secure?
 Are monitors properly exhausted from room or scrubbed?
 Are zero and span systems operational?

X		
X		
X		
X		
X		
X		
X		
X		
X		
X		
X		
X		
X		

WIND EQUIPMENT

Is wind sensor properly oriented?
 Does wind equipment appear to be functioning properly?
 Date of last calibration. Date: Dec 20/11

X		
X		

COMMENTS:

AUDITOR: Al Clark

DATE: March 16, 2012

STATION AUDIT

File No. 2012 - 444A / 449A

Date: March 13, 2012

Performed by: Al Clark

Station

Name: St Lina

Location: St Lina

Facility/Zone: Lica

Operator: Maxxam

Temp: 21.0 C

Barometric Press: 678 mm/hg

Location

Latitude N 56° 12' 59.3"

Longitude W 111° 30' 09.5"

Elevation 690 m

Status of Site Documentation On site - WR needs updating

Manifold Material Glass
Manifold Condition Good

Meteorological

	Observed	Audit Value
Wind Speed Direction	<u>13 kph / 276 deg</u>	<u>10-15 kph / SW</u>
Station Temperature	<u>21.6</u>	<u>19.6</u>
Relative Humidity	<u>56%</u>	<u>57%</u>
Ambient Temperature	<u>7.8</u>	<u>7.2</u>
BP	<u>899</u>	<u>892</u>
Precipitation	<u>1.0 mil</u>	<u>10 tips</u>

Remarks:

Site documentation finding was noted in 2010 audit. Please rectify.

SO₂ ANALYZER AUDIT

File No. 2012 - 444A

Date: March 13, 2012

Performed by: Al Clark

Station

Name: St Lina

Location: St Lina

Facility/Zone: Lica

Operator: Maxxam

Temp. 19.5 C

Barometric Press. 679 mm/hg

Monitor

Make/Model: API 100E Serial No: 468

Inlet flow (sccm): 506 Full Scale Range ppm: 1.0

Last cal. Date: Mar 6/12 Old C.F. 1.0013

Zero/Bkg 80.6

Span Coef 1.048

Calibrator

Calibration Method: GAS DILUTION

Make/Model: R&R MFC 201

AMU #: 1691

Cylinder #: CLM004813

SO₂ Concentration PPM: 50.4

Calibrator Flow (sccm)			Calculated Conc. (ppm)	Indicated Concentration (ppm)	% Difference	
Air	Gas	Total			vs Audit Gas	Limits
5078	0.0	5078	0.000	0.002		
5087	52.2	5139	0.512	0.505	-2%	± 15%
5107	22.1	5129	0.217	0.222	1%	± 15%
5074	8.1	5082	0.080	0.083	1%	± 15%
Absolute Average Percent Difference					0%	

Linear Regression Analysis:

$y=mx+b$ (where x =calculated concentration, y =indicated concentration)

Correlation Coeff.= 0.9999

m (Slope)= 0.9815

b (Intercept as % of full scale)= 0.4382

LIMITS

≥ **0.995**

0.85-1.15

± **3% F.S.**

Remarks:

H₂S ANALYZER AUDIT

File No. 2012 - 445A

Date: March 13, 2012

Performed by: Al Clark

Station

Name: St Lina

Location: St Lina

Facility/Zone: Lica

Operator: Maxxam

Temp. 19.5 C

Barometric Press. 679 mm/hg

Monitor

Make/Model: API 101E Serial No: 510

Inlet flow (sccm): 520 Full Scale Range ppm: 0.1

Last cal. Date: Mar 5/12 Old C.F. 1.0000

Zero/Bkg 77.4

Span Coef 1.035

Calibrator

Calibration Method: GAS DILUTION

Make/Model: R&R MFC 201

AMU #: 1691

Cylinder #: CAL011014

H₂S Concentration PPM: 9.4

Calibrator Flow (sccm)			Calculated Conc. (ppm)	Indicated Concentration (ppm)	% Difference	
Air	Gas	Total			vs Audit Gas	Limits
5078	0.0	5078	0.000	0.002		
5101	38.3	5139	0.070	0.077	7%	± 15%
5112	17.5	5129	0.032	0.037	9%	± 15%
5073	8.9	5082	0.016	0.020	9%	± 15%
Absolute Average Percent Difference					9%	

Linear Regression Analysis:

$y=mx+b$ (where x =calculated concentration, y =indicated concentration)

Correlation Coeff.= 0.9999

m (Slope)= 1.0693

b (Intercept as % of full scale)= 2.2971

LIMITS

≥ **0.995**

0.85-1.15

± **3% F.S.**

Remarks:

HC ANALYZER AUDIT

File No. 2012 - 446A

Date: March 13, 2012 Performed by: Al Clark

Station

Name: St Lina Location: St Lina
 Facility/Zone: Lica Operator: Maxxam
 Temp. 21.0 C Barometric Press. 678 mm/hg

Monitor

Make/Model: Teco 51CLT Serial No: 51CTL-77021-384
 Inlet flow (sccm): 6.90 psi Full Scale Range ppm: 50.0
 Last cal. Date: Mar 6/12 Old C.F. 0.9978

Calibrator

Calibration Method: Gas Dilution
 Make/Model: Sabio 2010 AMU #: 1778
 HC cylinder #: SG090044A HC concentration ppm: 1057

Calibrator Flow (sccm)			Calculated Conc. (ppm)	Indicated Concentration (ppm)	% Difference	
Air	Gas	Total			vs Audit Gas	Limits
2985	0.0	2985	0.0	0.1		
2987	79.5	3066	27.4	26.4	-4%	± 15%
2989	40.2	3029	14.0	13.3	-6%	± 15%
2989	20.3	3009	7.1	6.7	-7%	± 15%
Absolute Average Percent Difference					6%	

Linear Regression Analysis:

$y=mx+b$ (where x =calculated concentration, y =indicated concentration)

Correlation Coeff.= 0.9999
 m (Slope)= 0.9614
 b (Intercept as % of full scale)= -0.0950

LIMITS
≥ 0.995
0.85-1.15
± 3% F.S.

Remarks:

NO-NOx-NO2 Analyzer Audit

File No. 2012 - 447A

Date: March 13, 2012 Performed by: Al Clark

Station: Name: St Lina Location: St Lina Operator: Maxxam
 Facility/Zone: Lica Temp. 21.0 C BP: 678 mm/hg

Monitor: Make/Model: API 200E Serial No. 592
 Inlet flow (sccm): 466 Range ppm: 1.0
 Last cal. Date: Mar 5/12 Old C.F.'s NO: 1.0023
 NOx: 0.9977
 NO2: 1.0000
 NO Bkg 0.2
 NOx Bkg 1.5
 NO Coef 1.266
 NOx Coef 1.289
 NO2 Coef N/A

Calibration Method: Gas Dilution / GPT
Calibrator: Make/Model: Sabio 2010 AMU# 1749
 NO cylinder # CLM006307 NO conc. ppm 49.5 NOx conc. ppm 50.9

Calibrator Flows			Calc. Conc.		Indicated Concentration		% Difference vs Audit Gas	
			NO (ppm)	NOx (ppm)	NO (ppm)	NOx (ppm)	NO	NOx
Air	Gas	Total						
4920	0.0	4920	0.000	0.000	0.001	0.001	Limit ± 15%	
4935	80.7	5016	0.796	0.819	0.753	0.768	-6%	-6%
4956	40.6	4997	0.402	0.414	0.377	0.388	-7%	-6%
4963	19.8	4983	0.197	0.202	0.189	0.195	-4%	-4%
Absolute Average Percent Difference							6%	6%

Linear Regression Analysis: $y=mx+b$ (where x=calculated concentration, y=indicated concentration)

	NO	NOx	NO ₂	LIMITS
Correlation Coeff.=	<u>1.0000</u>	<u>1.0000</u>	<u>1.0000</u>	≥ 0.995
m (Slope)=	<u>0.9427</u>	<u>0.9346</u>	<u>1.0033</u>	0.85-1.15
b (Intercept as % of full scale)=	<u>0.1174</u>	<u>0.2771</u>	<u>0.4021</u>	± 3% F.S.

O ₃ Setting	Flow Rate	Indicated Conc. (ppm)			NO Decrease	NO ₂ Increase	% Difference vs Audit Gas	
		NO	NOx	NO ₂				
0.0 V	5016	0.753	0.769	0.016	0.336	0.341	1%	± 15%
0.760 V	5016	0.417	0.774	0.357	0.336	0.341	1%	± 15%
0.444 V	5016	0.588	0.773	0.186	0.165	0.170	3%	± 15%
0.280 V	5016	0.674	0.771	0.099	0.079	0.083	5%	± 15%
Absolute Average Percent Difference							3%	

Converter Efficiency
 Average Converter Efficiency 103.2%

Remarks: _____

O₃ ANALYZER AUDIT

File No. 2012 - 448A

Date: March 13, 2012 Performed by: Al Clark

Station

Name: St Lina Location: St Lina
 Facility/Zone: Lica Operator: Maxxam
 Temp. 19.5 C Barometric Press. 678 mm/hg

Monitor

Make/Model: Teco 49 C Serial No: 49C-5492-302
 Inlet flow (sccm): 821/839 Full Scale Range ppm: 0.5
 Last cal. Date: Mar 5/12 Old C.F. 1.0025
 Zero/Bkg 0.1
 Span Coeff. 0.976

Calibrator

Calibration Method: Generator
 Make/Model: Sabio 2010 AMU # : 1749
 NO cylinder # : N/A NO concentration ppm: N/A

Ozone Setting	Calibrator Flow (sccm)			Calculated Conc. (ppm)	Indicated Conc. (ppm)	% Difference	
	Air	Gas	Total			vs Audit Gas	Limits
0.000 V	4960	4960	4960	0.000	0.000		
0.760 V	4960	4960	4960	0.400	0.351	-12%	± 15%
0.444 V	4960	4960	4960	0.201	0.177	-12%	± 15%
0.280 V	4960	4960	4960	0.098	0.088	-10%	± 15%
Absolute Average Percent Difference						11%	

Linear Regression Analysis:

$y=mx+b$ (where x =calculated concentration, y =indicated concentration)

Correlation Coeff.= 1.0000
 m (Slope)= 0.8759
 b (Intercept as % of full scale)= 0.1861

LIMITS
≥ 0.995
0.85-1.15
± 3% F.S.

Remarks:

TEOM AUDIT

Date: March 13, 2012 File #: 2012 - 449A
 Performed by: Al Clark

Station			
Name:	<u>St Lina</u>	Location:	<u>St Lina</u>
Facility/Zone:	<u>Lica</u>	Operator:	<u>Maxxam</u>
Temperature:	<u>9.04</u>	Barometric Press.:	<u>676 mm/hg</u>

Audit Transfer Standard			
Make/Model:	<u>DeltaCal</u>	Cell s/n:	<u>1002</u>
Serial Number:	<u>1858</u>		
Sampler Set-up and Current Readings			
Make/Model	<u>Teom 1405-F</u>	F-Main Set Pt (l/min)	<u>3.00</u>
Unit #	<u>PM2.5</u>	F-Aux Set Pt (l/min)	<u>13.67</u>
Control unit s/n	<u>1405A207691003</u>	Filter Load (%)	<u>22</u>
Transducer s/n	<u>1405A207691003</u>	K _O Factor	<u>15634</u>
		Temp (°C)	<u>9.04</u>
		Press (ATM)	<u>0.894</u>

Conversion from mm Hg or " Hg to ATM (Atmospheres)

$ATM = (mm\ Hg) \times (1.316 \times 10^{-3})$ or $ATM = ("Hg) \times (3.34207 \times 10^{-2})$

Note: Tolerances are noted as **BOLD** in Brackets

Zero Flow			
Pump Off		Pump On (Time to reach set points)	
F-Main (l/min)	<u>N/A</u>	(45-60 Sec)	<u>N/A</u>
F-Aux (l/min)	<u>N/A</u>	(45-60 Sec)	<u>N/A</u>

Temperature/Pressure			
Measured Temp (± 2 °C)	<u>7.90</u>	Δ°C	<u>1.14</u>
Measured Press (± 1.5% ATM)	<u>0.890</u>	Δ% ATM	<u>-0.45%</u>

Flow Audit		Δ% of Measured Flow from Set-point	
Indicated Main/Aux Flow (l/min)	<u>3.01</u> <u>13.65</u>	(± 2%)	<u>0.3%</u> <u>-0.1%</u>
Total Flow = Main + Aux (l/min)	<u>16.66</u>	(± 2%)	<u>-0.1%</u>
		Δ of Measured Flow from Indicated	
Measured Total Flow (l/min)	<u>17.00</u>	(± 1.00 l/min)	<u>0.34</u>
Measured Main Flow (l/min)	<u>3.2</u>	(± 0.20 l/min.)	<u>0.19</u>

Leak Check		Actual leakage = Pump On – Pump Off	
Base (< 0.15 l/min)	<u>Pass</u>		<u>0.07</u>
Ref (< 0.65 l/min)	<u>Pass</u>		<u>-0.2</u>

K_O Factor			
Measured	<u>15511</u>		
K _O % Difference (± 2.5%)	<u>0.79</u>		

Remarks: Heads Clean. 1 oring in SCC needs replacing - torn.

Station Performance Audit Summary

Company: Lica Facility Name: St Lina
 Approval No.: N/A Site Name: St Lina
 AENV Region: Northern AENV District: North East

Parameters audited:

H ₂ S	X	SO ₂	X	NO _x	X	NH ₃		O ₃	X
CO		CH ₄		NonCH ₄		THC	X	Ethylene	
PM _{2.5}	X	PM ₁₀		TSP		BTEX		Wind Speed	X
Wind Dir	X	Amb. Temp	X	Stn.Temp	X	RH	X	Solar Radiation	
Rainfall	X	Precip		VWS		BP	X		
All parameters monitored as per approval: Yes _____ No _____ N/A _____									

GENERAL

Has the location remained unchanged from previous audit?
 Is site secure?
 Are station operating conditions adequate?

YES NO N/A

X		
X		
X		

DATA ACQUISITION

Are strip charts in use?
 Is a telemetry system for data acquisition in use?

	X	
X		

SYSTEM COMPONENTS

Is a glass sampling manifold installed?
 Is sampling manifold clean?
 Is a manifold trap in place?
 Are spare manifold ports capped?
 Is manifold oriented so it is not exactly horizontal?
 Are manifold ports situated to prevent water entering monitors?
 Is manifold pump properly installed and operative?
 Do sample lines extend at least 3/4" into manifold?
 Are monitor sampling lines connected to manifold?
 Are sampling lines clean?
 Are monitors properly mounted and secure?
 Are monitors properly exhausted from room or scrubbed?
 Are zero and span systems operational?

X		
X		
X		
X		
X		
X		
X		
X		
X		
X		
X		
X		
X		

WIND EQUIPMENT

Is wind sensor properly oriented?
 Does wind equipment appear to be functioning properly?
 Date of last calibration. Date: June 17/10

X		
X		

COMMENTS: Wind head calibration due in 2012 as per AMD.

AUDITOR: Al Clark DATE: March 13, 2012



Box 8237
5107W-50th Street
Bonnyville, AB T9N 2J5
Phone: (780) 812-2182
Fax: (780) 812-2186
Toll Free: 1-877-737-2182
E-Mail: lica2@lica.ca
Website: <http://www.lica.ca>

May 1, 2012

Alberta Environment and Water
Data, Monitoring and Validation
Monitoring and Science
4946 89 Street
Edmonton, AB T6E-5K1

Attention: Al Clark, Monitoring Systems Auditor

Dear Mr. Al Clark

RE: 2012 LICA Audits

Attached, please find the updated site documentation for the St. Lina and Portable Continuous Monitoring stations.

It appears that an older version of the site documentation was at the St. Lina station at the time of the audit. The out-of-date windrose was identified in a previous audit and the problem was corrected, however it seems that the new document was never placed in the St. Lina Station.

The site documentation for the Portable Continuous Monitoring station has been updated to reflect the conditions at the new site. In order to generate a windrose for the Elk Point Airport site, I used data from the National Climate Data and Information Archive for St. Paul which is reasonably close the station's current location.

Physical copies of these two documents will be placed in their respective stations over the next two weeks.

If you have any further questions, please don't hesitate to contact me.

Respectfully,

A handwritten signature in blue ink that reads "Michael Bisaga". The signature is written in a cursive style with a large, prominent "M" and "B".

Michael Bisaga
Airshed Program Manager
Lakeland Industry and Community Association

Site Documentation: LICA Portable Continuous Monitoring Station

General Site Information

Item	Description
Site ID (CASA ID)	N/A
Station Name	LICA Portable Continuous Monitoring Station (LPS)
General Description	The LPS monitoring station is located east of the Town of Elk Point at the Elk Point Airport.
Community	Elk Point
Station Address	Highway 646 & Range Road 61
Coordinates	53°53'28.60"N 110°45'49.88"W
Station Type	Rural Regional, Light Industry
Area Land Use	Rural, Agricultural
Angle of elevation to nearby building in area	<15 degrees, outbuildings, quanset, security building
Airflow Restrictions (yes/no)	North: No East: No South: No West: No
Nearest Tree	Single trees near security building 50 – 100 meters away to the south west
Sample Manifold Type	Glass
Meteorological Tower Information	Height: 10 meters Type: Crank Position: Attached to south side of monitoring shelter
Station Install Date	Original installation: March 2012
Station Origin	LICA owned and operated
Site Preparation	Gravel parking area for airport clients

Site Influences

Localized Sources (within 20 meters of station)

Type	Distance	Description
Automobile	200 meters	Highway Road 646
Space heating	Immediate area	Space heating for various buildings at the airport
Aircraft	Immediate area	Intermittent use of airport

Road Way Sources

Name	Type	Traffic Volume	Distance (m)	Description
Highway 646	Highway	Unknown – High Peak Hour Volume	200 m	Paved Rural Highway
Range Road 60, 61, 62	Gravel Road	Unknown – Minimal	500 m	Gravel Road
Airport access	Gravel Road	Unknown – Minimal	Immediate area	Gravel Road

Major Point/Area Sources

Name	Type	Major Emissions	Distance (m)	Direction
Primary Production / Well Site	Industrial	NOx, HC	500-1000 m	All directions
Sand/Gravel Pit	Industrial	PM _{2.5} , NOx	500-1000 m	



Figure 1: Satellite image showing LPS Continuous Monitoring Station Location




Figure 2: Road Map showing LPS Continuous Monitoring Station Location





Figure 3: Schematic showing LPS Continuous Monitoring Station and surrounding features.



● = LICA Portable Continuous Monitoring Station

Figure 4: Elevation Plot showing location of LPS Continuous Monitoring Station

Site Photographs – Cardinal Directions



Site Photographs – Monitoring Station

Exterior



Interior (Instrument Rack)



Interior (Intake Manifold)




Wind Rose Diagram

Wind Speed / Direction Frequency Distribution

St. Paul AGCM Climate Station

2011 Wind Speed/Direction



Data polled from National Climate Data and Information Archive:

http://www.climate.weatheroffice.gc.ca/advanceSearch/searchHistoricData_e.html

LICA Portable Continuous Monitoring Station Equipment Inventory

Air Quality

Parameter	Make/Model	Serial Number	Sampling Height (m)	Equipment Owner
Analytical Systems				
Hydrogen Sulphide	Teledyne API / 101E	509	4	LICA
Sulphur Dioxide	Teledyne API / 100E	467	4	LICA
Oxides of Nitrogen	Teledyne API / 200E	593	4	LICA
Total Hydrocarbons	Thermo Electron 51C	436609739	4	LICA
Ozone	API 400A	446	4	Maxxam
PM 2.5	R+P 1400a TEOM	140AB228740001	6	Maxxam
Volatile Organic Compounds	Xontech 910a	6200	6	LICA
Polycyclic Aromatic Hydrocarbons	Tisch PUF+	100-1015 (Motor SN 1139)	6	LICA
Meteorological Systems				
Wind Speed	RM Young 5103VK	41334	10	Maxxam
Wind Direction	RM Young 5103VK	41334	10	Maxxam
Ambient Temperature	R&R Environmental 61	N/A	4	LICA
Support Systems				
DACS	ESC 8832	AO 717	N/A	LICA
Trailer Temperature	R&R 61	N/A	N/A	LICA
Zero Air Supply	Teledyne API/701	1813	N/A	LICA
PM 10 Impacter	R+P	N/A		Maxxam
PM2.5 Cyclone	R+P	N/A		Maxxam

Revisions

Document Revision History

Revision No.	Date	Reason for Revision	Approved By
0	October 2009	Original Issue (Devon Wellsite Location, North of Bonnyville)	M. Bisaga, Airshed Program Manager
1	April 2012	Trailer moved to new location (Elk Point Airport)	M. Bisaga, Airshed Program Manager

Site Documentation: St. Lina Continuous Monitoring Station

General Site Information

Item	Description
Site ID (CASA ID)	N/A
Station Name	St. Lina Continuous Monitoring Station (STL)
General Description	The STL monitoring station is located just outside the LICA airshed boundary south west of St. Lina.
Community	Ashmont / St. Lina / McRae
Station Address	Highway 867 & Township Road 604, County of St. Paul
Coordinates	54°12'58"N 111°30'8"W
Station Type	Rural Regional
Area Land Use	Rural, Agricultural
Angle of elevation to nearby building in area	<15 degrees, trees surrounding knoll.
Airflow Restrictions (yes/no)	North: No East: No South: No West: No
Nearest Tree	Tree stands 50 – 100 meters away in all directions
Sample Manifold Type	Glass
Meteorological Tower Information	Height: 10 meters Type: Crank Position: Attached to north side of monitoring shelter
Station Install Date	Original installation: June 2009
Station Origin	LICA owned and operated
Site Preparation	Grassy open area on top of treed knoll.

Site Influences

Localized Sources (within 20 meters of station)

Type	Distance	Description
Automobile	To the east	Highway 867
Industrial	500 meters	Compressor station
Industrial	500 meters	Well site

Road Way Sources

Name	Type	Traffic Volume	Distance (m)	Description
Highway 867	Highway	Unknown – Moderate	Within 400 meters	Rural Highway
Township Road 604	Township Road	Unknown – Minimal	1 km	Gravel Road

Major Point/Area Sources

Name	Type	Major Emissions	Distance (m)	Direction
Compressor Station	Industrial	NO _x , PM, HC, TRS	500 meters	North west
Primary Production / Well Site	Industrial	NO _x , HC	500 meters	East




Figure 1: Satellite image showing STL Continuous Monitoring Station Location




Figure 2: Road Map showing STL Continuous Monitoring Station Location





Figure 3: Schematic showing STL Continuous Monitoring Station and surrounding features.



● = St. Lina Continuous Monitoring Station

Figure 4: Elevation Plot showing location of STL Continuous Monitoring Station

Site Photographs – Cardinal Directions

North



East



South



West



Site Photographs – Monitoring Station


Exterior



Interior (Instrument Rack)




Interior (Intake Manifold)



Wind Rose Diagram

Wind Speed / Direction Frequency Distribution



Data polled from CASA Data Warehouse (www.casadata.org)

Data Period: September 1, 2009 – August 31, 2010

Cold Lake South Continuous Monitoring Station Equipment Inventory

Air Quality

Parameter	Make/Model	Serial Number	Sampling Height (m)	Equipment Owner
Analytical Systems				
Hydrogen Sulphide	Teledyne API / 101E	510	4	LICA
Sulphur Dioxide	Teledyne API / 100E	468	4	LICA
Oxides of Nitrogen	Teledyne API / 200E	592	4	LICA
Ozone	Thermo Electron 51C	77021-384	4	LICA
Meteorological Systems				
Wind Speed	Met One 50.5	H12635	10	LICA
Wind Direction	Met One 50.5	H12635	10	LICA
Ambient Temperature	R&R Environmental 61	N/A	4	LICA
Support Systems				
DACS	ESC 8832	AO 717	N/A	LICA
Trailer Temperature	R&R 61	N/A	N/A	LICA
Zero Air Supply	Teledyne API/701	1812	N/A	LICA

Revisions

Document Revision History

Revision No.	Date	Reason for Revision	Approved By
0	October 2009	Original Issue	M. Bisaga, Airshed Program Manager
1	September 2010	Updated windrose diagram	M. Bisaga, Airshed Program Manager

May 1, 2012

File No(s): 2012 – 444A / 465A

Mr. Michael Bisaga
Program Manager
Lica Airshed
13440 – 62 street
Edmonton, AB T5A 0V7

Dear Mr. Bisaga:

Re: LICA Ambient Air Monitoring Station Audits

The Lica letter dated May 1, 2012 indicates that all actions required to address the audit findings have been taken.

Alberta Environment has verified that these actions have indeed been taken. Alberta Environment is satisfied that Lica has fulfilled the requirements of the audit findings and considers this audit closed.

Yours truly,



Al Clark
Monitoring Systems Auditor
Environmental Assurance

Attachment(s): Audit Summary Report

cc: Pat Marriot: District Approvals Manager
Jeff Toering: District Compliance Manager
Marilyn Albert: Air Quality Data Supervisor
Janine Ross: Ambient Air Specialist